

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NCBEP2200-000000-0034111145
LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CONT
01 L6050-0324709038180924819
REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During the performance of the Control Rod Withdrawal Block Channel Calibration and
03 Functional Test, PT 1.5PC, RBM "A" would not "inop" with <4 LPRM inputs. This
04 instrument normally has eight LPRM inputs assigned to it. This event did not affect
05 the health and safety of the public.
06
07

Technical Specifications 3.1.4.3, 6.9.1.9b

09 RB11 E12 F13 INSTRU14 X15 Z16
SYSTEM CODE 9 10 CAUSE CODE 11 12 CAUSE SUBCODE 12 13 COMPONENT CODE 18 19 COMP. SUBCODE 19 20 VALVE SUBCODE 20 21
17 81 093 03 L 0
LER/RO REPORT NUMBER 21 22 EVENT YEAR 23 24 SEQUENTIAL REPORT NO. 25 26 OCCURRENCE CODE 27 28 REPORT TYPE 29 30 REVISION NO. 31 32
A18 Z19 Z20 Z21 0000 N23 Y24 N25 P29726
ACTION TAKEN 33 34 FUTURE ACTION 35 36 EFFECT ON PLANT 37 38 SHUTDOWN METHOD 39 40 HOURS 41 42 ATTACHMENT SUBMITTED 43 44 NPRD-4 FORM SUB. 45 46 PRIME COMP. SUPPLIER 47 48 COMPONENT MANUFACTURER 49 50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 Instrument relay, K-12, which initiates the RBM "A" "inop," was found to have failed.
11 A complete check of the relay circuitry did not reveal a cause for the failure. The
12 relay, Model No. KH-4779-1, was replaced and the PT was satisfactorily completed. A
13 review of plant documentation showed this as an isolated event; therefore, no further
14 corrective action is planned or required.

15 E28 09129 NA B31 Periodic Test
FACILITY STATUS 7 8 9 % POWER 10 11 OTHER STATUS 12 13 METHOD OF DISCOVERY 44 45 DISCOVERY DESCRIPTION 32 46
16 Z33 Z34 NA NA
ACTIVITY CONTENT 7 8 9 RELEASED OF RELEASE 10 11 AMOUNT OF ACTIVITY 35 44 LOCATION OF RELEASE 36 45
17 00037 Z38 NA
PERSONNEL EXPOSURES NUMBER 11 12 TYPE 13 DESCRIPTION 39 40
18 00040 NA
PERSONNEL INJURIES NUMBER 11 12 DESCRIPTION 41 42
19 Z42 NA
LOSS OF OR DAMAGE TO FACILITY TYPE 11 12 DESCRIPTION 43 44
20 N44 NA
PUBLICITY DESCRIPTION 45 46

8110010144 810924
 PDR ADCK 05000324
 S PDR

NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr. PHONE: (919) 457-9521