



MAINE YANKEE ATOMIC POWER COMPANY •  
ENGINEERING OFFICE

1671 WORCESTER ROAD  
FRAMINGHAM, MASSACHUSETTS 01701  
617-872-8100

May 1, 1981  
FMY - 81-68  
2.C.2.1

United States Nuclear Regulatory Commission  
Washington, D.C. 20555

Attention: Office of Nuclear Reactor Regulation  
Division of Licensing  
Robert A. Clark  
Operating Reactors Branch No. 3

References:

- (a) License No. DPR-36 (Docket 50-309)
- (b) USNRC letter from Robert W. Reid, DOR to R. H. Groce, dated November 29, 1978
- (c) YAEAC letter to USNRC, dated December 29, 1978
- (d) USNRC letter to MYAPC, dated October 22, 1980
- (e) USNRC letter to MYAPC, dated September 17, 1979
- (f) MYAPC letter to USNRC, WMY 79-126, dated November 8, 1979
- (g) MYAPC letter to USNRC, WMY 79-144, dated December 10, 1979
- (h) MAYPC letter to USNRC, WMY 79-146, dated December 12, 1979
- (i) MYAPC letter to USNRC, WMY 80-78, dated May 16, 1980

Enclosures:

- (A) Valve Performance Calculations and Conclusions from Allis-Chalmers Company
- (B) Valve Seismic Calculations and Conclusions from Allis-Chalmers Company
- (C) Resultant Off-Site Doses from A LOCA During ON-Line Containment Purge at Maine Yankee

Subject: Unlimited Containment Purging During Normal Plant Operation

Dear Sir:

Reference (b) requested that the Maine Yankee Atomic Power Company commit to (1) cease all containment purge during operation and to propose an amendment relative to that commitment, or (2) provide justification for the continued practice of purging during operation whether limited, or unlimited.

Reference (c) was provided in response to that request and reflected our position that unlimited purging could be justified for the Maine Yankee Plant.

Pending the completion of the long-term review to justify unlimited purging, Maine Yankee committed to limiting containment purge to 90 hours per year when not in a cold shutdown or refueling mode as stated in References (c) and (h). This section was found acceptable by the NRC in Reference (d).



A034  
5  
1/1

The intent of this submittal is to provide the NRC with the necessary information to justify unlimited purge. Much of the required information for this justification has already been submitted to the Commission by Maine Yankee in References (c), (f), (g), (h) and (i).

The following information coupled with the information already submitted should complete the Maine Yankee justification for unlimited containment purge:

Operability of Containment Purge and Vent Valves

Reference (b) indicated that purging during normal operation may be permitted if the containment purge isolation valves are capable of closing against the dynamic forces of a design basis loss-of-coolant accident. Reference (e) from the NRC provided guidelines for valve operability when closing against the dynamic forces of a design basis loss-of-coolant accident. This evaluation was performed on the 42 inch containment purge valves at Maine Yankee by Allis-Chalmers, the valve manufacturer. The results of this evaluation are provided in Enclosure (A).

The original purchase requirements for the 42 inch containment purge valves required that the valves close in approximately 1.5 seconds from the full open position. It should be noted as specified in Reference (h), Maine Yankee will continue to restrict valve opening to 50° open (90° being full open). During a design basis accident, the containment pressure will reach the containment isolation set point of 5 psig in approximately 0.5 seconds. Therefore, assuming 0.1 seconds for instrument response, the containment purge valves should be closed in approximately 2.1 seconds at a respective containment pressure of approximately 15 psig.

In summary, the results of the evaluation performed by Allis-Chalmers show that the 42 inch containment purge valves are structurally adequate to close against the dynamic loads of the design basis accident in 2.1 seconds. In addition, the results show that the valves can also close against a hypothetical pressure drop across each valve of up to 27 psi, and maintain a design safety factor of 2 on all valve parts and valve operator. At an even greater hypothetical pressure drop of 60 psi across each valve the combined shear stress on the valve shaft would increase to 14,928 psi. The shear yield for the shaft material is approximately 18,000 psi. Realizing that the 14,928 psi is a maximum stress that occurs only at one point on the outside diameter of the shaft, it is Allis-Chalmers' position that even at this hypothetical pressure, the valve would close and structural integrity will be maintained. Note, maximum containment pressure during a postulated design basis accident is approximately 55 psig.

The guideline provided for valve operability in Reference (c) also specified that seismic loadings be addressed. The following was the original seismic requirements for these valves:

1. The equipment shall be designed within allowable working stresses for all normal loads, plus an earthquake load corresponding to a horizontally applied average acceleration of .09 g and a vertical of .06 g, both acting simultaneously.

2. The equipment shall also be designed to withstand, without loss of structural integrity or function, all normal loads plus an earthquake load corresponding to a horizontally applied average acceleration of .12 g and a vertical or .08 g, both acting simultaneously.

Since these seismic requirements did not specify frequency, Maine Yankee requested Allis-Chalmers to re-evaluate the seismic integrity of the valves and operators at 2.9 g's based on the appropriate amplified response spectrum for Maine Yankee. The seismic evaluation and conclusions from Allis-Chalmers are provided in Enclosure (B).

In summary, the stresses calculated for the internal valve parts and operator mounting components were found acceptable.

#### Radiological Analysis

A radiological analysis was performed to determine the incremental dose associated with a loss-of-coolant accident occurring during a period of on-line purging. Several break sizes were analyzed, and in all cases the total calculated accident doses are within the 10 CFR100 guideline values. The details and results regarding this analysis are provided in Enclosure (C).

Because of the complexities that arise when considering the analysis of various break sizes, break locations and the associated impact of on-line purging, Maine Yankee proposes to install an additional containment purge isolation signal which would close the purge valves on a pre-set low pressurizer pressure signal. This signal, which will be set at approximately 2200 psig, would be anticipatory to a safety injection actuation signal and would reduce the effects of small and intermediate breaks.

The proposed 2200 psig trip for the purge valves will be designed in accordance with 1E criteria for safety grade instrument systems. In addition to the 2200 psig trip, a high pressurizer pressure trip for the purge valves will also be installed. The set point for this high pressure trip will be below the set point pressure for the pressurizer safety valves. Installation of these trips will be contingent upon the Commission approving Maine Yankee's request for unlimited purge. Upon approval, on-line purge will be limited to 90 hours until the installation of these additional purge valve trips have been completed. During either heat-up or cool down of the primary system, these two additional purge valve trips may be manually by-passed. The design of this manual by-pass will not affect the other purge valve trips previously identified in the References.

Additional conservatism is included in the doses resulting from a LOCA while on-line purging, since the releases calculated from the containment did not take into account the fact that the purge valves are limited to 50° open (90° bring full open) and the throttling action created during valve closure. The calculation was done assuming a continuous 42 inch diameter opening from the containment to atmosphere throughout the specified time period.

Miscellaneous

An error has been found in the response to question 2C on Page 3 of Reference (g). The response stated that the transition from piping to ductwork occurred outside the room containing the purge exhaust valves. The transition from pipe to circular ductwork occurs approximately one foot from the outer exhaust purge valve. The structural integrity and supporting of the short section of 12 gauge circular weld duct within the valve area has been reviewed and we have concluded that the information given in the response regarding this area is still correct even though it is classified as circular weld duct and not pipe.

In the area where the welded circular duct exists the purge valve enclose through the concrete roof slab, there is approximately a 2 inch clearance between the duct and the circular hole through the slab. To better seal off this area, the clearance will be reduced by the installation of an apron around the duct where it exits the slab.


It has also been found that a supply air duct to the auxiliary feedwater pump room is routed through the enclosure containing the containment purge exhaust filter and fan. Seismic failure of the purge duct in this area of enclosure could result in damage to this supply duct. This problem will be addressed and necessary changes made (if necessary) as part of our efforts related to IE Bulletin 79-01B.

Based on the enclosed information, Maine Yankee concludes that the practice of purging during operation is justified and that it should not be limited to 90 hours per year. Purging during operation will not be done on a routine basis and emphasis will continue to be placed on operating the containment in a passive mode as much as possible and on limiting all purging and venting times to as low as reasonably achievable.

Until further notice from the Commission, Maine Yankee will continue to limit purging during operation to 90 hours per year.

Very truly yours,

MAINE YANKEE ATOMIC POWER COMPANY



Robert H. Groce  
Senior Engineer - Licensing

RHG/jlb




|   |  |                               |                   |                                 |
|---|--|-------------------------------|-------------------|---------------------------------|
| CUSTOMER<br><b>Maine Yankee</b>                               |  | DATE<br><b>2/18/80</b>        | SHEET 1 OF 10     |                                 |
| SUBJECT<br><b>42" Containment Supply &amp; Exhaust Valves</b> |  | PRELIM.                       | FINAL<br><b>X</b> |                                 |
| DRAWING NUMBER  |  | LITHO IN U.S.A. - A-C         |                   | CALCULATED BY<br><b>Zeiders</b> |
|   |  | ENGINEERING CALCULATION SHEET |                   | <b>P. SCHWARZ 3-5-80</b>        |
|   |  | ALLIS-CHALMERS                |                   | FORM 6715-1                     |

Valves: 42" - 75WR Streamseal Butterfly Valves  
 Operators: 8x30 Allis-Chalmers Standard Air Cyl.  
 @ 70 psig min. supply pressure


Valve Orientation: Per information from Yankee Atomic on 12/10/79, both supply and exhaust valves have the flat side of the disc toward containment. The supply valves are oriented as shown in Allis-Chalmers Test Report Fig. 10. The exhaust valves are oriented as shown in Fig. 9.

The thickness to diameter ratio for these valves is  $t/d = 6.0/39.6 = .152$ . Data from Test # 32 will be used for the supply valves and Test # 29 for the exhaust valves.  $t/d$  for tests # 32 & # 29 is .17.

Valve shaft diameter = 2.875" with a torque rating of 3400' per AWWA C504-74.



|                                 |  |                                      |                             |                                 |
|---------------------------------|--|--------------------------------------|-----------------------------|---------------------------------|
| CUSTOMER<br><i>Maine Yankee</i> |  | DATE<br><i>2/19/80</i>               | SHEET <b>2</b> OF <b>10</b> |                                 |
| SUBJECT                         |  | PRELIM.                              |                             | FINAL                           |
|                                 |  |                                      |                             |                                 |
| DRAWING NUMBER                  |  | LITHO IN U.S.A. - A-C                |                             | CALCULATED BY<br><i>Zeiders</i> |
|                                 |  | <b>ENGINEERING CALCULATION SHEET</b> |                             | <i>P. SCHWARZ 3-5-80</i>        |
|                                 |  |                                      |                             | FORM 6715-1                     |
|                                 |  | ALLIS CHALMERS                       |                             |                                 |



Graph assumes  
constant velocity of  
piston rod.

Assume as worst case that valve takes 2.5 sec. to close:

| Value Closing<br>Time | Disc<br>Angle | Containment<br>Pressure | * $\Delta P_{valve}$ |         |
|-----------------------|---------------|-------------------------|----------------------|---------|
|                       |               |                         | Test 32              | Test 29 |
| 0                     | 90            | 5 PSIG                  | 4                    | 4       |
| .2                    | 80            | 6                       | 5                    | 6       |
| .4                    | 70            | 7.5                     | 8                    | 7       |
| .65                   | 60            | 9                       | 11                   | 11.5    |
| .95                   | 50            | 11                      | 15                   | 15      |
| 1.2                   | 40            | 12.5                    | 17                   | 17      |
| 1.55                  | 30            | 14.5                    | 17                   | 17.5    |
| 1.85                  | 20            | 16.5                    | 19                   | 19      |
| 2.2                   | 10            | 18.5                    | 19                   | 19      |
| 2.5                   | 0             | 19.5                    |                      |         |

\* 20 PSIG upstream pressure test

|  |                       |                        |                                 |  |
|--|-----------------------|------------------------|---------------------------------|--|
| CUSTOMER<br><i>Maine Yankee</i>                    |                       | DATE<br><i>2/19/80</i> | SHEET <i>3</i> OF <i>10</i>     |  |
| SUBJECT<br><i>42" Containment Isolation Valves</i> |                       | PRELIM.                | FINAL                           |  |
| DRAWING NUMBER                                     | LITHO IN U.S.A. - A-C |                        | CALCULATED BY<br><i>Zeiders</i> |  |
| ENGINEERING CALCULATION SHEET                      |                       | P. SCHWARTZ 3-5-80     |                                 |  |
| ALLIS-CHALMERS                                     |                       | FORM 6715-1            |                                 |  |

*Test # 32 @ 15 PSIG*

| Disc Angle | $\Delta P$ Valve | $C_T$ | $T_d$ | $T_b$ | $T_o$ | Operator Tong<br>(@ 70 PSIG) |
|------------|------------------|-------|-------|-------|-------|------------------------------|
| 90         | 2                | -6.4  | 176   | 35    | 211   | 3541                         |
| 80         | 3                | 5     | 0     | 53    | 53    | 4062                         |
| 70         | 5                | 4.7   | 845   | 89    | 756   | 4550                         |
| 60         | 6                | 3.9   | 841   | 106   | 735   | 5002                         |
| 50         | 9                | 2.4   | 776   | 159   | 617   | 5410                         |
| 40         | 11               | .8    | 316   | 195   | 121   | 5771                         |
| 30         | 12               | 0     | 0     | 212   | 212   | 6080                         |
| 20         | 13               | -1.6  | 748   | 230   | 978   | 6321                         |
| 10         | 13               | -2.0  | 934   | 230   | 1164  | 6475                         |

*Test # 32 @ 20 PSIG*

| Disc Angle | $\Delta P$ Valve | $C_T$ | $T_d$ | $T_b$ | $T_o$ | Operator Tong<br>(@ 70 PSIG) |
|------------|------------------|-------|-------|-------|-------|------------------------------|
| 90         | 4                | -11.8 | 1696  | 71    | 1767  | 3541                         |
| 80         | 5                | -5    | 899   | 89    | 988   | 4062                         |
| 70         | 8                | 3.9   | 1121  | 142   | 979   | 4550                         |
| 60         | 11               | 3.4   | 1344  | 195   | 1149  | 5002                         |
| 50         | 15               | 1.1   | 593   | 266   | 327   | 5410                         |
| 40         | 17               | -4    | 244   | 301   | 545   | 5771                         |
| 30         | 17               | -6    | 367   | 301   | 668   | 6080                         |
| 20         | 19               | -7    | 478   | 336   | 814   | 6321                         |
| 10         | 19               | -1.3  | 678   | 336   | 1214  | 6475                         |

*Test # 32 @ 30 PSIG*

| Disc Angle | $\Delta P$ Valve | $C_T$ | $T_d$ | $T_b$ | $T_o$ | Operator Tong<br>(@ 70 PSIG) |
|------------|------------------|-------|-------|-------|-------|------------------------------|
| 90         | 3.5              | -26.7 | 3359  | 62    | 3421  | 3541                         |
| 80         | 6                | -6.4  | 1380  | 106   | 1486  | 4062                         |
| 70         | 11               | 1.6   | 593   | 195   | 398   | 4550                         |
| 60         | 17               | 1.5   | 916   | 301   | 615   | 5002                         |
| 50         | 24               | .27   | 233   | 425   | 192   | 5410                         |
| 40         | 26               | -5    | 467   | 460   | 927   | 5771                         |
| 30         | 28               | -34   | 342   | 496   | 838   | 6080                         |
| 20         | 28               | -69   | 694   | 496   | 1190  | 6321                         |
| 10         | 28.5             | -1.13 | 1157  | 504   | 1661  | 6475                         |

|  |                        |                                 |
|--|------------------------|---------------------------------|
| CUSTOMER<br><b>Maine Yankee</b>                    | DATE<br><b>2/18/80</b> | SHEET <b>4</b> OF <b>10</b>     |
| SUBJECT<br><b>42" Containment Isolation Valves</b> | PRELIM.                | FINAL                           |
| DRAWING NUMBER                                     | LITHO IN U.S.A. - A-C  |                                 |
| <b>ENGINEERING CALCULATION SHEET</b>               |                        | CALCULATED BY<br><b>Zeiders</b> |
| ALLIS-CHALMERS                                     |                        | <b>P. SCHWARZ 3-5-B</b>         |
| FORM 6715-1  |                        |                                 |

**Test #32 @ 40 PSIG**

| Disc Angle | ΔP Valve | C <sub>T</sub> | T <sub>d</sub> | T <sub>b</sub> | T <sub>0</sub> | Operator Torque @ 70 PSIG |
|------------|----------|----------------|----------------|----------------|----------------|---------------------------|
| 90         | 6        | -21            | 4528           | 106            | 4634           | 3541                      |
| 80         | 10       | 5.5            | 1977           | 177            | 1800           | 4062                      |
| 70         | 19       | .51            | 348            | 336            | 12             | 4550                      |
| 60         | 28       | .57            | 573            | 496            | 77             | 5002                      |
| 50         | 33       | -.195          | 231            | 584            | 816            | 5410                      |
| 40         | 36       | -.9            | 1164           | 637            | 1801           | 5771                      |
| 30         | 38       | -.59           | 806            | 673            | 1479           | 6080                      |
| 20         | 38       | -.85           | 1161           | 673            | 1834           | 6321                      |
| 10         | 38.5     | -1.0           | 1384           | 681            | 2065           | 6475                      |

**Test #32 @ 50 PSIG**

| Disc Angle | ΔP Valve | C <sub>T</sub> | T <sub>d</sub> | T <sub>b</sub> | T <sub>0</sub> | Operator Torque @ 70 PSIG |
|------------|----------|----------------|----------------|----------------|----------------|---------------------------|
| 90         | 10       | -14.1          | 5067           | 177            | 5244           | 3541                      |
| 80         | 11       | -7.1           | 2807           | 195            | 3002           | 4062                      |
| 70         | 22       | 0              | 0              | 389            | 389            | 4550                      |
| 60         | 28       | .6             | 604            | 496            | 108            | 5002                      |
| 50         | 36       | -.4            | 518            | 637            | 1155           | 5410                      |
| 40         | 42       | -.8            | 1208           | 743            | 1951           | 5771                      |
| 30         | 44       | -.7            | 1107           | 779            | 1886           | 6080                      |
| 20         | 44       | -.9            | 1423           | 779            | 2202           | 6321                      |
| 10         | 46       | -.8            | 1323           | 814            | 2137           | 6475                      |

**Test #32 @ 60 PSIG**

| Disc Angle | ΔP Valve | C <sub>T</sub> | T <sub>d</sub> | T <sub>b</sub> | T <sub>0</sub> | Operator Torque @ 70 PSIG |
|------------|----------|----------------|----------------|----------------|----------------|---------------------------|
| 90         | 15       | -3.2           | 4528           | 266            | 4794           | 3541                      |
| 80         | 18       | -3.2           | 2070           | 319            | 2389           | 4062                      |
| 70         | 23       | 0              | 0              | 407            | 407            | 4550                      |
| 60         | 32       | .8             | 920            | 566            | 354            | 5002                      |
| 50         | 43       | -.3            | 464            | 761            | 1225           | 5410                      |
| 40         | 49       | -.8            | 1409           | 867            | 2276           | 5771                      |
| 30         | 52       | -.6            | 1121           | 920            | 2041           | 6080                      |
| 20         | 53       | -.9            | 1714           | 938            | 2652           | 6321                      |
| 10         | 55       | -.9            | 1779           | 974            | 2753           | 6475                      |



|  |  |                               |         |                                 |  |
|--|--|-------------------------------|---------|---------------------------------|--|
| CUSTOMER<br><i>Maine Yankee</i>                    |  | DATE<br><i>2/18/80</i>        |         | SHEET <i>5</i> OF <i>10</i>     |  |
| SUBJECT<br><i>42" Containment Isolation Valves</i> |  |                               | PRELIM. | FINAL                           |  |
| DRAWING NUMBER                                     |  | LITHO IN U.S.A. - A-C         |         | CALCULATED BY<br><i>Zaiders</i> |  |
|  |  | ENGINEERING CALCULATION SHEET |         | <i>P. SCHWARTZ 3-5-80</i>       |  |
|  |  | ALLIS-CHALMERS                |         | FORM 6715-1                     |  |

*Test #29 @ 15 PSIG*

| Disc Angle | ΔP Valve | C <sub>T</sub> | T <sub>d</sub> | T <sub>b</sub> | T <sub>o</sub> | Operator Temp. @ 70 PSIG |
|------------|----------|----------------|----------------|----------------|----------------|--------------------------|
| 90         | 2.5      | .6             | 54             | 44             | 10             | 3541                     |
| 80         | 2.5      | 5.1            | 458            | 44             | 414            | 4062                     |
| 70         | 5        | 6.2            | 1114           | 88             | 1026           | 4550                     |
| 60         | 7.5      | 3.3            | 890            | 133            | 757            | 5002                     |
| 50         | 9.5      | 1.0            | 341            | 168            | 173            | 5410                     |
| 40         | 11.5     | -.6            | 248            | 204            | 452            | 5771                     |
| 30         | 12       | -1.1           | 474            | 212            | 686            | 6080                     |
| 20         | 12       | -1.3           | 561            | 212            | 773            | 6321                     |
| 10         | 12.5     | -1.8           | 809            | 221            | 1030           | 6475                     |

*Test #29 @ 20 PSIG*

| Disc Angle | ΔP Valve | C <sub>T</sub> | T <sub>d</sub> | T <sub>b</sub> | T <sub>o</sub> | Operator Temp. @ 70 PSIG |
|------------|----------|----------------|----------------|----------------|----------------|--------------------------|
| 90         | 4        | -10            | 1438           | 71             | 1509           | 3541                     |
| 80         | 6        | -4             | 863            | 106            | 969            | 4062                     |
| 70         | 7        | 9.2            | 2315           | 124            | 2191           | 4550                     |
| 60         | 11.5     | 4.2            | 1736           | 204            | 1534           | 5002                     |
| 50         | 15       | 1.1            | 593            | 266            | 327            | 5410                     |
| 40         | 17       | -2.4           | 1466           | 301            | 1767           | 5771                     |
| 30         | 17.5     | -2.7           | 1698           | 310            | 2008           | 6080                     |
| 20         | 19       | -3.4           | 2322           | 336            | 2658           | 6321                     |
| 10         | 19       | -4.2           | 2868           | 336            | 3204           | 6475                     |

*Test #29 @ 30 PSIG*

| Disc Angle | ΔP Valve | C <sub>T</sub> | T <sub>d</sub> | T <sub>b</sub> | T <sub>o</sub> | Operator Temp. @ 70 PSIG |
|------------|----------|----------------|----------------|----------------|----------------|--------------------------|
| 90         | 5        | -9.44          | 1696           | 88             | 1784           | 3541                     |
| 80         | 11       | -2.3           | 909            | 195            | 1104           | 4062                     |
| 70         | 13       | 0              | 0              | 231            | 230            | 4550                     |
| 60         | 17.5     | 0              | 0              | 310            | 310            | 5002                     |
| 50         | 22.5     | -.558          | 451            | 398            | 849            | 5410                     |
| 40         | 26       | -1.2           | 1121           | 460            | 1581           | 5771                     |
| 30         | 28       | -1.12          | 1127           | 496            | 1623           | 6080                     |
| 20         | 29       | -1.08          | 1125           | 513            | 1638           | 6321                     |
| 10         | 30       | -1.57          | 1692           | 531            | 2223           | 6475                     |

CUSTOMER

Maine Yankee

DATE

2/18/80

SHEET 6 OF 10

SUBJECT

42" Containment Isolation Valves

DRAWING NUMBER

LITHO IN U.S.A. - A-C

PRELIM.

FINAL

## ENGINEERING CALCULATION SHEET

CALCULATED BY

Zeiders

ALLIS-CHALMERS

FORM 6715-1

P.50AUK-22 3-5-80

Test #29 @ 40 PSIG

| Disc Angle | $\Delta P$ Valve | $C_T$  | $T_d$ | $T_b$ | $T_o$ | Operator Temp.<br>(@ 70 PSIG) |
|------------|------------------|--------|-------|-------|-------|-------------------------------|
| 90         | 10               | -6.29  | 2260  | 177   | 2437  | 3541                          |
| 80         | 10               | -3.74  | 1344  | 171   | 1521  | 4062                          |
| 70         | 15               | -1.99  | 1073  | 266   | 1339  | 4550                          |
| 60         | 22.5             | -1.66  | 534   | 398   | 932   | 5002                          |
| 50         | 30               | -1.05  | 1132  | 531   | 1663  | 5410                          |
| 40         | 35               | -1.36  | 1711  | 620   | 2331  | 5771                          |
| 30         | 38               | -1.985 | 1345  | 673   | 2018  | 6080                          |
| 20         | 39               | -1.15  | 1612  | 690   | 2302  | 6321                          |
| 10         | 39.5             | -1.21  | 1718  | 699   | 2417  | 6475                          |

Test #29 @ 50 PSIG

|    |      |       |      |     |      |      |
|----|------|-------|------|-----|------|------|
| 90 | 10   | -7.1  | 2552 | 177 | 2729 | 3541 |
| 80 | 10   | -4.11 | 1477 | 177 | 1654 | 4062 |
| 70 | 17.5 | -1.28 | 805  | 310 | 1115 | 4550 |
| 60 | 27.5 | -1.65 | 642  | 487 | 1129 | 5002 |
| 50 | 35   | -1.17 | 1472 | 620 | 2092 | 5410 |
| 40 | 42.5 | -1.48 | 2261 | 752 | 3018 | 5771 |
| 30 | 44   | -1.36 | 2151 | 779 | 2930 | 6080 |
| 20 | 46.5 | -1.35 | 2256 | 823 | 3079 | 6321 |
| 10 | 47   | -1.27 | 2145 | 832 | 2977 | 6475 |

Test #29 @ 60 PSIG

|    |      |       |      |      |      |      |
|----|------|-------|------|------|------|------|
| 90 | 14.5 | -4.34 | 2262 | 257  | 2519 | 3541 |
| 80 | 17   | -2.42 | 1478 | 301  | 1779 | 4062 |
| 70 | 24.5 | -1.28 | 1127 | 434  | 1561 | 4550 |
| 60 | 34   | -1.93 | 1136 | 602  | 1738 | 5002 |
| 50 | 42   | -1.25 | 1887 | 743  | 2630 | 5410 |
| 40 | 50   | -1.57 | 2821 | 885  | 3706 | 5771 |
| 30 | 54.5 | -1.44 | 2821 | 965  | 3786 | 6080 |
| 20 | 55.5 | -1.42 | 2832 | 982  | 3814 | 6321 |
| 10 | 57   | -1.18 | 2417 | 1009 | 3426 | 6475 |

|                                 |  |                               |  |                                 |  |
|---------------------------------|--|-------------------------------|--|---------------------------------|--|
| CUSTOMER<br><i>Maine Yankee</i> |  | DATE<br><i>2/20/80</i>        |  | SHEET <i>7</i> OF <i>10</i>     |  |
| SUBJECT                         |  | PRELIM.                       |  | FINAL                           |  |
| DRAWING NUMBER                  |  | LITHO IN U.S.A. - A-C         |  | CALCULATED BY<br><i>Zeiders</i> |  |
|                                 |  | ENGINEERING CALCULATION SHEET |  | <i>P.R. SCHWARZ 3-5-80</i>      |  |
|                                 |  | ALLIS CHAMBERS                |  | FORM 6715-1                     |  |

*Valve seating torque at the closed position:*

$$T_{os} = T_s + T_b$$

$T_s$  = rubber seating torque

$T_b$  = shaft bearing torque

$$T_s = C_s D^2 \quad \text{where } C_s = \text{coef. of seating} = 180$$

$D$  = valve dia. in feet

$$T_s = 180 \left( \frac{40}{12} \right)^2 = 2000 \text{ lbf}$$

$$T_b = 4.71 \times D^2 \times d \times f \times \Delta P \quad \text{where } d = \text{shaft dia. (inches)}$$

$f$  = coef. of friction

$$T_b = 4.71 \times \left( \frac{40}{12} \right)^2 \times 2.875 \times .12 \times \Delta P$$

$$= 18 \Delta P$$

*Shutoff Pressure*  
*psig*

|    | $T_b$ | $T_s$ | $T_b + T_s$ |
|----|-------|-------|-------------|
| 15 | 270   | 2000  | 2270 lbf    |
| 20 | 360   |       | 2360        |
| 30 | 540   |       | 2540        |
| 40 | 720   |       | 2720        |
| 50 | 900   |       | 2900        |
| 60 | 1080  |       | 3080        |

*Operator capability at the closed position @ 70 psig*  
*supply press. is 6491 lbf.*

|                                 |  |                                 |                             |         |
|---------------------------------|--|---------------------------------|-----------------------------|---------|
| CUSTOMER<br><b>Maine Yankee</b> |  | DATE<br><b>2/21/80</b>          | SHEET <b>8</b> OF <b>10</b> |         |
| SUBJECT                         |  | LITHO IN U.S.A. - A - C         |                             | PRELIM. |
| DRAWING NUMBER                  |  | ENGINEERING CALCULATION SHEET   |                             | FINAL   |
|                                 |  | ALLIS-CHALMERS                  |                             |         |
|                                 |  | FORM 6715-1                     |                             |         |
|                                 |  | CALCULATED BY<br><b>Zeiders</b> |                             |         |
|                                 |  | <b>P. R. SCHWARTZ 3-5-80</b>    |                             |         |

### Conclusions :

1. Using Tests #32 & 29, the pressure drop across the valve closely follows or exceeds containment ramp pressure. With the valves closing in 2.5 seconds (3 sec. total time from 0), the cylinder operators should close the valves with adequate margin from the full open position.

### 2. Supply valve (Ref. Test #32)

Valve should close from wide open with containment pressures up to 30 psig provided that connecting piping contributes to pressure drop exposing the valve to  $\Delta P$  shown in the test results. For containment pressures greater than 30 psig and up to 60 psig, the valve opening should be limited to 80°. With this opening limitation and  $\Delta P$  across the valve as shown in the test results, the valve should close from 80° open.

### 3. Exhaust valve (Ref. Test #29)

Valve should close from wide open with containment pressures up to 50 psig provided that connecting piping contributes to pressure drop exposing the valve to  $\Delta P$  shown in the test results. For containment pressures greater than 50 psig, the valve shaft may be exposed to torques beyond the 3400 lb rating.

4. Only single valve closure is considered in this report. Simultaneous closure of valves in series would tend to reduce torque.



|                                 |                       |                                 |                             |  |
|---------------------------------|-----------------------|---------------------------------|-----------------------------|--|
| CUSTOMER<br><i>Maine Yankee</i> |                       | DATE<br><i>2/22/80</i>          | SHEET <i>9</i> OF <i>10</i> |  |
| SUBJECT                         |                       | PRELIM.                         | FINAL                       |  |
| DRAWING NUMBER                  | LITHO IN U.S.A. - A-C | CALCULATED BY<br><i>Zeiders</i> |                             |  |
| ENGINEERING CALCULATION SHEET   |                       | P. SCHWARTZ 3-5-80              |                             |  |
| ALLIS-CHALMERS                  |                       | FORM 6715-1                     |                             |  |


5. Accumulator size:

$$\text{Volume} = 30 \text{ gal.} \times 231 \frac{\text{in}^3}{\text{gal.}} = 6930 \text{ in}^3 = 4 \text{ ft}^3$$

$$\text{Pressure} = 70 \text{ psig}$$

Cylinder size (full stroke disregarding rod)

$$\frac{\pi}{4} \times 8^2 \times 30 = 1508 \text{ in}^3 = .873 \text{ ft}^3$$



Above graph shows valve closure using accumulator tank.  
Accumulator pressure decay does not change conclusions 2 & 3.

|                                 |  |                               |         |                                 |  |
|---------------------------------|--|-------------------------------|---------|---------------------------------|--|
| CUSTOMER<br><i>Maine Yankee</i> |  | DATE<br><i>2/22/80</i>        |         | SHEET <i>10</i> OF <i>10</i>    |  |
| SUBJECT                         |  |                               | PRELIM. | FINAL                           |  |
| DRAWING NUMBER                  |  | LITHO IN U.S.A. - A-C         |         | CALCULATED BY<br><i>Zeiders</i> |  |
|                                 |  | ENGINEERING CALCULATION SHEET |         | <i>P. SCHWARZ 3-5-80</i>        |  |
|                                 |  | ALLIS-CHALMERS                |         | FORM 6715-1                     |  |

### 6. Valve shaft stresses:

During the valve closing stroke, the shaft is subjected to direct shear due to the pressure drop and to torsional shear due to the required closing torque.

$$S_{SD} = \frac{\pi \times D^2 \times \Delta P}{2 A_s} = \frac{\pi (39.6)^2 \Delta P}{8 (6.49)} = 94.89 \Delta P$$


$$S_{ST} = \frac{T \times 12}{Z_p} = \frac{12}{4.67} \times T = 2.57 T$$

$$S_{SD} + S_{ST} = 94.89 \Delta P + 2.57 T$$

Assume  $S_{SD} + S_{ST} = 9000 \text{ psi}$  max. for type 304 stainless steel  
If  $\Delta P_{\text{max.}} = 54.3 \text{ psig}$  then:

$$9000 = 94.89 (54.3) + 2.57 T$$

$$T = \frac{9000 - 94.89 (54.3)}{2.57} = 1497 \text{ lb}$$



Valve should be closed before pressure reaches 27 psig to avoid combined shear stress > 9000 psi on shaft.

Also note Test # 29 @ 20 psig shows combined stress higher than allowable at 10°. This is an instantaneous peak and should not be a structural concern.

|   |  |                               |              |                                    |
|---|--|-------------------------------|--------------|------------------------------------|
| CUSTOMER<br><i>Maine Yankee</i>                               |  | DATE<br><i>3/3/80</i>         | SHEET 1 OF 1 |                                    |
| SUBJECT<br><i>42" Containment Supply &amp; Exhaust Valves</i> |  | SLIM                          | FINAL        |                                    |
| DRAWING NUMBER  |  | LITHO IN U.S.A. - A.C.        |              | CALCULATED BY<br><i>R. Zeiders</i> |
|   |  | ENGINEERING CALCULATION SHEET |              | <i>P. R. SCHWARTZ 3-5-80</i>       |
|   |  | ALLIS-CHALMERS                |              | FORM 6715-1                        |

### Addendum #1


#### Conclusions (continued)

7. Per our discussions with Yankee Atomics, we have been advised that the subject valves will be blocked 50° open. With this condition, closing time should be 1.5 sec. max. and pressures seen by the valve will decrease.

Without considering the above margin, the maximum anticipated combined shear stress on the shaft would be :

$$\begin{aligned}
 S_{SD} + S_{ST} &= 94.89(54.3) + 3814(2.57) \quad (\text{from Test 429 @ 60 PSI}) \\
 &= 5126 + 9802 \\
 &= 14,928 \text{ PSI}
 \end{aligned}$$

The shear yield for the shaft material is  $\approx 18,000 \text{ PSI}$ . Realizing that the  $14,928 \text{ PSI}$  is a max. stress that occurs only at one point on the O.L. of the shaft, we feel that even in this worst case the valve would close and maintain structural integrity.



BOX M-93 • YORK, PENNSYLVANIA 17405/717-848-1126

YORK PLANT  
VALVE DIVISION

January 28, 1981

Yankee Atomic Electric Co.  
1671 Worcester Road  
Framingham, Mass 01701

ATTENTION: Bob Benson

Gentlemen,

In accordance with Yankee Atomic P.O. # 28191, Allis-Chalmers has submitted a static Seismic Analysis VER 0218 which verifies the ability of the equipment to withstand 2.9 g's applied simultaneously in three directions. Internal valve items, and operator mounting components have been analyzed to verify acceptable stress levels during a seismic event and the first mode natural frequency of the extended structure has been analyzed and found to be in excess of 33 hz, therefore the equipment is rigid.

In addition, Allis-Chalmers previously supplied performance calculations for the subject Containment Isolation Valve. These calculations evaluate the functional capability of the valve during a LOCA event. Based upon the criteria for Containment Pressure Ramp supplied to Allis-Chalmers by Yankee Atomic, our analysis shows that the subject valves will function and further that valve structural integrity will be maintained. Refer to our report and performance calculations sent to you in Feb. and March 1980.

Therefore the requirement for seismic qualification and functional qualification during LOCA have been seperately satisfied.

Sincerely,

G. Andzulis

GA/pmm  
3/pmm/5259



ALLIS-CHALMERS CORPORATION  
VALVE DIVISION, YORK, PA

VER 0218  
Page 1 of 28

Seismic Analysis  
for a  
42" Containment Purge Valve  
for  
Maine Yankee Atomic Power

Customer Purchase Order # 28191  
Allis-Chalmers Order # 4381

A-C Manufacturing No.: 76447  
Tag # P.O. 28191

Prepared By: H. Carl Barkner

Checked By: Barbara H. Gaither

Approved By: Alfred G. Lio 1/12/80

!!  
Table of Contents

| <u>Section No.</u> | <u>Title</u>                | <u>Page No.</u> |
|--------------------|-----------------------------|-----------------|
| 1.0                | Disc Analysis               | 3               |
| 2.0                | Pin Analysis                | 7               |
| 3.0                | Shaft Analysis              | 7               |
| 4.0                | Body Shaft Bore Analysis    | 8               |
| 5.0                | Cover End Bolt Analysis     | 8               |
| 6.0                | End Cover Analysis          | 9               |
| 7.0                | Body Analysis               | 10              |
| 8.0                | Extended Structure Analysis | 11              |
| 9.0                | Natural Frequency Analysis  | 28              |

— CONFIDENTIAL — PROPERTY OF

ALLIS-CHALMERS CORP. YORK PLANT, YORK, PA.

BY H.C. BARNUM DATE 11-13-80

SUBJECT MAINE YANKEE

SHEET NO. 2 OF 28

CHKD. BY RAY DATE 11-17-80

42"-175 WR. BUTTERFLY VALVE w/  
8x30" AIR CYLINDER

JOB NO.

The calculations for the valve and the mounting of the operators are based on the general practice of the Valve Industry and AWWA Specification C504 for butterfly valves, or the requirements of ASME Section III and ANSI B16.34 where applicable. The valve disc, shafts, body, mounting bracket, pins, bolts and bracket welding have all been reviewed.

The design stresses are within the maximum allowable stresses given in ASME Code Section III. The valve, the mounted operator and bolting meet code requirements.

Calculations shown are for valves with 75 psi design pressure at a temperature of 285 °F.

Seismic factors:

G. 2.9 horizontal one direction ☒ two orthogonal directions

G. 2.9 vertical

WORST CASE → The valve is oriented in a VERT. pipeline with the axis of the valve shaft HORIZ. and the operator \_\_\_\_\_ the valve.

Disc stresses and deflections are based upon weight, seismic factors and pressure. Shaft bearing and end cover stress calculations used disc loads, shaft weights, pressure and/or operating torques.

Body features exceeded requirements. Weights and center of gravities for the mounting bracket and operator are used in the calculation for the bolting and for the critical section in the mounting bracket.

Reference is made to:

1. "Formulas for Stress and Strain" by R. J. Roark, Table 26 Case 8b. 4<sup>TH</sup> EDITION
2. "Design of Welded Structures" by Omer W. Blodgett, Sections 2.10 and 70
3. "Vibration Theory and Application" by William T. Thomas, Page 7.

ALLIS-CHALMERS CORPORATION YORK PLANT, YORK, PA

By H.C.B. Date 11-13-80

Subject Seismic Calculation


Sheet No 3 of 28

Chkd by 244 Date 11-17-80

42"-75 WR. BFV

Job No

1. DISC STRESS & DEFLECTION:- Disc is calculated as a simple beam with maximum bending stress being on a plane thru the center perpendicular to the shaft centerline. Actual stress strain tests indicate the weakest section being in the center of the disc. Triangle loading is used to simulate a round disc, since the load is increasing towards the center and results in a higher bending load than using a uniform load. Cantilever bending calculation (90° to loading shown) has not been shown, since past experience has proven this stress to be insignificant.



| Section No. | A     | Y    | AY     | I <sub>o</sub> | d    | Ad <sup>2</sup> | I <sub>D</sub> |
|-------------|-------|------|--------|----------------|------|-----------------|----------------|
| 1           | 16.47 | .44  | 7.25   | 1.06           | 2.04 | 68.54           | 69.60          |
| 2           | 27.06 | 1.57 | 42.48  | 4.23           | 0.91 | 22.41           | 26.64          |
| 3           | 33.50 | 3.58 | 119.93 | 29.78          | 1.10 | 40.54           | 70.32          |
| 4           | 12.00 | 4.25 | 51.00  | 16.00          | 1.77 | 37.59           | 53.59          |
| Total       | 89.03 |      | 220.66 |                |      |                 | 220.15         |

$$2I_D = 440.3 \text{ IN}^4 = I_T$$

A = Area of section (sq. in)

Y = Distance from datum to centroid of section (in)

Y<sub>1</sub> = Distance from datum to neutral axis of disc (in)

I<sub>o</sub> = Moment of inertia of "A" section about its centroid

$$I_o \text{ SECT} = \frac{bh^3}{12}$$

$$I_o \text{ SECT} = \frac{bh^3}{36}$$

d = Distance from neutral axis of disc to centroid of section

I<sub>D</sub> = Moment of inertia of section about neutral axis of disc


$$I_D = I_o + Ad^2$$



ALLIS-CHALMERS MFG. CO. YORK PLANT, YORK, PA.

By H.C.B. Date 11-13-80 Subject SEISMIC CALCULATIONS Sheet No. 4 of 28  
 Chkd. by ~~8/4~~ Date 11-17-80 42"-75 WR R.F.V. Job No. \_\_\_\_\_

1.2 PRESSURE LOAD ON DISC ( $W_1$ )



$$\begin{aligned} W_1 &= \text{Pressure} \times \text{disc area} \\ W_1 &= 75 \text{ PSI} \times 1229.14 \text{ in}^2 \\ W_1 &= 92,186 \text{ LBS.} \end{aligned}$$

1.3 BENDING MOMENT ( $M_1$ )

$$\textcircled{1} M_1 = \frac{W_1 L}{6} = \frac{(92,186)(39.56)}{6} = 607,813 \text{ IN-LBS.}$$

1.4 BENDING STRESS ( $S_1$ )

$$S_1 = \frac{M_1 \times C}{I_T} = \frac{(607,813) \times (3.77)}{440.3} = 5204 \text{ PSI}$$

$M_1$  = bending moment  
 $C$  = distance from neutral axis to outermost fiber 3.77  
 $I_T$  = moment of inertia of disc =  $2I_D$  440.3

1.5 DEFLECTION FROM PRESSURE ( $Y_p$ )

$$Y_p = \frac{W_1 L^3}{60 E I_T} = \frac{(92,186)(39.56)^3}{(60)(30 \times 10^6)(440.3)} = .0072 \text{ IN}$$


$W_1$  = pressure load  
 $L$  = O.D. of disc  
 $E$  = modulus of elasticity (in tension)  $30 \times 10^6 \text{ PSI}$   
 $I_T$  = moment of inertia of disc

1 Ref from R. J. Roark, Table III, Case #17

By H.C.B. Date 11-13-80 Subject SEISMIC CALCULATIONS  
 Chkd. by ~~ELK~~ Date 11-17-80 42" 75 WR B.F.V.

Sheet No. 5 of 28  
 Job No. \_\_\_\_\_

1.5 CONCENTRATED LOAD ON DISC DUE TO SEISMIC SHOCK ( $W_2$ )



$$\begin{aligned} W_2 &= \text{Wt. of disc} \times \text{seismic factor} \\ W_2 &= 1060 \times 2.9 \\ W_2 &= 3074 \end{aligned}$$

1.7 BENDING MOMENT ( $M_2$ )

$$\textcircled{2} \quad M_2 = \frac{W_2 L}{4} = \frac{(3074)(39.56)}{4} = 30,402$$

1.8 BENDING STRESS ( $S_2$ )

$$S_2 = \frac{M_2 C}{I_T} = \frac{(30,402)(3.77)}{440.3} = 260 \text{ PSI}$$

$M_2$  = bending moment

$C$  = distance from neutral axis to outermost fiber 3.77

$I_T$  = moment of inertia of disc =  $2I_D$  443.84

1.9 DEFLECTION FROM SEISMIC LOAD ( $Y_S$ )

$$Y_S = \frac{W_2 L^3}{48 E I_T} = \frac{(3074)(39.56)^3}{48(30 \times 10^6)(440.3)} = .00030 \text{ IN}$$

TOTAL DISC STRESS ( $S_3$ )

$$S_3 = S_1 + S_2 = 5204 + 260$$

$$S_3 = 5464 \text{ PSI}$$

TOTAL DISC DEFLECTION ( $Y_T$ )

$$Y_T = Y_P + Y_S = .0072 + .0003$$

$$Y_T = .0075$$

FACTOR OF SAFETY ( $F_S$ )

$$F_S = \frac{\text{Max. Allowable Stress}}{\text{Disc Stress}} = \frac{16,000}{5464} = 2.93$$

ATE STEEL



STM-A516 GR60  $S_{YIELD} = 32,000 \text{ PSI}$ ,  $S_{YIELD} = 16,000 \text{ PSI}$

$\textcircled{2}$  Ref. from R. J. Roark. Table III, Case #11

BY H.C.B. DATE 11-13-80 SUBJECT SEISMIC CALCULATIONS  
 CHKD. BY R.H.Y. DATE 11-17-80 42" - 75 WR BFV

SHEET NO. 6 OF 28  
 JOB NO. \_\_\_\_\_

1.10 Shear stress in disc due to shaft loading (call = )



$$\begin{aligned} d_s &= 2.88 \\ L &= 5.50 \\ l_1 &= 3.25 \\ l_2 &= 3.00 \end{aligned}$$

Assume the shaft will shear out of the disc along plane "a-b". The plane of least resistance will be in the direction of the least distance  $l_1$  or  $l_2$ .

For Pressure load  $W_1$

$$\sigma_{sp} = \frac{W_1}{4lL} = \frac{92,186}{4(3.00)(5.50)} = 1397 \text{ PSI}$$

For Seismic load  $W_2$

$$\sigma_{sg} = \frac{W_2}{4lL} = \frac{3074}{4(3.00)(5.50)} = 46.6 \text{ PSI}$$

$$\text{Combined shear stress } \sigma_s = \sigma_{sp} + \sigma_{sg} = 1397 + 46.6 = 1443.6$$

1.11 Bearing Stress in shaft bore  
 (call = 32,000 PSI )

Pressure loading  $W_1$

$$\sigma_{bp} = \frac{W_1}{2d_sL} = \frac{92,186}{2(2.88)(5.50)} = 2909.9 \text{ PSI}$$

BY H.C.B. DATE 11-13-80 SUBJECT SEISMIC CALCULATIONS  
 CHKD. BY 2464 DATE 11-17-80 42"-75 WR. BFV

SHEET NO. 7 OF 28  
 JOB NO. \_\_\_\_\_

## 1.11 Continued \*

Seismic Loading  $W_2$ 

$$\sigma_{bg} = \frac{W_2}{2d_s L} = \frac{3074}{2(2.88)(5.50)} = 97 \text{ PSI}$$

1.12 Bearing Stress on Disc Due to Disc Pins  
( $\sigma_{all} = 32,000 \text{ PSI}$ )

8" 30 CYL.  
 70 PSI AIR  
 22.88" LEVER ARM

$$\sigma_b = \frac{T}{2r_{nd} p l}$$

T = Torque

$$T = 80,488 \text{ IN-LBS}$$

where r = avg. distance from  
 shaft  $\bar{c}$  to the  $\bar{c}$  of  
 the pin bearing area.  
 n = number of pins loaded  
 dp = avg. pin diameter  
 l = total length of pin  
 bearing on the disc.

$$\sigma_b = \frac{80,488}{2(1.75)(2)(.803)(6.62)} = 2163 \text{ PSI}$$

2.0 PIN: Shear Stress  
( $\sigma_{all} = 50,000 \text{ PSI}$ )

T = Torque

$$\sigma_s = \frac{2T}{\pi d_p^2 n} = \frac{2(80,488)}{\pi (.803)^2 2} = 39,733 \text{ PSI}$$

## 3.0 SHAFT: Shear Stress

Pressure Load =  $W_1$  from paragraph 1.11Seismic Load =  $W_2$  from paragraph 1.11 $W_2 + W_t$ . for Horizontal Shaft add weight of Disc.

Total Shear Stress

$$\sigma_s = \frac{W_1 + W_2}{2 A_s} + \frac{16T}{2\pi d^3} = \frac{95,260}{2(6.49)} + \frac{16(80,488)}{2(\pi)(2.88)^3}$$

$$\sigma_s = 15,919 \text{ PSI}$$

TAPER PINS  
 T.R. SST. TYPE 416

BY H.C.B. DATE 11-13-80 SUBJECT SEISMIC CALCULATION  
 CHKD. BY LLY DATE 11-17-80 42"-75 W.R. B.F.V.

SHEET NO. 8 OF 28  
 JOB NO.

#### 4.0 Bearing Stress ON BODY SHAFT BORE

Using " $W_1$ " & " $W_2$ " from 3.0

$$\sigma_b = \frac{W_1 + W_2}{2A_b}$$

$$A_b = \text{Bearing Area} = \text{OD} \times \text{length}$$

$$\sigma_b = \frac{92,186 + 3074}{2(2.88 \times 4.75)} = 3482 \text{ PSI}$$

#### 5.0 Tensile Stress in End cover bolts

$$S_T = \frac{F}{AN} = \frac{4980}{(.640) 4} = 1945 \text{ PSI}$$

$$P = \text{pressure} \times \text{area} + \text{seismic factor} \times \left( \text{wt. of disc} + \text{wt. of shafts} \right)$$

$P = 75 \times 22.4 \text{ in}^2 + \frac{1060}{2.9} \times \frac{78}{1000}$


IF VERTICAL

$$A = .7854 (D - .9743)^2$$

$$A = .7854 \left( 1 - \frac{.9743}{10} \right)^2 = .640$$

$$N = \text{NUMBER OF BOLTS} = 4$$

$$n = 10$$





By            Date            Subject            Sheet No. 9 of 28  
 Chkd. by HHH Date 11-17-80 Job No.           

## 6.0 End Cover Stresses

(Reference: Formulas for Stress & Strain  
 R. J. Roark Table 26 Case 8b)

$\sigma_b$  = BENDING STRESS

$$\sigma_b = \frac{3W_p}{2\pi t^2} \left[ \left\langle (1+V) \ln \frac{2b}{\gamma_o^1} \right\rangle + B_1 \right]$$

$$= \frac{3(4980)}{2\pi (1.5)^2} \left[ \left\langle (1.3) \ln \frac{2(9.5)}{2.67} \right\rangle + (-.238) \right] =$$

$$= 2444 \text{ PSI}$$

Where  $t$  = thickness of end cover = 1.50

$b$  = shortest side of rectangular end cover = 9.50

$B_1$  = dimension factor = -.238

$W_p = \pi \gamma_o^2 P$  for pressure loads + seismic factor x  
 (wt of vane & shafts) =  $\pi (2.67)^2 75 + 2.9(1138) = 4980 \text{ LBS}$   
 1060 + 78 = 1138

$V$  = Poisson ratio = .3

$\gamma_o^1$  = the equivalent radius of contact for a load concentrated on a very small area and is given

by  $\gamma_o^1 = \sqrt{1.6 \gamma_o^2 + t^2}$   
 = 0.675t if  $\gamma_o < 0.5t$  and  $\gamma_o^1 = \gamma_o$  if  $\gamma_o > 0.5t$

$$= 2.67 (\gamma_o > .5t)$$

$\sigma$  = BENDING STRESS

$a$  = LONGEST SIDE OF RECTANGULAR END COVER, = 9.50 IN

— CONFIDENTIAL — PROPERTY OF

ALLIS-CHALMERS CORP. YORK PLANT, YORK, PA.

BY H.C.B. DATE 11-13-80 SUBJECT SEISMIC CALCULATIONS SHEET NO. 10 OF 28  
CHKD. BY PHH DATE 11-17-80 42"-75 WR BFV JOB NO. \_\_\_\_\_

## 7.0 Body

### 7.1 Body Walls

Actual minimum wall thickness for the body flow passage is .75 in. Wall thickness for the flow passage, shaft penetration, bolt holes, etc. are all in accordance with ANSI B16.34-1977 Steel Valves.

### 2.1 Pipe loads


The moment of inertia, section modulus, and torsional resistance of the valve body is many times greater than the connecting pipe.

BY H.C.B. DATE 11-14-80 SUBJECT SEISMIC CALCULATIONS  
 CHKD. BY ANL DATE 11-17-80 42"-75 WR. B.F.V.

 SHEET NO. 11 OF 28  
 JOB NO. \_\_\_\_\_

# SUMMARY OF CENTER OF GRAVITIES

8.0



|                                   | Weight | X     | Y     | $\bar{Z}_{A-A}$ | $\bar{Z}_{B-B}$ | $\bar{Z}_{C-C}$ |
|-----------------------------------|--------|-------|-------|-----------------|-----------------|-----------------|
| Operator                          | 360    | -0.78 | -2.84 | 7.50            |                 |                 |
| Operator +<br>Bracket to<br>"B-B" | 788    | -9.44 | 17.19 |                 | 6.00            |                 |
| Operator +<br>Complete Brkt.      | 995    | -9.44 | 24.38 |                 |                 | 8.00            |

BY H.C.B. DATE 11-14-80 SUBJECT SEISMIC CALCULATIONS  
 CHKD. BY PHH DATE 11-17-80 42"-75 WR BFV

SHEET NO. 12 OF 28  
 JOB NO. \_\_\_\_\_

### 8.0 Extended Portions **CONTINUED**

(Reference drawing \_\_\_\_\_ for weight and combined C.G. of operator and mounting bracket)

### 8.1 Torsional Loads

#### 8.1.1 , Operating Torque


$$T_o = \underline{80,488 \text{ W-LBS}}$$

$$G_H = \sqrt{2.9^2 + 2.9^2} = 4.10$$

#### 8.1.2 Induced seismic torque

$$G_V = 2.9$$

##### 8.1.2.1 Horizontal valve shaft



$G$  = SEISMIC FACTORS

SUBSCRIPT  $V$  = VERTICAL

$H$  = HORIZONTAL

$T_g$  = NON OPERATING TORQUE

$G_V$  &  $G_H$  = SEISMIC FACTORS

$WT.$  = WEIGHT

Valve Shaft

$$T_g = (G_H \cdot WT. \cdot Y) + (G_V \cdot WT. + WT.) \cdot X$$

### TORQUE LOADING AT DIFFERENT SECTIONS

4/djc/8662  
 AT "A-A"  $T_g = (4.1 \times 360 \times 2.84) + [(2.9)(360) + 360] \cdot .78 = 5287 \text{ IN-LBS}$

AT "B-B"  $T_g = (4.1 \times 788 \times 17.19) + [(2.9)(788) + 788] \cdot 9.44 = 84,548 \text{ IN-LBS}$

AT "C-C"  $T_g = (4.1 \times 995 \times 24.38) + [(2.9)(995) + 995] \cdot 9.44 = 136,090 \text{ IN-LBS}$

ALLIS CHALMERS CORP. - YORK PLANT, YORK, PA.

 BY H.C.B. DATE 11-14-80 SUBJECT SEISMIC CALCULATIONS  
 CHKD. BY PHH DATE 11-17-80 4" 15 WR B.F.V.

 SHEET NO. 13 OF 28  
 JOB NO.

## 8.1.2.2 Vertical Valve Shaft

$$T_g = G_H \cdot W_T \sqrt{X^2 + Y^2}$$

TORQUE LOADING AT DIFFERENT SECTIONS.

AT "A-A"  $T_g = G_H \cdot W_T \sqrt{X^2 + Y^2} =$

"

AT "B-B"  $T_g = G_H \cdot W_T \sqrt{X^2 + Y^2} =$

AT "C-C"  $T_g = G_H \cdot W_T \sqrt{X^2 + Y^2} =$

NA

## 8.1.3 Total Torsional Load

 $T_o = \text{OPERATING TORQUE.}$ 

$$T = T_o + T_g =$$

$$T_o = 80,488 \text{ IN. LBS.}$$

AT "A-A"  $T = 80,488 + 5287 = 85,776 \text{ IN. LBS.}$

AT "B-B"  $T = 80,488 + 84,548 = 165,036 \text{ IN. LBS.}$

AT "C-C"  $T = 80,488 + 136,090 = 216,578 \text{ IN. LBS.}$



BY H.C.B. DATE 11-14-80 SUBJECT SEISMIC CALCULATIONS SHEET NO. 14 OF 28  
 CHKD. BY AKH DATE 11-17-80 42"-75 WR BEV JOB NO. \_\_\_\_\_

## 8.2 Toppling Moments and Bending Moment in Bracket

### 8.2.1 Horizontal Valve Shaft

At "A" - "A"

$$M_v(x-x) = [(wT_{Gv}) + (wt \text{ of operator})] (Z "A-A") =$$

$$[(30 \times 2.9) + (360)] \times 7.50 = 10,530 \text{ IN} \cdot \text{LBS}$$

$$M_h(y-y) = (Ghwt)(X) = (4.1)(360)(.78) = 1151 \text{ IN} \cdot \text{LBS}$$

$$M_h(x-x) = (Ghwt)(Y) = (4.1)(360)(2.84) = 4192 \text{ IN} \cdot \text{LBS}$$

At "B-B"

$$M_v(x-x) = [(wT_{Gv}) + wt \text{ of oper. \& brkt}] Z "B-B"$$

$$[(788)(2.9) + (788)] 6.00 = 18,439 \text{ IN} \cdot \text{LBS.}$$

$$M_h(y-y) = Gh(x)(wt) =$$

$$(4.1)(9.44)(788) = 30,499 \text{ IN} \cdot \text{LBS.}$$

$$M_h(x-x) = Gh(y)(wt) = (4.1)(17.19)(788) = 55,537 \text{ IN} \cdot \text{LBS}$$

At "C-C"

$$M_v(x-x) = [(wT_{Gv}) + (wt. \text{ of oper. \& brkt})] Z_{c-c}$$

$$[(995)(2.9) + (995)] 8.00 = 31,044 \text{ IN} \cdot \text{LBS}$$

$$M_h(y-y) = Gh(x)(wt) =$$

$$(4.1)(9.44)(995) = 38,510 \text{ IN} \cdot \text{LBS}$$


$$M_h(x-x) = Gh(y)(wt) =$$

$$(4.1)(24.38)(995) = 99,458 \text{ IN} \cdot \text{LBS}$$

BY H.C.B. DATE 11-14-80 SUBJECT SEISMIC CALCULATIONS  
 CHKD. BY 24/8 DATE 11-17-80 42" - 75 WR B.F.V.

SHEET NO. 15 OF 28  
 JOB NO. \_\_\_\_\_

TYPICAL MOUNTING HOLE PATTERN



Section: A-A

MOUNTING FOR H3BC

Eight hole mounting.  
 Two bolts per row

$r = 7.00$  in

Bolt size =  $\frac{3}{4}$  - 10HX x 2.75LS

Bolt Mat'l = ASTM-A307 GRA

YIELD STRESS = 60,000 PSI

BY H.C.B. DATE 1-14-80

SUBJECT SEISMIC CALCULATIONS

SHEET NO. 16 OF 28


CHKD. BY CHV DATE 11-17-80

42" - 75 W.P. REV.

JOB NO.

## TYPICAL MOUNTING HOLE PATTERN

Section C-C



Four hole rectangular mounting  
Two bolts per row

$t = 7.00$  in

Bolt size = 1.125-8N x 3.50 LG.

Bolt Mat'l = ASTM-A307 GRA

YIELD STRESS = 60,000 PSI

ALLIS-CHALMERS CORP. YORK PLANT, YORK, PA.

BY H.C.B. DATE 11-14-80 SUBJECT SEISMIC CALCULATIONS SHEET NO. 17 OF 28  
 CHKD. BY RLV DATE 11-18-80 42"-75 WR B.F.V. JOB NO. \_\_\_\_\_

8.3.1 BOLTS: Shear stress for section A-A

$G_H = 4.1$

$G_V = 2.9$

$T = \text{total torque in lb (8.1.3)} = 85,776 \text{ IN} \cdot \text{LBS}$

$r = \text{radius to bolts from centroid in.}$

$N = \text{number of bolts}$

$D = \text{bolt diameter in.}$

$n = \text{threads per inch}$

$A = \text{area of bolt in}^2 = .7854 (D - \frac{1.3}{n})^2$

$A = .7854 (.75 - \frac{1.3}{10})^2 = .302 \text{ IN}^2$

For Horizontal Shaft (8.1.2.1)

$$\text{Seismic Load } L_S = \sqrt{(G_V \text{ wt.} + \text{wt.})^2 + (G_H \text{ wt.})^2}$$

$$L_S = \sqrt{(2.9 \times 360 + 360)^2 + (4.1 \times 360)^2} = 2037 \text{ LBS}$$

$T = T_0 = 85,776 \text{ IN} \cdot \text{LBS}$

Shear stress per bolt = direct + torsional

$$\sigma_S = \frac{L_S}{NA} + \frac{T}{NrA} =$$

$$\frac{2037}{8(.302)} + \frac{85,776}{8(7.00)(.302)} = 5915 \text{ PSI}$$

BY H.C.B. DATE 11-14-80

SUBJECT SEISMIC CALCULATIONS

SHEET NO. 18 OF 28

CHKD. BY CHS DATE 11-18-80

42" - 75 WR BFV.

JOB NO.

## 8.3.1 CONTINUED

For Vertical ShaftSeismic Load  $L_S = G_H$  wt. (8.1.2.2)

NA.

Shear stress per bolt = direct + torsional

$$\sigma_S = \frac{L_S}{NA} + \frac{T}{NrA} =$$



ALLIS-CHALMERS CORP. YORK PLANT, YORK, PA.

BY H.C.B. DATE 11-14-80 SUBJECT SEISMIC CALCULATIONS  
CHKD. BY CH/L DATE 11-18-80 42" - 75 WR. B.F.V.SHEET NO. 19 OF 28  
JOB NO. \_\_\_\_\_8.3.2. BOLTS: TENSILE STRESS FOR SECTION  
Tensile Load on Critical Bolt Section A-A

For each toppling moment the critical bolt is that bolt most distant from the point or line about which the adapter would pivot if free to move.

From the previous calculations moments about X-X and y-y are treated separately. Where there are two moments about either x-x or y-y they are combined in the analysis.

1. Load due to moments about x-x  
(The critical bolt is marked No. 12 on the sketch of the section)

$$L_{T1} = \frac{M_{(x-x)} d_k}{N_1 d_1^2 + N_2 d_2^2 + \dots + N_n d_n^2}$$

where  $M_{(x-x)}$  = Sum of all moments about x-x = 14,722

$d_k$  = Distance from pivot point = 14.47 to most distant bolt.

$$L_{T1} = \frac{14,722 (14.47)}{2(1.53^2 + 5.32^2 + 10.68^2 + 14.47^2)} = \underline{300.8 \text{ LBS}}$$

$N_n$  = number of bolts per row = 2

$d_n$  = Distance from pivot point to each row of bolts

2. Load due to moments about y-y on bolt No. 3 & 4

$$L_{T2} = \frac{M_{(y-y)} d_k}{N_1 d_1^2 + N_2 d_2^2 + N_n d_n^2} \quad M_{(y-y)} = 1151$$

$d_k = 14.47$

$$L_{T2} = \frac{1151 (14.47)}{2(1.53^2 + 5.32^2 + 10.68^2 + 14.47^2)} = \underline{23.5 \text{ LBS}}$$

BY H.C.B. DATE 11-14-80

SUBJECT \_\_\_\_\_

SHEET NO. 20 OF 28CHKD. BY W.Y. DATE 11-18-80

JOB NO. \_\_\_\_\_

8.3.2. BOLTS: TENSILE STRESS FOR SECTION A-A

3. Now take the critical bolt due to moments about x-x and find the load on that bolt due to y-y moments.

$$L_{T3} = M_{(y-y)} d \frac{N_1 d_1^2 + N_2 d_2^2 + \dots + N_n d_n^2}{N_1 d_1^2 + N_2 d_2^2 + \dots + N_n d_n^2}$$

where  $d$  = Distance from adapter pivot to critical bolt found in .1 = \_\_\_\_\_ in.

The total load on bolt No. \_\_\_\_\_ is \_\_\_\_\_

$$L_{T4} = L_{T1} + L_{T3} = \text{_____} \text{ lbs.}$$

4. The load on bolt No. \_\_\_\_\_ due to x-x moments is

$$L_{T5} = M_{(x-x)} d \frac{N_1 d_1^2 + N_2 d_2^2 + \dots + N_n d_n^2}{N_1 d_1^2 + N_2 d_2^2 + \dots + N_n d_n^2} = \text{_____} \text{ lbs.}$$

The total load on bolt No. \_\_\_\_\_ is \_\_\_\_\_

$$L_{T6} = L_{T2} + L_{T5} = \text{_____} \text{ lbs.}$$

5. Therefore the critical bolt is No. \_\_\_\_\_.

6. Tensile Stress on Critical Bolt

$$\sigma_T = \frac{L_T}{A} = \frac{300.8 + 23.5}{.334} = \underline{971} \text{ psi}$$

$$\text{where } A = .7854 (d - .9743)^2$$

$$A = .7854 (.75 - .9743)^2$$

$$A = \underline{.334} \text{ in}^2$$

8.4. CRITICAL BOLT

$$\text{MAX. SHEAR} - \sigma_{SM} = \sqrt{\sigma_S^2 + \frac{\sigma_T^2}{4}} = \sqrt{5915^2 + \frac{(971)^2}{4}} = 5935 \text{ psi}$$

$$\text{MAX. TENSILE} = \sigma_{TM} = \frac{\sigma_T}{2} + \sqrt{\sigma_S^2 + \frac{\sigma_T^2}{2}} = \frac{971}{2} + \sqrt{5915^2 + \frac{(971)^2}{2}} = 6440 \text{ PSI}$$

BY H.C.B. DATE 11-14-80 SUBJECT SEISMIC CALCULATIONS SHEET NO. 21 OF 28  
 CHKD. BY PHZ DATE 11-18-80 42"-75 WR. B.F.V. JOB NO. \_\_\_\_\_

### 8.3.1 BOLTS: Shear stress for section C-C

T = total torque in lb (8.1.3) = 216,578  
 r = radius to bolts from centroid in. = 7.0 in.  
 N = number of bolts 4  
 D = bolt diameter in.  
 n = threads per inch  
 A = area of bolt in<sup>2</sup> = .7854 (D -  $\frac{1.3}{n}$ )<sup>2</sup>

BOLTS

1.125-8N

G<sub>H</sub> = 4.1G<sub>V</sub> = 2.9

$$A = .7854 \left( 1.125 - \frac{1.3}{8} \right)^2$$

$$A = .728 \text{ in}^2$$

For Horizontal Shaft (8.1.2.1)

$$\text{Seismic Load } L_s = \sqrt{(G_V \text{ wt.} + \text{wt.})^2 + (G_H \text{ wt.})^2}$$

$$L_s = \sqrt{(2.9 \times 995 + 995)^2 + (4.1 \times 995)^2} = 5630 \text{ LBS}$$

$$T = T_o = 216,578 \text{ IN. LBS} \quad (\text{SECTION C-C})$$

Shear stress per bolt = direct + torsional

$$\sigma_s = \frac{L_s}{NA} + \frac{T}{NrA} = \frac{5630}{4 \times .728} + \frac{216,578}{(4)(7)(.728)}$$

$$\tau_s = 12,558 \text{ PSI}$$

BY H.C.B. DATE 11-14-80 SUBJECT SEISMIC CALCULATIONS SHEET NO. 22 OF 28  
 CHKD. BY CHL DATE 11-18-80 JCB NO. \_\_\_\_\_

8.3.2. BOLTS: TENSILE STRESS FOR SECTION CC  
 Tensile Load on Critical Bolt Section \_\_\_\_\_

For each toppling moment the critical bolt is that bolt most distant from the point or line about which the adapter would pivot if free to move.

From the previous calculations moments about X-X and y-y are treated separately. Where there are two moments about either x-x or y-y they are combined in the analysis.

1. Load due to moments about x-x  
 (The critical bolt is marked No. 1+2 on the sketch of the section)

$$L_{T1} = \frac{M_{(x-x)} d_k}{N_1 d_1^2 + N_2 d_2^2 + \dots + N_n d_n^2}$$

where  $M_{(x-x)}$  = Sum of all moments about x-x = 130,502 in.-lbs

$d_k$  = Distance from pivot point = 12.94 in. to most distant bolt.

$$L_{T1} = \frac{(130,502)(12.94)}{2(3.06^2 + 12.94^2)}$$

$$= \underline{4776 \text{ LBS}}$$

$N_n$  = number of bolts per row

$d_n$  = Distance from pivot point to each row of bolts

2. Load due to moments about y-y on bolt No. 2+3

$$L_{T2} = \frac{M_{(y-y)} d_k}{N_1 d_1^2 + N_2 d_2^2 + \dots + N_n d_n^2}$$

$M_{(y-y)} = 38,510 \text{ in.-lbs.}$

$d_k = 12.94 \text{ in.}$

$$L_{T2} = \frac{38,510 \times 12.94}{2(3.06^2 + 12.94^2)}$$

$$= \underline{1409 \text{ LBS.}}$$

BY H.C.B. DATE 11-14-80SUBJECT SEISMIC CALCULATIONSSHEET NO. 23 OF 28CHKD. BY BAH DATE 11-18-8042"-75WR B.F.V.

JOB NO. \_\_\_\_\_

8.3.2. BOLTS: TENSILE STRESS FOR SECTION

3. Now take the critical bolt due to moments about x-x and find the load on that bolt due to y-y moments.

$$L_{T3} = M_{(y-y)} d$$

where d = Distance from adapter pivot to critical bolt found in .1 = \_\_\_\_\_ in.

$$\frac{N_1 d_1^2 + N_2 d_2^2 + \dots + N_n d_n^2}{N_1 d_1^2 + N_2 d_2^2 + \dots + N_n d_n^2}$$

The total load on bolt No. \_\_\_\_\_ is

$$L_{T4} = L_{T1} + L_{T3} = \text{_____} \text{ lbs.}$$

FOR VERTICAL

SHAFT ONLY

4. The load on bolt No. \_\_\_\_\_ due to x-x moments is

$$L_{T5} = M_{(x-x)} d$$

$$= \text{_____} = \text{_____} \text{ lbs.}$$

$$\frac{N_1 d_1^2 + N_2 d_2^2 + \dots + N_n d_n^2}{N_1 d_1^2 + N_2 d_2^2 + \dots + N_n d_n^2}$$

The total load on bolt No. \_\_\_\_\_ is

$$L_{T6} = L_{T2} + L_{T5} = \text{_____} \text{ lbs.}$$

5. Therefore the critical bolt is No. \_\_\_\_\_.

6. Tensile Stress on Critical Bolt

$$\sigma_T = \frac{L_T}{A} = \frac{4776 + 1409}{.790} = \frac{7829}{.790} \text{ psi}$$

$$\text{where } A = .7854 (d - \frac{.9743}{n})^2$$

$$A = .7854 (1.125 - \frac{.9743}{8})^2$$

$$A = .790 \text{ in}^2$$

8.4. CRITICAL BOLT

$$\text{MAX. SHEAR} = \sigma_{SM} = \sqrt{\sigma_S^2 + \frac{\sigma_T^2}{4}} = \sqrt{12,558^2 + \frac{7829^2}{4}} = 13,154 \text{ PSI}$$

$$\text{MAX. TENSILE} = \sigma_{TM} = \frac{\sigma_T}{2} + \sqrt{\sigma_S^2 + \frac{\sigma_T^2}{2}} = \frac{7829}{2} + \sqrt{12,558^2 + \frac{7829^2}{2}}$$

$$= 17,639 \text{ PSI}$$



By H.C.B. Date 11-14-80  
Chkd By CHH Date 11-18-80

Subject SEISMIC CALCULATIONS  
42-75WR BEV

Page No 24 of 28  
Job No \_\_\_\_\_

### 8.6 Bracket Section B-B

Minimum I is determined for the critical section

A = SECTION AREA  
 $I_T$  = MOMENT OF INERTIA,  
TRANSFER OF AXIS

$$I_x = \frac{b^3}{12} = I_{\text{HALF}} + I_x \text{ OF WELDED BARS. } = 5328 \text{ in}^4$$

$$I_T = 2I = 1066 \text{ in}^4$$

$$A = 2bh = \text{TOTAL BRACKET AREA} = 13.96 \text{ in}^2$$

$$I_x = .1098 (r_2^4 - r_1^4) - \frac{.283 (r_2^2 r_1^2) (r_2 - r_1)}{r_2 + r_1}$$

HALF CIRCLE

#### 8.6.1 Point farthest from the neutral axis

For horizontal shaft:

$$\sigma_{Ta} = \frac{wT_x G v x z_{bb} x C}{I_T} = \frac{788 \times 29 \times 6 \times 7}{1066} = 90.0$$

a) Tensile (flexural)

C = farthest distance from neutral axis = 7.0 in  
 $w_r$  = weight of operator + bracket to "B-B" = 788

b) Tensile (direct)  $\sigma_{Tb} = \frac{wT_x G_H}{A}$

A = section area

$$\sigma_{Tb} = \frac{788 \times 4.1}{13.96} = 231 \text{ PSI}$$

c) Stress (TOT)  $\sigma_T = \sigma_{Ta} + \sigma_{Tb}$

$$\sigma_T = 90.0 + 231 = 321 \text{ PSI}$$

ALLIS-CHALMERS CORPORATION  
VALVE DIVISION, YORK, PA

VER \_\_\_\_\_

By H.C.B. Date 11-19-80  
Chkd By R.H.Y. Date 11-18-80

Subject SEISMIC CALCULATIONS  
42"-75WR BEV

Page No 25 of 28  
Job No \_\_\_\_\_

8.6.1. CONTINUED

For Vertical Shaft:

a) Tensile (flexural)  $\sigma_{Ta} = \frac{W T_x G_H X Z_{bb} X C}{I_T}$

NA. b) Tensile (direct)  $\sigma_{tb} = \frac{W T_x G_V \pm W T}{A}$

c) Stress (Tot)  $\sigma_T = \sigma_{TA} + \sigma_{TB}$

ALLIS-CHALMERS CORPORATION  
VALVE DIVISION, YORK, PA

VER \_\_\_\_\_

By H.C.B. Date 11-14-80  
Chkd By 2/1/81 Date 11-18-80

Subject SEISMIC CALCULATIONS  
42"-75 WR. BFV

Page No 26 of 28  
Job No \_\_\_\_\_


8.6.2 Point of highest torsional stress in bracket section

a) Shear Stress (Torsional)

(Reference: Blodgett, Design of Welded Structures  
Section 2.10)

Torsional Resistance factor "R" for the section  
is the sum of the individual factors for each  
element of the section  $R_1 + R_2 + R_3 + \dots + R_n$ .

For the section sketched the value of "R" is  
calculated below.



| Element | d    | b    | b/d | $\beta$ | R    |
|---------|------|------|-----|---------|------|
| 1       | 2.67 | .75  |     | .320    | 4.57 |
| 2       | .75  | 2.65 |     | .320    | .36  |
| 3       | 2.65 | .75  |     | .320    | 4.47 |
| 4       |      |      |     |         | 26.5 |

Total  $R_T = 36$   $2R_T = 72$

$$R = \frac{.0982(d_2^4 - d_1^4)}{2} \text{ SECTION 4}$$

$$R = 3d^3b \text{ SECTIONS 1, 2, 3}$$

The shear stress

$$\sigma_{Sa} = \frac{Tt}{2R} \text{ for open sections where } T = \text{torque in inch lbs. } 165,036 \text{ lbs}$$

$$= \frac{165,036(.75)}{72} = 1719$$

t = Thickness of .75 the thickest plate

$$\sigma_{Sa} = \frac{165,036(.75)}{72} = 1719 \text{ psi}$$

b) Shear stress (direct)

For horizontal shaft:  $\sigma_{Sb} = \frac{wT_x Gv}{A}$

$$= \frac{995(2.9)}{6.49} = 445 \text{ psi}$$

For vertical shaft:  $\sigma_{Sb} = \frac{wT_x Gv}{A} \text{ N.A.}$

ALLIS-CHALMERS CORPORATION  
VALVE DIVISION, YORK, PA

VER \_\_\_\_\_

By H.C.B. Date 11-14-80  
Chkd By BH/L Date 11-18-80

Subject SEISMIC CALCULATIONS

Page No 2 of 28  
Job No \_\_\_\_\_

8.6.2 (CONTINUED)

c) Stress (Tot)  $\sigma_s = \sigma_{sa} + \sigma_{sb}$

$$1719 + 445 = 2164 \text{ PSI}$$

d) Combine shear and tensile stresses

$$\sigma_{T \text{ max}} = \frac{\sigma_t}{2} + \sqrt{\sigma_s^2 + \frac{\sigma_t^2}{4}}$$

$$\sigma_T = \frac{321}{2} + \sqrt{2164^2 + \frac{321^2}{4}} = 2330 \text{ PSI}$$

Factor of safety =  $\frac{\sigma_t \text{ allowable}}{\sigma_{T \text{ max.}}}$

PL. STL  
ASTM-A516 GR 60

$\sigma_{\text{SHEAR YIELD}} = 15,000 \text{ PSI}$

$$= \frac{15,000}{2330} = 6.44$$

Note: Plate weldments are designed to provide equivalent area, section modulus, and strength in the weld and base metal. The allowable stress has been limited to a level appropriate for a weldment.

ALLIS-CHALMERS CORP. YORK PLANT, YORK, PA.

BY H.C.B. DATE 11-14-80

SUBJECT SEISMIC CALCULATION

SHEET NO. 28 OF 28

CHKD. BY *PHY* DATE 11-18-80

42"-75" R. B.F.V.

JOB NO.

Natural Frequency at "B-B"

$$f = \frac{1}{2\pi} \sqrt{\frac{3gEI}{W(B_{B-B})^3}} \text{ cycles per second}$$

g = Acceleration of gravity = 32.2  $\frac{ft}{sec^2}$ E = Modulus of elasticity  $30 \times 10^6 \text{ PSI}$  $I_T$  = Moment of inertia (Lesser of  $I_{(x-x)}$  or  $I_{(y-y)}$ )  $I_x = 1066$ 

W = Wt. of oper. &amp; adapter beyond "B-B" = 788 lbs.

 $B_{B-B}$  = Distance from "B-B" to c.g. 6 in.

$$f = \frac{1}{2\pi} \sqrt{\frac{3 \times 32.2 (30 \times 10^6) (1066)}{788 (6^3)}} = 67.6 \text{ cps}$$

RESULTANT OFF-SITE DOSES FROM A LOCA  
DURING ON-LINE CONTAINMENT PURGE AT MAINE YANKEE

BACKGROUND INFORMATION

Radiation detectors in the containment and in the primary vent stack sample gaseous and particulate activity continuously. These detectors are designed to secure on-line purge on high gaseous activity in either the containment or the primary vent stack.

All on-line purge flow (23,000 CFM) is routed through a filter bank consisting of prefilters, HEPA filters, and a deep bed charcoal filter. The charcoal filter consists of a one-inch guard bed of activated charcoal followed by a four-inch bed of activated impregnated charcoal.

These features would serve to greatly reduce the off-site doses in the event of a LOCA occurring during a period of on-line purging; however, no credit has been taken in the analyses presented for either the on-line purge filter or automatic purge isolation on high radiation.

Several radiological analyses were performed covering the full spectrum of break sizes. The results are summarized below for each break size analyzed.

DESIGN BASIS LOCA WITH ON-LINE PURGE

The design basis accident with on-line purge was analyzed using conservative values for purge valve closure time and primary coolant concentrations. With the 42-inch diameter purge and supply valves open and with the purge fans running, the pressure rise following the DBA would reach the containment isolation setpoint of 5 psig in approximately 0.5 seconds. The purge valves are designed to close in approximately 1.5 seconds after receiving the containment isolation signal. A value of 2.1 seconds was used for the time period from the onset of the DBA to the time at which the purge valves are closed. The quantity of steam and air mixture which will be expelled from the containment under DBA conditions before the purge valves are secured was calculated to be 1600 LBM of air and 1040 LBM of water.

The source term considered in the analysis is the primary coolant activity at 1% failed fuel with a pre-existing Iodine spike of 60 uCi/gram dose equivalent iodine 131. The value of 60 uCi/gram dose equivalent iodine is the Technical Specification limit for periods not to exceed 48 hours. (The long-term operating limit for dose equivalent I-131 is 1 uCi/gram.)

Using these assumptions, the additional contribution to the thyroid and whole body gamma two-hour exclusion area boundary doses are 25 Rem and 0.01 Rem respectively. The DBA LOCA doses (without on-line purge considerations) are 178 Rem thyroid and 4.7 Rem whole body gamma. The total two-hour exclusion area boundary doses for the DBA occurring during a period of on-line purging would therefore be 203 Rem thyroid and 4.71 Rem whole body gamma.



SMALL BREAK LOCA WITH ON-LINE PURGE

An analysis was performed on the largest line-break which would not actuate an alarm for minimum letdown (60 gpm). It is assumed that after twenty minutes, the operator will manually secure the on-line purge valves, thus terminating the release. The primary coolant concentrations were set at their 1% failed fuel values, with a pre-existing Iodine spike of 60 uCi/gram dose equivalent I-131. The additional thyroid and whole body gamma doses for the small break, due to the on-line purge operation, are 3.53 Rem and 0.0015 Rem respectively.

INTERMEDIATE BREAK LOCAL WITH ON-LINE PURGE

The intermediate break analysis assumed the largest break which would not result in containment isolation on high pressure. In determining this break size, the in-containment pressure response was analyzed with the purge lines open and the purge fans running. Under these conditions, the largest break size which would not give a containment isolation on high containment pressure (5 psig) was calculated to be 0.1 ft<sup>2</sup>. A break of this magnitude would depressurize the primary coolant system to the safety injection setpoint in approximately 25 seconds.

Because of the complexities that arise when considering the analysis of various break sizes, break locations and the associated impact of on-line purging, Maine Yankee proposes to install an additional containment purge isolation signal which would close the purge valves on a pre-set low pressurizer pressure signal. This signal, which will be set at approximately 2200 psig, would be anticipatory to a safety injection actuation signal and would reduce the effects of small and intermediate breaks.

Analysis of the 0.1 ft<sup>2</sup> break size shows that the primary coolant pressure would drop below a 2200 psig purge line isolation setpoint in less than 1 sec. A value of 2.6 seconds was used for the time interval from the 0.1 ft<sup>2</sup> break until the on-line purge valves are closed by the proposed low pressure signal. During the 2.6 second interval between the line break and the purge valve closure, approximately 879 gallons of primary coolant would be released into the containment atmosphere. This quantity represents about 1% of the active primary coolant. During the 2.6 second time interval, approximately 80 lbm of steam is expelled from the containment via the open purge valves. Using conservative assumptions for primary coolant concentrations (1% failed fuel and a pre-existing Iodine spike of 60 uCi/ml), the additional LOCA dose from a 0.1 ft<sup>2</sup> break during on-line purge operations has been calculated to be 1.57 E-01 Rem thyroid and 7.18 E-05 Rem whole body gamma.

The radiological analysis of various LOCA conditions occurring during periods of on-line purging has shown that with the incorporation of the low pressure trip signal described, the limiting conditions for offsite doses is the large break DBA LOCA. Further, it has been shown that the offsite doses resulting from a large break LOCA with on-line purge would be well within the limits set forth in 10CFR100.