





Commonwealth Edison

# DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
D - 12 - 2 - 81 - 99				

<b>PART 1</b> TITLE OF DEVIATION	OCURRED
Leak in Floor Drain Collector Discharge Line	8/30/81 0300
	DATE TIME

SYSTEM AFFECTED 2000	PLANT CONDITIONS	TESTING
Rad Waste	MODE Run PWR(MWT) NA LOAD(MWE) NA	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

DESCRIPTION OF EVENT  
During a routine inspection of the Rad Waste Basement, a small leak was detected in the Floor

Drain Collector discharge line. The leak was located approximately 4 inches downstream of the Collector's discharge pump outlet along a weld between a short section of straight pipe and (over)

DESCRIPTION OF CAUSE  
The leak was caused by a failed weld which was weakened in part by chemically acidic and caustic solutions which enter the Collector System through plant floor drains.

OTHER APPLICABLE INFORMATION

EQUIPMENT FAILURE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	DR NO. N/A	WR NO. 15537	Terrence S. Palanyk	9/1/81
			RESPONSIBLE SUPERVISOR	DATE

**PART 2** OPERATING ENGINEERS COMMENTS  
A work request was submitted and the leak patched on 8/31/81. All leakage was contained within the Floor Drain System.

TYPE OF DEVIATION REPORTABLE OCCURRENCE	EVENT OF POTENTIAL PUBLIC INTEREST	TECH SPEC VIOLATION	NON-REPORTABLE OCCURRENCE	ANNUAL REPORTING	SAFETY-RELATED WR ISSUED
<input type="checkbox"/> 14 DAY <input type="checkbox"/> 10CFR21	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
<input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.d					

REPORTABLE OCCURRENCE NUMBER	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION
<del>81-55/03L-0</del>		R. M. Ragan 9/1/81 0800
		TITLE DATE TIME
		TITLE DATE TIME

24-HOUR NRC NOTIFICATION	PROMPT OFF-SITE NOTIFICATION
<input type="checkbox"/> TPH NA REGION III DATE TIME	F. Palmer 9/1/81
<input type="checkbox"/> TGM NA REGION III & DOL DATE TIME	TITLE DATE TIME
	TITLE DATE TIME

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC	TITLE	DATE
VIEW AND COMPLETED	Michael Wright	9/1/81
	OPERATING ENGINEER	DATE

ACCEPTANCE BY STATION REVIEW AS REQUIRED	<i>J. Brunner</i>	<i>John M. Palmer</i>
DATE	9/24/81	9/24/81
RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION	<i>Douglas J. ...</i>	9/24/81
	STATION SUPERINTENDENT	DATE