

# LICENSEE EVENT REPORT

Big Rock Point

CONTROL BLOCK: 1 2 3 4 5 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME 01 M I B R P 1 7 8 9 14	LICENSE NUMBER 0 0 - 0 0 0 0 0 - 0 0 15 25 25 30	LICENSE TYPE 4 1 1 1 1 25 30	EVENT TYPE 0 3 31 32
REPORT TYPE 01 CONT 7 8 57 58	REPORT SOURCE L 59 60	DOCKET NUMBER 0 5 0 - 0 1 5 5 61 68	EVENT DATE 1 2 2 2 7 7 69 74
			REPORT DATE 0 1 1 2 7 8 75 80

## EVENT DESCRIPTION

02 During monthly specific gravity checks on the Reactor Depressurization System Bat-  
 7 8 9 80

03 tery A, Cell 12 was found to have a specific gravity of 1.194. All other cells in  
 7 8 9 80

04 the unit satisfied the Technical Specification limit of  $\geq 1.200$  and the battery was  
 7 8 9 80

05 placed on equalizing charge. Previous incident reported as RO-77-49 on 10/27/77.  
 7 8 9 80

06 RO-77-50  
 7 8 9 80

SYSTEM CODE	CAUSE CODE	COMPONENT CODE	PRIME COMPONENT SUPPLIER	COMPONENT MANUFACTURER	VIOLATION
07 E C	F	B A T T E R Y	A	E S S S	N
7 8 9 10	11	12 17	43	44 47	48

## CAUSE DESCRIPTION

08 Exact cause is not known. Electrolyte mixing did not provide adequate specific  
 7 8 9 80

09 gravity sample but placing battery on equalizing charge brought specific gravity  
 7 8 9 80

10 to 1.200 in less than 8 hours.  
 7 8 9 80

FACILITY STATUS	% POWER	OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION
11 E	0 8 0	NA	B	NA
7 8 9	10 12 13	44	45 46	80

  

FORM OF ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY	LOCATION OF RELEASE
12 Z	Z	NA	NA
7 8 9	10 11	44	45 80

## PERSONNEL EXPOSURES

NUMBER	TYPE	DESCRIPTION
13 0 0 0	Z	NA
7 8 9 11	12 13	80

## PERSONNEL INJURIES

NUMBER	DESCRIPTION
14 0 0 0	NA
7 8 9 11 12	80

## PROBABLE CONSEQUENCES

15 None. Battery is deemed adequate to perform its safety function.  
 7 8 9 80

## LOSS OR DAMAGE TO FACILITY

TYPE	DESCRIPTION
16 Z	NA
7 8 9 10	80

## PUBLICITY

17 None  
 7 8 9 80

## ADDITIONAL FACTORS

18 NA  
 7 8 9 80

19  
 7 8 9 80

**END**

**DATE FILMED**

**04/28 /78**

---

---