

CONTROL BLOCK: _____ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | A | L | J | M | F | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5
3 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 4 | 8 | 7 | 0 | 9 | 1 | 2 | 8 | 1 | 3 | 0 | 9 | 2 | 8 | 8 | 1 | 9
50 51 DOCKET NUMBER 58 59 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 1 2 | At 0115 on 9/12/81 the oxygen concentration in the reactor coolant system reached 2.5 ppm |
0 1 3 | while the reactor coolant system was at 325°F. Tech. Spec. 3.4.7 requires the transient |
0 1 4 | oxygen concentration to be < 1.00 ppm. Tech. Spec. 3.4.7 action statement requirements |
0 1 5 | were met. The health/safety of the public was not affected. |
0 1 6 | _____ |
0 1 7 | _____ |
0 1 8 | _____ |

0 1 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE
3 9 | C | H | 11 | X | 12 | Z | 13 | Z | Z | Z | Z | Z | Z | 14 | Z | 15 | Z | 16 |

(17) LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
21 22 | 8 | 1 | 0 | 6 | 6 | / | 0 | 3 | L | 0 |

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRO-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
33 34 | Z | 18 | Z | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | N | 22 | N | 23 | Z | 24 | Z | 25 | Z | 9 | 9 | 9 | 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 1 0 | This event was caused by the addition of oxygenated RCS makeup water during system cool- |
1 1 1 | down. At 0343 on 9 13/81 Tav^hg was reduced to less than 250°F. (Tech. Spec. oxygen limit |
1 1 2 | no longer applicable.) |
1 1 3 | _____ |
1 1 4 | _____ |

1 1 5 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION
3 9 | G | 28 | 0 | 0 | 0 | 29 | NA | A | 30 | Operator observation | 32

1 1 6 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY | LOCATION OF RELEASE
3 9 | Z | 33 | Z | 34 | NA | NA | 35 | 36

1 1 7 | PERSONNEL EXPOSURES | DESCRIPTION
3 9 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39

1 1 8 | PERSONNEL INJURIES | DESCRIPTION
3 9 | 0 | 0 | 0 | 40 | NA | 41

1 1 9 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION
3 9 | Z | 42 | NA | 43

2 0 | PUBLICITY | ISSUED | DESCRIPTION | NAME OF PREPARER | PHONE
3 9 | N | 44 | NA | W. G. Hairston, III | (205) 899-5156

8110070310 810928
PDR ADOCK 05000348
S PDR

NRC USE ONLY