CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	A L J M F 1 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)	(5)	
	LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT	

REPORT SOURCE	L (6)	0 5 0 0 0 3 4 8 (7)	0 9 0 4 8 1 (8)	1 0 0 2 8 1 (9)	
		DOCKET NUMBER	EVENT DATE	REPORT DATE	

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 1245 on 9/4/81 the post LOCA Containment Hydrogen Analyzer "B" was declared inoperable
03 when a low analyzer temperatur[illegible] was received. Tech. Spec. 3.6.4.1 requires the
04 analyzer to be operable. Tech. [illegible] 3.6.4.1 action statement requirements were met.
05 Health/safety of the public was not affected.
06
07
08

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	S A (11)	A (12)	C (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

	LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
(17)		8 1	—	0 6 8	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X (18)	H (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	Z (25)	Z 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 This event was caused by the analyzer temperature switch being exposed to ambient air due
11 to the lack of insulation. The cause for the insulation being removed could not be deter-
12 mined. The switch was insulated, the alarm cleared and the Hydrogen Analyzer returned to
13 service at 0705 on 9/5/81. I&C personnel performing corrective and preventative mainten-
14 ance on this equipment will be instructed to insure that insulation is properly reinstalled.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
15	E (28)	1 0 0 (29)	NA	A (31)	Operator observation

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
17	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
18	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
19	Z (42)	NA

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
20	N (44)	NA	

8110140100 811002
PDR ADOCK 05000348
S PDR

NAME OF PREPARER: W. G. Hairston, III PHONE: (205)899-5156