

1 | G | A | E | I | H | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58 9

REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
On September 11, 1981, with the plant in steady state operation at 2416 Mwt and performing Reactor Building to Suppression Chamber Vacuum Relief System Operability Test, the Torus Vacuum Relief Valve, 1T48-F311, failed to open as required by Tech Specs 3.7A.3B. Plant operation was placed in a 7 day LCO. This event is non-repetitive. Public health and safety was not affected by this event.

SYSTEM CODE 9 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP. SUBCODE 19 VALVE SUBCODE 20
S B E X V A L V E X F A
EVENT YEAR 21 22 SEQUENTIAL REPORT NO. 24 26 OCCURRENCE CODE 28 29 REPORT TYPE 30 31 REVISION NO. 32
8 1 - 0 9 9 / 0 3 L - 0
ACTION TAKEN 37 FUTURE ACTION 34 EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 37 40 ATTACHMENT SUBMITTED 41 NPD-4 FORM SUB. 42 PRIME COMP. SUPPLIER 43 COMPONENT MANUFACTURER 44 47
A Z Z Z 0 0 0 0 Y N N A 4 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
The cause of this event has been attributed to sub-component failure.
The solenoid control valve which controls air to open and close the Torus Vacuum Relief Valve failed. The component was replaced, tested and 1T48-F311 returned to service.

FACILITY STATUS 8 9 % POWER 10 13 OTHER STATUS 30 METHOD OF DISCOVERY 45 DISCOVERY DESCRIPTION 32
E 0 9 9 NA Functional Test Procedure
ACTIVITY CONTENT 8 9 RELEASED OF RELEASE 10 13 AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
Z Z NA
PERSONNEL EXPOSURES 8 9 NUMBER 10 11 TYPE 12 13 DESCRIPTION 39
0 0 0 Z NA
PERSONNEL INJURIES 8 9 NUMBER 10 11 DESCRIPTION 41
0 0 0 NA
LOSS OF OR DAMAGE TO FACILITY 8 9 TYPE 10 11 DESCRIPTION 43
Z NA
PUBLICITY 8 9 ISSUED 10 11 DESCRIPTION 45
N NA

NAME OF PREPARER R. T. Nix, Supt. of Maint. PHONE: 912-367-7781

8110150481 811006
PDR ADOCK 05000321
S PDR

LER No.: 50-321/1981-099.
Licensee: Georgia Power Company.
Facility: Edwin I. Hatch
Docket No.: 50-321

Narrative Report
for LER 50-321/1981-099.

On September 11, 1981, with the plant in steady state operation at 2416 MWT and performing Reactor Building to Suppression Chamber Vacuum Relief System Operability Test, the Torus Vacuum Relief Valve, IT48-F311, failed to open as required by Tech Specs 3.7A.3B. The plant operation was placed in a 7 day LCO. This event is non-repetitive and neither public health or safety was affected.

The cause of this event has been attributed to sub-component failure. The solenoid control valve which controls air to open and close the Torus Vacuum Relief Valve failed. The component was replaced, tested and IT48-F311 returned to service.

A generic review revealed no inherent problems associated with this event.