

SEP 30 1981

Docket Nos. 50-317
and 50-318

Mr. A. E. Lundvall, Jr.
Vice President - Supply
Baltimore Gas & Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Ref: Status of NUREG-0737 Items II.F.1.1 and II.F.1.2 at Calvert Cliffs
Nuclear Power Plant, Units No. 1 and 2


Dear Mr. Lundvall:

NUREG-0737 Items II.F.1.1 and II.F.1.2 require the installation of high range noble gas effluent monitors and provisions for effluent monitoring of radioiodines at accident conditions, respectively, by January 1, 1982. Since a postimplementation review is planned, we are presently reviewing only deviations to the stated NRC positions.

Based on our review of your submittals, no technical deviations from our stated positions are requested to implement NUREG-0737 Items II.F.1.1 and II.F.1.2. If this understanding is not correct, we request formal notification of such within 30 days of the date of this letter.

Your submittal further indicates that you anticipate no problems meeting the implementation date of January 1, 1982 for Items II.F.1.1 and II.F.1.2. You should be aware that Commission approval is required to postpone the implementation date for any NUREG-0737 item at any facility. Therefore, any equipment delivery or installation problems should be brought to our attention as early as possible.

Changes to your plant Technical Specifications are necessary to fully implement NUREG-0737 Items II.F.1.1 and II.F.1.2. Sample Standard Technical Specification pages are provided as Enclosure 1 for your assistance. Your application for such proposed changes may be submitted any time prior to January 1, 1982.



OFFICE							
SUR	8110150554	810930					
P	PDR ADCK	05000317					
	PDR						

If you have questions on any portions of this letter, please contact your assigned NRC project manager.

Sincerely,
Original signed by
Robert A. Clark

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosures:
As stated

cc: See next page

DISTRIBUTION:	
Docket File	ACRS-10
NRC PDR	JHeltemes
L PDR	RAClark
NSIC	PMKreutzer-3
TERA	I&E-3
ORB#3 Rdg	EConner
DEisenhut	OELD
Gray Files	DJaffe

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL				
SURNAME	DJaffe	EConner	RACTark				
DATE	9/29/81	9/23/81	9/28/81				

Baltimore Gas and Electric Company

cc:

James A. Biddison, Jr.
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, MD 21203

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. R. C. L. Olson, Principal Engineer
Nuclear Licensing Analysis Unit
Baltimore Gas and Electric Company
Room 922 - G&E Building
P. O. Box 1475
Baltimore, MD 21203

Mr. Leon B. Russell
Plant Superintendent
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Bechtel Power Corporation
Attn: Mr. J. C. Judd
Chief Nuclear Engineer
15740 Shady Grove Road
Gaithersburg, MD 20760

Combustion Engineering, Inc.
Attn: Mr. P. W. Kruse, Manager
Engineering Services
P. O. Box 500
Windsor, CT 06095

Public Document Room
Calvert County Library
Prince Frederick, MD 20678

Director, Department of State Planning
301 West Preston Street
Baltimore, MD 21201

Mr. R. M. Douglass, Manager
Quality Assurance Department
Fort Smallwood Road Complex
P. O. Box 1475
Baltimore, MD 21203

Mr. T. L. Syndor, General Supervisor
Operations Quality Assurance
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Ms. Mary Harrison, President
Calvert County Board of County Commissioners
Prince Frederick, MD 20768

U. S. Environmental Protection Agency
Region III Office
Attn: EIS Coordinator
Curtis Building (Sixth Floor)
Sixth and Walnut Streets
Philadelphia, PA 19106

Mr. Ralph E. Architzel
Resident Reactor Inspector
NRC Inspection and Enforcement
P. O. Box 437
Lusby, MD 20657

Mr. Charles B. Brinkman
Manager - Washington Nuclear Operations
Combustion Engineering, Inc.
4853 Cordell Avenue, Suite A-1
Bethesda, MD 20014

Mr. J. A. Tierman, Manager
Nuclear Power Department
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Mr. W. J. Lippold, Supervisor
Nuclear Fuel Management
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
P. O. Box 1475
Baltimore, Maryland 21203

Mr. R. E. Denton, General Supervisor
Training & Technical Services
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Administrator, Power Plant Siting Program
Energy and Coastal Zone Administration
Department of Natural Resources
Tawes State Office Building
Annapolis, MD 21204