

OCTOBER 05 1981

DISTRIBUTION:

Docket File-2

NRC PDR

L PDR

TERA

NSIC

ORB#4 Rdg

DEisenhut

MFairtile

JStolz

RIngram

PStoddart

WGammill

OELD

AEOD

IE-3

ACRS-10

Gray File

Dockets Nos. 50-277
and 50-278

Mr. Edward G. Bauer, Jr.
Vice President and General
Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101



Dear Mr. Bauer:

Ref: Status of NUREG-0737 Items II.F.1.1 and II.F.1.2

NUREG-0737 Items II.F.1.1 and II.F.1.2 require the installation of high range noble gas effluent monitors and provisions for effluent monitoring of radiiodines at accident conditions, respectively, by January 1, 1982. Since a postimplementation review is planned, we are presently reviewing only deviations to the stated NRC positions.

Based on our review of your submittals, we understand that deviations from our stated positions are requested. Enclosure 2 provides some general information and comments that should assist you in your implementation of the subject requirements. Exxon Nuclear Company has been contracted to review these deviations. The NRC technical lead reviewer Mr. Phil Stoddart of our Effluent Treatment Systems Branch, has or soon will contact your staff through your assigned project manager to discuss the requested deviations. We request your cooperation to resolve the deviations expeditiously.

Your submittal further indicates that you anticipate no problems meeting the implementation date of January 1, 1982 for Items II.F.1.1 and II.F.1.2. You should be aware that Commission approval is required to postpone the implementation date for any NUREG-0737 item at any facility. Therefore, any equipment delivery or installation problems should be brought to our attention as early as possible.

Mr. Edward G. Bauer, Jr.

- 2 -

Changes to your plant Technical Specifications are necessary to fully implement NUREG-0737 Items II.F.1.1 and II.F.1.2. Sample Standard Technical Specification pages are provided as Enclosure 1 for your assistance. Your application for such proposed changes may be submitted any time prior to January 1, 1982.

If you have questions on any portions of this letter, please contact your assigned NRC project manager.

Sincerely,

***ORIGINAL SIGNED BY
JOHN F. STOLZ***

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosure(s):
As stated

cc w/enclosure: See next page

OFFICE ▶	ORB#4:DL <i>MA#</i>	ORB#3:DL <i>Conner</i>	C-ORB#4:DL <i>JStolz</i>				
SURNAME ▶	MFairtile	MConner	JStolz				
DATE ▶	10/1/81	10/1/81	10/2/81				

Philadelphia Electric Company

cc w/enclosure(s):

Eugene J. Bradley
Philadelphia Electric Company
Assistant General Counsel
2301 Market Street
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr.
1747 Pennsylvania Avenue, N.W.
Washington, D. C. 20006

Thomas A. Deming, Esq.
Assistant Attorney General
Department of Natural Resources
Annapolis, Maryland 21401

Philadelphia Electric Company
ATTN: Mr. W. T. Ullrich
Peach Bottom Atomic
Power Station
Delta, Pennsylvania 17314

Albert R. Steel, Chairman
Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

Curt Cowgill
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Peach Bottom Atomic Power Station
P. O. Box 399
Delta, Pennsylvania 17314

Regional Radiation Representative
EPA Region III
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

M. J. Cooney, Superintendent
Generation Division - Nuclear
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Government Publications Section
State Library of Pennsylvania
Education Building
Commonwealth and Walnut Streets
Harrisburg, Pennsylvania 17126

Mr. R. A. Heiss, Coordinator
Pennsylvania State Clearinghouse
Governor's Office of State Planning
and Development
P. O. Box 1323
Harrisburg, Pennsylvania 17120