

APPENDIX A

NOTICE OF VIOLATION

Tennessee Valley Authority
Hartsville A1, A2, B1 and B2

Docket Nos. 50-518, 50-519,
50-520 & 50-521
License Nos. CPPR-150,
CPPR-151, CPPR-152 &
CPPR-153

As a result of the inspection conducted on July 21-24, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violation was identified.

10 CFR 50, Appendix B, Criterion XIII as implemented by PSAR Section 17.1A.13 requires measures be established to control the storage and preservation of materials and equipment in accordance with work and inspection instructions to prevent damage or deterioration.

Contrary to the above, on July 21-24, 1981, measures were not established for preservation of equipment in that no preventative maintenance procedures were in effect for the fire pump diesel engines which were in long term storage.

This is a Severity Level VI Violation (Supplement II.F).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

Date: AUG 19 1981