

OCT 6 1981

Docket No. 50-266
Docket No. 50-301

Wisconsin Electric Power Company
ATTN: Mr. C. W. Fay
Director
Nuclear Power Department
231 West Michigan
Milwaukee, WI 53201



Gentlemen:

This is in regard to the September 24 and October 1, 1981, telephone discussions between you and Mr. J. F. Streeter of this office concerning your August 28, 1981 letter relating to Item 1 of the Notice of Violation for IE Inspection Report Nos. 50-266/81-10 and 50-301/81-11. We understand you will revise Item No. 7 of your procedure DCS 1.12.1 by October 9, 1981, to make it consistent with 10CFR50.72(a)(7) as clarified by the Supplement to IE Information Notice 80-08 dated July 29, 1980. Specifically, we understand you will revise Item No. 7 of DCS 1.12.1 to require the reporting of any event resulting in manual or automatic actuation of engineered safety features, including the reactor protection system, except those actuations which result from and are part of the planned sequence during surveillance testing. We understand that pending revision of DCS 1.12.1, interim direction was given to plant personnel on September 25, 1981, to report such events.

As explained by Mr. Streeter, Supplement to IE Information Notice 80-06 was not issued to allow licensees freedom to interpret reportability of events based on perceived significance. Rather, the clarification provided by the supplement is limited to the types of events that are reportable under Items (a)(1), (a)(7), and (a)(9) of 10CFR50.72.

Please inform us if your understandings are different than ours. We will review your revised procedure during a subsequent inspection.

James G. Keppler
Director

IE01
3
/11

cc w/ltr dtd 8/28/81:
DMB/Document Control Desk (RIDS)
John J. Duffy, Chief

8110190556 811006
PDR ADOCK 05000266
G PDR

OFFICE	Boiler Inspector					
SURNAME	Stanley York, Chairman	RIII Konklin/jk	RIII Streeter	RIII Speasgard	RIII Davis	RIII Keppler
DATE		10/3/81	10/5/81	10/5/81	10/5/81	10/6/81