

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | **F** | **L** | **C** | **R** | **P** | 3 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

L | 6 | 0 | 5 | 0 | - | 0 | 3 | 0 | 2 | 7 | 0 | 9 | 0 | 5 | 8 | 1 | 8

02 | During performance of SP-300, Operating Daily Surveillance Log, it was discovered
03 | that Remote Reactor Coolant Temperature Instrument RC-4A-T12 was inoperable. This
04 | created an event contrary to T. S. 3.3.3.5. Maintenance was initiated and
05 | operability was restored at 2230 on 9/5/81. There was no effect upon the health or
06 | safety of the general public. This was the second occurrence of this type and
07 | this is the ninth reported under this Specification.

09 | **I** | **C** | 11 | **X** | 12 | **Z** | 13 | **I** | **N** | **S** | **T** | **R** | **U** | 14 | **I** | 15 | **Z** | 16

17 | **8** | **1** | 0 | **5** | **9** | | **0** | **3** | **L** | 0

X | **A** | **Z** | **Z** | **0** | **0** | **0** | **0** | **Y** | **N** | **A** | **B** | **0** | **4** | **5**

10 | The cause of this event is attributed to a stuck meter. Redundant instruments
11 | were available. The instrument was exercised and the functional test was satisfactory.
12 | The meter is scheduled to be replaced during the refueling outage (WR #28310).
13 |
14 |

15 | **E** | **1** | **0** | **0** | **NA** | **B** | Operator observation

16 | **Z** | **Z** | **NA** | **NA**

17 | **0** | **0** | **0** | **Z** | **NA**

18 | **0** | **0** | **0** | **NA**

19 | **Z** | **NA**

20 | **N** | **NA**

NAME OF PREPARER: Victor A. Hernandez PHONE: 904/795-6486
 (SEE ATTACHED SUPPLEMENTARY INFORMATION SHEET)

8110220456 811013
 PDR AEDCK 0500C302
 S PDR

NRC USE ONLY

GPO 817-926

SUPPLEMENTARY INFORMATION

Report No.: 50-302/31-059/03L-0

Facility: Crystal River Unit #3

Report Date: 13 October 1981

Occurrence Date: September 5, 1981

Identification of Occurrence:

Remote Reactor Coolant Temperature Instrument was inoperable contrary to Technical Specification 3.3.3.5.

Conditions Prior to Occurrence:

Mode 1 power operation (100%).

Description of Occurrence:

During performance of SP-300, Operating Daily Surveillance Log, it was discovered that Remote Reactor Coolant Temperature Indicator RC-4A-T12 was inoperable. Maintenance was initiated and operability was restored at 2230 on September 5, 1981.

Designation of Apparent Cause:

The cause of this event is attributed to a stuck meter.

Analysis of Occurrence:

Redundant instruments were available. There was no effect upon the health or safety of the general public.

Corrective Action:

The instrument was exercised and the functional test was satisfactory. The meter is scheduled to be replaced during the refueling outage (WR #28310).

Failure Data:

This was the second occurrence of this type and this is the ninth event reported under this Specification.

/rc