

OCT 06 1981

Docket No. 99900510/81-03

United Engineers and Constructors, Inc.  
ATTN: Mr. R. A. Curnane  
Vice President Project Support  
Operations  
30 South 17th Street  
Philadelphia, PA 19101



Gentlemen:

This refers to the inspection conducted by Mr. D. D. Chamberlain of this office on September 16-18, 1981, of your facility at Philadelphia, Pennsylvania, and to the discussion of our findings with you and members of your staff at the conclusion of the inspection.

Areas examined during this inspection and our findings were discussed in the enclosed report. Within these areas, the inspection consisted of an examination of procedures and representative records, interviews, with personnel, and observations by the inspector.

During this inspection it was found that you failed to meet certain NRC requirements. The specific findings and references to the pertinent requirements are identified in the enclosures to this letter.

Please provide us within 30 days from the date of this letter a written statement containing, (1) a description of steps that have been or will be taken to correct these items; (2) a description of steps that have been or will be taken to prevent recurrence, and (3) the dates your corrective actions and preventive measures were or will be completed. Consideration may be given to extending your response time for good cause shown.

The responses directed by this Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room. If this report contains any information that you believe to be exempt from disclosure under 10 CFR 9.5(a)(4), it is necessary that you (a) notify this office by telephone within 10 days from the date of this letter of your intention to file a request

8110230306 811006  
PDR GA999 EECUNEC  
99900510 PDR

|         |         |               |           |             |           |
|---------|---------|---------------|-----------|-------------|-----------|
| OFFICE  | RIV     | SC:RSS        | BC:VIB    | D:I&ES      | DD        |
| SURNAME | CI:RSS  | DDChamberlain | UPotapovs | JEGagliardo | JTCollins |
| DATE    | 9/30/81 | 9/30/81       | 9/30/81   | 10/1/81     | 10/1/81   |

United Engineers &  
Constructors, Inc.

-2-

for withholding; and (b) submit within 25 days from the date of this letter a written application to this office to withhold such information. If your receipt of this letter has been delayed such that less than seven days are available for your review, please notify this office promptly so that a new due date may be established. Consistent with Section 2.790(b)(1), any such application must be accompanied by an affidavit executed by the owner of the information which identifies the document or part sought to be withheld, and which contains a full statement of the reasons on the basis which it is claimed that the information should be withheld from public disclosure. This section further requires the statement to address with specificity the considerations listed in 30 CFR 2.790(b)(4). The information sought to be withheld shall be incorporated as far as possible into a separate part of the affidavit. If we do not hear from you in this regard within the specified periods noted above, the report will be placed in the Public Document Room.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

"Original Signed by:

U. POTAPOVS"

Uldis Potapovs, Chief  
Vendor Inspection Branch

Enclosure:

1. Notice of Nonconformance
2. Inspection Report No. 99900510/81-03
3. Inspection Data Sheets (12 pages)

|         |  |  |  |  |  |  |  |
|---------|--|--|--|--|--|--|--|
| OFFICE  |  |  |  |  |  |  |  |
| SURNAME |  |  |  |  |  |  |  |
| DATE    |  |  |  |  |  |  |  |