

October 20, 1981

Docket No. 50-346

Toledo Edison Company
ATTN: Mr. Richard P. Crause
Vice President
Nuclear
Edison Plaza
360 Madison Avenue
Toledo, OH 43652



Gentlemen:

Attached is an addendum consisting of a Confirmatory Measurements Program data sheet for Report No. 50-346/81-06 transmitted by our letter dated April 13, 1981. The results are for a sample which had to be analyzed by our Reference Laboratory, and a spiked liquid sample supplied by our Reference Laboratory.

Please attach the addendum to your copy of our inspection report.

We will gladly discuss any questions you have regarding this addendum.

Sincerely,

J. A. Hind, Director
Division of Emergency Preparedness
and Operational Support

Enclosure: As stated

cc w/encl:
T. D. Murray, Station
Superintendent
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Harold W. Kohn, Power
Siting Commission
Helen W. Evans, State of Ohio

RIII
[Signature]
Januska/so
10/14/81

RIII
M.J.O.
Oestmann
10/14/81

RIII
[Signature]
Schumacher

RIII
[Signature]
Pateriello
10/19/81

RIII
[Signature]
Hind

IE04
S. J. I.

B110260200 B11020
PDR ADDCK 05000346
PDR
Q

IE06

TABLE T

U S NUCLEAR REGULATORY COMMISSION
 OFFICE OF INSPECTION AND ENFORCEMENT
 CONFIRMATORY MEASUREMENTS PROGRAM
 FACILITY: DAVIS BESSE
 FOR THE 1 QUARTER OF 1981

SAMPLE	ISOTOPE	-----NRC-----		---LICENSEE---		---NRC:LICENSEE---		
		RESULT	ERROR	RESULT	ERROR	RATIO	RES	T
L WASTE	H 3	5.1E-02	2.0E-04	5.0E-02	0.0	9.8E-01	2.6E+02	A
	BETA	3.1E-05	1.0E-06	3.2E-05	0.0	1.0E+00	3.1E+01	A
L SPIKED	CO 57	9.9E-05	3.5E-06	7.8E-05	0.0	7.9E-01	2.8E+01	A
	CO 60	1.9E-03	3.0E-05	1.8E-03	0.0	9.5E-01	6.3E+01	A
	CS 134	1.1E-03	3.0E-05	1.1E-03	0.0	1.0E+00	3.7E+01	A

T TEST RESULTS:

A=AGREEMENT

U=DISAGREEMENT

P=POSSIBLE AGREEMENT

N=NO COMPARISON