LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | MIDDC1 (2) | 000000000000000 (3) | 41111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 05000315 (7) | 091981 (8) | 101481 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | DURING THE PERFORMANCE OF A SURVEILLANCE TEST ON THE SOLID STATE PROTECTION SYSTEM
03 | (TRAIN A), A LOGIC TEST POSITION TESTED UNSATISFACTORILY. THIS AFFECTED THE CON-
04 | TAINMENT PRESSURE HI-HI PORTION OF THE AUTOMATIC ACTUATION LOGIC, T.S. TABLE 3.3-3
05 | ITEMS 2.b, 3.b.2, AND 4.b. THE REQUIREMENTS OF ACTION ITEM 13 WERE MET.
06 |
07 |
08 |

03 | SYSTEM CODE IB (11) | CAUSE CODE E (12) | CAUSE SUBCODE G (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE X (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 81 — SEQUENTIAL REPORT NO. 043 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN A (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER W120 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | UNIVERSAL CARD A-210 (WESTINGHOUSE, PART NO. 6056D21G01) WAS FOUND TO HAVE FAILED.
11 | THE LOGIC CARD WAS REPLACED, THE SURVEILLANCE TEST PROCEDURE WAS PERFORMED ON TRAIN
12 | "A" TO VERIFY SYSTEM OPERABILITY. NO FURTHER ACTION IS PLANNED.
13 |
14 |

15 | FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) SURVEILLANCE TEST

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 | NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES
18 | NUMBER 000 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (43)
19 | TYPE Z (42) | DESCRIPTION NA

PUBLICITY
20 | ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

8110270444 811014
PDR ADOCK 05000315
S PDR

NAME OF PREPARER R. A. PALMER PHONE 616-465-5901

GPO 917-926