

The information on this page is considered to be appropriate for public disclosure pursuant to 10 CFR 2.790.

U.S. NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT

Region V

Report No. 50-206/81-28 (IE-V--56)

Docket No. 50-206 License No. DPR-13 Safeguards Group II

Licensee: Southern California Edison Company
2244 Walnut Grove Avenue
Rosemead, California 91770

Facility Name: San Onofre Nuclear Generating Station, Unit 1

Inspection at: Camp Pendleton, California

Inspection Conducted: September 14-18, 1981

Date of Last Physical Security Inspection Visit: April 27 - May 1 and May 18-22, 1981

Type of Inspection: Routine Unannounced Physical Protection

Inspectors: *B. W. Schaefer* 10/16/81
B. W. Schaefer, Physical Protection Inspector Date Signed

A. D. McQueen 10/16/81
A. D. McQueen, Physical Protection Inspector Date Signed

Date Signed

Approved by: *M. D. Schuster* 10/16/81
M. D. Schuster, Chief, Physical Security Section Date Signed

Inspection Summary:

Areas Inspected: Included a review of Security Plan and Procedures; Security Organization - Management; Security Organization - Personnel; Security Organization - Response; Records and Reports; Testing and Maintenance; Locks, Keys and Combinations; Security System Power Supply; Lighting; Access Control - Personnel; Access Control - Packages; Access Control - Vehicles; Detection Aids - Protected Area; Detection Aids - Vita? Area; Follow up Items on Previous Inspections; and Independent Effort. The inspection involved 98 inspector hours by two NRC inspectors. The inspection was begun during regular hours; 30 inspection hours were accomplished during off shift periods.

Results: The licensee was found to be in compliance with NRC requirements within the sixteen areas examined during the inspection.

DETAILS

1. Persons Contacted 10 CFR 2.790 INFORMATION

J. Anaya, Supervisor, Plant Instrumentation, Unit 1
L. Bates, Supervising Security Officer, Unit 1
L. Baugher, Records Custodian, Corporate Document Center
*R. Bonnet, Security Supervisor, Unit 1
*F. Briggs, Compliance Engineer, SONGS
F. Bucelli, Supervising Security Officer, Unit 1
G. Buzard, Area Communication Technician, SONGS
M. Cochran, Access Control Officer, SONGS
*J. Curran, Manager, Quality Assurance, SCE
L. Gaspar, M.D., Atlantic Nuclear Services, Inc.
*E. Gault, Compliance Department, SCE
M. Goodwin, R.N., Atlantic Nuclear Services, Inc.
*K. Hadley, Supervisor, Station Security, SONGS
*G. Hammond, Nuclear Engineer, SCE
*J. Haynes, Manager, Nuclear Operations, SCE
J. Hobbs, Security Computer Programmer, Unit 1
E. Huffstutler, Alarm/Key Control Officer, SONGS
C. Johnson, Test Technician, Instrumentation Department, Unit 1
W. Jones, Maintenance Planner, Unit 1
*B. Katz, Assistant Station Manager, Technical, SONGS
R. Kelly, Nuclear Computer Technician, Unit 1
H. Key, Quality Assurance Engineer, Unit 1
R. Lemien, Supervising Security Officer, Unit 1
*G. McDonald, Supervisor, QA/QC, Unit 1
J. Pressney, Test Technician, Instrumentation Department, Unit 1
P. Rankin, Budget and Controls Supervisor, SONGS
*H. Ray, Station Manager, SONGS
G. Robinson, Security Supervisor, Unit 2
J. Summy, Computer Maintenance Foreman, SONGS
P. Talley, Security Training Officer, SONGS

81-132
8-95-
Copy 1 of 7 copies
23 pages

THIS DOCUMENT IS NOT TO BE
REPRODUCED WITHOUT SPECIFIC
APPROVAL OF IEV

The inspectors also interviewed other members of the security organization and technical staff during the course of this inspection.

*Denotes those present at the September 18, 1981 exit interview.

2. Licensee's Action on Previous Inspection Findings

(Closed) Noncompliance (80-29-02). Maintenance on non-operational alarm zones was not accomplished as soon as possible. The inspectors determined that work orders for non-operational alarm zones were receiving adequate priority. See paragraph 10.

10 CFR 2.790 INFORMATION