NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE: C O F S V 1 ②	LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 ③	LICENSE TYPE: 4 1 1 2 0 ④	CAT ⑤

CON'T 0 1	REPORT SOURCE: L ⑥	DOCKET NUMBER: 0 5 0 0 0 2 6 7 ⑦	EVENT DATE: 0 8 2 1 8 1 ⑧	REPORT DATE: 0 9 1 8 8 1 ⑨

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

0 2 During normal operation, instrument personnel performed the primary coolant pressure
0 3 scram calibration check and found that the voltage outputs of one of the three pres-
0 4 sure transmitters was low and could have caused the primary coolant high pressure
0 5 switches to trip above the limits of LCO 4.4.1, Table 4.4-1. This is being reported
0 6 per Fort St. Vrain Technical Specification AC 7.5.2(b)1 and AC 7.5.2(b)2. No effect
0 7 on public health or safety. Similar occurrences RO 77-46, 79-57, 81-008, and 81-030.
0 8

0 9	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
	I B ⑪	E ⑫	E ⑬	I N S T R U ⑭	E ⑮	Z ⑯

⑰ LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 1	—	0 5 5	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS ㉒	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
F ⑱	X ⑲	Z ⑳	Z ㉑	0 0 0 0	Y ㉓	N ㉔	N ㉕	G 0 6 3 ㉖

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ㉗

1 0 The low voltage from the pressure transmitter was due to instrument drift of the
1 1 pressure transmitter. The pressure transmitter was calibrated. Once a month
1 2 (when the reactor is pressurized above 400 psia), on a temporary basis, the pressure
1 3 transmitter voltage outputs will be checked against reactor pressure to determine if
1 4 further instrument drift is occurring. This will continue until the next calibration.

1 5	FACILITY STATUS	% POWER	OTHER STATUS ㉚	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION ㉜
	E ㉘	0 5 0 ㉙	N/A	B ㉛	Scheduled Test

1 6	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY ㉟	LOCATION OF RELEASE ㊱
	Z ㉝	Z ㉞	N/A	N/A

PERSONNEL EXPOSURES

1 7	NUMBER	TYPE	DESCRIPTION ㊴
	0 0 0 ㊲	Z ㊳	N/A

PERSONNEL INJURIES

1 8	NUMBER	DESCRIPTION ㊶
	0 0 0 ㊵	N/A

LOSS OF OR DAMAGE TO FACILITY ㊸

1 9	TYPE	DESCRIPTION
	Z ㊷	N/A

8111020257
S

PUBLICITY

2 0	ISSUED	DESCRIPTION ㊺	NRC USE ONLY
	N ㊹	N/A	

NAME OF PREPARER: Milt McBride

PHONE: (303) 785-2224

GPO 917-926