



VERMONT YANKEE NUCLEAR POWER CORPORATION

SEVENTY SEVEN GROVE STREET

RUTLAND, VERMONT 05701

2.C.2.1
FVY 81-150

REPLY TO:

ENGINEERING OFFICE

1671 WORCESTER ROAD

October 28, 1981 FRAMINGHAM, MASSACHUSETTS 01701

TELEPHONE 617-872-8100

United States Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Office of Nuclear Reactor Regulation
Mr. Darrell G. Eisenhut, Director
Division of Licensing

References: a) License No. DPR-28 (Docket No. 50-271)
b) Letter, VYNPC to USNRC, dated December 15, 1980

Subject: NUREG 0737, Item II.D.3 - Valve Position Indication

Dear Sir:

This letter provides the current status of the subject NUREG item at Vermont Yankee. As stated in Reference (b), equipment to directly monitor the position of safety and safety/relief valves is installed and functioning at our facility. However, due to the vendor's inability to provide acceptable documentation for the environmental qualification of new pressure switches in a timely fashion, the valve indication installed on the safety/relief valves is not yet fully qualified. This condition is not in agreement with Reference (b) which stated that we expected to obtain and install qualified pressure switches during the second quarter of 1981.

We are pursuing this matter with the vendor, and will install new pressure switches as soon as practicable following the receipt of qualified equipment.

We trust this information will be satisfactory; however, should you have any questions, please contact us.

Very truly yours,

VERMONT YANKEE NUCLEAR POWER CORPORATION

R. L. Smith
Licensing Engineer

RLS/smw

8111020 432
P

A046
S10

