

ATTACHMENT 2

NRC DOCKET 50-321
OPERATING LICENSE DPR-57
EDWIN I. HATCH NUCLEAR PLANT UNIT 1
PROPOSED CHANGES TO TECHNICAL SPECIFICATIONS

Pursuant to 10 CFR 170.12 (c), Georgia Power Company has evaluated the attached proposed amendments to Operating License DPR-57 and has determined that:

- a) The proposed amendment does not require the evaluation of a new Safety Analysis Report or rewrite of the facility license;
- b) The proposed amendment does not contain several complex issues, does not involve ACRS review, and does not require an environmental impact statement;
- c) The proposed amendment does not involve a complex issue, an environmental issue or more than one safety issue;
- d) The proposed amendment consists of two changes, each involving, a single safety issue, namely, addition of MAPLHGR operating limits for two new fuel types, and an increase in the Rod Block Monitor setpoint and MCPR limit as a result of new analyses.
- e) The proposed change is therefore two Class III amendments.

Table 3.2-7 (Continued)

<u>Ref. No. (a)</u>	<u>Instrument</u>	<u>Trip Condition Nomenclature</u>	<u>Required Operable Channels per Trip System (b)</u>	<u>Trip Setting</u>	<u>Remarks</u>
3	APRM	Downscale	2(e)	$\geq 3/125$ of full scale	Not required while performing low power physics test at atmospheric pressure during or after refueling at power levels not to exceed 5 MWt.
		12% Flux	2(e)	$\leq 12/125$ of full scale	This function is bypassed when the Mode Switch is placed in the RUN position.
		High Flux	2(e)	$\leq 0.66W + 42\%$	W is the loop recirculation flow rate in percent of rated. Trip level setting is in percent of rated power. Not required while performing low power physics tests at atmospheric pressure during or after refueling at power levels not to exceed 5 MWt.
4	RBM	Inoperative	1(e)(f) (g)(h)	Not applicable	Inoperative trip produced by switch not in operate, circuit boards not in circuit, fails to null, less than required number of LPRM inputs for rod selected.
		Downscale	1(e)(f) (g)(h)	$\geq 3/125$ of full scale	
		High Flux	1(e)(f)	$\leq 0.66W + 41\%$	W is the loop recirculation flow rate in percent of rated. Trip level setting is in percent of rated thermal power.

Amendment No. 38, 42

3.2-16

3.11 FUEL RODS

Applicability

The Limiting Conditions for Operation associated with the fuel rods apply to those parameters which monitor the fuel rod operating conditions.

Objective

The Objective of the Limiting Conditions for Operation is to assure the performance of the fuel rods.

Specifications

A. Average Planar Linear Heat Generation Rate (APLHGR)

During power operation, the APLHGR for each type of fuel as a function of average planar exposure shall not exceed the limiting value shown in Figure 3.11-1, sheets 1, 2 and 3. If at any time during operation it is determined by normal surveillance that the limiting value for APLHGR is being exceeded, action shall be initiated within 15 minutes to restore operation to within the prescribed limits. If the APLHGR is not returned to within the prescribed limits within two (2) hours, then reduce reactor power to less than 25% of rated thermal power within the next four (4) hours. If the limiting condition for operation is restored prior to expiration of the specified time interval, then further progression to less than 25% of rated thermal power is not required.

B. Linear Heat Generation Rate (LHGR)

During power operation, the LHGR as a function of core height shall not exceed the limiting value shown in Figure 3.11-2 for 7 x 7 fuel or the limiting value of 13.4 kw/ft for 8 x 8/8 x 8R fuel. If at any time during operation it is determined by normal surveillance that the limiting value for LHGR is being exceeded, action shall be initiated within 15 minutes to restore operation to within the prescribed limits. If the

4.11 FUEL RODS

Applicability

The Surveillance Requirements apply to the parameters which monitor the fuel rod operating conditions.

Objective

The Objective of the Surveillance Requirements is to specify the type and frequency of surveillance to be applied to the fuel rods.

Specifications

A. Average Planar Linear Heat Generation Rate (APLHGR)

The APLHGR for each type of fuel as a function of average planar exposure shall be determined daily during reactor operation at $\geq 25\%$ rated thermal power.

B. Linear Heat Generation Rate (LHGR)

The LHGR as function of core height shall be checked daily during reactor operation at $\geq 25\%$ rated thermal power.







Figure 3.11-1 (Sheet 3)




MCPR LIMIT FOR P8X8R FUEL

FIGURE 3.11.5



MCPR LIMIT FOR 8X8R FUEL

FIGURE 3.11.4



MCPR LIMIT FOR 7X7 FUEL
FIGURE 3.11.6