

TENNESSEE VALLEY AUTHORITY


CHATTANOOGA, TENNESSEE 37401
1750 Chestnut Street Tower II

USNRC REGION 2
ATLANTA, GEORGIA

October 29, 1981

81 NOV 2 A 8

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 - DOCKET
NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE OCCURRENCE
REPORT BFRO-50-296/81054

The enclosed report provides details concerning pressure switch PS-64-67
which was found to operate at 0.14 psig above Technical Specification
3.2.F limit of 35 psig. This report is submitted in accordance with
Browns Ferry unit 3 Technical Specification 6.7.2.b(2).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. J. Green
H. J. Green
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)

Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)

Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Records Center

Institute of Nuclear Power Operations
1320 Water Place
Atlanta, Georgia 30339

Mr. R. F. Sullivan, NRC Inspector, Browns Ferry

IE22
3
1/1

5111050673 811029
PDR ADOCK 05000296
S PDR