

TABLE 1
U S NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
CONFIRMATORY MEASUREMENTS PROGRAM
FACILITY: QUAD CITIES
FOR THE 3 QUARTER OF 1981

SAMPLE	ISOTOPE	-----NRC-----		---LICENSEE---		---NRC:LICENSEE---		
		RESULT	ERROR	RESULT	ERROR	RATIO	RES	T
L WASTE	H 3	3.9E-03	2.0E-05	3.4E-03	6.0E-04	8.7E-01	1.9E+02	A
	BETA	3.8E-06	2.0E-07	5.3E-06	8.0E-07	1.4E+00	1.9E+01	P
P FILTER	CS 137	6.0E-02	3.2E-05	5.0E-02	6.0E-03	8.3E-01	1.9E+03	P
	Y 88	6.0E-03	1.9E-05	5.6E-03	7.0E-04	9.3E-01	3.2E+02	A
	CO 60	7.2E-02	4.6E-05	6.4E-02	8.0E-03	8.9E-01	1.6E+03	A
	CO 57	2.7E-03	4.1E-06	2.9E-03	3.0E-04	1.1E+00	6.6E+02	A

T TEST RESULTS:
A=AGREEMENT
D=DISAGREEMENT
P=POSSIBLE AGREEMENT
N=NO COMPARISON