

RELATED CORRESPONDENCE

DOCKETED
USNRC

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

'81 NOV -5 P2:15

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of)


PACIFIC GAS AND ELECTRIC COMPANY)

Diablo Canyon Nuclear Power Plant)
Units Nos. 1 and 2)

Docket No. 50-275

Docket No. 50-323

(Full Power Proceedings)



APPLICANT PACIFIC GAS AND ELECTRIC COMPANY'S
ANSWERS TO GOVERNOR EDMUND G. BROWN JR's
SECOND SET OF INTERROGATORIES

INTERROGATORY NO. 1:

At page 36 of the PG&E Response, PG&E states that it has an agreement with Rogers Helicopter Service to provide a helicopter in the event of an emergency situation.

- A. What is the basis for the PG&E statement that "this helicopter will be used to notify persons in the Park if the County requested such assistance"? Describe all tests, analyses, or other documents which relate in any way to use of helicopters for this notification purpose.

DS03
S
111

1 B. Produce all documents constituting or relating to
2 the Rogers Agreement. l
3

4 ANSWER TO INTERROGATORY NO. 1:

5 A. PGandE has stated that a helicopter will be
6 used to notify persons in Montana de Oro State Park if
7 assistance is requested based on a contract executed
8 with Rogers Helicopter, Inc. dated 10/3/80.

9 On August 20, 1981, a test was conducted that
10 successfully demonstrated the ability to utilize a
11 helicopter both over the Diablo Canyon Plant site and
12 Montana de Oro State Park to notify public visitors of
13 an emergency. The test was witnessed by NRC
14 representatives. Transmission of emergency
15 notification information utilizing high power PA
16 systems was successfully demonstrated at altitudes of
17 500, 1,000, and 1,500 feet.

18 B. Documents constituting or relating to the
19 Rogers Agreement have been submitted for discovery.
20 Ref. EPNG 0009416-0009420.
21
22
23

24 INTERROGATORY NO. 2:

25 At page 40 of the PG&E Response, PG&E states that
26 the onsite meteorological tower is capable of withstanding

1 winds of 110 miles per hour within normal working stresses
2 and that such winds constitute the equivalent of a seismic
3 loading of 1.2g. Provide all analyses, calculations, and
4 other documents which support or in any way relate to the
5 PG&E conclusion that winds of 100 miles per hour constitute
6 the equivalent of a seismic loading of 1.2g and/or that the
7 tower will, in fact, remain operable in such a situation.
8

9 ANSWER TO INTERROGATORY NO. 2:

10 The meteorological tower is a latticed steel mast,
11 guyed at intervals along its length to resist lateral loads.
12 Due to its relatively light weight, its design is controlled
13 by wind loading rather than by earthquake. In order to find
14 the safe wind loading on the towers, the ultimate capacity
15 of each principal element of the tower was first determined.
16 Then, for each element, the wind force necessary to stress
17 it to no more than two-thirds of its ultimate capacity was
18 determined. Finally, the smallest such wind force thus
19 determined was converted to the corresponding wind velocity;
20 in this case 110 miles per hour. The equivalent seismic
21 coefficient was determined simply by dividing the wind
22 loading per unit length of the mast by the weight per unit
23 lengths of the mast. These computations and reference
24 material will be made available for discovery in San
25 Francisco.
26

1 INTERROGATORY NO. 3:

2 At page 75 of the PG&E Response, PG&E states its
3 intention to construct a permanent EOF.

- 4 A. When does PG&E intend to complete construction of
5 a permanent EOF?
- 6 B. What is the current status of meeting the
7 foregoing construction completion objective?
- 8 C. Describe all documents related to construction of
9 this permanent EOF.
- 10 D. Will the permanent EOF be seismically qualified to
11 remain functional in all respects in the event of
12 an earthquake up to and including the SSE on the
13 Hosgri fault and a 7.0-7.5 magnitude earthquake on
14 the Rhinconada fault?

15

16 ANSWER TO INTERROGATORY NO. 3:

- 17 A. Construction of the EOF, which will meet the
18 requirements of NUREG-0696, is currently scheduled to
19 be completed by October 1, 1982.
- 20 B. To date, Central Coast Labs, at PGandE's
21 request, has performed a soil analysis of the area; and
22 PGandE has prepared a topographic map, presented a
23 letter of intent to the San Luis Obispo County Board of
24 Supervisors, and reviewed preliminary floor plans with
25 County officials. PGandE is also assembling the
26 necessary information to file an application for a land

1 use permit and to prepare the EOF design criteria
2 memorandum. PGandE has received County approval for
3 both the conceptual design and location of the EOF.
4 Equipment is being purchased which conforms to
5 NUREG-0696 requirements, and an estimate of the cost of
6 the permanent EOF is being prepared.

7 C. Some documents have been generated to assist
8 the design of the permanent EOF, and they are available
9 for discovery in San Francisco. However, to date, no
10 documents have been issued which will be used in the
11 construction of this facility.

12 D. PGandE does not know if the permanent EOF
13 will be "seismically qualified to remain functional in
14 all respects" because it does not know what the phrase
15 means.

16 The permanent EOF building will be designed
17 seismically in accordance with the principles of the
18 Uniform Building Code and the Lateral Force
19 Requirements of the Structural Engineers Association of
20 California (the "Blue Book"). In part this states,
21 "... structures designed in conformance with the
22 provisions and principles set forth herein should, in
23 general, be able to:

- 24 3. Resist major earthquakes, of the intensity of
25 severity of the strongest experienced in
26

///

1 California, without collapse, but with some
2 structural as well as nonstructural damage. ¹
3 In most structures, it is expected that structural
4 damage, even in a major earthquake, could be limited to
5 repairable damage"

6
7
8
9 INTERROGATORY NO. 4:

10 At page 81 of the PG&E Response, PG&E states that
11 in the event of OBE and SSE accelerations at the Diablo
12 Canyon site, UDAC and its related equipment will remain
13 functional.

- 14 A. What accelerations does PG&E assume would occur in
15 the OBE and SSE at the UDAC site? (If the
16 accelerations are those set forth in Table I,
17 p. 84, so state.)
- 18 B. What analyses support PG&E's statement that UDAC
19 and its associated equipment will remain
20 functional under such accelerations?
- 21 C. Has PG&E performed any analyses to determine
22 whether UDAC and its related equipment will still
23 remain functional in the event of a magnitude
24 7.0-7.5 earthquake on the Rhinconcada fault
25 located at its closest point to UDAC? If so,
26 please describe such analyses and produce them.

1 If not, please describe the reason why such
2 analyses have not been performed.

3
4 ANSWER TO INTERROGATORY NO. 4:

5 A. Those set forth in Table I, page 84, of the
6 PG&E Response.

7 B. A formal analysis to support PG&E's
8 statement that UDAC and its associated equipment will
9 remain functional under postulated seismic
10 accelerations was not required. UDAC primarily
11 contains tables and chairs to provide a work area for
12 technical personnel to perform independent dose
13 assessment tasks. This equipment is not considered
14 essential to maintain the functional objectives of UDAC
15 since these dose assessment tasks can be performed
16 essentially at any location.

17 C. No. See answer to 4B, above.
18
19
20

21 INTERROGATORY NO. 5:

22 At pages 84-89 of the PG&E Response, PG&E presents
23 in tables its predicted accelerations at various onsite and
24 offsite locations in the event of the SSE and the OBE. In
25 these tables, PG&E uses the term "Distance from Hosgri
26 fault." Define that term.

1 ANSWER TO INTERROGATORY NO. 5:

2 The term "distance from Hosgri fault" is defined
3 as the shortest distance between the site in question and
4 the surface trace of the Hosgri fault. In applying this
5 definition of distance to the estimation of peak
6 acceleration at each site using Equation 1 of the TERA
7 report (pp. 3-7), two conservative assumptions were made:
8 (1) both the SSE and OBE were assumed to rupture to the
9 surface, and (2) both the SSE and OBE were assumed to
10 rupture that part of the Hosgri fault closest to the site in
11 question.

12
13
14
15 INTERROGATORY NO. 6:

16 A. With reference to the tables beginning at page 84
17 of the PG&E Response, what was the rationale for
18 using accelerations less than those postulated for
19 the SSE in the Diablo Canyon seismic proceeding?
20 For example, the onsite meteorological towers are
21 located at the Diablo Canyon facility. During the
22 seismic proceeding, a free field acceleration for
23 the SSE was postulated at 0.75g for that location.
24 Why was a lesser acceleration, namely 0.48g,
25 postulated in Table 1 and also in the Tera Report?

26 ///

1 B. At page 66 of the PG&E Response, the following
2 statement is made:

3 The postulated magnitude 7.5 earth-
4 quake on the Hosgri fault was
5 chosen because of its use as the
6 seismic design basis for the Diablo
Canyon Power Plant and its dominant
seismic hazard to the plant.

7 Explain why an acceleration of 0.75g was not also
8 assumed at the plant site for this magnitude 7.5
9 earthquake since: (i) this was the free field
10 acceleration used in the seismic design basis for
11 the Diablo Canyon plant; and (ii) a 0.75g SSE
12 acceleration is specifically set forth in the
13 Diablo Canyon Emergency Plan (Table 4.1-1, p. 15.)
14

15 ANSWER TO INTERROGATORY NO. 6:

16 A. The peak acceleration values provided in
17 response to Interrogatory 34 of the first set of
18 Governor Brown's interrogatories represent those
19 "expected" to occur during the SSE and OBE and were
20 computed as median estimates of acceleration using
21 Equation 1 of the TERA report. By definition, the
22 median estimate is one for which 50 percent of the
23 values are larger and 50 percent of the values are
24 smaller. The postulated 0.75g SSE for the Diablo
25 Canyon facility represents a design acceleration which
26 incorporates a margin of safety larger than a median or

1 "expected" value of acceleration. In this context, the
2 value of peak acceleration expected for the SSE at the
3 Diablo Canyon facility is 0.48g.

4 B. As explained in Part A of this response, the
5 0.75g SSE used as the seismic design basis for the
6 Diablo Canyon facility represents an acceleration that
7 is larger than would be expected at the facility during
8 an M_s 7.5 earthquake on the Hosgri fault, and includes
9 a margin of safety in addition to that incorporated in
10 the selection of the design basis earthquake. Use of
11 an M_s 7.5 earthquake on the Hosgri fault for emergency
12 planning purposes does not necessarily imply 0.75g as
13 the value of acceleration expected at the site during
14 such an earthquake. In fact, as stated above, the
15 value of peak acceleration expected at the Diablo
16 Canyon facility for this earthquake is 0.48g. For
17 planning purposes, expected values of peak acceleration
18 were used so that realistic damage scenarios would be
19 considered. Scenarios incorporating greater and lesser
20 damage were also considered to account for uncertainty
21 associated with this assessment of expected damages.
22
23
24
25
26

1 INTERROGATORY NO. 7:

2 With reference to the tables beginning at page 84
3 of the PG&E Response, are the peak accelerations listed mean
4 peak accelerations or medians and what is the assumed
5 standard deviation?
6

7 ANSWER TO INTERROGATORY NO. 7:

8 The acceleration parameter used to represent peak
9 acceleration in the response to Interrogatory 34 of the
10 first set of interrogatories is defined as the mean of the
11 two peak values scaled from the horizontal components of an
12 accelerogram. The estimate of this parameter, as listed in
13 Tables I, II, and III, is the median value or that value
14 expected to occur at the site during the specified
15 earthquake. The standard deviation associated with this
16 estimate is 0.405 for the natural logarithm of peak
17 acceleration, representing a multiplicative factor of 1.50
18 on the estimate of acceleration.
19
20
21

22 INTERROGATORY NO. 8:

23 At page 5 of the PG&E Response, lines 14-16, PG&E
24 states that "the dose reduction benefit of sheltering versus
25 evacuation and being overtaken by the passing plume will be
26 evaluated on a case-by-case basis." What criteria will be

1 utilized in this case-by-case determination? What training
2 is being and/or has been provided to PG&E personnel on
3 application of these criteria?

4
5 ANSWER TO INTERROGATORY NO. 8:

6 As required by NUREG-0654/FEMA-REP-1, criteria for
7 plume exposure pathway protective action recommendations for
8 the general public are based on the "Manual of Protective
9 Action Guides and Protective Actions for Nuclear Incidents"
10 (EPA-520/1-75-001). In order to determine the most
11 effective protective action, the dose reduction factor for
12 whole body dose and thyroid dose would be determined for
13 sheltering and evacuation. The dose reduction factor
14 depends upon composition of plume, magnitude of plume, plume
15 arrival time, duration of release (duration of plume
16 exposure), projected evacuation time, and plume transit
17 time. The protective action which has the greatest dose
18 reduction factor would be the protective action recommended.
19 In cases where the dose reduction benefits are nearly equal,
20 sheltering would be initiated with evaluation of advantages
21 gained by subsequent evacuation. With sheltering followed
22 by evacuation, advantages increase as degree of protection
23 by shelter decrease and plume exposure period increases.

24 PGandE personnel have been trained and will
25 continue to be trained on the applicable emergency
26 procedures. In addition, PGandE personnel have attended

1 radiological accident assessment courses sponsored by the
2 State of California and the NRC/FEMA in which instruction
3 was provided by experts in the areas of protective action
4 application.

5
6
7
8 INTERROGATORY NO. 9:

9 At page 7 of the PG&E Reponse, reference is made
10 to the media center at Cuesta College. What is the seismic
11 qualification of that media center?

12
13 ANSWER TO INTERROGATORY NO. 9:

14 The seismic qualification of the media center at
15 Cuesta College is unknown.

16
17
18
19 INTERROGATORY NO. 10:

20 At pages 15-19 of the PG&E Response, PG&E has
21 described many elements of its public information program.
22 Has this information been produced in response to Governor
23 Brown's prior document production requests? If not, the
24 Governor requests that all documents described at pages
25 15-19 and drafts of documents not in complete form be
26 produced.

1 ANSWER TO INTERROGATORY NO. 10:

2 To the best of its knowledge, all documents and
3 drafts of documents listed in pages 15-19 of the PGandE
4 Response have been made available for discovery.
5

6
7
8 INTERROGATORY NO. 11:

9 At page 27 of the PG&E Response, seven documents
10 are described related to emergency planning drills. Have
11 these documents been produced in response to Governor
12 Brown's document production requests? If not, produce
13 these documents.
14

15 ANSWER TO INTERROGATORY NO. 11:

16 The documents described on page 27 of the PGandE
17 Response were not produced in response to Governor Brown's
18 Document Production request because of their irrelevancy.
19 However, with the exception of the Drill Logs, which were
20 unsigned and dated August 13 and 17, 1981, respectively, all
21 other documents will be produced.
22
23
24
25
26

1 INTERROGATORY NO. 12:

2 At page 32 of the PG&E Response, PG&E describes
3 various documents. Documents Nos. 13 and 14, to our
4 knowledge, have not yet been produced by PG&E in response to
5 the Governor's document production requests. Produce these
6 documents.

7
8 ANSWER TO INTERROGATORY NO. 12:

9 The requested documents (Nos. 13 and 14) are
10 attached.

11
12
13
14 INTERROGATORY NO. 13:

15 In Interrogatory 9 of Governor Brown's first set
16 of Interrogatories to PG&E, the Governor asked PG&E, inter
17 alia, to identify and describe any tests or analyses which
18 have been performed either by PG&E or others on the
19 qualifications, characteristics, and response features of
20 the real-time monitors and the equipment at the
21 environmental monitoring stations. PG&E omitted any
22 response to this Interrogatory in its earlier answers.
23 Please provide a response at this time.

1 ANSWER TO INTERROGATORY NO. 13:

2 No analyses or tests have been performed by PGandE
3 or others on the qualifications, characteristics, and
4 response features of the real-time monitors and the
5 equipment at the environmental monitoring stations.
6

7
8
9 INTERROGATORY NO. 14:

10 At page 40 of the PG&E Response, PG&E referenced
11 that the Federal Signal Company has recently completed some
12 seismic work on the largest siren. PG&E also stated that
13 this information was being forwarded to PG&E and will be
14 used to supplement PG&E's earlier response when available.
15 Has this information yet been provided to PG&E? When does
16 PG&E anticipate supplementing its earlier responses?
17

18 ANSWER TO INTERROGATORY NO. 14:

19 PGandE received the information concerning the
20 seismic testing of the Model 1000 siren from the Federal
21 Signal Company in mid-September. The actual testing was
22 performed by Wyle Laboratory for the Federal Signal Company.
23 The document is available for discovery in the PGandE office
24 in San Francisco.
25
26

1 INTERROGATORY NO. 15:

2 At page 42, lines 19-21, of the PG&E Response, 1
3 reference is made to the compressor and the compressor
4 platform related to the siren system. Have any seismic
5 analyses been performed regarding the compressor and/or the
6 associated platform? If so, describe and provide these
7 analyses.
8

9 ANSWER TO INTERROGATORY NO. 15:

10 No.
11
12
13

14 INTERROGATORY NO. 16:

15 At page 56 of the PG&E Response, it is stated that
16 the standard operating procedures for the San Luis Obispo
17 County Emergency Plan would be described in PG&E's responses
18 to requests for production. Our review of PG&E's production
19 responses discloses that these procedures were not so
20 described. Accordingly, describe each of those operating
21 procedures or, in the alternative, produce them for
22 inspection and copying.
23

24 ANSWER TO INTERROGATORY NO. 16:

25 Standard Operating Procedures for the upgraded
26 County Emergency Plan are not yet finalized and approved by

2 cognizant county authorities. Requests for copies of County
3 de- must be directed to the county.
4
5

6 INTERROGATORY NO. 17:

7 At page 66 of the PG&E Response, the following
8 statement is made:

9 A large variability of off-site damage
10 would be expected to result from the
11 Hosgri earthquake. This diversity of
12 damage comprehensively challenges
13 emergency plans and requires them to be
14 extremely flexible. The variety of
15 damage scenarios considered largely
16 envelopes the expected effects of both
17 smaller and larger earthquakes that
18 might occur within San Luis Obispo
19 County. The main difference being the
20 relative likelihood of specific
21 scenarios.

- 22 A. In what way do the damage scenarios considered not
23 envelope the expected effects of both large and
24 smaller earthquakes that might occur within San
25 Luis Obispo County?
26 B. Describe all analyses or other documents which
support the statement quote above.

22 ///

23 ///

24 ///

1 ANSWER TO INTERROGATORY NO. 17:

2 A. PG&E does not believe an enveloping of
3 expected earthquake effects is particularly useful for
4 emergency planning. By evaluating a spectrum of
5 potential damage levels and the effects of these damage
6 levels on evacuation time estimates, the appropriate
7 emergency response can be determined for a wide range
8 of earthquakes, both large and small.

9 B. Supporting analyses and documents are
10 provided in the TERA report on Earthquake Emergency
11 Planning at Diablo Canyon, copies of which have been
12 furnished to all parties.

13
14
15
16 INTERROGATORY NO. 18:

17 On page 72 of the PG&E Response, PG&E states that
18 it believes all applicable emergency plans will be in
19 compliance with all applicable regulations prior to
20 commercial operation of the Diablo Canyon facility.

21 A. As of September 15, 1981, the date of the PG&E
22 Response, (or, if PG&E prefers, on the date PG&E
23 responds to these Interrogatories) what were (are)
24 the items of noncompliance with applicable
25 regulations for the PG&E, the County, and the
26 State emergency response plans?

1 B. What schedule for resolution of these items of
2 noncompliance did PG&E assume when it made the
3 foregoing statement on page 72?
4

5 ANSWER TO INTERROGATORY NO. 18:

6 A. As stated previously, it is PGandE's position
7 that all applicable emergency plans will be in
8 compliance with all applicable regulations prior to
9 commercial operation of the Diablo Canyon nuclear power
10 plant in order to assure that adequate protective
11 measures can and will be taken in the event of a
12 radiological emergency.

13 This opinion is based on the individual and
14 collective judgment of Applicant's staff who have been
15 intimately involved in emergency response planning for
16 the past several years as well as the opinions of
17 various federal, state and county emergency response
18 planners and evaluators. In addition, Applicant has
19 retained consultants who have reviewed the various
20 plans and applicable regulations and have formed
21 similar opinions. Finally, the joint full field
22 exercise conducted on August 19, 1981 demonstrated a
23 capability to respond to a radiological emergency at
24 Diablo Canyon.

25 ///

26 ///

1 B. These items will be resolved prior to
2 commercial operation.

3
4
5
6 INTERROGATORY NO. 19:

7 Describe all human factors or other analyses which
8 have been performed or are to be performed in PG&E's
9 implementing procedures for the PG&E Emergency Response
10 Plan, Revision 3.

11
12 ANSWER TO INTERROGATORY NO. 19:

13 To date, no human factors or other related
14 analyses have been performed on the implementing procedures
15 associated with the PG&E Emergency Response Plan,
16 Revision 3. At the present time, there are no requirements
17 for the performance of human factors analyses on nuclear
18 power plant emergency response plans. PG&E will consider
19 appropriate future actions or analyses when definitive
20 standards or criteria are established.

21
22
23
24 INTERROGATORY NO. 20:

25 At page 76 of the PG&E Response, PG&E objected as
26 irrelevant and outside of the scope of discovery to Governor

1 Brown's request that PG&E describe human factors or other
2 analyses which have been performed on PG&E's emergency
3 operating procedures. Emergency operating procedures are
4 relevant, however, since the Emergency Plan (e.g., pp. 6-8,
5 et. seq.) specifically addresses assessment activities
6 covered by such procedures. Further, in Joint Intervenor's
7 Statement of Clarified Contentions dated June 30, 1981,
8 emergency operating procedures were specifically included.
9 The Board restated Joint Intervenor's contention, but it
10 expressed no disagreement [sic] that emergency operating
11 procedures were part of that contention. Accordingly,
12 Governor Brown requests PG&E to respond to the Governor's
13 original Interrogatory No. 30 which requests as follows:

14 Describe all human factors or other
15 analyses which have been performed on or
16 are proposed to be performed on PG&E's
Emergency Operating Procedures. When
and by whom was each analysis performed?

17 ANSWER TO INTERROGATORY NO. 20:

18 Objected to as irrelevant and outside the scope of
19 discovery. Emergency operating procedures are not the
20 subject of the contention before this Board, but rather
21 emergency planning under 10 C.F.R. §§ 50.33(g), 50.47 and
22 Appendix E to Part 50.
23
24
25
26

1 INTERROGATORY NO. 21:

2 At page 82 of the PG&E Response, PG&E identifies a
3 Tera Corporation report entitled, "Evaluation of Peak
4 Horizontal Ground Acceleration Associated with the Hosgri
5 Fault at the Diablo Canyon Nuclear Power Plant," dated
6 August 1980.

7 A. Has this document been produced by PG&E?

8 B. If not, produce this document.
9

10 ANSWER TO INTERROGATORY NO. 21:

11 Yes. This document is Exhibit 1 to PGandE's
12 prefiled testimony for the ASLAB seismic hearings.
13
14
15

16 INTERROGATORY NO. 22:

17 At page 17 of the PG&E J.I. Response, PG&E states
18 that the Tera Report will be evaluated and appropriate
19 changes to the Emergency Plans and Procedures will be made
20 as required.

21 A. Has PG&E conducted analyses of the Tera Report to
22 identify any changes in plans and procedures which
23 will be required?

24 B. If the answer to the foregoing is yes, describe
25 all these analyses and changes and produce them.
26

///

1 C. If such analyses have not been performed, when
2 will they be performed?
3

4 ANSWER TO INTERROGATORY NO. 22:

5 A. PG&E is continuing its review of the TERA
6 report. Currently, changes to the PG&E plan do not
7 appear warranted since Section 6 of that report
8 provides an augmented plan for earthquake effects.

9 B. Not applicable.

10 C. If changes to the Emergency Plans are
11 warranted after review of the TERA report by federal,
12 state, and local planning officials is complete, PG&E
13 will include these in its annual review and update.
14

15
16
17 INTERROGATORY NO. 23:

18 At page 18 of PG&E's J.I. Response PG&E states
19 that it understands that the forthcoming Tera report would
20 be applicable to earthquakes greater than the M 7.5 SSE.
21 Subsequent to PG&E's answers, PG&E has received the Tera
22 Report. Does PG&E contend that this report is applicable to
23 earthquakes greater than the SSE? If so, identify what
24 portions, in PG&E's opinion, address earthquakes greater
25 than the SSE.
26

///

1 ANSWER TO INTERROGATORY NO. 23:

2 Earthquakes greater than the M_s 7.5 SSE were not
3 explicitly considered in the TERA report; rather, the
4 methodology for developing damage scenarios implicitly
5 considers larger earthquakes. For instance, the scenario
6 that considered damage greater than that expected from the
7 SSE also represents damage that is expected from an
8 earthquake of M_s greater than 7.5.
9

10
11
12 INTERROGATORY NO. 24:

13 At pages 41 and 42 of PG&E's J.I. Response, PG&E
14 identifies four land routes, in addition to the north and
15 south land routes, which might be utilized by vehicles or
16 foot traffic to leave Diablo Canyon. The second route
17 (lines 18-22 on page 41) is identified as perhaps not being
18 available to ordinary vehicles. Are routes 1, 3 and 4
19 available to ordinary vehicles? If the answer is
20 affirmative, describe any analyses performed by or for PG&E
21 to document that ordinary vehicles can use these other three
22 routes.
23

24 ANSWER TO INTERROGATORY NO. 24:

25 Route No. 1 can be utilized by ordinary vehicles.
26 During previous public demonstrations at the Diablo Canyon

1 Power Plant, this route was utilized as an access road by
2 plant personnel. Routes Nos. 3 and 4 can be utilized by
3 high-chassis vehicles (e.g., pick-up trucks). However, to
4 the best of our knowledge, passage over these routes by
5 ordinary vehicles has not been demonstrated.
6
7
8

9 INTERROGATORY NO. 25:

10 In document EPNG0005395, produced by PG&E in
11 response to Governor Brown's document production requests,
12 PG&E states that all "critical equipment" is securely braced
13 and anchored to prevent sliding, overturning, or striking
14 other equipment or the building. How does PG&E define
15 critical equipment? Does such critical equipment include
16 the onsite and offsite real-time monitors, environmental
17 monitoring equipment, and public notification system sirens?
18

19 ANSWER TO INTERROGATORY NO. 25:

20 Document EPNG0005395 discussed the seismic
21 resistance of the Diablo Canyon Power Plant communication
22 system. The term "critical equipment" was used in the
23 subject document to describe equipment specific to the
24 communications system (i.e., equipment and battery racks,
25 antennae and supports). "Critical equipment" has no
26 relationship to the onsite and offsite real-time monitors,

1 environmental monitoring equipment, and public notification
2 system sirens.

3
4
5
6 INTERROGATORY NO. 26:

7 At pages EPNG0010795-96 of the documents produced
8 by PG&E in discovery (Tera proposal TR-81-1247), Tera states
9 that it proposes to analyze "other earthquake effects."

10 A. Has Tera performed such an analysis? If so,
11 provide such analysis.

12 B. If Tera has not yet performed such analysis, is it
13 in the process of performing such analysis, and if
14 so, when will it be performed? Provide such
15 analysis when it has been performed.

16
17 ANSWER TO INTERROGATORY NO. 26:

18 This study was performed at the request of
19 counsel and is a privileged communication not subject to
20 discovery.

21 ///

22 ///

23 ///

1 INTERROGATORY NO. 27:

2 In the event of a major earthquake on the Hosgri
3 fault up to and including the SSE, does PG&E expect that
4 there would be sufficient damage to homes and residences in
5 San Luis Obispo County (or any part of it) such that
6 sheltering, at least in areas of greatest earthquake damage,
7 no longer will be a viable protective action alternative?

8 A. Describe the bases for your response.

9 B. Identify any documents which relate in any way to
10 this matter.

11

12 ANSWER TO INTERROGATORY NO. 27:

13 Based upon experience from other large
14 earthquakes, one might anticipate some damage to homes and
15 residences in the area nearby the earthquake rupture. While
16 instances of damage to specific buildings sufficient to
17 preclude sheltering in those buildings may occur, there
18 should be other structures without such major damage to
19 allow sheltering as a viable protective action.

20

21

22

23 INTERROGATORY NO. 28:

24 A page 8 of Tera Corporation's April 8, 1981
25 "Proposal for Earthquake Emergency Planning" (page
26 EPNG0017126 of documents produced by PG&E), personnel from

1 Tera Corporation who propose to work on the Tera
2 Corporation's study are identified.

3 A. Are these the persons from Tera Corporation who
4 did, in fact, work on and prepare the Tera
5 Corporation report submitted in September 1981?

6 B. Describe for each individual what his or her role
7 was in preparation of said report.

8 C. Identify, with reference to specific sections of
9 the Tera Report and its appendices, the persons
10 primarily responsible for the analyses,
11 calculations, and technical portions of that
12 report.

13
14 ANSWER TO INTERROGATORY NO. 28:

15 A. Yes, except for Mr. Joseph A. Fischer and Mr.
16 G. Smith, who were not actively involved in the study.

17 B. Mr. Robert L. Cudlin acted as Project Manager
18 and directed the emergency planning effort. Dr. R.
19 Winslow and Mr. Brian Davis assisted Mr. Cudlin in the
20 evacuation studies. Dr. K. Campbell directed the
21 ground motion effort. Dr. C. Mortgat directed the
22 assessment of damage to structures and roadways.
23 Messrs. L. Wright and D. Davis were responsible for
24 corporate and division management.

25 ///

26 ///

1	C. <u>Main Report</u>	
2	1.0 Introduction and Executive Summary	Mr. R. Cudlin Mr. D. Davis
3		
4	2.0 Study Areas	Mr. R. Cudlin
5	3.0 Earthquake Effects	
6	3.1 General Earthquake Effects	Dr. K. Campbell
7	3.2 Earthquake Effects on Transportation	Dr. C. Mortgat
8		
9	4.0 Evacuation Time Estimates	Mr. B. Davis Dr. R. Winslow
10	5.0 Communications	Dr. C. Mortgat
11	6.0 Diablo Canyon Earthquake Response Plan	Mr. R. Cudlin
12	<u>Appendix: Ground Failure</u>	
13	1.0 Overview of Critical Routes	Mr. M. Payne 34071 Peguito Dr. Dana Point, CA 92629
14		
15	2.0 Landslide Potential	Dr. J. Chameau, Professor School of Engineering Grisson Hall Purdue University West Lafayette, IN 47907
16		
17	<u>Appendix: Bridges and Evacuation</u>	
18		
19	1.0 Guideline for Evaluating the Probable Seismic Damage to Highway Bridges in the San Luis Obispo Area	Mr. R. Nutt 5311 Dredger Way Orangevale, CA 95662
20		
21	2.0 Testing of Bridge Evaluation Guidelines	Mr. R. Nutt
22		
23	3.0 Seismic Evaluation of Bridge Columns	Mr. R. Nutt
24	///	
25	///	
26		

1 4.0 Summary of Bridges Surveyed

Mr. R. Nutt

2 5.0 Evacuation Network

Dr. R. Winslow
3301 Ginger Tree Ct.
Fairfax, VA
22030

3
4
5
6
7 INTERROGATORY NO. 29:

8 In the document production responses of PG&E, a
9 number of documents constituting minutes of the PG&E
10 Emergency Planning Task Force were provided. Have all
11 minutes up to the current time been provided? If not, which
12 minutes have not been provided? Provide all those not
13 previously provided. In that regard, at page EPNP0047862
14 (minutes of February 4, 1981 Emergency Planning Task Force
15 Meeting, there is a statement that the Task Force will meet
16 bi-weekly until the field exercises are concluded. We do
17 not have bi-weekly minutes up through August 19, 1981.

18
19 ANSWER TO INTERROGATORY NO. 29:

20 Records provided to date include all minutes for
21 the Emergency Planning Task Force. The Emergency Planning
22 Task Force ceased to exist upon reorganization of the
23 Personnel and Environmental Safety Section in the month of
24 April, 1981.
25
26

1 INTERROGATORY NO. 30:

2 Three Tera Corporation references (pp. 7-1 and
3 7-2) are not publicly available. These are:

4 Applied Technology Council, 1981, "Guidelines
5 for the Evaluation of Highway Bridges,
6 ATC-b, Final Draft Report," Applied
Technology Council, Berkeley,
California.

7 Campbell, K. W., 1980, "Attenuation of Peak
8 Horizontal Acceleration within the
9 Near-Source Region of Moderate to Large
Earthquakes," TERA Corporation,
Technical Report 80-1, Berkeley,
California.

10 Campbell, K. W., 1981, "Near-Source Attenua-
11 tion of Peak Horizontal Acceleration,"
12 Bulletin of the Seismological Society of
AMerica, Vol. 71 (in press).

13 Produce these documents.

14
15 ANSWER TO INTERROGATORY NO. 30:

16 The three documents listed in Interrogatory 30 of
17 the second set of interrogatories are available for
18 inspection at the PGandE office in San Francisco.

19
20
21
22 INTERROGATORY NO. 31:

23 At page 6-8 of the PG&E Emergency Plan, the
24 following statement appears:

25 In the case of the LOCA with inadequate
26 core cooling, the major release would
not be expected for at least two hours

1 and probably much longer, due to the
2 time required to melt a large fraction
3 of the core and the expected time before
any containment failure would be likely.

4 A. What analyses have been performed to support the
5 foregoing statement?

6 B. Describe all documents which relate in any way to
7 the foregoing statement.
8

9 ANSWER TO INTERROGATORY NO. 31:

10 A. No analysis is required for the statement in
11 the context in which it was used in the paragraph.
12 This text provides a general background for a reader on
13 the significance of the postulated event.

14 B. Not applicable.
15
16
17

18 INTERROGATORY NO. 32:

19 At page 6-17 of the PG&E Emergency Plan, it is
20 stated that "the real-time monitors would be automatically
21 interrogated throughout the course of the accident and any
22 environmental assessment."

23 A. Does the capability exist at this time to
24 automatically interrogate from the plant all
25 onsite and offsite real-time monitors?
26

///

1 B. If the answer is affirmative, when was this
2 capability established and please describe its
3 technical basis.

4 C. If not, does PG&E intend to establish such
5 automatic interrogation capability and if so,
6 when?

7
8 ANSWER TO INTERROGATORY NO. 32

9 A. Yes.

10 B. This capability was established on a
11 conceptual basis in the Fall of 1979, and installation
12 of this equipment occurred during the Spring and Summer
13 of this year.

14 The technical basis for the automatic
15 interrogation capability is the desire of radiological
16 assessment personnel to obtain as much radiation dose
17 rate information in the environs of Diablo Canyon Power
18 Plant as possible. This information provided by the
19 real-time monitors is supplementary to radiological
20 information obtained from other sources such as field
21 teams. The automatic interrogation capability provides
22 a radiological data source which would normally not
23 require the dispatch of personnel to each monitor
24 location to retrieve data.

25 C. Not applicable.
26

1 INTERROGATORY NO. 33:

2 In the event the EOF and UDAC are not functional,
3 what communication and assessment capabilities are available
4 at the County's EOC?

5
6 ANSWER TO INTERROGATORY NO. 33:

7 1. Communication Capabilities

8 In the event the UDAC and EOF are not functional,
9 the County EOC presently has or is in the process of
10 obtaining the following communications capabilities:

- 11 1. Ten Pacific Telephone business lines.
- 12 2. A Private-Line Selective Signaling Circuit
13 connecting the EOC to the OES headquarters, EOF,
14 NRC office in the EOC, Diablo Canyon Power Plant
15 Control Rooms Unit 1 and Unit 2 and Technical
16 Support Center.
- 17 3. An NRC ENS Hot-Line to the NRC Bethesda, Maryland,
18 Headquarters.
- 19 4. An NRC Health Physics Region V network hot-line.
- 20 5. A Public Information Private-Line Selective
21 Signaling Circuit connecting the EOC-P10 to the
22 EOF-P10, PGandE Media Center at Questa College,
23 and the PGandE San Luis Obispo Office P10.

24 ///

25 ///

26 ///

- 1 6. A Hot-Line telephone circuit connecting the
- 2 EOC-Sheriff's dispatch center to Diablo Canyon
- 3 Power Plant Control Room and Technical Support
- 4 Center.
- 5 7. A UHF Radio Link connecting the EOC-Sheriff's
- 6 dispatch center to Diablo Canyon Power Plant
- 7 Control Room and Technical Support Center.
- 8 8. Eleven Pacific Telephone Co. business lines
- 9 serving the following offices in the EOC:
- 10 2 lines - FEMA Office
- 11 2 lines - DOE/EPA Office
- 12 3 lines - NRC Office
- 13 3 lines - State of California Office
- 14 1 line - PGandE Office
- 15 9. A private intercom link connecting the County P10,
- 16 UDAC, and EOF.
- 17 10. (Under Investigation.) A Private-Line Selective
- 18 Signaling Circuit connecting the EOC to the
- 19 following nearby cities:
- 20 (a) Morro Bay
- 21 (b) Paso Robles
- 22 (c) Atascadero
- 23 (d) San Luis Obispo
- 24 (e) South Bay
- 25 (f) Pismo Beach
- 26 (g) Arroyo Grande

1 (h) Grover City

2 (i) CAL POLY University

3 2. Assessment Capabilities

4 Dose Assessment capabilities will not be
5 significantly affected if the EOF and UDAC are not
6 functional since dose assessment tasks can be performed
7 manually at virtually any location.
8
9
10

11 INTERROGATORY NO. 34:

12 At page 7-25 of the PG&E Emergency Plan, PG&E
13 states that the County Emergency Plan will provide for
14 special notification arrangements in the wilderness area
15 near the plant, particularly the State Park.

16 A. What are these special notification arrangements?

17 B. Have these arrangements ever been practiced? If
18 so, describe the practice sessions.
19

20 ANSWER TO INTERROGATORY NO. 34:

21 A. All of the land around the Diablo Canyon
22 facility is either a part of the Montana de Oro State
23 Park or privately owned. There is no additional
24 "wilderness" area. See PGandE's response to
25 Interrogatory 8 of the Governor's First Set of
26 Interrogatories.

1 B. The only notification process tested to date
2 has been the October 20, 1981, demonstration utilizing
3 the Roger's Helicopter Service as described in
4 Interrogatory No. 1.

5
6
7
8 INTERROGATORY NO. 35:

9 At page 7-25 of the PG&E Emergency Plan, PG&E
10 explains that the early warning notification sirens are
11 activated by a microwave signal from the Sheriff's office to
12 three transmitter stations at Cuesta Peak, Rocky Butte, and
13 Davis Peak.

14 A. What are the seismic qualifications of the
15 Sheriff's microwave equipment and the three
16 transmitter stations noted above? Describe all
17 documents which relate to the seismic
18 qualification of this equipment.

19 B. In the event the Sheriff's microwave equipment
20 fails, three backup encoders, located at County
21 fire stations, can be used to activate the early
22 warning notification sirens.

23 (1) What procedures exist for use of these
24 alternate activation systems?

25 (2) What are the seismic qualifications of these
26 backup encoders?

1 (3) At which County fire stations are these
2 encoders located?
3

4 ANSWER TO INTERROGATORY NO. 35:

5 A. The transmitter equipment that is being
6 purchased for this application is not seismically
7 qualified. All other structures and equipment are not
8 owned or maintained by PGandE and information relating
9 to their seismic design is unknown.

10 B. (1) The County Emergency Plan SOP for the San
11 Luis County Sheriff's Department includes the
12 procedure for activation of the early warning
13 system and the method for contacting the
14 backup locations. Final operating
15 procedures, based on the instruction sheet
16 for encoder operation, will be written for
17 each location when the backup system is
18 completed.

19 (2) The backup encoders have not been seismically
20 tested. These encoders are desk-top models,
21 about the size of a telephone.

22 ///

23 ///

24 ///

1 (3) The equipment for backup activation has not
2 been installed. The original fire department
3 locations did not have 24-hour dispatch
4 capabilities and the activation sites have
5 therefore been moved to the local sheriff's
6 departments.
7
8
9

10 INTERROGATORY NO. 36:

11 At page 7-35 of the PG&E Emergency Plan, PG&E
12 states that "the central computer sub-system is the heart of
13 the emergency dose assessment and response system."

14 A. Has the central computer system referred to above
15 been classified as safety-grade equipment?

16 B. If the answer is no, explain the rationale for
17 this decision.

18 C. If the answer is yes, describe all analyses which
19 document that the computer meets safety-grade
20 requirements.
21

22 ANSWER TO INTERROGATORY NO. 36:

23 A. No.

24 B. Regulatory requirements state the need for
25 the ability of the licensee to promptly determine the
26 extent of any potential or actual accidental release of

1 radioactive materials from the plant, assess the
2 potential or actual consequences that may result from
3 the accidental release of radioactive materials on the
4 public health and safety, and to distribute such
5 information and assessments to the various emergency
6 response centers. The central computer in the EARS
7 system is only one of several means to determine,
8 assess, and distribute radiological information. Other
9 means in the form of personnel actions (manual sample
10 collection, calculation, etc.) and backup computers,
11 data and voice communications links provide the
12 capability to determine, assess and distribute
13 radiological information in emergency situations. On
14 this basis, and on the fact that the central EARS
15 computer is not involved with nuclear safety related
16 activities, the central EARS computer is not considered
17 to be safety related.

18 C. Not applicable.

19
20
21
22 INTERROGATORY NO. 37:

23 (a) Describe the power source configuration for
24 the Diablo Canyon pressurizer heaters. (b) What other
25 power source configurations were evaluated by PG&E to supply
26 power to the pressurizer heaters? (c) What is PG&E's

1 rationale for its choice of configuration? (d) If the
2 heaters were classified as safety-grade, what configuration
3 would be utilized?
4

5 ANSWER TO INTERROGATORY NO. 37:

6 (a) The power source configuration for the
7 pressurizer heaters at Diablo Canyon Power Plant has
8 been described in PGandE's submittal to the NRC dated
9 January 26, 1981, responding to the requirements of
10 Item II.E.3.1 of NUREG-0737, copies of which were
11 served on all parties. In addition, the power source
12 configuration was discussed in detail, including a
13 point by point evaluation of the pressurizer heater
14 power supply design with the requirements of
15 NUREG-0737, in PGandE's answer to Joint Intervenor's
16 interrogatories (pp. 45-67) relating to Joint
17 Intervenor's Contention 11 for low power test
18 proceedings. This information was served on all
19 parties March 16, 1981.

20 (b) None.

21 (c) PGandE chose the power source configuration
22 for the pressurizer heaters to comply with the
23 requirements of Item II.E.3.1 of NUREG-0737.

24 ///

25 ///

26 ///

1 (d) If the pressurizer heaters were classified as
2 safety-grade, the power source configuration would be
3 the same as the present design.
4
5
6

7 INTERROGATORY NO. 38:

8 What is the reliability of the power sources for
9 the Diablo Canyon pressurizer heaters? Describe all
10 documents which relate in any way to the reliability of
11 these power sources.
12

13 ANSWER TO INTERROGATORY NO. 38:

14 PGandE objects to this interrogatory as being
15 beyond the scope of Joint Intervenor's Contention 10. There
16 are no safety grade requirements that define an acceptable
17 level of reliability of "components important to safety."

18 In addition, the interrogatory lacks specificity
19 in that reliability is not defined, the power sources of
20 interest are not identified, the conditions related to
21 reliability aspects are not identified, etc.
22
23
24
25
26

1 INTERROGATORY NO. 39:

2 What is the worst case loading on the busses
3 supplying power to the pressurizer heaters at Diablo Canyon?
4 Include in your answer a description of the types of loads,
5 whether they are starting or transient loads, and the time
6 they are likely to occur.

7
8 ANSWER TO INTERROGATORY NO. 39:

9 PGandE objects to this interrogatory as being
10 beyond the scope of Joint Intervenor's Contention 10. The
11 loading on the busses to the pressurizer heaters, whether
12 being the worst case or the nominal case, is not related to
13 how the components are classified with respect to
14 "importance to safety."

15
16
17
18 INTERROGATORY NO. 40:

19 For what seismic and environmental conditions have
20 the Diablo Canyon pressurizer heaters and related
21 structures, instruments, controls and power sources been
22 qualified? Include in your answer a description of all
23 analyses and other documents which relate in any way to
24 qualification of these heaters.

1 ANSWER TO INTERROGATORY NO. 40:

2 The pressurizer heaters and associated controls
3 are not required by NRC regulations to be classified as
4 "important to safety" and therefore are not required to meet
5 all safety grade design criteria. Therefore, the
6 pressurizer heaters have not been qualified for any specific
7 seismic event. However, their design does ensure that the
8 pressure boundary of the pressurizer is not jeopardized by
9 penetrations in the pressurizer vessel for the external
10 electrical connections to the heaters.

11 To comply with item II.E.3.1 of NUREG-0737,
12 certain controls and power sources for the pressurizer
13 heaters have been designed to withstand the postulated
14 Hosgri seismic event. These include:

- 15 1. The emergency diesel generator
- 16 2. 4KV vital switchgear
- 17 3. 480V vital circuit breaker
- 18 4. 480V vital load center/motor control center

19 which are required to provide protection to the emergency
20 bus supplying power to the pressurizer heaters.

21 None of the instruments or controls associated
22 with the pressurizer heaters are subjected to a harsh
23 environment and therefore they have not been qualified to
24 specific environmental conditions.

25 The pressurizer heaters were manufactured to
26 Westinghouse Equipment Specification 676440, Rev. 4 and

1 Addendum 677231, Rev. 0. The following tests as required by
2 the Westinghouse specification were performed by the
3 supplier of the pressurizer heaters:

- 4 1. Continuity test
- 5 2. High potential test
- 6 3. Radiography - full length examination in two
7 planes 90 degrees apart
- 8 4. Megger resistance test

10
11
12 INTERROGATORY NO. 41:

13 What accident or off-normal conditions at Diablo
14 Canyon would require the pressurizer heaters to operate?
15

16 ANSWER TO INTERROGATORY NO. 41:

17 Although alternative methods of reactor coolant
18 system (RCS) pressure control are available, procedures for
19 the Diablo Canyon Power Plant indicate the pressurizer
20 heaters could be used:

- 21 1. After a postulated loss of offsite power;
- 22 2. Following design basis accidents in which the
23 safety injection system is manually or
24 automatically initiated; and

25 ///

26 ///

1 3. Following anticipated events in which reactor trip
2 is manually or automatically initiated. l
3
4
5
6

7 INTERROGATORY NO. 42:

8 (a) Are the pressurizer heaters anticipated to be
9 utilized at Diablo Canyon when natural circulation needs to
10 be established? (b) If so, which emergency operating
11 procedure(s) would be involved? (c) What action or actions
12 would be planned in the event that natural circulation needs
13 to be achieved at Diablo Canyon and the pressurizer heaters
14 and/or the power sources thereto are not operative?
15

16 ANSWER TO INTERROGATORY NO. 42:

17 (a) Yes.

18 (b) EP OP-0, REACTOR TRIP WITH SAFETY INJECTION
19 EP OP-1, LOSS OF COOLANT ACCIDENT
20 EP OP-2, LOSS OF SECONDARY COOLANT
21 EP OP-3A, STEAM GENERATOR TUBE RUPTURE
22 EP OP-4, LOSS OF ELECTRICAL POWER
23 EP OP-8, CONTROL ROOM INACCESSIBILITY
24 EP OP-13, MALFUNCTION OF REACTOR PRESSURE CONTROL SYSTEM
25 EP OP-23, NATURAL CIRCULATION OF REACTOR COOLANT
26 EP OP-44, GASEOUS VOIDS IN THE RCS.

1 (c) If the pressurizer heaters are not available, (1
2 the operator can use either the normal charging and
3 letdown system or the high head safety injection system
4 to maintain or restore RCS pressure at the nominal
5 value. Adoption of one of the two pressure control
6 modes in conjunction with maintaining an effective heat
7 sink in the secondary of the steam generator via the
8 auxiliary feedwater system will ensure that the system
9 can be stabilized following a postulated accident.

10 If there is a loss of offsite power, the
11 pressurizer heaters would obtain power from the onsite
12 emergency power supplies.
13
14
15

16 INTERROGATORY NO. 43:

17 What rationale is utilized by PG&E to justify
18 classification of the pressurizer heaters and related
19 instruments, controls, structures and power sources as
20 non-safety grade? Provide all documents, analyses, or other
21 materials which relate in any way to this rationale.
22

23 ANSWER TO INTERROGATORY NO. 43:

24 It is PGandE's position that the pressurizer
25 heaters and associated controls are not required to be
26 classified as safety grade components and therefore are not

1 required to meet all safety grade design criteria. However,
2 the pressurizer heater design associated with the capability
3 of obtaining power from the onsite emergency power supply
4 meets GDC 10, 14, 15, 17 and 20 of Appendix A to 10 CFR 50.
5 Therefore, PGandE believes the method that has been used to
6 connect the pressurizer heaters to the onsite emergency
7 power supply is fully adequate.

8 PGandE's position is based on the fact that the
9 design of the pressurizer heaters meets the NRC regulatory
10 requirements including those arising from post TMI lessons
11 learned, specifically NUREG-0737.

12 The plant design, including operational practice
13 (training, procedures, etc.) provides alternative and
14 reliable methods of maintaining pressure control, and
15 therefore maintaining natural circulation, which use systems
16 and components designed to safety grade requirements.
17 Therefore, the pressurizer heaters and associated controls
18 are not classified as safety grade. Further, there are no
19 NRC regulations or requirements that require the pressurizer
20 heaters and their associated controls to be classified
21 safety grade. The NRC Staff, on page A-2, NUREG-0578,
22 states ". . . there is a need to consider the upgrading of
23 those pressurizer heaters and associated controls . . . to a
24 safety grade classification. . . ." The NRC Staff further
25 states, on page A-2 of NUREG-0878, "in the short term,
26 designs should be upgraded to provide the operator with the

1 capability to maintain natural circulation at hot standby
2 through the use of pressurizer heaters when offsite power is
3 not available." This last statement has become a require-
4 ment as identified in item 11.E.3.1 of NUREG-0737.

5 Pressurizer heaters and associated controls meet
6 both the requirements of item 11.E.3.1 and GDC 17 in terms
7 of emergency on-site power supplies for the pressurizer
8 heaters. Item 11.E.3.1 does not require the pressurizer
9 heaters or associated controls to be designed to safety
10 grade requirements. In fact item 11.E.3.1 states, "Being
11 non-Class IE loads, the pressurizer heaters must be
12 automatically shed from the emergency power sources. . . ."

13 The NRC Staff's characterization of the
14 pressurizer heaters as non-Class IE loads, by definition,
15 precludes them from being classed as safety grade
16 components.

17
18
19
20 INTERROGATORY NO. 44:

21 What is the status of the EPRI tests on block and
22 power operated relief valves of the kinds utilized at Diablo
23 Canyon?
24
25
26

1 ANSWER TO INTERROGATORY NO. 44:

2 PGandE objects to this interrogatory on the basis
3 of relevancy. The EPRI valve performance testing program is
4 clearly outside the scope of Joint Intervenor's Contention
5 12, which concerns only classification of relief valves,
6 block valves and associated circuitry, and compliance with
7 design criteria.

8
9
10
11 INTERROGATORY NO. 45:

12 Have the structures, instruments, control systems,
13 and power sources supporting and/or relating to the block
14 and relief valves at Diablo Canyon been analyzed and
15 qualified for all potential operating and accident
16 conditions?

17 A. If so, describe these analyses and all other
18 documents relating thereto.

19 B. If not, why have these analyses not been carried
20 out?

21
22 ANSWER TO INTERROGATORY NO. 45:

23 The instruments, control systems and backup power
24 sources supporting and/or relating to the safety-related
25 block and relief valves at Diablo Canyon have been analyzed
26 and qualified for the conditions to which they may be

1 subjected, whether during normal operation or an accident.
2 Analyses and qualification of structures for these valves
3 are outside the scope of Joint Intervenor's Contention 12
4 and this portion of the interrogatory is objected to on that
5 basis.

6 A. The conditions to which these instruments, control
7 systems, and backup power sources may be subjected
8 have been described in the FSAR. The analysis and
9 qualification of such instruments, control
10 systems, and backup power sources to those
11 potential conditions have been accepted by the
12 Staff, as indicated in SER Supplement 15.

13 B. Not applicable.
14
15
16

17 INTERROGATORY NO. 46:

18 Does the EPRI test program for relief and block
19 valves cover structures, instruments, control systems, and
20 power sources of the type(s) utilized at Diablo Canyon?
21 Provide the bases for your response.
22

23 ANSWER TO INTERROGATORY NO. 46:

24 PGandE objects to this interrogatory on the basis
25 of relevancy. See the answer to interrogatory 44.
26

1 INTERROGATORY NO. 47:

2 Has PG&E seismically and environmentally qualified ;
3 the instrumentation, controls, structures and power sources
4 for its block and relief valves?
5

6 ANSWER TO INTERROGATORY NO. 47:

7 PGandE objects to this interrogatory. Environ-
8 mental qualification of equipment is the subject of another
9 contention, which is being considered separately by the
10 Board. Furthermore, the seismic issue has already been
11 litigated and ruled upon by both the Licensing Board and the
12 Atomic Safety and Licensing Appeal Board.
13
14
15

16 INTERROGATORY NO. 48:

17 The power operated relief valves and block valves
18 at Diablo Canyon are not classified as safety grade. What
19 is the rationale for failing to classify these items as
20 safety grade and what analyses, if any, have been conducted
21 to support such classification as non-safety grade? Describe
22 all such analyses and all other documents relating to the
23 question of the classification of block and relief valves.
24
25
26

1 ANSWER TO INTERROGATORY NO. 48:

2 The assertion made in the interrogatory is ↓
3 erroneous.

4 All of the block valves have been classified as
5 components important to safety and meet all safety-grade
6 design criteria. Two of the three relief valves at Diablo
7 Canyon have been classified as safety grade components and
8 meet all applicable safety-grade design criteria. The
9 remaining valve, which does not meet safety-grade design
10 criteria, was installed to provide 100 percent load
11 rejection without tripping the reactor. It provides no
12 safety-related function. The following materials have been
13 identified as relating to the classification of block and
14 relief valves:

15 FSAR Sections:

- 16 3.1 Conformance with AEC General Design Criteria
17 3.2 Classification of Structures, Components and Systems
18 3.6 Criteria for Protection Against Dynamic Effects
19 Associated with a Postulated Rupture of Piping
20 3.9 Mechanical Systems and Components
21 5.2 Integrity of the Reactor Coolant System Boundary
22 15.1 Condition I-Normal Operation and Operational Transients
23
24
25
26

1 INTERROGATORY NO. 49:

2 Does PG&E intend to rely on block and/or relief
3 valves during an emergency situation such as a
4 loss-of-coolant accident? Provide the bases for your
5 response, including identification of all emergency
6 operating procedures related thereto.

7
8 ANSWER TO INTERROGATORY NO. 49:

9 PGandE is prepared to utilize block and/or relief
10 valves during an emergency situation such as a
11 loss-of-coolant accident. Postulated transients have been
12 analyzed which would result in conditions that necessitate
13 the operation of relief or block valves. The following DCP
14 Emergency Operating Procedures specify the use of relief or
15 block valves:

16 EP OP-0, REACTOR TRIP WITH SAFETY INJECTION
17 EP OP-1, LOSS OF COOLANT ACCIDENT
18 EP OP-2, LOSS OF SECONDARY COOLANT
19 EP OP-3A, STEAM GENERATOR TUBE RUPTURE
20 EP OP-4, LOSS OF ELECTRICAL POWER
21 EP OP-5, REACTOR TRIP WITHOUT SAFETY INJECTION

22 ///

23 ///

24 ///

1 EP OP-13, MALFUNCTION OF REACTOR PRESSURE CONTROL
2 SYSTEM

3 EP OP-22, EMERGENCY SHUTDOWN

4 EP OP-38, ANTICIPATED TRANSIENT WITHOUT TRIP
5
6
7


8 Respectfully submitted,

9 MALCOLM H. FURBUSH
10 PHILIP A. CRANE, JR.
11 RICHARD F. LOCKE
12 Pacific Gas and Electric Company
13 P.O. Box 7442
14 San Francisco, California 94120
15 (415) 781-4211

16 ARTHUR C. GEHR
17 Snell & Wilmer
18 3100 Valley Center
19 Phoenix, Arizona 85073
20 (602) 257-7288

21 BRUCE NORTON
22 Norton, Burke, Berry & French, P.C.
23 3216 N. Third Street
24 Suite 300
25 Phoenix, Arizona 85012-2699
26 (602) 264-0033

Attorneys for
Pacific Gas and Electric Company

By 
Philip A. Crane, Jr.

DATED: November 3, 1981.

PACIFIC GAS AND ELECTRIC COMPANY
DEPARTMENT OF NUCLEAR PLANT OPERATIONS
DIABLO CANYON POWER PLANT UNIT NOS. 1 and 2

13

TITLE: RADIOLOGICAL EMERGENCY PLAN AND R-PROCEDURES EXAM

1. In the event of a Radiological Emergency, which of the following will initially assume the position of emergency coordinator:
 - a. Security Supervisor
 - b. Shift Foreman
 - c. Security Shift Supervisor
 - d. CAS Operator.
2. The Site Emergency Signal:
 - a. Chirps
 - b. Is a steady siren
 - c. Has a characteristic sound which is a rapid rise in pitch followed by a slower drop.
 - d. Is a bell.
3. If you are escorting someone in the plant protected area when the emergency signal sounds, where do you take them?
 - a. The Administration Building
 - b. Radiation Access Control
 - c. Security Building
 - d. Control Room
4. If you are in the containment when the containment evacuation signal sounds, you would immediately leave and go to:
 - a. The Control Room
 - b. Radiation Access Control
 - c. CAS
 - d. Auxiliary operator's office 85' elevation
5. The fire signal:
 - a. Chirps
 - b. Is a monotone siren followed by a two-digit bell code call
 - c. Is a warbler siren followed by a two-digit bell code call
 - d. Is a bell.
6. When the rotating amber light is on in areas equipped with the Cardox fire suppression system, this indicates the system has been turned off:
 - a. True
 - b. False

Radiological Emergency Plan and R-Procedures Exam

7. If you are in a room and a radiation area monitor alarms you should:
 - a. Immediately call the shift foreman if there is a phone in the room.
 - b. Immediately leave and proceed to radiation access control and report the alarm to a radiation protection monitor.
 - c. Immediately notify the Security officer on duty
 - d. Notify the County Sheriff.
8. If you are in the fuel handling building when the criticality monitor alarms, you should immediately leave and go to:
 - a. The Control Room
 - b. Radiation access control
 - c. CAS
 - d. Auxiliary operator's office 85' elevation.
9. If someone receives a serious injury on the radiation controlled side of the plant, first aid measures should take precedence over contamination control measures:
 - a. True
 - b. False
10. There is a possibility of a chlorine release from the intake structure.
 - a. True
 - b. False
11. Which of these can order a site evacuation:
 - a. Security Supervisor
 - b. Radiation Protection Monitor
 - c. Site Emergency Coordinator
 - d. Maintenance Supervisor
12. Following initial response to an emergency, who assumes the roll of Site Emergency Coordinator:
 - a. Plant Superintendent
 - b. Plant Manager
 - c. Technical Assistant to the Plant Manager
 - d. Power Plant Engineer
 - e. Any of the above.
13. One of the following organizations does not receive information of an emergency from the plant site:
 - a. San Luis Obispo County
 - b. State of California
 - c. Federal Emergency Management Agency
 - d. Nuclear Regulatory Commission

Radiological Emergency Plan and R-Procedures Exam

14. Which agency is notified by the plant first in the event of an emergency situation:
- NRC
 - FEMA
 - State of California
 - San Luis Obispo County
15. If a site evacuation is ordered, where do personnel go:
- Home
 - San Luis Obispo PG&E Service Center
 - Designated off-site assembly area for monitoring prior to release
 - San Luis Obispo County Sheriff's Office.
16. If called in for response to an emergency situation where do you report:
- Visitors Center
 - Administration Building
 - Technical Support Center
 - Operational Support Center (Security Building lunch room).
17. Following sounding of the site emergency signal you are the person in charge of your assembly area. Where will instructions come from:
- Security Shift Supervisor
 - Site Emergency Coordinator
 - Plant Manager
 - From b through a.
18. At 10:00pm one of two mechanical maintenance personnel working on a radwaste concentrator is severely injured by falling due to a sudden leak on the concentrate pump. His companion helps him to Access Control where you are the RPM on shift. You should:
- Assist in care of the injury
 - Notify the Control Room to request an ambulance
 - Determine the extent of contamination involved with the injury
 - All of the above.
19. You are entering the radwaste storage area on the east side of the plant alone to label waste containers, and notice a box of dry waste is smoking. You should:
- Discharge a fire extinguisher in the box and then continue your labeling.
 - Exit the area, go to a phone dial 779-21 and remain on the phone
 - Get your labeling done and report the smoke to your supervisor afterwards.

Radiological Emergency Plan and R-Procedure Exam

20. While on the graveyard shift the Shift Foreman calls and requests a radiation survey around the waste drumming station due to an area alarm indication. Upon entering the area, you report 150 mr/hr above the normal ambient radiation. The Shift Foreman declares an Alert Emergency condition and notifies the following:

- a. San Luis Obispo County, State office of Emergency Services, NRC
- b. Plant Manager, Plant Superintendent, Plant Engineer, Supervisor of Chemistry and Radiation Protection.
- c. Manager of Nuclear Plant Operations
- d. All of the above.

MAINTENANCE AND REPAIR UNDER RADIOLOGICAL
Emergency Condition

14

- I. Introduction
 1. Purpose of Course
 2. Review of Basic Actions in the Event of an Emergency Onsite

- II. Site Emergency Plan
 1. Purpose
 2. NRC Requirements Summarized
 3. Summary and Organization
 4. Emergency Procedure
 5. Site Emergency Organization
 6. Corporate E.P. Interfaces
 7. Emergency Facilities

- III. Emergency Action Levels

- IV. Administration Under Emergency Conditions
 1. Site Assembly and Accountability
 2. Use of the Operational Support Center
 3. Communication With The Technical Support Center

MAINTENANCE AND REPAIR AND
RADIOLOGICAL EMERGENCY CONDITIONS

I. Introduction

1. Purpose of Course

This course is intended to provide a broad overview of the Diablo Canyon Emergency Plan and those implementing procedures dealing with topics such as organization, communications, emergency facilities and responsibilities in an emergency situation.

It is intended for those who may have the responsibility to perform their normal activities (maintenance and repair) under abnormal conditions when the Site Emergency Organization is in effect.

2. Review of Basic Actions in the Event of an Emergency Onsite.

Refer to the lecture notes for EPD-600.

II. Site Emergency Plan

1. Purpose - A) Demonstrate compliance with NRC requirements for Emergency Planning.

B) Provide an overview of the organization, facilities, equipment and procedures used in an emergency and in maintaining emergency preparedness.

2. NRC Requirements Summarized:

10CFR50.33 Contents of Applications

Must submit state and local Radiological Emergency Plans for an Operating License.

10CFR50.47 Emergency Plans

Must have finding for an operating license that the state of onsite and offsite emergency preparedness provides reasonable assurance that protection measures can and will be taken in the event of a radiological emergency.

Federal Emergency Management Agency (FEMA) to review state and local emergency plans. FEMA finding of adequacy is a rebuttable presumption in NRC proceeding.

Sixteen standards for Emergency Plans defined.

Emergency Planning Zones set:

Plume Exposure Pathway = 10 miles

Ingestion Pathway = 50 miles

3. Summary and Organization

A. Organization and Contents

- 1) Definitions - Brief definitions of unusual terms.
- 2) Scope and Applicability - Establishes purpose of document.
- 3) Summary - brief summary of following sections.
- 4) Emergency Conditions - Contains information on the identification and classification of an emergency situation. This information is basically the same as that in Procedure GA-1. Standard NRC emergency action levels are used to facilitate identification and non-technical assessment of emergency conditions. These come from NUREG-0654, Appendix 1. The use of emergency action levels assist various affected parties in understanding the potential severity and initiating a preplanned response during the early stages of an emergency situation. Examples of Diablo Canyon conditions for each emergency action level are also included in Section 4.
- 5) Organizational Control of Emergencies - The normal plant operating and emergency organizations are identified in this section. The Section also summarizes the relationship between the plant staff and participating offsite emergency authorities and responsibilities of individuals and organizations involved in response organizations. This section is the only place where such a summary exists without reviewing each of the individual plans.
- 6) Emergency Measures - Specific emergency response measures are outlined in this section. The activation and actions of the emergency organization, onsite evacuation, and personnel injury are also addressed. This information is summarized from the various emergency procedures.
- 7) Emergency Facilities and Equipment - Emergency control centers, communication systems, and assessment, protective and medical facilities are described in this section. This is also the only place where such a convenient summary exists.
- 8) Maintaining Emergency Preparedness describes training, drills and exercises to be used to maintain emergency preparedness and the program for emergency plan reviews and equipment maintenance.
- 9) Recovery - describes general plans for restoring the plant to a safe status.
- 10) Appendices - Contains interfacing emergency plans and miscellaneous information, such as a listing of emergency procedure and letters of agreement on emergency response.

Interfacing Plans include:

- a) Corporate Emergency Plan
- b) San Luis Obispo County Nuclear Power Plant Emergency Plan
- c) State of California Nuclear Power Plant Emergency Plan
- d) French Hospital Emergency Plan
- e) USDOE Radiological Assistance Plan
- f) Westinghouse Emergency Response Plan

Letters of Agreement Include:

- a) U.S. Guard - The Coast Guard provides warning to craft off-shore in the event of a plant emergency.
- b) California Department of Forestry - CDF provides off-site support in the case of a fire on-site.
- c) San Luis Ambulance Service - Provides ambulance service on-site in case of injured, contamination victims.

4. Emergency Procedure

Emergency procedures are located in Volume 3 of the plant manual (Red Book)

Volume 3 of the plant manual is in the control room, each supervisor's office and a copy is available for inspection in the plant library.

The procedures are organized in the following categories:

- OP - Equipment Operation
- R - Radiological
- M - Miscellaneous
- GA - General Appendices

A future addition to Volume 3 (3B) will contain the following series of procedures:

- OR - Organization
- EF - Emergency Facility
- RB - Radiological (post accident)

5. Site Emergency Organization

A. Shift Organization

The emergency plan and procedures permit broad discretion on the part of the Shift Foreman regarding assignments under emergency conditions.

Refer to Figure 1 for typical assignments.

The on-shift fire brigade contains a minimum of 5 persons. These are designated as

- 1) Senior Control Operator (Fire Captain)
- 2) Auxiliary Operator

- 3) Auxiliary Operator
- 4) Security Shift Supervisor
- 5) Shift RPM

In addition two fire crews are established from plant personnel normally on-site during normal working hours.

B. Long Term Organization

The long term organization is also flexible at the discretion of the Site Emergency Coordinator. The general structure is shown on figure 2. As indicated a minimum number of these positions must be filled at the Alert (in higher) emergency level.

6. Corporate EF Interface

The corporate emergency response organization is headed by a Corporate Emergency Coordinator (normally the Vice President Nuclear Power Generation) while technical direction and control is under a Recovery Manager (normally the Manager-Nuclear Plant Operations). Figure 3 shows the organization structure.

Assistance to the site organization in supplying material or manpower for repairs would be provided under the control of the Corporate Technical and Logistical Coordinator (normally the Manager, Nuclear Projects) with the organizations shown in figure 4 and 5.

Interface with the Corporate response organization for maintenance and repairs assistance is through the Emergency Maintenance Coordinator. Besides PG&E assistance, further aid may be obtained through Westinghouse, agreements with other utilities or other vendors or consultants.

7. Emergency Facilities

The primary emergency facilities are the control room and the H.P. and Chemistry labs. The experience at TMI-2 with control room overcrowding and high radiation in the plant has led to the establishment of facilities away from the control room to accommodate emergency response.

A. Technical Support Center (TSC)

The TSC has been established to move emergency response and recovery management at the plant out of the control room but still provide a radiologically hardened facility.

The TSC is located on the Unit 2 buttresses. It consists of seven rooms, one of which is dedicated to HVAC equipment. The structure is seismic class 1, shielded and the ventilation is connected to the control room pressurization system. This facility has the RMS Health Physics and Harris computer facilities and has communications equipment installed (telephone and radio). A closed circuit TV monitor system and video cameras in the control room provide plant status monitoring. Office space is provided for plant personnel and NRC.

A health physics counting laboratory is also being installed in the south end of this facility.

B. Operational Support Center

The security building lunch room has been designated as the operational support center in the event of an emergency. Its function is to provide space for personnel awaiting emergency response assignment, where they are readily available, but away from the control room, laboratories or the TSC. Direct communication with the TSC is available from this facility.

C. Off-site Facilities

Visitors' Center

The visitors' center off highway 101 has communications including an NRC, red phone, blue phone, plant phone, radio and emergency kit. It has the potential for being used as a site evacuation assembly area, an off-site monitoring coordination area and is, at least temporarily, the backup EOF.

Emergency Operations Facility (EOF)

The EOF is located at the SLO county Sheriff's office off Highway 1 between San Luis Obispo and Morro Bay. It is a trailer office equipped with emergency power, emergency communications and computer display equipment. It is immediately adjacent to the county emergency operations center (EOC) which is the inservice training facility at the county jail. Overall response management will be conducted here.

Real Time Radiation Monitors

A network of 9 radiation monitors will be located off-site to provide general area readings from Morro Bay to south of Oceano. Data from these monitors will be processed by the EARS system. This information will assist in off-site monitoring and will be available to off-site authorities as well as the other parameters monitored by EARS.

Early Warning System

This is a network of civil defense sirens to provide a capability to alert the public to an emergency condition in a short period of time. An emergency broadcast system (EBS) will follow the alerting siren signal to provide people instructions and information on what protective actions may be recommended by the authorities. This system is required by NRC to extend to the 10-mile EPZ. Our present intention is to cover heavily populated areas from Cayucos to Oceano. This system is under the control of San Luis Obispo County.

D. Portable Emergency Equipment

Radiological monitoring and respiratory equipment is available in sufficient quantities on site. In addition emergency supplies for monitoring and setting up controlled access areas are stored in the security building and off-site at the Visitors Center, Sheriff's office and Morro Bay Power Plant.

III. Emergency Action Levels

The NRC has defined four classes of Emergency Action Levels. These are:

Notification of Unusual Event
Alert
Site Area Emergency
General Emergency

It is the responsibility of the plant to determine which class a given situation fits. The classification can be revised as the situation changes or more information is available, but the initial classification is very important as it determines:

- a. The extent of response by off-site agencies including company, federal, state, county and city.
- b. The extent of immediate public alerting and protective actions.
- c. The number of plant personnel called to respond.
- d. The promptness of notifying off-site authorities. NRC guidelines class for notification within about 15 minutes for an unusual event and sooner (consistent with the need for other emergency actions) for other classes.

Determination of the classification for an event is the responsibility initially of the Shift Foreman. This is assumed by the Site Emergency Coordinator, when available.

Procedure guidance is provided to allow determining a classification based either on the type of event, or the actual (or potential) radiological effects.

(examples of each classification)

IV. Administration under Emergency Conditions

A. Site Assembly and Accountability

(see procedure GA-3 for a description of the accountability process).

B. Use of the Operational Support Center

The Operational Support Center is intended as an initial staging area for personnel reporting on-site in an emergency or for persons retained on-site awaiting assignment in an emergency situation.

It is expected that personnel with specific assignments will be moved to a location where the work is to be performed or in the case of complex jobs, to a staging area for that activity (ie the shops or labs).

Personnel entering or leaving the site should check in and out of the OSC to maintain a current status of on-site personnel.

C. Communication with the Technical Support Center

1. Telephone

The plant has three telephone capabilities:

- a. Computerized Branch Exchange - (Rolm CBX), handles outgoing (PTOT) calls and connect to the Company private automatic branch exchange (PABX). Most phones in the TSC are on the CBX.
- b. PABX - Handles only calls within the PGandE private telephone system. Most phones in the plant are on this system.
- c. Dedicated phones - Go between the TSC and the following:
 - 1) Control Room
 - 2) OSC
 - 3) EOF
 - 4) County Sheriff's Office
 - 5) State OES

The CBX is programmed to give the TSC, and other emergency extensions priority access to available lines and sole access to certain emergency service lines. In order to maintain this priority service, normal plant phones (and other in the PG&E system) cannot call direct to the TSC. They can be called from the TSC phones.

Calls to TSC extensions from plant phones will be diverted to a phone control console in the TSC where they can be forwarded to the desired extension.

Outside calls to the plant normal number will be diverted to the TSC if the administration building phone console is off and the TSC phones are manned. Priority will be given to answering a special plant phone number designated for emergency use only.

Phone calls on both numbers divert to the control room if both the administration building and TSC phone console are off.

2. Radio

The TSC has access to 6 plant radio frequencies, 3 of which are for local use only. These are:

Operations


Security

Health Physics

Portable radios will be available for in plant use on these local frequencies to communicate with the TSC.

FIGURE /

YPICAL ON-SHIFT EMERGENCY ORGANIZATION
AND ASSIGNMENTS




Position	Typical Assignment
Interim Site Emergency Coordinator ¹	Shift Foreman (Sr. Control Operator if not available) —
Interim Emergency Liaison Coordinator ¹	Shift Control Technician or Auxiliary Operator
Interim Emergency Operations Coordinator ¹	Sr. Control Operator or Control Operator
Interim Emergency Evaluations & Recovery Coordinator	Shift Engineer
Liaison Assistant	Control Technician or Shift Clerk
Operators	Assignments per the Interim Site Emergency Coordinator
Fire Brigade	See Procedure M-6 or R-6
Emergency Radiological Team	Shift RRM or Auxiliary Operator (if required)
First Aid and Medical	Employees at the scene.

¹Required Assignment

Figure 2

DIABLO CANYON POWER PLANT SITE EMERGENCY ORGANIZATION ASSIGNMENTS

Primary Assignments




Position filled at Alert Level

PACIFIC S AND ELECTRIC COMPANY
CORPORATE EMERGENCY RESPONSE PLAN
IMPLEMENTING PROCEDURE

Rev. 0
01/07/81

PROCEDURE 1.1
ACTIVATION OF THE CORPORATE EMERGENCY ORGANIZATION

APPENDIX E-1
EMERGENCY RESPONSE ORGANIZATION,
CORPORATE EMERGENCY RESPONSE ORGANIZATION MANAGEMENT



NOTE: The Advisor to the County Emergency Organization is not considered part of the Corporate Emergency Response Organization Management Team.

Legend:

- Line Authority
- - - - - Coordination
- BOP - Emergency Operations Facility
- CERC - Corporate Incident Response Center

Figure 3

PACIFIC GAS AND ELECTRIC COMPANY
CORPORATE EMERGENCY RESPONSE PLAN
IMPLEMENTING PROCEDURE

Rev. U
01/07/81

PROCEDURE 4.1
MATERIALS

APPENDIX E-1
EMERGENCY RESPONSE ORGANIZATION,
MATERIALS DEPARTMENT RELATIONSHIPS





Figure 4

**CORPORATE EMERGENCY RESPONSE PLAN
IMPLEMENTING PROCEDURE**

**PROCEDURE 4.4
GENERAL CONSTRUCTION**

**APPENDIX E-1
EMERGENCY RESPONSE ORGANIZATION,
GENERAL CONSTRUCTION DEPARTMENT RELATIONSHIPS**



Legend:

- Line Authority
- - - - - Coordination
- - - - - Corporate Construction Department Personnel
- EDF - Emergency Operations Facility
- CIRC - Corporate Incident Response Center

Figure 5

GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 16, 29, 31. Said
answers are true and correct to the best of my knowledge
and belief.

J. L. Potter
J. L. Potter

Subscribed and sworn to
before me this 2nd day
of November, 1981

Theodore S. Cooke
Theodore S. Cooke Notary Public
in and for City and County
of San Francisco, State of California

SEAL

My Commission expires January 28, 1985

GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories _____ Said
answers are true and correct to the best of my knowledge
and belief. 3

E. P. Wollak
E. P. Wollak

Subscribed and sworn to
before me this 2nd day
of November, 1981


Thomas A. Cooke
Thomas A. Cooke, Notary Public
for the City and County
of San Francisco, State of California



My commission expires January 28, 1985


GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 3. Said
answers are true and correct to the best of my knowledge
and belief.



E. P. Wollak

Subscribed and sworn to
before me this 2nd day
of November, 1981


Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of California

SEAL


My Commission expires January 28, 1985

GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 11. Said
answers are true and correct to the best of my knowledge
and belief.


Ann Hartwell-Spann

Subscribed and sworn to
before me this 2nd day
of November, 1981



Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of California

SEAL

My Commission expires January 28, 1985


GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 3. Said
answers are true and correct to the best of my knowledge
and belief.



P. D. Newell

Subscribed and sworn to
before me this 2nd day
of November, 1981


Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of California


SEAL

My Commission expires January 28, 1985


i

GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 10. Said
answers are true and correct to the best of my knowledge
and belief.


Faith Rockmaker

Subscribed and sworn to
before me this 2nd day
of November, 1981


Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of California

(SEAL)

My Commission expires January 28, 1985


GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 1, 3, 4B,C, 9, 12, 24, 34. Said
answers are true and correct to the best of my knowledge
and belief.



R. J. McDevitt

Subscribed and sworn to
before me this 2nd day
of November, 1981




Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of California

SEAL


My Commission expires January 28, 1985

GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 2. Said
answers are true and correct to the best of my knowledge
and belief.


G. C. Lenfesty

Subscribed and sworn to
before me this 2nd day
of November, 1981



Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of California

SEAL


My Commission expires January 28, 1985

GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 33, 35A. Said
answers are true and correct to the best of my knowledge
and belief.


A. J. Nevoio

Subscribed and sworn to
before me this 2nd day
of November, 1981



Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of California

SEAL


My Commission expires January 28, 1985

GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 14, 15, 34A, 35B. Said
answers are true and correct to the best of my knowledge
and belief.


K. M. Godfrey

Subscribed and sworn to
before me this 2nd day
of November, 1981

 (SEAL)
Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of California

My Commission expires January 28, 1985

GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 8. Said
answers are true and correct to the best of my knowledge
and belief.

T. A. Mack

T. A. Mack

Subscribed and sworn to
before me this 2nd day
of November, 1981

Theodora Cooke


Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of California

SEAL



My Commission expires January 28, 1985

GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers to
Interrogatories 20, 41, 42, 49. Said answers
are true and correct to the best of my knowledge and
belief.


W. H. FUJIMOTO

Subscribed and sworn to
before me this 2nd day
of November, 1981

 
Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of
California


My Commission expires January 28, 1985

GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers to
Interrogatories 37, 38, 39, 40, 43 . Said answers
are true and correct to the best of my knowledge and
belief.


C. O. COFFER

Subscribed and sworn to
before me this 2nd day
of November, 1981



Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of
California

SEAL


My Commission expires January 28, 1985

GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers to
Interrogatories 37, 40, 45. Said answers
are true and correct to the best of my knowledge and
belief.


J. E. HERBST


Subscribed and sworn to
before me this 2nd day
of November, 1981


Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of
California

SEAL


My Commission expires January 28, 1985

I have assisted in preparing the answers
to Interrogatories 4, 5, 6, 7, 17, 21, 23, 26, 27,
28 and 30. Said answers are true and correct to the
best of my knowledge and belief.



Don K. Davis

Subscribed and sworn to
before me this 3rd day of
November, 1981.




Notary Public in and for the
County of Alameda, the
State of California.


My Commission Expires May 4, 1984

GOVERNOR EDMUND G. BROWN, JR.
SECOND SET OF INTERROGATORIES
AND
THIRD REQUEST FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers to
Interrogatories 44, 46, 47, 48. Said answers
are true and correct to the best of my knowledge and
belief.


G. C. WU

Subscribed and sworn to
before me this 2nd day
of November, 1981


Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of
California

SEAL

My Commission expires January 28, 1985

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)

PACIFIC GAS AND ELECTRIC COMPANY)

Diablo Canyon Nuclear Power Plant,)
Units 1 and 2)

Docket No. 50-275

Docket No. 50-323

(Full Power Proceeding)

CERTIFICATE OF SERVICE

The foregoing document ~~(of)~~ of Pacific Gas and Electric Company has ~~(been)~~ been served today on the following by deposit in the United States mail, properly stamped and addressed:

Judge John F. Wolf
Chairman
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Judge Glenn O. Bright
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Judge Jerry R. Kline
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mrs. Elizabeth Apfelberg
C/o Nancy Culver
192 Luneta Drive
San Luis Obispo, California 93401

Janice E. Kerr, Esq.
Public Utilities Commission
of the State of California
5246 State Building
350 McAllister Street
San Francisco, California 94102

Mrs. Raye Fleming
1920 Mattie Road
Shell Beach, California 93449

Mr. Frederick Eissler
Scenic Shoreline Preservation
Conference, Inc.
4623 More Mesa Drive
Santa Barbara, California 93105

Mrs. Sandra A. Silver
1760 Alisal Street
San Luis Obispo, California 93401

Mr. Gordon Silver
1760 Alisal Street
San Luis Obispo, California 93401

John Phillips, Esq.
Joel Reynolds, Esq.
Center for Law in the Public Interest
10203 Santa Monica Drive
Los Angeles, California 90067

David F. Fleischaker, Esq.
P. O. Box 1178
Oklahoma City
Oklahoma 73101

Arthur C. Gehr, Esq.
Snell & Wilmer
3100 Valley Bank Center
Phoenix, Arizona 85073

Bruce Norton, Esq.
Norton, Burke, Berry & French, P.C.
3216 N. Third Street
Suite 300
Phoenix, Arizona 85012-2699

Chairman
Atomic Safety and Licensing
Board Panel
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Chairman
Atomic Safety and Licensing
Appeal Panel
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Secretary
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attn.: Docketing and Service Section

William J. Olmstead, Esq.
Bradley W. Jones, Esq.
Office of Executive Legal Director
BETH 042
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Richard B. Hubbard
MHB Technical Associates
1703 Hamilton Avenue, Suite K
San Jose, California 95125

Mr. Carl Neiberger
Telegram Tribune
P. O. Box 112
San Luis Obispo, California 93402


Herbert H. Brown, Esq.
Lawrence Coe Lanpher, Esq.
Christopher B. Hanback, Esq.
Hill, Christopher & Phillips
1900 M Street, N.W.
Washington, D. C. 20036

Byron S. Georgiou, Esq.
Legal Affairs Secretary
Governor's Office
State Capitol
Sacramento, California 95814

Judge Thomas S. Moore
Chairman
Atomic Safety and Licensing
Appeal Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Judge W. Reed Johnson
Atomic Safety and Licensing
Appeal Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Judge John H. Buck
Atomic Safety and Licensing
Appeal Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555


Philip A. Crane, Jr.
Attorney
Pacific Gas and Electric Company

Date: November 3, 1981