


ORIGINAL

NUCLEAR REGULATORY COMMISSION



In the Matter of: ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
CALLAWAY UNIT 1 PLANT TOUR AND MEETING

DATE: November 5, 1981 PAGES: 219 - 351
AT: Columbia, Missouri

TR04
3/1
delete B. White
[Handwritten signature]

ALDERSON *AR* REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

8111100433 811105
PDR ACRS
T-1023 PDR

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION

3 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
4 CALLAWAY UNIT 1 PLANT TOUR AND MEETING

5 - - -

6 End Zone Room
7 Holiday Inn West
8 1900 I-70 Drive, S.W.
9 Columbia, Missouri
10 Thursday, November 5, 1981

11 The meeting of the Advisory Committee on Reactor

12 Safeguards as convened at 8:30 a.m.

13 PRESENT FOR THE ACRS:

14 M. CARBON, Chairman
15 C. MARK, Member
16 J. RAY, Member
17 J. ARNOLD, Consultant
18 W. LIPINSKI, Consultant
19 Z. ZUDANS, Consultant
20
21
22
23
24
25

1 DESIGNATED FEDERAL EMPLOYEE:

R. MAJOR

2

ALSO PRESENT:

3

For the NRC Staff and Industry:

4

G. EDISON

B. YOUNGBLOOD

5

D. SCHNELL

6

R. SCHUKAI

J. MC LAUGHLIN

7

D. CAPONE

A. PASSWATER

8

N. SLATEN

G. HUGHES

9

D. SHAFER

D. WALKER

10

R. DETTENMIER

M. STILLER

11

S. MILTENBERGER

A. NEUHALFEN

12

R. WILKES

P. APPLEBY

13

M. TAYLOR

14

15

16

17

18

19

20

21

22

23

24

25

1 ALSO PRESENT (continued):

2 D. HEINLEIN
W. WEBER
J. KAE LIN
3 K. KUFCHENMEISTER
R. COTHREN
4 F. FIELD
D. MC ALEENAN
5 J. WATSON
N. PETRICK
6 F. SCHWOERER
R. STRIGHT
7 E. BECKETT
J. CERMAK
8 J. SMITH
J. PREBULA
9 D. GASDA
K. LEE
10 P. WAED
D. GROVE
11 F. RODDY
E. THOMAS
12 R. FOX
D. RAWLINS
13 W. LUCE
J. SWOGER

14

15

16

17

18

19

20

21

22

23

24

25

1 ALSO PRESENT (continued):

2 C. TULEY
3 D. PADDLEFORD
4 G. BUTTERWORTH
5 G. LAND
6 J. MESMERINGER
7 J. IRONS
8 S. SANCAKTER
9 J. GRESHAM
10 T. TIMMONS
11 D. BALLMANN
12 G. RATHBUN
13
14
15
16
17
18
19
20
21
22
23
24
25

1 and give them to me before the end of the meeting, we will
2 try and put something together.

3 Does anyone have any comments to make, or any
4 questions at this time?

5 (No response.)

6 MR. CARBON: Let's go ahead then. I will call on
7 Mr. Edison to cover both the confirmatory issues and the
8 licensing conditions, and then we will call on the applicant
9 for a response to his comments in both categories.

10 (Slide.)

11 MR. EDISON: Thank you, Mr. Chairman. My name is
12 Gordon Edison. I am the NRC Staff Licensing Project
13 Manager, and my Branch Chief, Mr. Joe Youngblood, is the
14 other member of the Staff here to represent the Staff.

15 (Slide.)

16 I am going to summarize the confirmatory items to
17 the license condition that we found and placed in the Safety
18 Evaluation Report for the Callaway operating license.

19 First of all, the summary will cover the
20 confirmatory items from the safety benefit. What we mean by
21 a "confirmatory item is that the Staff basically agrees with
22 the Applicant's design, but that there may be a need to
23 complete documentation or to verify some implementation at
24 the site; perhaps the analyses are 95 percent complete and
25 we want to make sure that the last 5 percent are what we

1 think they are going to be, and the analyses will not change
2 the result; or we want to look at some test results or
3 records at the site.

4 (Slide.)

5 The status of the confirmatory items is that we
6 found a total of 27 items, in addition to 12 TMI-related
7 confirmatory items. Two of these items may be confirmed by
8 the full committee meeting next week. Those items are Items
9 Nos. 4 and 9 in the Safety Evaluation Report. Number 4 has
10 to do with cladding collapse time; and number 9 has to do
11 with operator actions for safe shutdown from outside the
12 control room.

13 We have received submittals from the Applicant on
14 both of those items in the last few days, and the Staff is
15 now reviewing those submittals.

16 (Slide.)

17 I will summarize the license conditions that are
18 in the Safety Evaluation Report, NUREG-0830.

19 (Slide.)

20 By "license condition" we mean some action that
21 the Applicant must take, or a condition to be maintained
22 over the operating license of the plant. An example of a
23 license condition are the technical specifications.

24 (Slide.)

25 Section 1.9 of the Safety Evaluation Report shows

1 some 20 license conditions. A number of these we expect to
2 be implemented prior to licensing and fuel load. Therefore,
3 these may cease to exist as licensing conditions once the
4 Staff sees that they are in place and we are satisfied and
5 they will no longer be a license condition.

6 I would like to say something about one of these
7 license conditions. Number 17 refers to "separation
8 barriers" between cabling. We indicated in the Safety
9 Evaluation Report that we were going to require tests to
10 substantiate the barrier. That is no longer the case. We
11 do not feel that we need that test.

12 The Staff was discussing whether there would be a
13 need for testing, or whether an on-site visit to inspect the
14 separation and satisfy ourselves that it was adequate would
15 be good enough, and we decided that the on-site visit was
16 satisfactory. So there will be a change, and hopefully we
17 can get that in the supplement that is to be published on
18 November 27th to show that that testing is no longer
19 required.

20 That completes the Staff's presentation on the
21 confirmatory items and the license conditions. Unless there
22 are any questions, I will step down and allow the Applicant
23 to respond.

24 MR. CARBON: I wonder if you would take one of the
25 confirmatory issues -- I would arbitrarily take number 7,

1 for example, steam generator level control and detection --
2 and simply state what it is that the Applicant has not yet
3 provided? I am asking this just for an example.

4 MR. EDISON: All right. Let me get my SER off the
5 table there and look at what number 7 is.

6 (Pause.)

7 All right. This is an issue having to do with
8 steam generator level control and detection. In its review,
9 the Staff noted that three steam generator level channels
10 were used in two out of three logic for isolation of
11 feedwater high steam generator level. One of those same
12 three level channels was also used for control.

13 This did not meet IEEE Standard 2.79, so the Staff
14 asked that the Applicant modify the design. The Applicant
15 did modify the design. They have changed to a two out of
16 four logic. So we found that to be acceptable and in
17 compliance with this IEEE Standard.

18 Now what we want the applicant to do is to modify
19 the Final Safety Analysis Report's description of this, so
20 that it is documented. What the Staff has done has been
21 to-- I think this is one we have required as a license
22 condition, and said the Applicant must modify the design, we
23 must have this two out of four, and we are going to insist
24 that that be there. And if you in fact implement that and
25 build that into -- it is so important, that you build that

1 into the design before the fuel load date. We will look at
2 that, and we will take that off of the list of license
3 conditions.

4 As a matter of a confirmatory item, however, we
5 want to see that in the documentation for the rest of the
6 public and the Staff in the future.

7 So we have a license condition that they must make
8 the change to the hardware and the design.

9 Secondly, as a confirmatory item we want to see
10 the documentation in the book.

11 MR. CARBON: So they have done it, and it is on
12 this list simply because the paperwork has not been done?

13 MR. EDISON: That is correct.

14 MR. CARBON: Are there any questions?

15 (No response.)

16 MR. CARBON: Fine. Thank you.

17 MR. PASSWATER: Mr. Chairman, Bob Stright, the
18 SNUPPS Licensing Manager, will respond to the confirmatory
19 items.

20 (Slide.)

21 MR. STRIGHT: Good morning.

22 In general we agree with Dr. Edison's assessment
23 of the confirmatory items and license conditions. We were
24 going to note a couple of the confirmatory items that we
25 have recently submitted information on, but Dr. Edison has

1 already passed that information on.

2 Concerning Confirmatory Issue No. 9, that has to
3 do with operator actions from outside the control room. I
4 thought we might talk about this for a minute, and possibly
5 take care of an agenda item on today's agenda for later on.

6 (Slide.)

7 The original issue came up because our FSAR had
8 some words in there -- "jerryrigging" was the term that was
9 used for extended hot shutdown from outside the control
10 room. This brought up some discussion with the Staff about
11 what actual steps were required.

12 We clarified that with the Staff, and removed the
13 term "jerryrigging" because there are no special adjustments
14 or unusual arrangements that have to be done. The FSAR has
15 been changed.

16 Then we recently submitted a letter that detailed
17 the steps, including boration, that would be required to
18 maintain an extended hot shutdown from outside the control
19 room. Concerning the agenda item on your agenda today I
20 believe this issue came about because some other designs the
21 Committee may have reviewed that had one train of
22 instrumentation and controls outside of the control room at
23 the remote shutdown panel. Therefore, with the single
24 failure we could not guarantee that they could maintain this
25 safe shutdown condition from the remote panel.

1 The SNUPPS design is different from that. The remote
2 shutdown panel is actually two separate panels. We can
3 sustain a single failure and still meet the functions that
4 were intended for the remote shutdown panel.

5 That has been reviewed by the Staff and that is
6 why it was not an open item on Callaway SER as has been on
7 some recent plants.

8 MR. ZUDANS: Those two panels are in a single
9 room. What do you plan to do then?

10 MR. STRIGHT: The two panels? They are in a
11 single room right now. However, as part of our evaluation
12 of the control room fire which we touched on yesterday, we
13 are considering the possibility and the capability that the
14 design exists for the fire barrier between the two remote
15 shutdown panels.

16 That decision has not been made yet, but that's
17 very likely a possibility.

18 MR. ZUDANS: I see. Thank you.

19

20

21

22

23

24

25

1 MR. STRIGHT: Concerning the license conditions,
2 we agree with Dr. Edison that most of these items would not
3 really appear as license conditions. A good many of them
4 are duplicated from the confirmatory list and we believe
5 these will be cleared up a long time prior to licensing.

6 I would like to make a couple of comments on two
7 of the license conditions. Item number three is really an
8 administrative matter. However, this matter states that
9 there will be a license condition that we will implement,
10 the secondary chemistry program that we described in the
11 FSAR. We fully intend to do that.

12 We also fully intend to implement all the other
13 programs that are described in the FSAR. We don't really
14 understand why this one is called out special. But it is an
15 administrative problem, not a real problem.

16 Concerning license condition number one, the Staff
17 has a stated requirement to perform surveillance on the
18 control rods. We don't believe at this time that the
19 surveillance program suggested by the Staff is necessary.
20 We intend to propose an alternative program and we will
21 discuss this issue with the Staff further.

22 Other than those clarifications we don't have any
23 problems with the confirmatory items or the license
24 conditions and do not see that any of those are going to be
25 hard to resolve or to implement.

1 MR. CARBON: Questions?

2 MR. MARK: On the matter you mentioned on the
3 control rods, what is it that the Staff has proposed which
4 seems to you undue and is haphnium control rod a new thing?
5 Or is it just another example of a sort of control that has
6 generally been used before?

7 MR. STRIGHT: Your first question, the Staff
8 suggested a visual surveillance at the beginning of the
9 first, third, seventh, and ninth, or something like that,
10 cycles.

11 Let me back off now to the second question.
12 Haphnium used in control rods. There is a considerable
13 wealth of experience using haphnium in control rods.
14 However, most of that is not in the commercial nuclear
15 plants. There is some experience with commercial nuclear
16 plants.

17 However, recently Comanche Peak and both of the
18 SNUPPS plants are the first ones to recently shift from
19 silver indiancadmium to haphnium. The Staff required a
20 survey surveillance program at the Comanche Peak and those
21 applicants agreed to institute this program.

22 We don't feel it's necessary and especially if
23 Comanche Peak does it we're going to be able to get
24 information from them.

25 MR. CARBON: Fine, thank you.

1 MR. PASSWATER: Mr. Chairman, an administrative
2 thing. On the agenda, as Mr. Stright mentioned, there's an
3 item called Interpretation of DDST. We really don't have
4 anything to add beyond what he said unless there are some
5 questions that the Committee has.

6 MR. CARBON: Any questions on that?

7 (No response.)

8 MR. PASSWATER: So we won't have a separate
9 presentation on that item.

10 The next item, then, is the preparation of
11 emergency operating procedures. Andy Neuhalfen, who is the
12 Superintendent of Operations, Callaway, will talk on that
13 topic.

14 MR. NEUHALFEN: Mr. Chairman, my name is Andrew
15 Neuhalfen. I'm the Superintendent of Operations, Callaway
16 Nuclear Plant. Part of my responsibility is for the
17 implementation and development of the emergency procedures
18 for Callaway.

19 (Slide.)

20 A brief outline of what I had planned to cover
21 this morning is the current development of our emergency
22 procedures. I would like to delve into the philosophy of
23 the format. I would like to show you an example of just a
24 page from one of the procedures. We went to the procedures
25 structure. Then I plan to show you lists of the guidelines

1 themselves.

2 We have discussed the status trees in yesterday's
3 presentation. I have a little bit more to add to the status
4 trees.

5 Then we go into the use of the coordinated
6 procedures along with the status trees. I am prepared to
7 show you an example of the dianostic procedure and a brief
8 summary.

9 (Slide.)

10 We are currently using the guidelines developed by
11 the Westinghouse Owners Groups. These are written
12 generically for Westinghouse four-loop, twelve-foot core
13 plants, 25-35 watts. This provide a comprehensive and
14 integrated set of emergency guidelines along with related
15 background information for each procedure.

16 In addition, there are analytical bases and
17 training and application information, again for each
18 procedure. Included is also a preparation and users guide
19 for writing procedures.

20 These guidelines address the immediate procedures
21 for addressing transients and emergencies and long-term
22 requirements. This gives us the assurance of operator
23 preparedness for events up to and beyond the design basis
24 event.

25 The development of emergency procedures gives

1 consideration to normal patterns of training operators when
2 confronted with a plant upset condition. These include, of
3 course, the immediate actions, immediate verifications, and
4 the system checks. Consideration is also given to the
5 usefulness of a procedure to an experienced operator versus
6 a relatively inexperienced operator, given the fact that the
7 procedures are not overwhelming to an experienced operator.

8 They serve as a guide to the operator when
9 verifications of manual or automatic actions cannot be
10 obtained. They provide for smooth transitions between the
11 guidelines and the contingencies. They minimize the impact
12 of adding new contingencies to an existing procedure. They
13 also allow us to reference the alarm responses into specific
14 contingency procedures.

15 What this will do for us, then, is present a
16 plant-specific procedure which adheres to the human factors
17 concept in facilitating clear understanding and transfer of
18 information to the operator under stressful conditions.

19 An example, then, of the format we are using. It
20 is a two-column format. The lefthand portion of the column
21 is the action and expected response. The righthand portion
22 is to be used if the action or expected response is not
23 obtained. It is in the righthand portion of the procedure,
24 but in a column where we refer the operator to his
25 contingency actions. We spoke of this yesterday.

1 As you can see, each page is blocked out. This
2 will be on the righthand side of the page to allow for
3 binding on the lefthand side. Each page has its own title,
4 guideline title, series, current revision date and the
5 procedures utilized, very strategically placed words,
6 cautions, as you can see, and notes precede the step rather
7 than being steps to be performed which are advisory.

8 Format E is using strategically placed words --
9 if/then, less than/greater than -- in the format and they
10 are very consistent throughout. All of our abbreviations
11 are standard abbreviations also.

12 As you can see, we place only steps within the
13 guidelines. There is little, if any, background
14 information. This is all provided to our operators in their
15 training program. Of course, it is available for each
16 procedure, but it is not in the procedure itself.

17 MR. ZUDANS: Could you qualify the distinction
18 between guideline and procedure?

19 MR. NEUHALFEN: Yes, sir. These are the
20 guidelines that we will be using to write our procedures.
21 They are Westinghouse Owners Group guidelines.

22 MR. ZUDANS: I see.

23 (Slide.)

24 MR. NEUHALFEN: The procedure structure is divided
25 into two sets. The first set consists of two parts: one,

1 emergency procedure for diagnosis and mitigation in the
2 classical sense; number two, emergency subprocedures with
3 additional steps applicable to a particular emergency
4 procedure; number three, emergency contingency actions
5 applicable to more than one emergency procedure.

6 The second set utilizes successive halves, as we
7 saw yesterday, to provide a systematic approach and
8 hierarchy of protection for the operator to use to mitigate
9 consequences of any accident that jeopardizes the nuclear
10 safety of the plant.

11 The second set consists of two parts: the
12 critical safety function monitoring, using status trees;
13 number two, the restoration guidelines to address loss of
14 the critical safety functions.

15 (Slide.)

16 The optimal recovery guidelines are contained in
17 this list. As I say, the emergency procedures are
18 designated in the E series. They cover loss of reactor
19 coolant, of course, the diagnostic EO and steam generator
20 tube rupture. There are, in addition, emergency
21 subprocedures which can be referenced or are referenced from
22 the E procedures.

23 (Slide.)

24 The emergency contingency actions, of which I
25 spoke previously, are the anticipated transients without

1 scram, loss of AC power. This emergency contingency action
2 has a recovery with or without safety injection required.
3 Also, the steam generator tube rupture contingencies, which
4 cover multiple tube failures within a steam generator or
5 tube ruptures within more than one steam generator.

6 MR. LIPINSKI: On the loss of AC power recovery
7 with safety injection, how do you accomplish safety
8 injection without AC power?

9 MR. NEUHALFEN: In the background information this
10 is accomplished through the use of bleed and feed, if I am
11 not mistaken. Mr. Lang is here to delve into the actual
12 background information on that procedure.

13 MR. LIPINSKI: That will come in later in our
14 agenda? I'll delay questions, then, until then.

15 MR. NEUHALFEN: Thank you.

16 (Slide.)

17 The function restoration guideline set will be
18 available in mid-'82 through the Westinghouse Owners
19 Groups. These are used in conjunction with but are not
20 limited to use with the status tree. These are, as we saw
21 yesterday, referenced from the status trees out into another
22 procedure. They take care of the subcriticality critical
23 function, the reactor coolant system integrity, reactor
24 coolant -- no, this is inadequate core cooling -- reactor
25 coolant inventory, loss of secondary heat sink and also the

1 Z series, which is the containment critical safety
2 function.

3 (Slide.)

4 An example, we saw the one on inadequate core
5 cooling yesterday, this is an example of subcriticality. as
6 Mr. Cermak pointed out to us yesterday, they are
7 color-coded. Plants are using them in the SPDS, red meaning
8 a critical safety function has been violated and you have to
9 take immediate action.

10 Orange is the critical safety is in jeopardy,
11 subsequent action is necessary. Yellow means the critical
12 safety function has not been satisfied; actions will be
13 necessary on the part of the operator. Green, of course,
14 means that in this case subcriticality critical safety
15 function has been satisfied.

16 We enter the status tree from the left. I hope
17 the writing is large enough so that you can read it.

18 MR. ZUDANS: I have a question. From what I
19 gather up to this point you have two sets of procedures.
20 One is that it directs you to the set you call optimum
21 procedure or optimal recovery. The other one is based on
22 the status trees, which you call functional recovery.

23 Is it to be understood that the first step would
24 always refer to the case where you know for sure what's
25 happened?

1 MR. NEUHALFEN: I think in my next slide I can
2 address that for you, if I might, sir.

3 MR. ZUDANS: Fine.

4 (Slide.)

5 MR. NEUHALFEN: The next one is the coordinated
6 use of the procedures. It shows, of course, when an
7 abnormal condition is encountered, response is required by
8 the operator. The response he takes, he takes immediate
9 action. He restores the condition. Of course, he goes back
10 to normal operation.

11 Should it not, we then encounter a dual path where
12 we are monitoring the critical safety function trees as well
13 as going into our emergency procedures. In this way we are
14 affecting recovery through the optimal recovery guidelines
15 or procedures in order to get back to normal operation.

16 Should, during the course of carrying out the
17 emergency procedure, one of our critical safety functions
18 becomes in jeopardy, then by monitoring our SPDS we can
19 refer into one of the function restoration guidelines and
20 get the plant back into a safe mode as far as critical
21 safety functions are concerned and recovery the plant using
22 the optimal recovery guidelines.

23 Does this answer your question?

24 MR. ZUDANS: Yes, it does. In this critical
25 safety function you have identified six items there?

1 MR. NEUHALFEN: Yes, sir.

2 MR. ZUDANS: For which you had these critical
3 function status trees.

4 MR. NEUHALFEN: Yes, sir.

5 MR. ZUDANS: It seems to be clear but not quite
6 completely when you really branch. Do you branch in every
7 case where you cannot restore the condition that you show on
8 your chart? Do you branch in both directions?

9 MR. NEUHALFEN: Yes, sir.

10 MR. ZUDANS: And this monitor on SPDS would just
11 flash different in one of your six states and scan through
12 them and see whether any of these six functions is affected,
13 right? In the meantime, the emergency procedure would be
14 followed on the basis of some other deterministic
15 indication?

16 MR. NEUHALFEN: You are absolutely correct, sir.
17 But what I am trying to point out here is that we are not
18 going into the procedures blind. We are always continuously
19 monitoring our critical safety functions in order to cover
20 any contingency that might not be covered in our emergency
21 procedures.

22 It also allows us to maintain an ever-watchful eye
23 on our plant.

24 MR. ZUDANS: How do you decide? Say, look at your
25 emergency procedures block. How do you decide to get on

1 this "no" path that you indicated?

2 MR. NEUHALFEN: This one here?

3 MR. ZUDANS: Right.

4 MR. NEUHALFEN: If we are not -- okay, if the
5 emergency procedure is not covering --

6 MR. ZUDANS: How do you know that?

7 MR. NEUHALFEN: We can tell by the indication in
8 the control room. The trained operator, of course, is going
9 to be looking at his control board and his parameters that
10 he is trying to recover. If he's not able to recover the
11 parameters using the emergency procedures, his critical
12 safety function trees and the SPDS will be telling him where
13 he is in core cooling, et cetera, any one of a number of
14 six.

15 So he then refers to the function restoration
16 guidelines in order to recover the plant to a safe condition
17 so that he can effect repairs and go back to normal
18 operation again.

19 MR. ZUDANS: Maybe it's clear to you, but you're
20 not really conveying it completely clearly to me. Maybe it's
21 not important. I think what you have is a good thing, but
22 there are a few links missing, at least to convey to me.
23 Maybe others --

24 MR. LANG: Dr. Zudans, the idea is if you get into
25 one of these E-1, 2, 3, guidelines, which is an

1 event-specific procedure, if you are in that procedure and
2 you're not getting the expected response the operator would
3 be trained to see then, he would kick out of the
4 event-specific procedure and go back to his critical safety
5 functions until he can rediagnose or find out if an
6 additional failure occurred.

7 MR. ZUDANS: That's exactly how I thought you
8 would answer my question. The point is, when you follow
9 emergency procedures you know what you are trying to do.
10 When you find out that that is not leading you to the
11 expected goal, then you have this other resource to go and
12 start looking at your event or status event tree.

13 MR. NEUHALFEN: That's correct.

14 MR. ZUDANS: So that's when you go on that "no"
15 path. But the way you show in that procedure, the monitor
16 SPDS is the only one that has the status trees. I thought
17 you had duplicate pictures you could do at the same control
18 room location also following the status trees. Do you have
19 to go to SPDS, wherever that is, to get that done?

20 MR. NEUHALFEN: We also have the instrumentation
21 that is on the control board.

22 MR. ZUDANS: Physically where is this monitor SPDS
23 located?

24 MR. NEUHALFEN: At this time we are still
25 evaluating that.

1 MR. PASSWATER: It's in the control room. The
2 SPDS will be --

3 MR. ZUDANS: It's recallable on any of your CRTs
4 which are in the control room or tech support center?

5 MR. PASSWATER: The final design of whether we're
6 going to use the CRTs that you saw in the control room
7 yesterday or whether we're going to add CRTs, one or two, is
8 still being decided. There is some consideration about
9 matching the software and so forth in this system and the
10 existing system, but it would be available in the control
11 room to the operator. It is not that he has to go somewhere
12 else to get information from the SPDS.

13 MR. ZUDANS: The only thing is, the way this graph
14 shows here, the only unit that would have that capability is
15 the SPDS. I thought the SPDS was in addition to whatever
16 else you have in the control room.

17 MR. PASSWATER: As I said, that's still being
18 decided as to whether or not the capability to call that up
19 will be on the existing CRTs in the control room or whether
20 we're going to add another panel in the control room.

21 MR. ZUDANS: I would just like to add this is the
22 first sensible thing I see in trying to do a nice job, so
23 maybe you should make clear that each of the little items is
24 fully understood.

25 MR. LIPINSKI: Let me clarify something for

1 myself. The SPDS, the safety parameter display system, that
2 NRC is asking for is simply a display of the critical values
3 in the plant. It has nothing to do with your trees. The
4 trees are not being asked for by the NRC in the SPDS.

5 MR. ZUDANS: They are proposing something else.

6 MR. LIPINSKI: The way this diagram shows it, the
7 way the operator consults the SPDS and finds out what the
8 status of the plant is, then he himself is going to make
9 decisions on whether these parameters are proceeding in the
10 right direction or not.

11 MR. ZUDANS: We agree on that. That's why I said
12 I would like to see the operator do it in another box.

13 MR. ARNOLD: I am getting lost. Could you just
14 run through a simple scenario which involves a
15 person-to-person interaction? You've used the word "we" and
16 "us" and "you". Who's doing all of these things? Who is
17 making the responses? Is it just the operator that's
18 responding or is someone else responding to the operator?
19 What is happening?

20 MR. NEUHALFEN: In our control room we have a
21 supervisor who is on shift. We have currently two reactor
22 operators stationed in the control room along with him. In
23 an emergency situation there is, of course, continuous
24 communication between the operators and the operating
25 supervisor.

1 When a situation comes about that we need to get
2 into the emergency procedures, the procedures are followed
3 both by the operator and the operating supervisor. The
4 supervisor, of course, is fully cognizant of what is going
5 on in the big picture in the control room, so he is the one
6 who is picking up on something that is an unexpected
7 response and then leading the operator on the right path.

8 Does this answer your question, sir?

9 MR. ARNOLD: I guess so, if you tell me that the
10 response really is the responsibility of the supervisor.
11 He's in charge and he is making all of the decisions.

12 MR. NEUHALFEN: He is not. He is making the
13 decisions. However, he has licensed people giving him the
14 input he needs to make the decisions.

15 MR. ARNOLD: I appreciate that. I'm just trying
16 to understand who is involved here. It's just the
17 operator.

18 MR. NEUHALFEN: Yes, sir, the way we envision it.
19 Were there any more questions on this slide?

20 MR. ZUDANS: The only final remark I would like to
21 make, it's not a question exactly, not a concern, my
22 objection, if one would want to label it that way is here
23 you have other people to assist the operator. I would like
24 to see the same capabilities you say in SPDS also exists in
25 the operators. It's at the operator's direct disposal. He

1 uses this only as a standby, in an assisting capacity rather
2 than a primary capacity.

3 The way you show this chart he goes through normal
4 optimal recovery procedures by himself. Then he hits this
5 need to address the status trees. He has to go and call up
6 the SDPS, which in my opinion should not be the case. He
7 should be able to do the very same thing the SPDS can do but
8 the SPDS only acts as an assisting unit and not as a
9 principal unit of control.

10 That is just a thought now.

11 MR. NEUHALFEN: Along with the electronic display
12 coming about through the SPDS we have a backup method. I
13 had not planned to get into them, but we have backup methods
14 of monitoring the critical safety function status trees.
15 SPDS was a convenient term to put in this block because we
16 do plan to use it and I see where your concern lies.

17 As I said, our operators are trained to look to
18 these critical safety functions themselves. As I said, this
19 is a backup for them. This is a backup reminder.

20 MR. LIPINSKI: One further question. The block
21 contingency action, does this imply written material or are
22 these decisions to be performed by the operator based on the
23 conditions he observes?

24 MR. NEUHALFEN: These are the function restoration
25 guides that are keyed from the safety parameter display

1 system.

2 MR. LIPINSKI: Okay.

3 MR. ZUDANS: C-1, C-2, C-3.

4 MR. LIPINSKI: You ought to label the blocks so
5 that there is a one-to-one correspondence between the other
6 material.

7 MR. NEUHALFEN: Excuse me?

8 MR. LIPINSKI: I said you ought to label that
9 block so that there is a one-to-one correspondence with the
10 previous presentation.

11 MR. NEUHALFEN: My next slide are examples.

12 (Slide.)

13 What I want to do is briefly go down the procedure
14 and show how we use it. We, of course, are verifying
15 reactor trip. The procedure, very briefly, tells how to do
16 this. This is, of course, the action or expected response.
17 Should we not obtain this response, then we manually trip
18 the reactor and go to the emergency contingency action,
19 which is ATWS, verify turbine trip, which is step two. If
20 the action response is not routine, then we manually trip
21 the reactor.

22 Of course we can follow on down AC, initial safety
23 injection has activated, verify feedwater, verify all the
24 way down through on the contingency side, the righthand
25 column.

1 Then we go to the emergency contingency actions or
2 emergency subprocedures.

3 (Slide.)

4 I have one more slide. The circled items are
5 immediate operator actions, circled for training purposes
6 right now. As you can see, we are still lacking the
7 background information in the procedure, which gets rid of
8 its bulk. It is strictly the steps that the operator must go
9 through in order to restore his plant.

10 MR. ARNOLD: A question. Have these instructions
11 been tested on a simulator or validated in some other way to
12 be sure that indeed when you get an indication of a problem
13 that you are including in your instruction all of the
14 possibilities or all of the sources of such an indication of
15 a problem?

16 MR. NEUHALFEN: Sir, we are in the development
17 stage now. It is our intent, when we get our simulator
18 on-site, to write the procedures. We will then run them on
19 our simulator, debug them on our simulator, and at that time
20 we will have our procedures completely developed. But we do
21 intend, I hope this answers your question, to debug them on
22 our simulator.

23 MR. ARNOLD: And does your simulator software --
24 well, it just covers certain accidents, does it not, and
25 certain responses and so on? What can you do or what have

1 you done to further validate that this is a complete
2 analysis of all of the probable sources of the indications
3 of trouble that you are listing?

4 MR. NEUHALFEN: I will say that our simulator is
5 current state-of-the-art. It has some, is it 800, some
6 phenomenal amount of --

7 MR. ARNOLD: I'm talking about the input to the
8 simulator rather than the simulator itself.

9 MR. NEUHALFEN: You are talking about the software
10 for it.

11 MR. ARNOLD: The information, the knowledge you
12 are putting into it. How do you know that you have all the
13 knowledge necessary to give a set of instructions that is as
14 definitive as these and know that you are not missing some
15 important --

16 MR. LANG: We fully recognize that the capability
17 of the simulators today do not fully check out with the
18 precedures. However, what we want to verify using the
19 simulators is the interaction between the individual
20 control room monitoring the critical safety functions and
21 those that are actually looking at the plant-specific
22 optimal recovery guidelines.

23 We think that we can verify the interaction
24 between these two individuals, that we have gone a long way
25 toward verifying this concept.

1 MR. ARNOLD: I recognize that it's a very probable
2 tool, but at the same time I recognize that there is nothing
3 so disruptive as wrong information or wrong interpretation
4 of a signal and a surprise to the operators as to the
5 response to the corrective action.

6 What I am trying to understand is how completely
7 you figured you have analyzed all of these situations so
8 that when the fellow looks at the chart he makes a move to
9 drop the temperature, it rises. That's just devastating. I
10 don't know whether I'm making myself clear or not.

11 MR. LANG: Yes, sir. Again, I guess I would
12 reiterate that we recognize that we cannot begin to pretend
13 that we've considered every scenario that could occur in a
14 power plant or an operation. However, we think that with
15 these critical safety trees that if a situation does occur
16 that takes you beyond an expected response where you cannot
17 diagnose an event-specific event, we fell very strongly that
18 the critical safety functions and the function recovery
19 guidelines will lead us on a safe path.

20 As far as the instrumentation and getting an
21 erroneous signal, the implementation of Reg Guide 197
22 addresses ambiguity, for instance. It will give you an
23 indication that one parameter is being given erroneous to an
24 operator. If you have two indications, the Reg Guide will
25 require a third to determine which one is correct.

1 MR. ARNOLD: That is to the extent of the power of
2 the simulator as it is today. I guess what I'm trying to
3 see is, do you have an ongoing program that will continue to
4 expand the knowledge that is in the simulator?

5 MR. RAWLINS: Yes, sir, we do. We have just
6 completed construction and it's currently in operation in a
7 new facility in Pittsburgh, in which we have a simulator
8 tied in. The development and research effort is continuing
9 to put such things such as two-phase flow-in.

10 Going back to your original question, I would also
11 like to bring out the point of view that in the development
12 of these guidelines that it is not just a Westinghouse alone
13 effort. It is a cooperative program through the Owners
14 Group in which we have thirty, forty utilities involved with
15 their operations people. With that collective experience,
16 not only from U.S. plants but our international plants also,
17 I think it goes a long way toward testing these out with
18 people who have actually operated the nuclear power plants.

19 We also try to bring in not just the operations
20 but the interdisciplinary aspects where we have accident
21 analysis people, training people, human factors experts
22 working on that subcommittee to develop these.

23 MR. ARNOLD: You are saying you do have feedback
24 from the performances of simulators throughout the world?

25 MR. RAWLINS: Yes, sir.

1 MR. ARNOLD: Tell me, how does that feedback get
2 back to the operators who are not involved in a particular
3 incident?

4 MR. RAWLINS: It's fed back -- first of all, the
5 procedures comes in to the Westinghouse Owners Group.
6 Periodically there are training seminars. I believe --
7 Glenn, you can correct me if I'm wrong -- the last one was a
8 week-long seminar held in September at which the procedures
9 and the bases, all the information behind what you see here,
10 is explained to the operations staff of the various
11 utilities. They are brought in and actually given seminars
12 on the steps and why those steps are there.

13 MR. ARNOLD: Do you have any emergency rules in
14 case you get something that is really vital knowledge for
15 all of the other simulator operators? Do you pass that on
16 quickly without going through seminars?

17 MR. RAWLINS: Yes, sir. If we find any validation
18 of a bases for which the plant is licensed, we have our
19 Safety Review Committee and its reporting structure to have
20 the information out to any of the operators, plus the fact
21 that within Westinghouse we have also created an emergency
22 response facility of our own which any of the utilities has
23 direct immediate access to, and we can assemble within our
24 command structure and technical command center the necessary
25 people to deal with the problems that come up that maybe we

1 have not covered here.

2 MR. ARNOLD: Fine. Thank you.

3 MR. LIPINSKI: Could you back this slide up to the
4 previous one?

5 MR. NEUHALFEN: Sure.

6 (Slide.)

7 MR. LIPINSKI: At the very bottom you've got
8 verify auxiliary feedwater pumps running and then on the
9 next one it shows verify the valve alignment. The basic
10 function of interest is auxiliary feedwater flow. This is
11 where trouble developed on TMI. The flow itself was not
12 directly verified.

13 You are giving me two steps to try to verify that
14 the flow is there, but if I've got a blockage in the line,
15 then I've got an anomaly. I'll have my pump spray and I'll
16 have my valves open. I still may not have flow, if I don't
17 have a direct measure of flow displayed to the operator. He
18 could verify both of these and still not have the flow
19 condition satisfied and stand there and scratch his head.

20 MR. NEUHALFEN: If I understand your question
21 correctly, sir, you are wondering -- well, let me go through
22 how it works.

23 You are verifying that the pumps are running,
24 first of all, both the motor-driven and the turbine-driven.

25 MR. LIPINSKI: Right.

1 MR. NEUHALFEN: Then on the next one we're
2 verifying alignment. Part of our normal operating procedure
3 is to be in the ESF lineup at all times. We are here
4 verifying alignment and you're saying somewhere later on
5 we've verifying flow or not?

6 MR. LIPINSKI: I am saying the flow is a function
7 of interest. This procedure does not identify flow as the
8 item of interest. You then get into subtasks that should
9 identify flow, but if I have an anomaly of a blockage, then
10 he doesn't look for the flow directly. He satisfies your
11 requirements, but he still does not know whether he has flow
12 or not.

13 MR. PASSWATER: Andy, if I could interject
14 something here. This is a generic Westinghouse guideline or
15 procedure. On Callaway we do have instrumentation to verify
16 flow from auxiliary feedwater flow instrumentation.

17 MR. LIPINSKI: What bothers me is to see this as a
18 generic output. After all, it happened at TMI. There was a
19 lesson to be learned, and that is that the flow was the item
20 of interest. The flow was up. The operators observed
21 that. They were happy, but they didn't look to see whether
22 they had flow.

23 MR. LANG: If you look down the procedure, sir,
24 you will see on step 15 that you do verify aux feed flow.
25 The reason for this, you must be setting up zero, which is

1 the initial diagnostic issue. You must go through the
2 immediate verifications of your safety function. A very
3 quick pass over the control board verifies that all your
4 safety equipment came on.

5 After the operator finishes that phase of
6 verification he then goes and looks at the specific flow of
7 the safety systems and you get to that in step 15. It says
8 verify aux feed flow. So it is a logical way that we were
9 told by the feedback of the Owners Group that an operator
10 should function in the control room and that was later put
11 in.

12 MR. LIPINSKI: No further comment.

13 MR. NEUHALFEN: Gentlemen, in summary, we are
14 writing our emergency procedures to the Westinghouse Owners
15 Group guidelines. I have attended the seminar in which Mr.
16 Lang was relaying his information the last weekend in
17 September, the last week in September. We have participated
18 along with thirty other utilities in the development of
19 these guidelines.

20 Our procedures will be plant-specific. They will
21 adhere to human factors engineering. They will be useful.
22 They will be of extreme use to an operator even under
23 stressful conditions through the structure of the
24 guideline. Our operators will receive a thorough
25 understanding of the procedures through their training and

1 simulator use.

2 MR. ZUDANS: On these procedures, in particular
3 the functional recovery procedures, I don't remember whether
4 you showed the slide or not when you listed those six
5 particular aspects.

6 MR. NEUHOLFEN: The critical safety functions? I
7 did not, sir. That was function restorations.

8 MR. ZUDANS: The next slide, not this one.

9 MR. NEUHOLFEN: I do have another slide.

10 (Slide.)

11 MR. ZUDANS: These are the six particular states
12 that you have as status trees. You either have or will have
13 status trees worked out?

14 MR. NEUHOLFEN: Yes, sir.

15 MR. ZUDANS: These are the ones you will call on
16 on your CRTs in a flow chart form in the color just like you
17 showed?

18 MR. NEUHOLFEN: Yes, sir.

19 MR. ZUDANS: The question is, how much of the rest
20 of the procedures will be in computer storage so that they
21 will flash up automatically and tell the operator that here
22 you have these choices from what the parameters are that
23 would indicate that you should either follow this optimal
24 recovery procedure or you should stick to the functional
25 recovery? It will guide him rather than looking for the

1 looseleaf or whatever he might keep those papers in.

2 Is that someplace in the future in your mind?

3 MR. NEUHALFEN: Sir, it could be done. I am still
4 under the current philosophy that we will have hard copies
5 of our procedures. We are expanding our computer for the
6 plant. This is a possibility. I have thought about it, but
7 we still plan to go with hard copy at this time.

8 MR. CERMAK: I would like to amend what Andy said
9 in that the procedures are not going to be on the CRT. They
10 will be hard copy. However, we have also developed, in
11 addition to the status trees and in addition to all the
12 procedures, an accident identification diagnostic system
13 which will lead you to which accident you are involved in.

14 We haven't discussed that in detail. It's still
15 under development with a group of twelve BWR facilities, of
16 which SNUPPS is a member.

17 MR. ZUDANS: This accident diagnostic
18 identification system, that, of course, is a computerized
19 system.

20 MR. CERMAK: Yes.

21 MR. ZUDANS: Why don't you talk about it?

22 MR. CERMAK: Because it's not fully developed at
23 this point in time. We are in the process of developing
24 it. It's going to be tested on the Indian Point simulator
25 next January and we will be making full submittals to the

1 NRC at that time.

2 MR. ZUDANS: That's exactly what the industry
3 needs.

4 MR. CERMAK: That's what we're looking on.

5 MR. ZUDANS: Nice to see that.

6 MR. NEUHALFEN: Further questions, gentlemen?

7 MR. LIPINSKI: No, but I would like to make a
8 comment to the Chairman. This relates to the Callaway
9 review now, but generically I think this information is of
10 direct interest to the ACRS in terms of how industry
11 procedures are proceeding. I'm not sure where it fits
12 within the Committee structure, but I think the Committee
13 should take a close look at what is being done.

14 MR. NEUHALFEN: Gentlemen, I have a full set of
15 procedures and guidelines as they have been written with me,
16 and you may, of course, look at them if you care to, as well
17 as all of the critical safety function status trees. I have
18 all of the information with me.

19 MR. CARBON: Thank you. Any other questions?

20 (No response.)

21 MR. PASSWATER: Mr. Chairman, just in the interest
22 of not leaving any misunderstanding, there was a question by
23 Dr. Lipinski earlier about the safety injection being
24 required in loss of all AC. I thought there might be a
25 misunderstanding that there was going to be another

1 presentation.

2 MR. LIPINSKI: They made reference to feed and
3 bleed and we're going to talk about feed and bleed last on
4 the agenda, I believe.

5 MR. LANG: What that entails is recovery of the
6 event with and without. If you restore AC, how do you
7 recover with and without? That is the intent.

8 MR. LIPINSKI: I don't get that from the single
9 line statement.

10 MR. MILTENBERGER: Steve Miltenberger, Union
11 Electric. In the outline it had three items listed. It had
12 ECA-2. That was loss of all AC. That's the overriding
13 procedure called for loss of AC and what to do about it.

14 The next item was ECA-2.1, subtier of a main
15 procedure. 2.2, as was mentioned, the 2.1 and the 2.2 are
16 subtiers of a main procedure that go into the recovery. So
17 the main loss of all AC is covered in the main procedure,
18 and then when you get into where you get AC back you get
19 proper guidance to restore power directly.

20 MR. PASSWATER: Our next topic is the design of
21 control room. Mike Taylor, Assistant Superintendent of
22 Operations for Callaway, is going to speak on that topic.

23 MR. TAYLOR: My name is Mike Taylor. I'm the
24 Assistant Superintendent of Operations for the Callaway
25 plant and I'm going to discuss the control room design used

1 at Callaway.

2 Initially in the SNUPPS concept Bechtel was tasked
3 with designing the control room for the Callaway plant as
4 well as all the SNUPPS plants. The concept to be used was a
5 centralized control room with a pitch board, vertical board,
6 enunciator panel on the read, a portion of the control
7 panel, as we saw yesterday in the control room, and also a
8 lower section benchboard and incline board on the front
9 section.

10 The controls and indications were divided among
11 these different boards with the front portions utilizing
12 controls that would be most frequently used by the operators
13 during normal and abnormal situations.

14 Bechtel produced this design and submitted it to
15 the various utilities. As we heard yesterday, two of these
16 utilities, Rochester Gas and Electric and Northern States
17 Power Company, had operating nuclear plants at that time and
18 could provide valuable input to the evaluation of this
19 design. In addition, Union Electric Company had had over
20 twenty years of design work in centralized control rooms.

21 The design was evaluated by plant review groups in
22 these utilities and upon finalization of the design a wooden
23 mockup was constructed. This mockup was a full-scale mockup
24 so that operators and various other personnel from the
25 utilities could evaluate this result.

1 Some of the things that were evaluated by licensed
2 operators from both the Prairie Island plant and the Ginna
3 station were the following: the man/machine interface;
4 video displays, two on the rear panel, two on the front
5 panel; the actual control layout; functional grouping of
6 controls; switch placement sizes; labeling; enunciator
7 systems; and actual access to the boards themselves.

8 One of the features that came about as a result of
9 this review was very noticeable. You may have noticed
10 yesterday the gap in the front panels which allows easier
11 access to the rear board from the operation stations.
12 Bechtel then incorporated these changes that were
13 recommended into a final design and the Callaway simulator
14 was constructed at Zion, Illinois, at the Westinghouse
15 nuclear training center. This was the first SNUPPS
16 simulator.

17 As was stated yesterday, this was a Callaway
18 simulator. The one portion on the left rear panel is a
19 site-specific portion of the board. That one at Zion is the
20 same as Callaway as well the new simulator is the same at
21 Callaway. Our simulator will be the third to be operated of
22 this type. It's undergoing further testing at Pittsburgh
23 right now.

24 All of our operational personnel that will be
25 licensed have gone through certification training on the

1 simulator at Zion, Illinois. They have provided additional
2 input as far as the design and use of this control room and
3 the design of the control board.

4 I would like to take a few minutes here to just go
5 over some of the features on the control board.

6 MR. CARBON: When was the simulator at Zion built
7 and started?

8 MR. TAYLOR: It was first designed in 1979. Our
9 first plant went through in 1979 and I believe it was the
10 second or third class to use that simulator.

11 MR. CARBON: When was the design on it frozen?

12 MR. TAYLOR: I'm not sure of that exact date,
13 sir.

14 MR. CAPONE: I would say about a year prior to
15 that. Of course, changes that could be fed in were fed in
16 as we were going along, but at some point you have to freeze
17 the design.

18 MR. RAY: Evidently, then, this review process and
19 the evolutionary deliberations that took place were before
20 TMI.

21 MR. TAYLOR: For the most part, yes, sir.

22 MR. RAY: Have you made any changes since TMI in
23 what you are projecting to do?

24 MR. TAYLOR: There are some changes to the control
25 board since TMI. Those will not be shown on this slide

1 because these were taken at the simulator at Zion just for
2 the ease of demonstration.

3 MR. RAY: But you did update the design to
4 encompass the lessons learned from TMI?

5 MR. TAYLOR: Yes, sir.

6 MR. CARBON: I had forgotten from yesterday where
7 the board is split. Would you point that out?

8 MR. TAYLOR: Right here, sir (indicating).

9 MR. CARBON: That's for access to the rear?

10 TAYLOR: Normally the two operators would be
11 in this position and this position over here (indicating).
12 Turbine generator steam volume control system, and for ease
13 of access back to the rear boards right there.

14 (Slide.)

15 This is a view looking from the left side of the
16 control room.

17 (Slide.)

18 And from the right side. You can see the spacing
19 here between the front and rear panels. Also we can see how
20 an operator stationed at the front panel can look over the
21 back of this panel and observe indications of controls on
22 the rear panel also, as well as the visual enunciators
23 around the top.

24 An operator can acknowledge enunciators on the
25 front panels as well as the rear panels.

1 MR. ZUDANS: I guess I must recall incorrectly. I
2 thought you have four CRTs on the main panel.

3 MR. TAYLOR: Here and here.

4 MR. ZUDANS: On the front. Just two?

5 MR. TAYLOR: There are separate keyboards for the
6 two pairs.

7 (Slide.)

8 MR. PAY: Question. I think you said there was
9 consideration being given to an additional CRT. Where will
10 that go in that previous diagram?

11 MR. TAYLOR: That has not been decided as yet.

12 MR. RAY: But it will be in this area presumably.

13 MR. TAYLOR: Some of the options being considered
14 would be maybe an extension on one of the front panels.

15 MR. ZUDANS: So what you are showing is at Zion?

16 MR. TAYLOR: This is at Zion, but for our purposes
17 this is the Callaway design.

18 MR. ARNOLD: Yesterday I believe we were told, in
19 answer to a question, that all fourteen of the shift
20 personnel had their major point of presence in the control
21 room. Is that wrong?

22 MR. TAYLOR: The two --

23 MR. ARNOLD: If so, where were the other two?

24 MR. TAYLOR: Normally the control room would be
25 manned by two licensed reactor operators and one licensed

1 senior reactor operator. That is the normal manning. There
2 would be another licensed senior reactor operator on site.
3 He, too, will be in the control room.

4 MR. ARNOLD: I guess I misunderstood yesterday.
5 Could someone clarify that?

6 MR. STILLER: Let me clear that up. The comment
7 was made, where are the fourteen people?

8 MR. ARNOLD: Exactly.

9 MR. STILLER: The fourteen people are all
10 dispatched from this control room. At some time during the
11 shift they may or may not be at the control room. We have
12 two there at all times. Where they go --

13 MR. ARNOLD: Where do they gather in the control
14 room? I'm just trying to understand.

15 MR. STILLER: They don't gather. They don't
16 assemble in the control room. They may be there. When a
17 man shows up on watch he is relieving someone. What is that
18 man doing that he is relieving? The water treating plant?
19 Fine, at that particular time he will go to the water
20 treating plant, complete the operation that's going on at
21 that time, contact the shift supervisor. I'm finished;
22 what's the next activity.

23 MR. ARNOLD: So basically they spend most of their
24 time outside of the control room.

25 MR. STILLER: That's correct.

1 MR. ZUDANS: The shift supervisor is one of the
2 SROs?

3 MR. TAYLOR: Yes, sir.

4 MR. ZUDANS: Where does the STA reside relative to
5 the control room?

6 MR. TAYLOR: I think, as we were told yesterday,
7 that the STA would normally work out of an office in the
8 technical support center. He could come to the control room
9 at any time.

10 MR. ZUDANS: So you could have a legal occupancy
11 there of about four people, right, and then transients?

12 MR. TAYLOR: On a normal shift-work basis, there
13 would be around four people here. There would be people in
14 and out with job assignments, picking up procedures and so
15 forth.

16

17

18

19

20

21

22

23

24

25

1 MR. LIPINSKI: Where there is a shift turnover, do
2 the 14 people turn up in the control room to get their
3 assignments?

4 MR. TAYLOR: No, sir.

5 MR. LIPINSKI: How do they know what their
6 assignments are?

7 MR. TAYLOR: The reactor operators will actually
8 direct the people in the field under the direction of the
9 shift supervisor.

10 MR. LIPINSKI: I am coming on shift, I have to
11 report to somebody when I show up to my shift. Who do I
12 show up to?

13 MR. TAYLOR: Normally, if you were reporting as a
14 person who worked outside the control room, you would
15 receive a turnover from your counterpart if there were a job
16 in progress.

17 MR. LIPINSKI: How do I find him?

18 MR. TAYLOR: There would be a station I show up
19 to.

20 MR. LIPINSKI: So when I show up to my shift, I go
21 to some station in the plant?

22 MR. TAYLOR: Possibly. You do not necessarily go
23 to the control room. There would be assigned stations for
24 various outside personnel.

25 MR. LIPINSKI: Okay.

1 MR. ZUDANS: You have got to be a little more
2 precise than that.

3 MR. STILLER: Mike, let me bail you out on that.

4 (Laughter.)

5 MR. STILLER: We have several categories of
6 people. Let us define them. We have two supervisory
7 personnel, senior reactor operators who go to the control
8 room, are properly relieved, relieving their predecessor,
9 and we have a shift turnover.

10 We have two licensed operators who go to the
11 control room and relieve in the control room. We then have
12 six personnel who are operating types of people outside of
13 the control room. They would be showing up to set down
14 their lunchbox, for one. They would be calling the control
15 room, "I am here." Keep in mind they have no assigned spot,
16 this is not "my desk," this is not "my workbench." They
17 were directed there by their supervisor and relieved at that
18 spot.

19 Now, there are four other types of people that we
20 are looking at, other security now. This is the
21 technicians, the I&C technician would go the I&C shop. The
22 rad chem type of personnel would go to the chem lab or to
23 the rad protection area.

24 So where he goes, really, it is a minor issue. It
25 depends upon what type of job he is doing. Believe me, he

1 must go somewhere, report to someone and be properly
2 relieving. Procedures are set up for each and every one of
3 them.

4 MR. LIPINSKI: Your explanation helps, because I
5 could visualize where you are saying everybody departs to
6 the control room where there are 28 people in that control
7 room during a shift turnover.

8 MR. STILLER: Believe me, Mr. Lipinski, that is
9 not the case. If a man is working, say, in a remote station
10 in the water treating plant, for example, and it is 10:30 at
11 night and his relief is not there, he is going to be
12 calling, "Where is my relief?" This is a catalyst right
13 there.

14 MR. LIPINSKI: That explains it. Thank you.

15 (Slide)

16 MR. TAYLOR: I will go on now and show some of the
17 closer views of the portions of the control room and briefly
18 describe what is located in these areas. As I said before,
19 the turbine generator controls are located on this panel;
20 the steam generator controls, main feedwater and auxiliary
21 feedwater controls are located on this panel. Behind here
22 we have associated turbine generator support as well as
23 steam system and condensate and feed system equipment.

24 (Slide)

25 This is the reactor control station. Two video

1 displays with the CRT keyboard, rod controls, nuclear
2 instrumentation, rod control indication.

3 Then on the rear panel we have reactor coolant
4 system indications and controls as well as cooling water,
5 heating, ventilating, air conditioning. The two other
6 visual displays.

7 MR. ZUDANS: The operator sits right here?

8 MR. TAYLOR: He would sit or stand in this area.

9 MR. ZUDANS: Whe he sits, he cannot see over the
10 front panel.

11 MR. TAYLOR: Normally, when the operator sits, he
12 would be on an elevated seat where he could see over it.
13 You will notice this portion is slightly lower than even
14 this one to aid in seeing over it.

15 MR. RAY: As I understand it, anything that is in
16 storage in the CPU with the computer can be called up on any
17 one of these four CRTs?

18 MR. TAYLOR: I would have to defer that question.

19 MR. MILTENBERGER: You have four CRTs in the
20 control room with two sets of keyboards, one on the front
21 panel and one on the back panel. You have the capability of
22 the four CRTs that any of the information can be stored on
23 any of the four CRTs. You can put the same pressurizer
24 level diagram could be entered on all four CRTs
25 simultaneously or anything that could be displayed on any

1 one of the screens could be displayed on any of the others.

2 So you do have that capability.

3 MR. RAY: The keyboards on all four, controlling
4 all four, have access to all the memory in the CPU; that is
5 what I am asking.

6 MR. MILTENBERGER: That is my understanding.

7 MR. RAY: There is no specific information that is
8 limited to any one CRT?

9 MR. MILTENBERGER: That is correct.

10 MR. RAY: Thank you.

11 MR. WILKES: Richard Wilkes, Union Electric.

12 All the operator information would be accessible
13 on the CRTs. Some programming type of information would
14 only be accessible from the computer, but all the informaton
15 that the operator needs --

16 MR. RAY: That is what I was interested in. Thank
17 you.

18 MR. TAYLOR: The final portion of the front panel
19 is the chemical and volume control system. Behind that is
20 the safeguards equipment, electrical distribution within the
21 power block. And then site-related electrical dtribution
22 adn other systems.

23 (Slide)

24 MR. MARK: Safeguards equipment? This is like
25 safety injection containment spray, RHR equipment such as

1 that?

2 MR. RAY: Since TMI we have been concerned,
3 particularly those who are concerned with human factors,
4 with demarcation between systems on the panels. As I
5 remember what I saw yesterday, this demarcation between
6 systems is by way of color-coded tags.

7 MR. TAYLOR: Not necessarily, sir. Let me go back
8 to the previous slide. We have no demarcation lines, as
9 such. What we have is more of a functional group; systems
10 are grouped within one area.

11 MR. ZUDANS: And you also had line mimic, which
12 you do not show on this slide.

13 MR. TAYLOR: That was what I was going to show on
14 the slide I was just one.

15 MR. MILTENBERGER: Mike, if I can address that, on
16 the safeguards train, the nameplates that are affixed to the
17 tags have different color coding for the different trains.
18 I think this is what Mr. Ray is addressing. You might want
19 to go into that aspect.

20 MR. TAYLOR: I will. This is an illustration of
21 the mimicing that is used on the various systems. This is
22 not used on all of the systems, but most of the major
23 systems uses this, this being the chemical and volume
24 control system.

25 We see here lines indicating piping systems with

1 prompt control switches right in the mimic, showing the
2 relative location of the pump in the system as well as
3 valves and static components such as heat exchangers and
4 tanks.

5 Also, we have the indications corresponding to
6 those various parameters right above the control.

7 (Slide)

8 This is the safeguards system. As I pointed out
9 on a previous slide, it shows the general layout of the rear
10 board, with additional mimicing, portions of that system and
11 indications directly above associated controls. I will
12 address these panels on a close-up slide in just a moment.

13 (Slide)

14 This is a little better picture of some of the
15 mimicing. It has flow arrows actually engraved on the
16 little plastic begalite bars, and you can see how the
17 various components tie right into the mimicing to show the
18 locations.

19 (Slide)

20 This is the safeguards status panel, one of two,
21 one for each train of safeguards systems. These panels will
22 be used to alert the operator to both normal and abnormal
23 situations.

24 First of all, there are amber lights that would
25 come on, indicating the inability of a specific component to

1 function. If, for instance, a breaker was open on a
2 specific pump, the operator would receive an amber light,
3 saying that pump is inoperable. That would warn him that
4 there was a problem with that safeguards system.

5 Normally, this panel should be dark, no lights on
6 for normal operations. Upon receipt of a safeguards
7 actuation signal -- and I will use containment spray right
8 up here (indicating) -- the portion of the status board
9 should light up with white lights. The operator could then
10 look and see if the individual white lights were on in the
11 overall system, indicating that that system was performing
12 the safeguards function.

13 In addition to this panel, the operator also has
14 the indications on the control board to check.

15 MR. BAY: Let us assume something was blocked out
16 of service, one of the auxiliary feedwater pumps, for
17 instance, or main feedwater pumps. There would be tags on
18 the controls on the bench board indicating they have been
19 blocked. The status is there. So that if a man goes and
20 reaches a switch that inhibits him doing something with it,
21 he knows from the back tag the status of the system.

22 Now, when something is blocked out of service, is
23 there a light in these positions on the panel, or are they
24 only to indicate abnormalities in operation?

25 MR. TAYLOR: Depending upon the actual component

1 and the indication used, like breaker control for pump
2 motors such as that, we would get these lights under certain
3 conditions.

4 MR. FAY: When equipment is in an abnormal state
5 for maintenance reasons, you will have an indication here as
6 well as the tag?

7 MR. TAYLOR: Yes, sir.

8 MR. RAY: So you will have a double check.

9 MR. TAYLOR: Yes, sir.

10 (Slide)

11 Two other status panels that I would like to point
12 out. One is a rod position indication system. This
13 utilizes LEDs, red LEDs that move up and down in
14 relationship to the rod travel in the core. This provides a
15 very quick and easy method for the reactor operator or other
16 operator to determine the position of the rod upon a trip
17 condition or something like that. He can easily look and
18 see if all the rods have actually entered the core or not.
19 This is actually from the position indication on the drive
20 shafts themselves.

21 This is a trip status panel, indicating both the
22 status of various permissives interlocks in the control
23 system and also the status of bistables in the trip and
24 protection systems. So if we have a coincidence of two or
25 four on some trip, we will get indication when just one of

1 those four goes to the trip condition. So that the operator
2 is aware of the status of the various systems.

3 This is for information such as during maintenance
4 procedures or during actual instrument faults or abnormal
5 conditions.

6 (Slide.)

7 Recently, we have completed three human
8 engineering studies of our control board design. The first
9 was a preliminary design assessment conducted by the Essex
10 Corporation for the SNUPPS organization. The Essex
11 Corporation reviewed both the Callaway simulator at Zion as
12 well as the Callaway plant control board. Their findings
13 were presented to the organization, and we are presently
14 reviewing, resolving those findings.

15 Additionally, as was mentioned yesterday, the NRC
16 completed a modified human factors evaluation. They were
17 not able to evaluate all conditions such as lighting, heavy
18 noise, furnishings, such as that. But a preliminary
19 evaluation was conducted of the Callaway control room, and
20 we are reviewing and attempting to resolve those findings.

21 One other study has been conducted. That was
22 concerning the annunciator systems as well as the status
23 panels, the safeguards status panels and the trip status
24 panels that we just looked at. This was conducted by
25 Westinghouse Offshore Power Systems and included both a

1 review of the display information as well as establishing
2 priorities of the various enunciator systems.

3 These three evaluations are being used to complete
4 the review of the Callaway control room and consideration
5 for possible changes.

6 MR. ZUDANS: I have a question. Flash back the
7 CRT picture, please.

8 (Slide)

9 I did not realize it was that far down. Okay.
10 Good enough. On the CRTs the operator can recall functional
11 diagrams of various systems. I was told he also can recall
12 trends in certain parameters, a past value and a current
13 value, showing the trend, say, reactor pressure, for
14 example--

15 MR. TAYLOR: Yes.

16 MR. ZUDANS: -- show the curve showing how the
17 pressure varies. I was told this trend could be recalled
18 for quite a long time going back.

19 MR. TAYLOR: We can recall that trend also on
20 paper recorders, such as this one right here.

21 MR. ZUDANS: I am more interested in the screen.
22 Can the operator also recall your status diagrams here for
23 six critical parameters?

24 MR. TAYLOR: On these displays?

25 MR. ZUDANS: Right.

1 MR. CERMACK: The displays have not been
2 programmed yet, first of all; let me point that out. They
3 have not been formally incorporated in the design. The
4 displays would be current displays, not previous displays.
5 It would give you a current indication on each display where
6 you are. It is a snapshot in time.

7 MR. ZUDANS: I understand that. You have a
8 primary coolant system recall which would show the current
9 values of pressure and temperature at points. If they do
10 change during the display, they will also change on your
11 screen. It is a live display. I am now talking about the
12 other part, the procedures part that takes care of those
13 status trees. The question is whether you can call that up
14 here.

15 MR. CERMACK: Yes, you can call them up, but they
16 would be a snapshot of where you were at the point in time.

17 MR. ZUDANS: Would they be?

18 MR. CERMACK: Yes, they would.

19 MR. ZUDANS: That would be very interesting.

20 MR. CERMACK: But they will not give you the
21 previous history.

22 MR. ZUDANS: I understand that.

23 MR. CERMACK: Which is what I thought as your
24 question.

25 MR. ZUDANS: I am satisfied with the trending

1 capability. That is another issue.

2 Now if the operator can recall the status trees
3 and they are active snapshots for the current state, then we
4 would see what is happening, what the results of these
5 actions are.

6 MR. CERMACK: That is correct.

7 MR. CARBON: If I understand you correctly,
8 though, Jim, it would not show on the screen. He would have
9 to remember what it was 30 seconds before or 60 seconds. It
10 would not show a path of what has been happening for several
11 minutes.

12 MR. CERMACK: Right. There is no way to show on a
13 snapshot status tree a path. You are either on one line or
14 you are in another line. It is a snapshot of where you are
15 at that point in time.

16 MR. LIPINSKI: Let me interject. It depends on
17 how you want to write your software. One of the thoughts I
18 had with respect to our trees is that they are
19 time-dependent. As the accident is evolving, you can
20 proceed along different branches.

21 As you point out, if you do not retain that
22 information in memory, then you are going to recall it or
23 you are going to rely on the operator, but if you chose to
24 write the software properly, you could incorporate memory
25 into those trees. It would depend upon how much you want to

1 devote to memory storage inside the computer.

2 It is conceivable that you could use those trees
3 to be time-dependent, not just snapshot.

4 MR. CERMACK: What you are saying is true. We had
5 not planned to incorporate previous history and recall
6 previous snapshots. That was not in our design.

7 MR. ZUDANS: Okay. Thank you. I think it is
8 good. There is no point in dwelling on that anymore.

9 MR. WILKES: Richard Wilkes, Union Electric.

10 One feature that the computer system does have is
11 the ability to take a moving time frame involving the alarms
12 coming into the computer system. I do not remember the
13 exact time frames. But if upon, say, a trip of the
14 generator, the computer would have previous, say, five- or
15 ten-minute history of the alarms that were coming in up to
16 that, then it would record the alarms that took place after
17 that, and they would be available on the memory such that
18 the operator could go back and recover that information.

19 MR. ZUDANS: But I was distinctly told yesterday
20 on the control room there was no connection between a CRT
21 capability and the enunciators and all such things as you
22 said they could not recall the past history of sequence of
23 enunciators on the CRTs.

24 MR. WILKES: There is a sequence-of-event monitor
25 within the computer.

1 MR. LIPINSKI: What you have just described is
2 what happened at TMI, where the computer was just overloaded
3 with alarms and the operators were not able to keep up with
4 that volume of information. The computer could not keep up
5 with it.

6 It was not the computer system but that amount of
7 information did not help them one bit with the volume that
8 came in because it listed the important information in with
9 the miscellaneous information and it all got lost in one big
10 jumble.

11 MR. WILKES: I understand what you are saying.
12 And that is one reason why this is recorded on the magnetic
13 memory as opposed to being printed out in the control room:
14 to reduce the amount of information which the operator is
15 receiving.

16 MR. CERMACK: Let me clarify the status trees
17 again, what I said about the snapshots at any given point in
18 time. However, we do have these trend graphs that were
19 previously referred to by Mr. Taylor, where you can call up,
20 for example, the reactor coolant system pressure as a
21 function of time, you can call up hot-leg temperature as a
22 function of time, the parameters that you are measuring,
23 reactor vessel water level. You also have a trend graph.
24 So the parameters you are measuring you can call up as a
25 function of time.

1 MR. CARBON: Are there further questions?

2 (No response.)

3 Are you implying that that finishes your
4 presentation?

5 MR. TAYLOR: Yes, sir.

6 MR. CARBON: I guess we have no more. Thank you.

7 MR. PASSWATER: I have to introduce myself for
8 this particular topic.

9 (Laughter.)

10 MR. PASSWATER: The purpose of this presentation
11 is to go through an item that has been of interest to the
12 ACRS, to the NRC staff in the most recent applications. The
13 generic title of the topic is systems interaction. I would
14 like to do two things, the first one being to describ
15 briefly the background of te topic and what we understand
16 the major points of the topic are.

17 Secondly, I would like to discuss what in the
18 SNUPPS design we have done to address the concerns of
19 systems interactions.

20 (Slide)

21 I would also like to say as kind if a sideline
22 that systems interaction responses I am going to address
23 include the effects of internal flooding. Internal flooding
24 was culled out as a separate agenda item in one of the
25 earlier agendas we received.

1 By way of background, the systems interaction came
2 about as a result of some operating experience from
3 operating plants. The concern that was perceived by the
4 staff was that things were happening in these operating
5 plants that were unacceptable or undesirable, and that the
6 probable cause of that was that there was lack of any
7 interdisciplinary review during the design of those plants.

8 In other words, the architect-engineers had their
9 civil group, they did their thing, the electrical group did
10 their thing, the mechanical group did their thing. Nobody
11 talked to anybody, and they all came out with a powerplant.
12 But they had not really considered the possible interaction
13 of different systems and different hazards. So it is now
14 carried as an unresolved safety issue, specifically A-17,
15 and it is also a topic of the TMI Action Plan NUREG-0660 as
16 Item 2.C.3.

17 To date the action that has been taken on this
18 topic was there was a study done by Sandia on a typical
19 LWR. It was categorized as a limited study on systems
20 interaction. They identified some action items which had
21 been addressed by the staff, and I believe that the TMI
22 Action Plan was recommended by the staff, by the Commission,
23 that further work needed to be done in this area
24 generically.

25 (Slide)

1 That is the background. The next part of my
2 presentation deals with the SNUPPS approach and what we have
3 done in regard to the area of systems interaction.

4 I would to say that the design of the SNUPPS took
5 into account in a broad sort of way the area of systems
6 interaction from day one. Yesterday on your tour of the
7 plant one of the things that we tried to point out on the
8 tour was the concept, the separation concept that we used in
9 the design of the plant.

10 There is an upper and lower cable spreading room,
11 redundant trains are -- come into the control room through
12 two separate cable spreading rooms. We have two separate
13 electrical penetration rooms and two separate mechanical or
14 piping penetration rooms. Those are located at a
15 considerable distance -- there is a considerable distance
16 between the redundant penetration rooms around the
17 containment.

18 So the systems interaction idea specifically with
19 regard to separation was an initial consideration in the
20 design of Callaway SNUPPS design.

21 There have been some additional studies done with
22 regard to certain aspects of the systems interaction. Those
23 are the hazards analysis that we have done, FSAR Appendix
24 B. There was an item that came up during the FSAR review on
25 control system failures, which is addressed in the questions

1 and answers in the FSAR.

2 There was a separate question in the environmental
3 impacts on the control systems which was also documented and
4 answered in the FSAR. And then a study that is now underway
5 is one on heavy loads analysis, which is again a separate
6 category of hazard.

7 (Slide)

8 I am going to go through the basis for the hazards
9 analysis. Again, I am not planning to get into any detail
10 on the hazards analysis itself. It is very lengthy. As I
11 mentioned, it is in Appendix B in the FSAR.

12 It considers four types of hazards. Those are:
13 pipe break effects on systems; missiles both internal and
14 external; earthquake-induced failures, specifically
15 nonseismically designed systems; and fire hazards.

16 Some of the major assumptions -- these are not the
17 only two assumptions, but they are kind of key to the way
18 the analysis was done -- first of all, it is assumed the
19 plant is operated by the technical specifications. The
20 reason that was looked at is that would delineate times,
21 limiting conditions for operation and so forth. The second
22 one was we did not assume a loss of off-site power except
23 for cases where the hazard itself would result in the
24 turbine trip or generator trip or reactor trip.

25 The first of the types of hazards we considered,

1 pipe break effects. Pipe break effects includes flooding,
2 which is one of your topics that was culled out separately
3 earlier, jet impingement for pressurized line, pipe whip,
4 and environmental effects.

5 The analysis that has been done on pipe break is
6 in accordance with the NPC branch technical positions MEB
7 3-1 and ASB 3-1 criteria. Those criteria dictate where
8 breaks are assumed for moderate high-energy lines and als
9 dictate what happens to the piping system following a
10 break. Those are again high- and moderate-energy lines.

11 We also did a study because it was a specific
12 licensing concern back at the PSAR stage. That was in the
13 rupture of circulating water expansion joint and the
14 consequences of that rupture flooding from the cooling tower
15 into the turbine building.

16 The second type of hazard is missiles. Missile
17 analysis, missile hazards analysis is specifically culled
18 out in the FSAR section 3.5. Internal missiles consist of
19 rotating and pressurized component sources. Selecting their
20 trajectories and so forth is culled out in 3.5 of the FSAR.

21 External missiles, we considered tornado missiles
22 and the turbine missiles. As Mr. Schnell pointed out
23 yesterday, the plant is arranged in a peninsular fashion.
24 The expected high-energy missiles from a turbine failure
25 would not be perpendicular to the reactor building or the

1 rest of the plant.

2 Tornado missiles were analyzed in accordance with
3 the NRC regulatory guide. Essentially, we say that the
4 tornado missiles are external because the plant is designed
5 to exclude those missiles from entering the plant and coming
6 in contact with any safety-related equipment.

7 The next category of hazard was earthquake-induced
8 hazards. This was specifically addressed in Reg Guide 1.29;
9 specifically, position C.2. That position states,
10 essentially, that -- it lists categories of safety-related
11 equipment -- and essentially, it says that nonseismically
12 designed equipment which is not designed to function
13 following an earthquake should be restrained or should not
14 be allowed to affect the operation of the seismically
15 designed safety-related equipment that does have to function
16 following an earthquake.

17 This is a very great portion of the hazards
18 analysis that has been done on SNUPPS. Hazards from the
19 earthquake-induced failure include drop impact forces and
20 spray and flooding by an outside designed piping system.

21 I should point out that resolution on seismically
22 induced failures as well as the other hazards we have talked
23 about has been by prevention of the hazard occurring rather
24 than by analysis of the effects of the hazards.

25 In other words, if we have a nonseismically

1 designed line that passes through a space where
2 safety-related equipment is located, rather than analyze the
3 effects of that line breaking on safety-related equipment,
4 we have installed what we call two-over-one piping
5 restraints to prevent the line, the breakage of that line
6 from impacting safety-related equipment.

7 We have also done a very extensive fire hazards
8 analysis.

9 MR. LIPINSKI: Before you proceed, on the
10 earthquake-induced failures can you comment on your
11 cinderblock walls and if the hangers and the effect on
12 seismically qualified equipment?

13 MR. PASSWATER: Masonry walls at Callaway are all
14 seismically designed. We do not have any nonseismic in
15 safety-related areas, that is.

16 MR. LIPINSKI: So you did not have an interaction
17 in that area?

18 MR. PASSWATER: We did not have that interaction;
19 that is correct.

20 We have also done an extensive fire hazards
21 analysis, which is in the FSAR section 9.5 and the four
22 different appendices to that section. Essentially, what was
23 done there was we defined fire areas. They are all given a
24 number which shows that they are separate fire areas. Those
25 areas are separated by three-hour or greater barriers, again

1 talking about safety-related areas.

2 And the analysis that has been done on that is to
3 look at the equipment that is located in the spaces and the
4 effects of not only the fire but also the subsequent fire
5 suppression system actuation and the capability to safely
6 shut down the fire, given the fire and given the fire
7 area.

8 MR. RAY: I assume that these analyses for these
9 various hazards are based on installation as designed rather
10 than how they were installed, the various facilities of the
11 various systems. Do you anticipate or plan any walkthrough
12 audit of the plant at each stage of construction to make
13 sure that actual installation has not introduced some hazard
14 that you did not anticipate in your design?

15 MR. PASSWATER: That is a good point. I forgot to
16 bring it up. The actual hazards analysis was done using the
17 three-quarter-inch scale model of the SNUPPS plant which is
18 located in Bechtel's office in Gaithersburg, Maryland.

19 The model is somewhat unique from other models of
20 large powerplants in that it includes all sizes of lines;
21 for example, even down to instrument lines. There is very
22 little at Callaway that is field-run. Everything was
23 designed by Bechtel in Gaithersburg and is incorporated in
24 the model. The actual hazards analysis was done on the
25 model looking at, in plastic, what exists in the field at

1 Callaway.

2 As far as plans for a walkdown to verify what we
3 have done in the hazards analysis, as of right now I do not
4 believe there are any specific plans to do that kind of
5 walkdown. There are other design verifications that are
6 done in the field, such as walkdowns, but as far as I know,
7 none of those specifically address what was done in the
8 hazards analysis.

9 MR. ZUDANS: You said a three-quarter-inch model?

10 MR. PASSWATER: Three-quarter-inch equals one
11 foot.

12 MR. ZUDANS: And that is sitting at Bechtel?

13 MR. PASSWATER: It is in a room a little smaller
14 than this.

15 MR. ZUDANS: And you say all the piping is
16 represented?

17 MR. PASSWATER: That is right.

18 MR. ZUDANS: But nevertheless, you will have to
19 verify that your drawings represent the actual drawings as
20 built.

21 MR. SMITH: Joel Smith, Bechtel.

22 When we evaluated nonconformance such things as
23 large pipe, small pipe, we take that into consideration.
24 And we would not disposition one that would affect our
25 two-over-one analysis.

1 MR. CAPONE: Don Capone, Union Electric.

2 I would like to clarify this a little bit, the
3 two-over-one. Most of the activities on the quality control
4 program are under a Q program quality control check. Any
5 discrepancies from the drawings have to be dispositioned by
6 the designer.

7 Two-over-one piping systems that we talk about are
8 under a limited Q program, which involves checks by quality
9 control people to verify their installed as shown on the
10 drawing. If they are not, they have to be referred back to
11 the designer for disposition.

12 I do not know if that addresses your concern, but
13 it is under the quality control program. That is how we
14 verify that it is installed the way it is shown on the
15 drawing.

16 MR. ZUDANS: In other words, if they would find --

17 MR. CAPONE: There is no field engineering, I
18 guess is what I am saying, it is designed back in
19 Gaithersburg. If it is not installed that way, it is under
20 the quality assurance program, it will be a nonconformance,
21 it will have to go back to the designer to be
22 dispositioned. And that evaluation would be documented.

23 In other words, if it is not where it is shown on
24 the drawings, it has to be verified that it is acceptable to
25 be left there or it has to be moved back to where it was

1 originally shown.

2 MR. ZUDANS: Let us walk through an example.

3 Yesterday we saw a drawing with the piping run up there.

4 Now, he goes and takes a drawing and puts that pipe in

5 place. It is not likely that he would put it exactly within

6 an eighth of an inch of these things, is it?

7 MR. CAPONE: There are tolerances.

8 MR. ZUDANS: Does he look at that after he has

9 done it, look at the elbows and what not, and compares it

10 with the drawing?

11 MR. CAPONE: There are two things when you talk
12 about the drawing. Yes, if it is a safety-related system, a

13 two-over-one system that is under the quality control
14 program, then there would be a separate check after it is
15 installed to verify location.

16 In addition, there is a 79-14 walkdown of the
17 piping systems that is going to come later. That is an IE
18 Bulletin that requires a complete walkdown for location of
19 hanger snubbers as a final check.

20 Sp when we speak of piping, you might say there is
21 a double check on the cable tray and that it would be under
22 the quality assurance program. It would be checked out at
23 the final location. There is no final walkdown on cable
24 tray like there is in the piping system.

25 MR. ZUDANS: But it would not be then for

1 safety-related piping?

2 MR. CAPONE: If it was a two-over-one system, it
3 would be.

4 MR. ZUDANS: Could you explain the two-over-one?

5 MR. CAPONE: That means you have got a seismic
6 Category I system, but you have got a system that is not a
7 safety system, but it is hung over the top of that system
8 and you have to design systems to assure that that is not
9 going to fall down or in any way impact the safety system.

10 So our way around that was to design the supports
11 for those systems so that they would not fall down, rather
12 than to evaluate the hazard of it falling.

13 MR. ZUDANS: So what you are saying, your hazards
14 analysis would be based on actual installation for all
15 safety-related systems and two-over-one systems as defined
16 by you now?

17 MR. CAPONE: Yes.

18 MR. ZUDANS: You do not particularly worry about
19 deviations of a foot or inch in systems that do not have an
20 impact on anything that is safety-related?

21 MR. CAPONE: That is right. And there are some
22 tolerances in the specifications. There maybe tolerances up
23 to two inches; in other words, that pipe could be within two
24 inches or an inch and a half, depending on that system and
25 how critical it is. Those tolerances are looked at when

1 they do the analysis, that if that pipe happens to be an
2 inch and a half and is impacted.

3 MR. PASSWATER: I might point out also that the
4 way the analysis is done, if it is close, if it is possible
5 that the tolerance is going to put it close, it has been
6 restrained; that has been the philosophy.

7 MR. ZUDANS: Your piping system is designed and
8 analyzed before it is built. The analyst assumes that it
9 has certain space configurations. He determines where
10 supports go. Supposing you did not do what you are saying
11 you are doing now. You did not install it exactly; you
12 relocated the supports a little bit because of convenience.
13 All of the analysis -- it does not mean the piping system is
14 not good, but the analysis would not be of system as
15 built.

16 MR. PASSWATER: If it was not built as designed,
17 that would generate a nonconformance report from the field
18 which would go back to the designer for disposition. One
19 of his things that he does with NCRs is look at the effect
20 of that on hazards analysis, by the hazards analysis at
21 Bechtel.

22 MR. ZUDANS: Thank you.

23 MR. CAPONE: In addition, you have got the 79-14
24 walkdown, which is a requirement.

25 MR. ZUDANS: That is where that came from.

1 MR. CARBON: When you make the design change, do
2 you make the same change in this big mockup at
3 Gaithersburg?

4 MR. CAPONE: Yes, sir. There are two things that
5 happen. We talked about the standardized concept. If there
6 is a change that is made at Callaway, it is made at Wolf
7 Creek and it is made at the model.

8 MR. RAY: Are these nonconformance reports
9 required only for safety systems and two-over--one systems,
10 ore are they required also for nonsafety systems?

11 MR. CAPONE: For all systems.

12 MR. RAY: Do I understand clearly that you have no
13 site design of any of the systems?

14 MR. CAPONE: That is correct.

15 MR. PASSWATER: Inside the SNUPPS power block we
16 are talking about we do have a site AE.

17 MR. CAPONE: None of that work is done on site.
18 None of that design work is done on the site.

19 MR. RAY: So there are no field innovations then
20 that are likely to occur that will incur interactions that
21 were not anticipated in your hazards analyses?

22 MR. CAPONE: That is correct.

23 MR. RAY: How about the problem of an EMI
24 interaction, electromagnetic interaction induction, is this
25 given any specific consideration from interactions

1 anticipation, or do you rely on the original design to have
2 anticipated that and avoided it?

3 LR. GASDA: I believe what you are referring to is
4 interferences particularly with instrumentation systems?

5 MR. RAY: Yes. False signals developed because of
6 heavy current induction between wiring.

7 MR. GASDA: The way we have designed our cable
8 tray and conduit system is that we provide for spatial
9 separation between what we identify as instrumentation
10 cables, low-level signal cables, more than 4 to 20 milliamp
11 or thermocouple cables such that we maintain a spatial
12 separation between those cables and large power cables.

13 One of the things we do, to start out, we have 13
14 20-KV power cables on the top layers, 41 60-volt cables on
15 the next layers, 600-volt power control and then
16 instrumentation cable. So instrumentation cable is always
17 maintained separately from the cables which interfere.

18 MR. RAY: Now, once again the wiring systems,
19 power signals and so on, are subject to nonconformance
20 reports also. So if anyone should violate those standards,
21 you would know it.

22 MR. GASDA: That is right. We provide for
23 specific routing of cables through the tray system. That is
24 controlled by the quality control program and our quality
25 control program such that any deviation from that routing is

1 immediately brought back to us for our evaluation.

2 MR. RAY: And construction QC surveills this, I
3 presume?

4 MR. GASDA: Yes.

5 MR. RAY: Nonsafety as well as safety systems?

6 MR. GASDA: Yes.

7 MR. RAY: Thank you.

8 MR. CAPONE: Yes.

9 MR. ZUDANS: Could you tell us a little bit about
10 that computerized system that you have for cable tray
11 numbers and cable routing? It would appear that it would be
12 impossible to route it incorrectly from what we heard at the
13 plant.

14 MR. GASDA: A qualified "Yes." It is impossible
15 to route it incorrectly, although mistakes are made and this
16 is what the nonconformance program is designed to pick up.

17 MR. PASSWATER: I just wanted to finish up on
18 hazards analysis by saying that it is an interdisciplinary
19 review. There is a task force made up of the different
20 disciplines on the project. It is an ongoing review. It is
21 not a static thing that has been completed; it is ongoing.
22 It takes into account these kinds of changes we were just
23 talking about.

24 MR. LIPINSKI: On your assumptions you list
25 technical specifications. Licensee event reports are still

1 being written at the same rate with no change in violation
2 of the tech spec. It initiates the licensee event report.
3 Your conclusions are based on this assumption.

4 Would you change your conclusions if you did have
5 a violation of the tech spec on some portion of the system
6 that you are reviewing? How sensitive is your assumption or
7 your analysis to this initial assumption that you are
8 performing going to the tech spec?

9 MR. PASSWATER: It is not very sensitive at all to
10 that. If we are talking about a case where I have a
11 deviation from a technical specification that would generate
12 an LER, I would have to have, in order to be outside the
13 analysis that I have done, I would have to have this
14 particular hazard occur at the same instant I was outside
15 the technical specifications. So those two things would
16 have to be concurrent in order for me to be in the position
17 that was not analyzed by the hazards analysis.

18 MR. CARBON: Mr. Stright.

19 MR. STRIGHT: Just one further addition to what
20 Mr. Passwater said. I do not believe either of those
21 assumptions are particularly pertinent, because of the
22 conservative nature and the way that interactions are
23 corrected.

24 For example, the seismically induced failures, as
25 I said, if there is any remote chance that something could

1 fail or damage or break a safety system, rather than doing a
2 complicated analysis in order to determine whether this
3 really would fall over here, we fix it. Therefore, the
4 assumptions of the technical specifications and the loss of
5 off-site power are not really critical and limiting.

6 MR. ZUDANS: In other words, if you find a hazard
7 exists, you simply eliminate the source of it?

8 MR. STRIGHT: Yes, we fix it rather than analyze
9 our way out of it.

10 (Slide)

11 MR. PASSWATER: Three other specialized analyses
12 that we are doing -- I should say of the four I am talking
13 about, hazards analysis is certainly the biggest and the
14 most complex, the most man-hours spent and so forth, the one
15 we just talked about.

16 Control systems failures was specifically an NRC
17 question that came up during the FSAR review. In response
18 to that question we did an analysis documented in the FSAR.
19 The concern was do we have multiple control systems failures
20 that could occur from a single event that would put us
21 outside what we have analyzed for Chapter 15 of the FSAR?

22 So we looked at the control systems, loss of a
23 single instrument, break of a single instrument line, and
24 loss of a power supply where that power supply supplies
25 power to more than one system and more than one component

1 in the control room. It was done for the five major NSSS
2 control systems: reactor control, steam dump system,
3 pressurizer pressure control, level control, and feedwater
4 control. That analysis is, as I said, in the FSAR.

5 The conclusion of it was that any of those
6 occurrences on any of those systems were all bounded by what
7 we call Condition II events in the FSAR. Those events
8 specifically are loss of feedwater event or turbine trip
9 event.

10 (Slide)

11 Another analysis that was done, again in response
12 to an NRC question, is the environmental impacts and control
13 systems, on control systems. These were initially
14 identified by Westinghouse, I believe, in a report to the
15 Commission about certain conditions in a plant, such as the
16 small steam break or a moderate steam break which could
17 impact control systems that might interact or might affect
18 the operation of safety-related systems.

19 Two of those on the power-operated relief valves
20 on both the primary and the secondary side were not
21 applicable to SNUPPS because we have qualified those PORVs
22 to the environment that was discussed in that report by
23 Westinghouse.

24 Two others, the impact on rod control system by
25 break in the turbine building and the other one had to do

1 with the steam generator reference leg, had already been
2 answered in other questions to the NRC. We talked about
3 steam generator reference leg yesterday and the fact that
4 may be resolved very soon.

5 The turbine instrumentation was actually -- we
6 were looking at qualifying the instrumentation for that
7 particular one. So it will be in the same category as the
8 two PORV issues.

9 (Slide)

10 The final one I am going to talk about is the
11 heavy loads analysis. This was brought about by a generic
12 letter from the NRC staff to all the licensees to look at,
13 procedures and administrative controls on lifting the cranes
14 currently installed and temporarily installed in the plant,
15 to look at the possible effects of dropping loads.

16 We had a study underway. We have made a
17 preliminary response to the NRC back about six months ago.
18 The results of the completion of that study are expected to
19 be done sometime before the end of this year. And that will
20 be reported to the staff also.

21 Are there any questions?

22 MR. ZUDANS: Yes, I have a question. It relates
23 to other interactions not discussed by you. You have the
24 RHR system which is designed for lower pressure and reactor
25 coolant designed for higher pressure. The two systems are

1 separated by a couple of valves. What do you do with the
2 dead space between these valves? Do you monitor it?

3 MR. PASSWATER: Monitor it for?

4 MR. ZUDANS: Whatever. Whatever you do, I would
5 like to make sure that that interface between these two
6 systems is not violated.

7 MR. PASSWATER: John Prebula from Bechtel.

8 MR. PREBULA: We have a perfectly installed test
9 system that tests the leakage rates through each valve. And
10 periodically, we test the flow rate through the valves.
11 Downstream of the valve there is a relief valve which
12 relieves the pressure from the relief valve if there is
13 leakage past the second.

14 MR. ZUDANS: How can you test both of these
15 valves? You do not know where the leakage comes from.

16 MR. PREBULA: We test each valve individually with
17 this remote testing system. It is permanently piped up
18 through proper valve configurations. We measure the flow
19 from each valve individually.

20 MR. ZUDANS: Yes?

21 MR. PREBULA: We test that the valves are actually
22 closed during normal power operation as you are coming up in
23 pressure. And then we test the leakage rate from the
24 valves.

25 MR. ZUDANS: Okay, let us leave that.

1 There is another system I would like to hear
2 about. You have an instrument and a service air ^Xsystem.
3 Are these interconnected in any way?

4 MR. PASSWATER: This is Dennis Grove from Bechtel.

5 MR. GROVE: The air service is tied into the air
6 service system. There is an automatic isolation valve that
7 isolates the instrument air from loss of flow. They are
8 inter-tied.

9 MR. ZUDANS: What is used for separation of these
10 two systems? How easy is it to open one and get air from
11 the other?

12 MR. GROVE: I will have to get out the pipe
13 drawing and get back to you.

14 MR. ZUDANS: That is all right.

15 MR. LIPINSKI: Do your demineralizers use any
16 flushing operation to break up the resin beds with air and
17 water?

18 MR. SCHWOERER: Frank Schwoerer of the SNUPPS
19 staff. We have deep bed condensate demineralizers, and we
20 do have a resin regeneration cycle that we go through in
21 which we flush the resins out of the demineralizer vessels
22 and take them off to other vessels where they are treated.

23 MR. LIPINSKI: Are you using air-water combination
24 in these operations?

25 MR. SCHWOWERER: I do not believe we are using

1 air.

2 MR. LIPINSKI: Because one of the things that
3 happened at TMI, the early initiating part of that accident,
4 is that they drove the water into their service air system
5 and that was interconnected to the instrument air system,
6 and the water got into the instrument air.

7 MR. SCHWOERER: Three Mile Island has a different
8 type of demineralizer. It is a Powdex, P-o-w-d-e-x, type
9 demineralizer. We have a different type. It is a large
10 vessel containing resin beads, so-called deep-bed
11 demineralizer. And the method of regenerating these beads
12 is totally different than what was done at Three Mile
13 Island.

14 MR. CARBON: Any other questions?

15 MR. ARNOLD: I would like to ask a question. If
16 it takes a very involved answer, I will drop it. But when
17 you look at systems interaction, generally you are looking
18 at interactions between hardware or between a person and
19 hardware. Superimposed upon that is a person-to-person
20 interacting system.

21 Do you stop to look at that to see whether it or
22 not it is appropriate for handling the particular problem
23 and whether or not some other interaction of person to
24 person prior to -- well, in the design phase on, really,
25 might have reduced the probability of the particular

1 undesired action?

2 MR. PASSWATER: In the design stage, as mentioned,
3 the hazards analysis, for example, is an ongoing
4 interdisciplinary review. It is several people in the
5 hazards analysis task force at Bechtel that are looking at
6 not only their own systems but as a group looking at the
7 system and looking at potential hazards from the design
8 standpoint.

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 Looking at operation of the plant, the procedures
2 that we talked about earlier, both emergency operating and
3 normal operating procedures Mr. Schwoerer talked about, and
4 the training, the extensive training we give operators, to
5 point out that those potential pitfalls and unsatisfactory
6 interactions, the training does incorporate that. So the
7 operators from the time the plant loads fuel on, are aware
8 of that. They are retrained, and their memory is refreshed
9 on those areas.

10 MR. ARNOLD: My question was prompted by the fact
11 that earlier in the week in the Wall Street Journal there
12 was an advertisement of a well-known engineering firm -- the
13 name escapes me at the moment -- offering person-to-person
14 systems interaction analyses.

15 I thought there might be there some thought that
16 not the group that is concerned with the design and so on,
17 but the people who actually get involved in communicating
18 about the particular incident that happened or who had some
19 responsibility for communicating on the procedures relative
20 to the carrying out of the procedures rather than
21 necessarily the development of the procedures.

22 MR. PASSWATER: We talked yesterday about the
23 various review safety committees that exist to support the
24 operation of the plant. One of their functions is, for the
25 on site review committee and the NSRB, is just such a thing

1 -- reviewing abnormal occurrences, what went wrong. It is
2 also an interdisciplinary or interdepartmental-type review
3 process.

4 MR. ARNOLD: Thank you.

5 MR. RAY: John, is it possible that the Wall
6 Street Journal ad was an ad for marriage counseling?

7 (Laughter.)

8 MR. ARNOLD: Well, I wouldn't have noticed it if
9 it was.

10 MR. CARBON: With that let's take a short break.

11 (Brief recess.)

12 MR. CARBON: Let's reconvene.

13 MR. PASSWATER: The next presentation is on
14 hydrogen control, and this was called out in the agenda as
15 being something by the staff and the Applicant.

16 Dr. Carbon, I don't know how you want to handle
17 that. We have a presentation that we can give you now or
18 later.

19 MR. CARBON: Do you have many comments?

20 MR. EDISON: I have just a few.

21 MR. CARBON: Why don't you lead off?

22 MR. EDISON: Gordon Edison, NRC staff.

23 (Slide.)

24 I'm going to present the staff position on
25 hydrogen control for large dry containments and relate it to

1 the Callaway-1 review.

2 (Slide.)

3 First, I will talk about the staff position, and
4 second, I will present a few details about the Callaway
5 design and show how that relates to the staff position.

6 (Slide.)

7 The staff position on the review process at this
8 time is essentially the pre-TMI requirement; that is, 10 CFR
9 50.44 for core response for something like five percent
10 metal-water reaction or equivalent to approximately five
11 times the amount of hydrogen calculated in the ECCS
12 calculation.

13 That doesn't mean that the staff is ignoring the
14 effects of the Three Mile Island accident. I will get to
15 that point.

16 Let me mention the second bullet here; that is,
17 the staff position on Callaway and review of Callaway is
18 consistent with the full power licensing of North Anna-2,
19 Salem-2, Farley-2, and the TMI restart review. The staff
20 does have a proposed interim rule which is not now imposed
21 on large dry containment designs. That proposed interim
22 rule is continuing to be revised. It is in draft form, and
23 the staff is not now imposing that rule on large dry
24 containments.

25 The staff does have confidence that large dry

1 containments can withstand hydrogen generation in an
2 accident, so the staff is not overly concerned that we have
3 a problem here. We expect that the interim rule that is
4 prepared and developed for hydrogen control is not going to
5 be difficult for large dry containments to meet.

6 Are there questions in this area before I go to
7 the Callaway plant specific review?

8 (No response.)

9 (Slide.)

10 The Callaway plant, the containment has two and a
11 half million cubic feet of free volume. The staff has
12 looked at a TMI-2 type event which we estimate to have about
13 a 30 to 50 percent metal-water reaction, and calculated that
14 that gives about a 6 to 10 percent hydrogen uniformly mixed
15 concentration in the containment, which is well below the
16 detonation limit.

17 The design pressure of that containment is 60 psi,
18 and failure pressure is twice the design pressure. It could
19 be larger than 120 psi. It probably would be smaller than
20 three times the failure pressure.

21 The staff feels the design can accommodate
22 pressure from hydrogen combustion. We have an experimental
23 data point at TMI where there was a large dry containment.
24 The pressure didn't approach the 120 psi or anything like it.

25 In addition, the staff has laid on a whole bevy of

1 post-TMI requirements, so we feel that type of accident is
2 considerably less likely to occur in the future than it was
3 in the past.

4 You gentlemen are aware of NUREG-0737 requirements
5 the staff is laying on new applicants at this time to
6 examine their auxiliary feedwater systems and improve the
7 reliability of those. We've made operator training
8 improvements in programs to, require things like safety valve
9 and PORV valve qualification and training, and many more.

10 So what we think we have here is an accident that
11 is less likely than before. The large dry containment has a
12 large amount of volume to contain hydrogen should it be
13 generated, and we don't think there will be a problem
14 there. This is an unresolved safety issue within the
15 Commission. The large dry containments I think have less of
16 a problem.

17 MR. LIPINSKI: On your 6 to 10 percent hydrogen
18 you're assuming perfect mixing is in that volume.

19 MR. EDISON: That is correct.

20 MR. LIPINSKI: You've discounted the possibility
21 that there's going to be stratification, and the hydrogen
22 will rise and collect in the top of the containment?

23 MR. EDISON: No, the staff has not overlooked that
24 possibility. You have to look at pocketing. Of course, if
25 you have pocketing you will have smaller -- possibly a

1 smaller local combustion.

2 The staff is reviewing this. However, the staff
3 does feel that the containment is large enough, has enough
4 volume that it can withstand this. We can't get too much
5 into the technical concerns about bringing in some of our
6 reviewers, and we will have those people available at the
7 full committee meeting next week.

8 But some of the scenario kinds of things that go
9 on here are that if you do have a metal-water reaction,
10 you're also going to have steam generated in the containment
11 to help dilute the hydrogen and keep it down below the
12 detonation limit.

13 At a later point in time after say a LOCA type of
14 accident, the steam will be condensing and leave you more
15 pressure capability for the containment to accommodate a
16 large amount of hydrogen.

17 MR. LIPINSKI: But if you go back to the TMI-type
18 of accident where the vents are now being provided on the
19 primary system to get the gas out, their venting was to
20 shoot directly upward to the top of the containment so it
21 would give it a velocity stream upwards, and no provision to
22 direct the hydrogen to the collectors that will remove it
23 from the containment.

24 The natural path is to rise and possibly pocket in
25 the very top. The ventilation system simply stops at the

1 crane rail level, and there's nothing in the very top of the
2 containment.

3 MR. ZUDANS: There is something I forgot to ask.
4 I saw an outlet right at the top of the roof. What is that
5 in your containment? Is it inlet or outlet ventilation?
6 Right on the top of the dome.

7 MR. CAPONE: Are you speaking of the duct that
8 comes down?

9 MR. ZUDANS: From the very top of the dome.

10 MR. LIPINSKI: It looked like a cage.

11 MR. CAPONE: I think that is temporary.

12 MR. PREBULA: That is the plant unit vent. That
13 is an elevated release point for the buildings. It is not
14 associated with the containment structure itself. It
15 originates in the auxiliary and fuel buildings.

16 MR. ZUDANS: It's not the vent outlet for the
17 containment?

18 MR. PREBULA: Yes, it is, but the containment
19 purge systems enter that system and then get exhausted up
20 the side of the containment and out.

21 MR. ZUDANS: Okay. But that is one of the purge
22 points. It would be the inlet for your purge system and go
23 out some place through the wall.

24 MR. PREBULA: No. That is -- that's not the inlet
25 to the purge system. It is the discharge from the plant.

1 The purge system takes suction from the auxiliary building
2 roof.

3 MR. LIPINSKI: Is there a hole in the very top of
4 the containment?

5 MR. PREBULA: No, sir, there is not.

6 MR. SCHNELL: Don Schnell, Union Electric.

7 Don, I think he probably saw what was an opening,
8 an access opening intended for construction.

9 MR. ZUDANS: No. It's a big duct.

10 MR. SCHNELL: The duct you saw on the outside of
11 containment --

12 MR. ZUDANS: Inside.

13 MR. LIPINSKI: It's a cage that rises from the
14 crane rail level. It follows the contour of the containment
15 right to the center of the top of the containment. It looks
16 like a cage-mounted duct.

17 MR. SCHNELL: Oh, I know what you're talking about
18 now. There is what we call a maintenance truss that takes
19 that configuration. The access is from the crane
20 elevation. And the idea of that is to service the fixtures
21 that are in the interior of the dome.

22 MR. LIPINSKI: It has nothing to do with
23 ventilation.

24 MR. SCHNELL: No.

25 MR. CARBON: Other questions?

1 MR. ZUDANS: Yes. I have one question. The
2 proposed rule that's being revised, what level of
3 water-metal reaction is in that one?

4 MR. EDISON: It's changing weekly.

5 MR. ZUDANS: Moving target.

6 MR. EDISON: The numbers have been bouncing
7 around. I don't think really the technical people who are
8 going to set some number have the large dry containments in
9 mind. I think they're more concerned about small
10 containment designs.

11 This isn't to say that the staff wouldn't impose
12 the interim rule also on large dry designs. It's just that
13 at this time the staff feels the large dry containment
14 designs are much more likely to be able to deal with the
15 interim rule without fixes. So we have a fairly high
16 confidence that the large dry containment designs will not
17 have a problem even with the proposed interim rule, however
18 it develops.

19 MR. ZUDANS: Well, of course I agree with you.
20 The only problem that bugs me is this. If you set the
21 source of the hydrogen for one plant at one level and for a
22 different type plant at a different level, it doesn't quite
23 make sense to me unless there are some specific features in
24 the plant that really --

25 MR. EDISON: I'm not saying the rule will be

1 different for different designs.

2 MR. ZUDANS: I know some plants are required to
3 take care of one hundred percent of metal-water reaction.
4 They have to do two design systems to cope with that. This
5 is 30-50. I've heard 75 percent. So it's really a moving
6 target.

7 MR. EDISON: That's right. This is -- this 30 to
8 50 is not a staff position. The staff simply looked at what
9 happened at Three Mile Island and said what would happen at
10 Callaway.

11 MR. ZUDANS: But you do accept this for the
12 Callaway design.

13 MR. EDISON: No. The 30 to 50 is not a design
14 requirement for Callaway. Five percent, as I showed on my
15 first slide, 50.44 is the requirement.

16 MR. CARBON: We can move on now.

17 MR. PASSWATER: Jim Cermak will --

18 MR. EDISON: There was one more thing in my
19 presentation that I have to show you. This is a prepared
20 staff statement from the review branch on hydrogen control.

21 (Slide.)

22 I will read it for those in the back who can't see
23 it up here. It's in the handout. It says, "Pending the
24 rulemakings called for in item II.B.8 of the TMI Action
25 Plan, NUREG-0660, the staff is not now imposing any new

1 requirements beyond 10 CFR 50.44 for hydrogen control in
2 large dry containments. The staff completed its reviews for
3 the full power licensing of North Anna-2, Salem-2, Farley-2,
4 and TMI-1 restart without imposing any new requirement for
5 hydrogen control. This decision was based on the staff's
6 view that large dry containments had sufficient capability
7 to accommodate hydrogen combustion so that no new
8 requirements needed to be imposed pending the rulemaking
9 proceeding on degraded core cooling. In the proposed rule
10 portion of the interim rule, which is documented in
11 SECY-81.245A, the staff proposes to require that certain
12 specific analyses be performed for all large dry
13 containments to assure that containment integrity and safe
14 shutdown will not be jeopardized by hydrogen released from
15 the postulated degraded core accidents."

16 MR. CARBON: I would like to go back to Dr.
17 Zudans' question. You are imposing different requirements
18 on different plants in terms of the amount of hydrogen being
19 released, are you not?

20 MR. EDISON: Do you want to talk about large dry
21 containments?

22 MR. CARBON: I'm just saying across the board
23 irrespective of containment, you're saying in some plants
24 you assume so much hydrogen and other plants you assume some
25 different amount.

1 MR. EDISON: No, I'm not saying that, and I'm not
2 sure I could tell you what is happening on large dry
3 containment designs. I am prepared here today to deal with
4 the agenda questions on large dry containment.

5 MR. CARBON: Would you be prepared to answer that
6 question next week, tell us how this varies from one to
7 another?

8 MR. EDISON: Certainly.

9 MR. LIPINSKI: Going back to your assumption of
10 perfect mixing, the one data point that's available is TMI-2
11 where hydrogen was vented within the containment and there
12 was a burn.

13 Has a conclusion been drawn based on some of the
14 investigations as to where that hydrogen may have been
15 pocketed?

16 MR. EDISON: I've heard different opinions
17 expressed. I don't think a conclusion has been drawn and
18 probably won't be drawn until people go inside the
19 containment and look.

20 The number that I remember from the pressure
21 generation is a peak of something like 28 or 29 psi, which
22 is well below the failure pressure here -- anywhere from 120
23 to 180. But as to where it happened or where exactly it
24 occurred, I don't know.

25 MR. LIPINSKI: But I think it relates to this

1 assumption of perfect mixing.

2 MR. EDISON: Yes. There are a lot of technical
3 parameter considerations in trying to come up with the
4 proposed rule, obviously, and there's a lot of manpower and
5 thinking going into it.

6 MR. ZUDANS: There are lots of experiments being
7 done right now.

8 MR. EDISON: It's not something that -- we could
9 spend hours developing that question here if we wanted to.
10 I don't think we want to do that. But we will have the
11 staff, who can talk to the position on other containments,
12 with us at the full committee meeting next week at your
13 request.

14 MR. CARBON: Let's move on then.

15 MR. EDISON: That completes the staff's
16 presentation.

17 (Slide.)

18 MR. CERMAK: Jim Cermak, SNUPPS staff.

19 Let me briefly describe the hydrogen control
20 system that we have on the plant and the assumptions that
21 went into the design basis for the plant, and then I will
22 move on to other scenarios.

23 The hydrogen control system consists of redundant
24 hydrogen recombiners, a redundant hydrogen mixing system,
25 redundant hydrogen monitoring system which uses

1 thermoclimativity to analyze hydrogen concentration, and it
2 has a backup hydrogen purge subsystem.

3 MR. MARK: The particular hydrogen monitoring
4 system, how long does it take to get a reading from it and
5 with roughly what accuracy does it perform?

6 MR. GROVE: Dennis Grove, Bechtel.

7 The hydrogen monitor we have has the capability to
8 be put in the standby mode when the heat tracer is on and
9 the generator within the cabinet itself stays hot. The time
10 it would take to get a measurement would just be the sample
11 transport time from the time you open the isolation valve
12 and pump the sample to the analyzer. I don't have that
13 right now. I can get that for you.

14 MR. MARK: It's not important, but within a
15 percent or something?

16 MR. GROVE: It will be something like that.

17 MR. CEIMAK: The sources of hydrogen used in the
18 design basis analysis consisted of a five percent
19 zirconium-water reaction post-LOCA. This, I should point
20 out, was about 50 times the calculated core-metal reaction
21 for the worst case loss of coolant accident.

22 (Slide.)

23 The post-LOCA radiolytic decomposition of water
24 and the post-LOCA corrosion of metals and paints.

25 (Slide.)

1 This was all combined together as a function of
2 time during the accident to look at the hydrogen
3 concentration in the containment as a function of time after
4 the loss of coolant accident.

5 In this particular curve it assumed that the
6 hydrogen recombiners came into operation one day after the
7 loss of coolant accident. As you can see, the hydrogen
8 volume concentration never exceeded two percent. Then it
9 came down as a function of time after the accident as a
10 function of the hydrogen recombiners.

11 MR. LIPINSKI: This is under a perfect mixing
12 assumption?

13 MR. CERMAK: This is under a perfect mixing
14 assumption, that's correct.

15 (Slide.)

16 But these are just hydrogen recombiners. We are
17 well below the flammability limit for hydrogen even in an
18 atmosphere without steam at all, because the flammability is
19 about four percent.

20 MR. LIPINSKI: Your two percent is based on your
21 total volume of containment, but if I restrict that hydrogen
22 into a smaller volume, the concentration goes up.

23 MR. CERMAK: Yes, it is spread out over all the
24 containment, but there are studies that show -- for example,
25 Bechtel-Frankfurt -- that show that you get very good

1 mixing. And let me hit mixing right now since it seems to
2 be your interest.

3 When you have a loss of coolant accident you have
4 a release of steam-water mixture, and you have a lot of
5 steam in the containment. And when you -- first of all, you
6 create a lot of turbulence. Second, when the sprays come
7 on, the process of condensing steam with the sprays causes a
8 very turbulent effect and high mixing, and you also have
9 your fan coolers that will also permit mixing. This is in
10 addition to the hydrogen mixing system.

11 Now, what I am about to get into is the burning of
12 all the hydrogen released under certain hypothetical
13 assumptions that were in the proposed rule that the staff
14 has proposed. The 75 percent is the proposed metal-water
15 reaction that I've read inferring all that and what results
16 you get from that.

17 If you don't have complete mixing, there's another
18 part of that. Then you only burn this part, and you will
19 have parts of the hydrogen that won't completely burn, and
20 the result will be less of a peak pressure.

21 MR. LIPINSKI: You've eliminated the TMI accident
22 type of scenario from your discussion because the high point
23 vents are being installed on the primary system now to
24 relieve the hydrogen if you should have a contained
25 metal-water reaction within the vessel. So you don't have

1 steam released necessarily if the hydrogen is at the high
2 point.

3 MR. CERMAK: We looked at the location of the
4 vents coming out of the top of the vessel, and they are into
5 a very open area in the containment where you would get what
6 we feel is very good mixing. We have fans that will give
7 you this mixing. In addition, there is no equipment up in
8 that area.

9 MR. LIPINSKI: NASA has had some experience where
10 hydrogen has accumulated in the top of their buildings, and
11 they have blown the roofs off. It was not perfect mixing.

12 MR. CERMAK: What was the mechanism that they blew
13 the roof off?

14 MR. LIPINSKI: Evidently the equipment had been
15 turned off over the weekend. The hydrogen stratified in
16 the top of the building, and somebody energized the
17 equipment on Monday, and the roof went off.

18 MR. CERMAK: Well, if I went along with that
19 scenario and put all this hydrogen in the top of the
20 containment, there isn't any equipment up in the top of the
21 containment to ignite the hydrogen.

22 MR. LIPINSKI: It depends on where the level comes
23 down to. Your crane rails are halfway up.

24 MR. CERMAK: But we're talking -- first of all,
25 let me get back to the fact that we would expect .1 percent

1 metal-water reaction, and we keep escalating this upward on
2 hypothetical scenarios. Then you have to go and look at the
3 flammability limit and the detonability limit.

4 The detonability limit for hydrogen and air
5 without any steam is generally considered to be around 19
6 percent. You have to have a 19 percent concentration. In
7 order to have a 19 percent concentration over the whole dome
8 of the containment, that's quite a bit of metal-water
9 reaction as we will see here in the next slides. So I think
10 it's very probable you get to detonability limits, and then
11 you have to have something to ignite the whole thing.

12 MR. LIPINSKI: You have lighting systems at the
13 top of the containment. You've got to guarantee that all
14 your electrical systems are intact and there's no arcing or
15 sparking because of a loose connection somewhere.

16 MR. CERMAK: Well, my basic hypothesis -- I was
17 trying to go along that scenario to answer your question.
18 My basic hypothesis is you get pretty good mixing because of
19 the fan coolers and also the hydrogen mixing.

20 MR. LIPINSKI: Those fan coolers aren't directed
21 to the top of the containment.

22 MR. PREBULA: John Prebula, Bechtel.

23 The containment air coolers draw air from
24 elevation 2,068 and discharge to lower areas of the
25 containment.

1 MR. LIPINSKI: Where is that relative to the crane
2 rail?

3 MR. PREBULA: The crane rail is at approximately
4 2,120. The hydrogen mixing fans are located at elevation
5 2,047. There are four of them in operation during normal
6 operation. These same fans are Class 1A, and they operate
7 post-accident. They blow air into the containment dome, so
8 that by a replacement mechanism for blowing air out and
9 allowing it to come down the outside shell of the
10 containment to get the proper mixing in the dome. If you
11 actuate the containment sprays you have additional mixing.

12 MR. CERMAK: The last part I wanted to address is
13 if I put the hypothetical case for large amounts of hydrogen
14 in the large dry containment --

15 (Slide.)

16 If I took the 75 percent metal-water reaction that
17 was proposed in the rule I saw about a year ago, in a
18 proposed rule, the results showed 12.5 percent hydrogen by
19 volume in the containment. If I took a constant volume and
20 adiabatic burn of this hydrogen, I would have a pressure
21 increase of 60 PSI. If I did this in a completely dry
22 containment without any steam, that would just equal my
23 design pressure of my containment which is 75 psia. So that
24 for the 75 percent metal-water reaction I am equal to the
25 containment design pressure.

1 If I went and superimposed a loss of coolant
2 accident on this particular 75 percent metal-water reaction
3 case --

4 (Slide.)

5 I am assuming now, and this is very conservative
6 because I'm really below the flammability limit when I do
7 this, I am assuming that the hydrogen burn occurs at the
8 time of the peak containment pressure from the LOCA, which
9 is 47.3 psig at 134 seconds. There is enough steam here
10 that I will not get flammability of the hydrogen. But I
11 made this assumption just to show some degree of
12 conservatism. I then burn the hydrogen and add it to my
13 LOCA peak and I am at 125 psia.

14 The ultimate static pressure failure for the
15 containment has been estimated to be 175 psia. This follows
16 roughly, and Bechtel's engineering judgment supports this;
17 but if you just take the two and a half multiplier times the
18 design of the containment, which is one 75 psia, you get 187
19 psia, and 175 is lower than the 187.

20 Actual analyses have shown to date that pressures
21 above 150 psia, and it can actually be supported today, but
22 the estimate is if the detailed analysis were done, 175 psia
23 could be supported.

24 MR. ZUDANS: What --

25 MR. CERMAK: This is about 50 psi below the 125

1 psia -- sorry -- is about 50 below.

2 MR. ZUDANS: What is the failure mode associated
3 with 175 psia?

4 MR. CERMAK: We have Ken Lee of Bechtel here to
5 address the failure mode.

6 MR. LEE: Kenneth Lee from Bechtel.

7 The failure mode is in the cylinder of the
8 containment slightly below the transition where the dome
9 meets the cylinder.

10 MR. ZUDANS: What is the failure mode?

11 MR. LEE: That's by the rebar reinforcement
12 yielding.

13 MR. ZUDANS: What about your equipment access
14 hatch and other accesses? Are they able to take all of
15 those pressures as well?

16 MR. LEE: We have not looked at the penetrations
17 and the personnel lock and equipment hatch at this time.
18 But based on the past few projects that we've looked at, the
19 penetrations do have the capacity higher than the
20 containment shell.

21 MR. ZUDANS: Of course, your concrete at that
22 stage would be cracking, but you assume that the liner won't.

23 MR. LEE: That's correct. The liner will be
24 well below the strain where it would rupture, well below.

25 MR. CARBON: John.

1 MR. ARNOLD: I'm not familiar with the engineering
2 of a containment, but in a steel pressure vessel there is an
3 operating pressure, the pressure at which the vessel is
4 intended to operate, and then above that there is generally
5 a design pressure that allows for the operation of the
6 relief valve safely above the operating pressure.

7 What pressure is -- when you call it a design
8 pressure, what is that? .

9 MR. LEF: The design pressure is the pressure that
10 we will exceed to calculate above the maximum pressure
11 inside containment. It's the margin we put in exceeding the
12 design pressure.

13 As Jim mentioned before, we had 47 PSI to
14 calculate a maximum pressure inside containment, and the
15 design pressure for containment is 60 PSI. Then we have an
16 additional factor of 1.2 to assure that we have a margin on
17 top of the design pressure of 60. That is how Jim arrived
18 at the 75 psig.

19

20

21

22

23

24

25

1 MR. ARNOLD: Okay.

2 MR. LEE: That pressure assumes that you have the
3 low loading combinations of earthquake pressure, jet
4 impingement. That is why we have substantial margin beyond
5 that design pressure.

6 MR. MARK: Is it that the design pressure is
7 approximately at the top of the elastic limit of the
8 members?

9 MR. LEE: At the specified yield strength of the
10 reinforcement, so you have substantial margin beyond the
11 point where the reinforcement will yield.

12 MR. ARNOLD: When you take all of that into
13 consideration, what does that mean with respect to the 175
14 that you had talked about?

15 MR. LEE: We have not yet made that
16 determination. The calculation that we have made is
17 strictly based on the elastic behavior of the containment.
18 That is why we carry it to the elastic yield limit of the
19 reinforcement. Now, beyond that, the calculations will
20 require a linear analysis, and that is the extra margin that
21 we have not yet identified.

22 MR. CERMACK: And just to clarify, that is the
23 difference between the 150 that you are now at and the
24 estimated number from the engineering judgment of 175; is
25 that correct?

1 MR. ZUDANS: Just one more question, since we
2 have a structural person here. Looking at the plant, I
3 could not figure out how your tendons go through the
4 hemispherical part of the head. Do they wrap around and go
5 down to the gallery?

6 MR. LEE: That is correct.

7 MR. ZUDANS: Okay. Thank you.

8 MR. CARBON: Are there questions?

9 (No response.)

10 MR. CERMACK: Go ahead.

11 MR. PASSWATER: I have an answer to one of the
12 questions we did not have an answer to before. The accuracy
13 of the hydrogen monitoring system is .5 percent.

14 MR. ZUDANS: What is the time delay between
15 sampling and getting to the number? A couple of seconds?
16 You have to pump it through the line.

MR. PASSWATER: It is a very short time. We did
18 not look up the actual figure. It is just a transport time
19 from the atmosphere into the monitor. He is looking for it
20 right now.

21 The next topic we wanted to present is the
22 capability and reliability of the decay heat removal
23 systems. Hank Schwowerer, who is the technical director for
24 SNUPPS, will speak on that topic.

25 MR. SCHWOERER: I will just put this up here.

1 (Slide)

2 As of PSAR stage the design basis for safe
3 shutdown of UPPS plant was extended, hot standby.
4 Using hot standby in the term in which it is defined in the
5 technical specification, that is you are subcritical but you
6 are at or close to operating temperature.

7 Prior to Three Mile Island we on our own
8 initiative began to reexamine that design basis. We decided
9 to change that design basis to one of having the capability
10 in the plant to go to cold shutdown with safety-related
11 systems. We really did it for two reasons. One was that we
12 anticipated that cold shutdown was going to be a requirement
13 at the operating license stage. And also we felt that this
14 would enhance the safety of the plant.

15 The functions that are necessary to go to cold
16 shutdown are listed here in summary fashion. I would just
17 like to tell you rather quickly how these functions are
18 performed with safety-related systems. Heat removal at hot
19 standby is accomplished by natural circulation. When we
20 talk about cold shutdown with safety-related systems, we are
21 also assuming we have a loss of off-site power.

22 Heat removal at hot standby then is accomplished
23 by natural circulation within the reactor coolant system of
24 feedwater being supplied to the auxiliary generator by the
25 steam supply system, steam being relieved from the steam

1 generators by the atmospheric relief valves, which in SNUPPS
2 are Class IE fully qualified valves.

3 The reactor coolant pump seals under this mode of
4 operation would be cooled by pump cooling water system. And
5 we have made some modifications to the component cooling
6 water system to increase its reliability. Specifically, the
7 pump cooling water system isolates on one of the containment
8 isolation signals.

9 And we have added some redundant valves in
10 parallel to the existing isolation valves, so that if we
11 were to get an inadvertent isolation of the component
12 cooling water system, we are sure that we can reopen the
13 component cooling water paths.

14 The next thing you have to do is borate the
15 reactor coolant system. If you are at hot standby, you have
16 to do this within about 24 hours. The way we would do this
17 using safety-related equipment is we would utilize the
18 charging pumps which are capable of pumping against the
19 reactor design pressure. If the boric acid tanks and boric
20 acid transfer pumps were available, we would use that as a
21 source of boration.

22 As you saw yesterday, though, those tanks and
23 pumps are in the basement of the auxiliary building. They
24 could conceivably be flooded by an earthquake event that
25 might rupture fire protection piping, or they could

1 conceivably be damaged by some nonseismic component that
2 could fall down on them.

3 So after examining what we might have to do to
4 backfit those tanks and pumps to be fully safety-grade, we
5 decided instead that what we would do would be to use the
6 refueling water storage tank as a source of boration. This
7 means now that if we are going to borate with the refueling
8 water storage tank, which has water at about 1000 ppm, that
9 we have got to have a capability to let down water so that
10 we can inject into the reactor coolant system this 2000 ppm
11 water from the refueling storage tank.

12 One of the things then that we have added as part
13 of the cold shutdown package is a fully safety-related
14 letdown system. We take off from the excess letdown line.
15 That is part of the standard Westinghouse system. We have
16 added some safety-related valves that allow us to drain to
17 the pressurizer relief tank in the containment.

18 Now, this tank has limited capacity for water and
19 we do not want to rupture the tank. So we have also added
20 some safety-related valves which allow us to drain down from
21 the pressurizer relief tank to the containment itself. So
22 ultimately, the scheme here is that for boration we would
23 plan to inject water from the refueling water storage tank
24 using the storage tank, letting water down to the
25 containment floor.

1 The next step is the cooldown of the reactor
2 coolant system to -- we want to get it down to about 400
3 degrees, 350-400 degrees, where we can start operating the
4 RHR system. The method of cooldown is exactly the same
5 method we have used for heat removal at hot standby. We can
6 control the pressurizer -- we can control the atmospheric
7 relief valves on the steam generators to cooldown secondary
8 side and also to cool down the primary side.

9 Depressurization of the reactor coolant system is
10 the next thing that we have to do. In the procedure that we
11 contemplate here we would want to retain water level in the
12 pressurizer. If we are retaining water level in the
13 pressurizer, we may have hot water retained in the
14 pressurizer, which would tend to hold the pressure up.

15 We looked at various ways of doing this and
16 finally decided that we would do is change out the
17 power-operated pressure relief valves, which in the standard
18 design were not fully safety-related and not fully
19 qualified.

20 In the SNUPPS design we have replaced those valves
21 with new valves, electrically operated, that is DC solenoid
22 operated, Class 1E power, fully qualified valves.

23 Finally, this gets us down to the temperature and
24 pressure at which we can put in the RHR system.

25 There are two other points here to mention. One

1 concern is if you are going into RHR operation with only
2 safety-related equipment, that you might discharge water
3 from the accumulators, the large safety accumulators, and
4 vent nitrogen into the reactor coolant system. We do not
5 think this would be a problem, but in order to preclude this
6 problem, we have provided safety-related redundant valves
7 that would allow us to vent nitrogen from these accumulators
8 and prevent the injection of the water in these
9 accumulators.

10 The other potential concern here is that in order
11 to get the RHR system into operation, there are two valves in
12 series. We have two trains. Each train has two valves in
13 series. The arrangement of the power to those valves is
14 such that we have one train of power powering one valve in
15 each RHR system. This is done to be sure that you always
16 close those valves.

17 In this kind of an operation, if we postulate that
18 in addition to all the other things that have happened, we
19 should lose one train of power, we would not have the
20 capability to open those valves to the RHR system. The plan
21 for that remote possibility is we would be able to jump our
22 power from one of the electrical penetration rooms around to
23 the other electrical penetration room so that we could be
24 sure that we could open at least one train of our RHR and
25 continue the cooldown process.

1 Okay. All of these changes, all of these features
2 are described in the FSAR. We can perform all of the
3 actions that I have described from the control room.

4 I would just like to go on and say a little bit
5 more. We feel that in addition to coming close to meeting
6 the requirements of Regulatory Guide 1.139, which was the
7 one that we anticipated as possibly being a requirement for
8 SNUPPS, we feel this gives us considerable diversity and
9 ability to cope with events beyond design basis events.

10 One of these, just for example, is the case that
11 has been analyzed by the Westinghouse owners group, which is
12 the loss of all feedwater followed by a loss of all
13 auxiliary feedwater. So it is postulated that you have
14 totally lost the capability to supply feedwater to the steam
15 generators.

16 This particular scenario has been evaluated by the
17 Westinghouse owners group for a four-loop reactor such as
18 the SNUPPS reactor. It has been determined that for the
19 first 20 minutes nothing particular happens. You boil away
20 water from the steam generators and then at the time that
21 you start to approach dryout of the steam generators, one
22 would then -- there is a standard operating procedure that
23 has been developed that says as you start to approach dryout
24 of the steam generators you initiate feed-and-bleed cooling
25 approach whereby you use the charging pumps to inject water

1 into the reactor coolant system, you use the pressurizer
2 PORVs to let down fluid from the pressurizer.

3 And for this mode of operation it is possible to
4 keep the core covered and avoid any core damage. We feel
5 that with the safety-related PORVs we have real capability
6 to do this under almost any situation.

7 MR. ZUDANS: Are your PORVs big enough to remove
8 all the residual heat?

9 MR. SCHWOERER: Yes, they are.

10 MR. ZUDANS: How many do you have?

11 MR. SCHWOERER: We have two.

12 MR. ZUDANS: Where does the discharge go?

13 MR. SCHWOERER: The discharge also goes to the
14 pressurizer relief tank. Once again, the pressurizer relief
15 tank is not large enough to contain all the steam, so what
16 would happen in all this mode is we would be transferring
17 water from the reactor coolant system to the containment.

18 MR. ZUDANS: Right.

19 MR. SCHWOERER: Now, one of the things I failed to
20 mention is in the -- well, okay.

21 MR. ZUDANS: But how long could you do that? You
22 cannot keep on transferring to the containment. What about
23 the feed capacity?

24 MR. SCHWOERER: Well, we have enough -- as part of
25 these modifications that we made, we made certain that we

1 did not have any safety-related equipment in the containment
2 below a certain level. I am not sure just offhand what the
3 number is. Is it 600,000 gallons of water?

4 MR. STRIGHT: Yes.

5 MR. SCHWOERER: We are capable of taking 6000
6 gallons of water into the containment without flooding any
7 safety-related equipment. The capacity of the reactor
8 coolant system is approximately 100,000 gallons.

9 MR. ZUDANS: But to feed that many gallons, where
10 do you get the water from?

11 MR. SCHWOERER: The refueling water storage tank.

12 MR. ZUDANS: How big is that?

13 MR. SCHWOERER: Well, I am not just sure.

14 MR. PREBULA: The short capacity is 379,000
15 gallons.

16 MR. ZUDANS: So you already use some of it for
17 your boration.

18 MR. SCHWOERER: I think you get into -- I give you
19 the same numbers that Steve Miltenberger showed yesterday,
20 because again now we are coping with decay heat. His
21 numbers showed that we have many, many hours to -- we could
22 carry this one for many, many hours.

23 We are talking about a very hypothetical
24 situation. You know, we are talking about a case where we
25 have lost off-site power, we have lost all of our feedwater

1 and our auxiliary feedwater. We have gone pretty far down a
2 road that is very improbable. I just cite this to give you
3 an example of some of the diversity that exists in the
4 design.

5 MR. ZUDANS: So you have several hours to recover
6 your off-site power.

7 MR. SCHWOERER: Many hours, yes.

8 MR. ZUDANS: Your diesels are running, though.

9 MR. SCHWOERER: We assume our diesels are running,
10 yes.

11 MR. CARBON: I was mixed up on that. When you
12 talked about item number 1, I thought you were talking about
13 natural circulation. I lost out on what happened.

14 MR. SCHWOERER: Yes, sir, I am. The reactor
15 coolant pumps are not powered by the diesels. Reactor
16 coolant pumps are powered by off-site.

17 MR. ZUDANS: They are much too big, and you do not
18 have extra spray for the pressurizer either.

19 MR. SCHWOERER: Well, in this thing we are looking
20 at, fully safety-related systems, one of the difficulties is
21 the chemical volume control system, which would normally be
22 supplying water to the reactor coolant system, this has many
23 air-operated valves that is supplied by the instrument air
24 system, which is not a fully safety-related system.

25 So we assume that all the air-operated valves

1 failed and the valves failed in open or closed conditions
2 depending upon the particular design. But we do not have
3 auxiliary spray available to the pressurizer, because that
4 is supplied by this containment supply system through a
5 valve that would fail closed.

6 MR. ZUDANS: Now, are there any of the valves in
7 any of the safety-related systems, such as the feedwater
8 system or RHR or any other one that is controlled by
9 instrument air as a driving power to open or close the
10 valves in any of the safety-related systems? Are there any
11 valves whose operation depends on instrument air?

12 MR. SCHWOERER: No.

13 MR. ZUDANS: That is why you kicked out the
14 chemical control?

15 MR. SCHWOERER: That's right.

16 MR. ZUDANS: The cooldown on item 3, cooldown of
17 the RCS, you do that by controlling the PORVs on the
18 pressurizer; right?

19 MR. SCHWOERER: No. You do that by controlling
20 the PORVs on the steam generator, what we call the
21 atmospheric relief valves.

22 MR. ZUDANS: I am sorry, I really wanted to talk
23 about item 4. This is where you replace your regular PORVs
24 with Class 1E PORVs and those you can open and close and
25 they will survive any environment; is that right?

1 MR. SCHWOERER: Yes.

2 MR. ZUDANS: Is that conclusion based on some test
3 valves, or are these valves to be designed yet?

4 MR. SCHWOERER: They are new valves. These are
5 valves manufactured by Air Research. I do not believe the
6 entire test program has been completed. They have been
7 tested as part of the EPRI safety relief valve program. The
8 functional test has been performed under that program and
9 shows that they perform as designed.

10 There is also a seismic and environmental
11 qualification program that is being performed by
12 Westinghouse, and I am just not aware of whether all of
13 those tests have been completed yet.

14 MR. ZUDANS: Would they include testing against
15 discharging just all water, or a mixture of water, or just
16 all steam, or all the combinations?

17 MR. SCHWOERER: I think I need a little bit of
18 help on this. Jim, maybe you know, on the EPRI valve test
19 program, I do not know what the test conditions were for
20 these particular valves.

21 MR. CERMACK: First of all, the steam testing was
22 done, the steam testing was done at the Marshall facility of
23 the Duke Power Company. The water testing of the valves at
24 the Wylie Laboratories in California. And the
25 water-followed-by-steam testing was done also at the Wylie

1 Laboratories.

2 In all cases the test results were very good,
3 excellent, virtually no leakage of the valves.

4 The environmental qualification of the valve, as
5 Frank was saying, is being conducted by Westinghouse at the
6 Air Research facility.

7 MR. SCHWOERER: My speculation would be that that
8 is probably not completed as yet. The valves were scheduled
9 to be delivered to the Callaway plant in December of this
10 year.

11 MR. CERMACK: That is correct. The qualification
12 tests will be then.

13 MR. ZUDANS: I am going to speculate now. If you
14 also lost the diesel, you could still stay in a hot shutdown
15 state but you could not go to cold, naturally.

16 MR. SCHWOERER: Well, if you lose a diesel, if you
17 lose off-site power and you lose the diesel, that was the
18 case discussed by Steve Miltenberger yesterday, the concern
19 is that you do not have any way of making up water to the
20 reactor coolant system.

21 So then the concern is that you must minimize
22 leakage from that system. One of the concerns is what
23 happens to the reactor coolant pump seals. That was
24 discussed in that context. We are not assuming that we lose
25 the diesel in this case. We are assuming that we have the

1 diesel. You need the diesel to run the charging pumps.

2 Actually, the first place we need the diesel is
3 here (indicating). When we decide we are going to borate
4 and we need to have some ability to charge borated water
5 into the reactor coolant pump system.

6 Also, part of our thought here is that under
7 normal procedures when you are taking a plant from a hot
8 condition down to a cold condition, you borate to the cold
9 shutdown concentration before you start cooling down. We
10 wanted to have that capability.

11 It is possible, of course, to borate while you are
12 cooling down, and this would still be safe. One of the
13 advantages of doing that is as you cool down you make volume
14 to accept the boric acid. With the refueling water storage
15 tank as the source of borated water, however, you cannot get
16 enough boron in if you are just taking advantage of
17 shrinkage of the whole system.

18 The other thing is we wanted to maintain
19 pressurizer level throughout this entire evolution.

20 MR. ZUDANS: Thank you.

21 MR. CARBON: Are there any other questions?

22 (No response.)

23 MR. CARBON: We thank you.

24 Does the Staff have any final comments of any kind
25 to make?

1 MR. EDISON: No, sir.

2 MR. CARBON: Anything else?

3 MR. PASSWATER: No, sir. That concludes our
4 presentation.

5 MR. CARBON: I guess I would ask the committee
6 members is there any question on bringing this to the full
7 committee next week? Carson?

8 MR. MARK: I see no reason why not.

9 MR. CARBON: Fine. We will expect you to come to
10 the full committee meeting next week, Thursday afternoon.

11 In terms of the topics, have you put notes or
12 anything together?

13 MR. ARNOLD: Do we have time to have a little
14 recess to go over them? I think we might want to look at
15 them first, if that is a reasonable suggestion.

16 MR. CARBON: You mean for us to discuss among
17 ourselves or to break and give a little thought to it?

18 MR. MARK: We could really end this meeting, I
19 think, and confer with the Staff and the Applicant
20 afterwards about the topics at the next meeting on this
21 one.

22 MR. CARBON: Let us take that approach then of
23 adjourning the meeting, and the subcommittee will continue
24 to discuss the topics and the timing that we would like to
25 ask you to present next week.

1 Before we do adjourn the meeting, I would like to
2 make one statement to you, Mr. Schnell. It has been my
3 impression, rightly or wrongly, that you and your people
4 have sort of bent over to try and be open and candid and
5 honest and aboveboard and not mislead us. I cannot really
6 say that about all of the groups that have met before us in
7 the past. And I simply wanted to recognize this. That is
8 my impression, and I commend you for it. I just think it is
9 the best way to go at it.

10 MR. SCHNELL: Dr. Carbon, thank you very much for
11 those remarks. We continue this very important step in the
12 licensing process of obtaining our operating permit for
13 Callaway. And we certainly want to be responsive to all of
14 your questions, and we appreciate that remark.

15 MR. CARBON: Well, we will adjourn the meeting
16 then. The subcommittee will continue to come up with the
17 topics for presentation next week.

18 (Brief recess.)

19 MR. CARBON: What we would like to ask, if you are
20 set here, is the following kind of things, which I do not
21 have into a really polished list, but I think you can make
22 out from it. We would ask for about a total of 30 minutes
23 of organization and management by UE, by the Applicant,
24 organization, technical competence, experience levels, with
25 some technical discussion on SNUPPS.

1 We would ask that you hold down the organizational
2 aspect of SNUPPS, but we think that the technical backup
3 flavor ought to come through. And we would urge that.

4 In connection with experience levels, we wonder if
5 you could put some sort of quick chart together which the
6 committee could see. We are going to have lots of questions
7 on the experience level.

8 If you could, show the people in the organization
9 both at the management engineering level as well as in the
10 operations level. And perhaps indicate their positions and
11 their years or professional experience and the years of
12 nuclear experience and the years of commercial nuclear
13 experience, one column or something showing where your
14 counting Callaway and where you are not counting Callaway so
15 that we can look at this and say, "Gee, someone has five
16 years of professional experience. This was at Callaway or
17 it was three at Callaway and two at some place else."

18 We do not really care too much about the names of
19 the people except perhaps the management people. And if
20 they have ten engineers, you do not have to name them all,
21 or five reactor supervisors, do not name them. But indicate
22 their positions and the numbers of people and so on. We
23 will have considerable questions in that area.

24 Another aspect there that we will be concerned
25 about has to do with the startup. We wonder somewhat in

1 more detail than you explained before what the relationship
2 during startup between the startup supervisor and the plant
3 superintendent will be. We are not real clear on this. We
4 are wondering who will have what specific responsibility and
5 authority and so on.

6 Then in addition, your startup crew, as you
7 indicated, will have the 44 total professional people, a
8 dozen or so of these being your people. And we would
9 welcome additional information than we feel we have as to
10 how these people mesh together, how your people are going to
11 get the experience that you want them to get, and how is
12 going to call the shots during the startup, what authority
13 do the non-UE people have, those being the ones with the
14 most experience as contrasted to your own people.

15 Is that clear, what I am saying there?

16 MR. PASSWATER: Yes.

17 MR. CARBON: Going on then to the second topic,
18 and again these are not in order, perhaps 20 minutes or so
19 of operations staffing and training, current status of
20 staffing, selection and training of operators, something on
21 your simulator, 15 minutes on emergency planning,
22 coordination with FEMA and the state, emergency support
23 facilities, population projections. We have that down here,
24 but population projections, 10 seconds is about adequate.

25 Would you try and combine the topic, the

1 instrumentation to follow the course of an accident, Jim
2 Cermack's discussion, with the emergency operating procedures
3 discussion by Mr. Neuhalfen, combine those into one single
4 presentation of not more than 45 minutes.

5 We would like certainly the discussion of open
6 items both by the Staff and UE, and perhaps we could squeeze
7 those into about 45 minutes, because they are not really
8 very earthshaking and I do not think we need too much
9 discussion.

10 Perhaps a 15-minute discussion on the control room
11 and perhaps about 15 minutes of discussion on the last
12 topic, the decay heat removal by Mr. Schwoerer, that topic
13 anyway.

14 Now, this does not come out to quite four hours.
15 We want to limit the total time at the full committee
16 meeting to four hours. And Mr. Majors will be in touch with
17 you to expand some of these times and juggle them briefly.

18 MR. PASSWATER: Dr. Carbon, are these our
19 presentation times, or does this include time for
20 questions?

21 MR. CARBON: It is going to have to include the
22 time for questions. I think if you add up what I have cited
23 here, it probably comes out to about three hours and 20
24 minutes if my arithmetic was correct. And then I will need
25 15 minutes or so. So that comes out nominally to 3-1/2

1 hours already, and we will expand this a little to take up
2 the total of four. But that has to include everything.

3 Let me ask if you would and if you would, when you
4 show your organization chart, it seems like at so many of
5 our meetings so much time is spent telling what person holds
6 what position. If you could show an organization chart with
7 manager of engineering or manager of something, simply put
8 their name on there and then you will not have to tell us
9 who it is. We can read it and save a little bit of time.

10 Have I left anything out?

11 MR. MARK: You did not mention the situation
12 involved in the station blackout, and yet there is very
13 likely to be a question on that. We would hope you would
14 have someone who would be able to describe the situation
15 even if it is not scheduled.

16 MR. CARBON: I have left three or four topics
17 off. I will report to the committee on those topics, such
18 as AC/DC power reliability, hydrogen control, your systems
19 interaction discussion. They are not on the agenda here.
20 But do have people prepared to answer questions in case the
21 committee members do have such questions -- and they will,
22 there will be questions that are not covered here.

23 What other things are there?

24 MR. PASSWATER: One thing I understand that has
25 been on many recent committee meetings has been the item of

1 security, plant security.

2 MR. CARBON: I guess probably we will want some
3 discussion on that. We have your security plan, and I plan
4 to read it next week, but I have not done so yet. Let us
5 schedule --

6 MR. EDISON: I might interject, there is no issue
7 on this as far as the Staff is concerned.

8 MR. RAY: I think we should give them 10 or 15
9 minutes.

10 MR. MARK: It is not the question of what we
11 want. The fact that it is mentioned that the thing has been
12 looked and it seems to be well within the pattern of other
13 provisions for security. If we go much further than that,
14 we are going to close the lousy meeting and that takes 10
15 minutes to get in and out.

16 MR. CARBON: Let me suggest this. We will not put
17 it on the agenda, but have an individual there who could
18 answer questions if we get into them. And if we want to
19 close the meeting, we can always do it, but it is unlikely
20 that we will.

21 MR. CAPONE: I know it is hard to depict, but
22 would that be more along the line of security during
23 operations or the design of the security system itself? We
24 can bring people to go both ways. We can discuss the
25 overall design, how it has been put together, or are you

1 more concerned about how the security --

2 MR. CARBON: Lots of people ask the question, "How
3 about the card system and the buddy system," but also other
4 questions.

5 MR. MARK: What is that? Part 73 something or
6 other?

7 MR. EDISON: Yes.

8 MR. MARK: I think it is 73. The fact that you
9 have met the requirements of this -- which I presume is the
10 case?

11 MR. EDISON: Right.

12 MR. MARK: And that you are prepared to enumerate
13 and keep a tight control of vital areas and use keycards, if
14 that is the right word, if that is what they are doing, and
15 you have all of the standard fences and guard levels and
16 alarms, I think you can say that much in an open meeting.

17 But if you get down to describing drawings, "Here
18 is where that is, there is where that is," then we have
19 probably got to close the meeting.

20 MR. PASSWATER: Right. I understand.

21 MR. MARK: So I think we ought to be able to get
22 through without needing to close it, by giving the general
23 status of things.

24 Does that sound right?

25 MR. EDISON: If we do that, it will not be

1 necessary for me to bring the Staff security reviewer to the
2 meeting, because I was present with him and walked down the
3 site and we have that well documented.

4 MR. MARK: You would be prepared to say what had
5 been looked and that seems to cover all the points that we
6 usually try to cover, if that is the case. To say that is
7 all right. To describe them is not.

8 MR. EDISON: Right.

9 MR. CARBON: Are there any other questions?

10 MR. PASSWATER: I do not think so at this time.

11 MR. CARBON: Fine. We will see you all next
12 week.

13 MR. PASSWATER: Thank you.

14 (Whereupon, at 12:40 p.m., the Subcommittee
15 adjourned.)

16

* * *

17

18

19

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: ACRS/CALLAWAY UNIT 1 PLANT TOUR AND MEETING

Date of Proceeding: November 5, 1981


Docket Number: _____

Place of Proceeding: Columbia, Missouri

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Jane W. Beach

Official Reporter (Typed)



Official Reporter (Signature)

SUMMARY OF
CONFIRMATORY ITEMS
FROM SAFETY EVALUATION
REPORT FOR CALLAWAY
PLANT, UNIT 1

T1 11-5-81

CONFIRMATORY ITEMS FROM SER

CHARACTERISTICS

- o STAFF AGREES WITH APPLICANT'S DESIGN
- o NEED TO COMPLETE DOCUMENTATION
- o STAFF WANTS TO VERIFY IMPLEMENTATION AT SITE
- o ANALYSES NEARLY COMPLETE AND FINAL TOUCHES WILL NOT CHANGE RESULT
- o INSPECTION OF TEST RESULTS

CONFIRMATORY ITEMS FROM SER

STATUS

- o TOTAL OF 27 ITEMS + 12 TMI-RELATED ITEMS
- o TWO ITEMS MAY BE CONFIRMED BY 11-12-81
- o MOST IN 1982-1983

SUMMARY OF
LICENSE CONDITIONS
FROM SAFETY EVALUATION
REPORT FOR
CALLAWAY PLANT, UNIT 1

LICENSE CONDITIONS FROM SER

CHARACTERISTICS

- o ACTIONS THE APPLICANT MUST TAKE (OR CONDITIONS TO BE MAINTAINED) OVER THE OPERATING LIFE OF THE PLANT
- o TECHNICAL SPECIFICATIONS

LICENSE CONDITIONS FROM SER

STATUS

- o 20 LICENSE CONDITIONS
- o EXPECT MOST TO BE IMPLEMENTED PRIOR TO LICENSING
AND THEREFORE WILL NOT BECOME LICENSE CONDITIONS

OPEN ITEMS FROM SER
&
SUMMARY OF SER CONFIRMATORY ISSUES
&
SUMMARY OF SER LICENSING CONDITIONS

R. L. Stright, Licensing Manager - SNUPPS

11-5-81
Tape
14

PREPARATION OF EMERGENCY OPERATING PROCEDURES

A. P. Neuhalfen, Superintendent of Operations

PREPARATION OF EMERGENCY OPERATING PROCEDURES

- I. CURRENT DEVELOPMENT
- II. FORMAT PHILOSOPHY
- III. EXAMPLE FORMAT
- IV. PROCEDURE STRUCTURE
- V. GUIDELINE LISTS
- VI. STATUS TREES
- VII. CO-ORDINATED USE
- VIII. E-0 PROCEDURES
- IX. SUMMARY

GUIDELINE SERIES AND NUMBER

GUIDELINE TITLE

REVISION NUMBER/DATE

LEFT-HAND COLUMN - BASIC ACTION SEQUENCE

RIGHT-HAND COLUMN - CONTINGENCIES AND TRANSITIONS

CAUTION: - CRITICAL AND PRECAUTIONARY INFORMATION

NOTE - ADVISORY INFORMATION

HIGH-LEVEL ACTION STEP - BOLD TYPE

DETAILED STEPS - HOW TO DO HIGH-LEVEL ACTION

CONTINGENCY ACTION WHEN EXPECTED RESPONSE NOT OBTAINED

TRANSITION TO ANOTHER GUIDELINE - NUMBER AND TITLE

LOGIC STATEMENT EMPHASIZED - IF... THEN

PLANT-SPECIFIC DATA REQUIRED - FOOTNOTE NUMBER

ES-0.1	REACTOR TRIP RECOVERY	Revision No./Date Basic 1 Sept. 1981
--------	-----------------------	--

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
	<p><i>Caution</i> If SI actuation occurs at any time, immediately go to E-O, REACTOR TRIP OR SAFETY INJECTION STEP 5.</p> <p>NOTE Foldout page should be open.</p>	
1	<p>Check RCS Average Temperature:</p> <p>a. Temperature - DECREASING TO <u>(1)</u> °F</p> <p>b. Temperature - LESS THAN <u>(2)</u> °F</p> <p>1) Verify feedwater flow control valves - CLOSED <u>(3)</u></p> <p>c. Temperature - STABILIZES AT <u>(4)</u> °F</p>	<p>a. Dump steam:</p> <p>1) Manually open condenser steam dump valves</p> <p>-OR-</p> <p>manually open steam generator PORVs.</p> <p>2) Manually close valves.</p> <p>c. Stop dumping steam. <u>IF</u> cooldown continues, <u>THEN</u> close main steamline isolation valves.</p>
2	<p>Establish AFW Flows</p> <p>a. Start AFW pumps</p> <p>b. Align AFW valves - OPEN OR CLOSE AS APPROPRIATE <u>(5)</u></p> <p>c. Verify AFW flow</p>	<p>c. <u>IF</u> AFW flow NOT verified, <u>THEN</u> go to FR-H.1, LOSS OF SECONDARY HEAT SINK.</p>
3	<p>Verify All Control Rods Fully Inserted.</p>	<p><u>IF</u> two or more control rods NOT fully inserted, <u>THEN</u> emergency borate <u>(5)</u> ppm for each control rod not fully inserted.</p>
	<p><small>(1) Enter programmed set-point temperature (2) Enter temperature for low average temperature setpoint (3) Enter plant specific set of values (4) Enter plant specific set (5) Enter plant specific boration measurement.</small></p>	

1 of 7

FOOTNOTES-DEFINE REQUIRED PLANT-SPECIFIC DATA

PAGE NUMBER-ACCOUNTS FOR ALL PAGES

FIGURE 1. FORMAT EXAMPLE

PROCEDURE STRUCTURE

- I. OPTIMAL RECOVERY
 1. EMERGENCY PROCEDURES (E)
 2. EMERGENCY SUBPROCEDURES (ES)
 3. EMERGENCY CONTINGENCY ACTIONS (ECA)

- II. FUNCTIONAL RECOVERY
 1. CRITICAL SAFETY FUNCTION STATUS TREES
 2. FUNCTIONAL RESTORATION GUIDELINES (FRG)

TABLE 1A

OPTIMAL RECOVERY GUIDELINES

E-0 REACTOR TRIP OR SAFETY INJECTION

- ES-0.1 REACTOR TRIP RECOVERY
- ES-0.2 NATURAL CIRCULATION COOLDOWN
- ES-0.3 SI TERMINATION FOLLOWING SPURIOUS SAFETY INJECTION

E-1 LOSS OF REACTOR COOLANT

- ES-1.1 SI TERMINATION FOLLOWING LOSS OF REACTOR COOLANT
- ES-1.2 POST-LOCA COOLDOWN AND DEPRESSURIZATION
- ES-1.3 TRANSFER TO COLD LEG RECIRCULATION FOLLOWING LOSS OF REACTOR COOLANT
- ES-1.4 TRANSFER TO HOT LEG RECIRCULATION

E-2 LOSS OF SECONDARY COOLANT

- ES-2.1 SI TERMINATION FOLLOWING LOSS OF SECONDARY COOLANT
- ES-2.2 TRANSFER TO COLD LEG RECIRCULATION FOLLOWING LOSS OF SECONDARY COOLANT

E-3 STEAM GENERATOR TUBE RUPTURE

- ES-3.1 SI TERMINATION FOLLOWING STEAM GENERATOR TUBE RUPTURE
- ES-3.2 ALTERNATE SGTR COOLDOWN
- ES-3.3 SGTR WITH SECONDARY DEPRESSURIZATION

TABLE 1B

EMERGENCY CONTINGENCY ACTIONS

ECA-1 ANTICIPATED TRANSIENTS WITHOUT SCRAM

ECA-2 LOSS OF ALL AC POWER

ECA-2.1 LOSS OF ALL AC POWER RECOVERY WITHOUT SI REQUIRED

ECA-2.2 LOSS OF ALL AC POWER RECOVERY WITH SI REQUIRED

ECA-3 SGTR CONTINGENCIES


TABLE 2


FUNCTION RESTORATION GUIDELINE SET (FRGs)

FR-S.1	RESPONSE TO NUCLEAR POWER GENERATION
FR-S.2	RESPONSE TO LOSS OF CORE SHUTDOWN
FR-P.1	RESPONSE TO RCS OVERPRESSURIZATION
FR-P.2	RESPONSE TO HIGH RCS PRESSURE
FR-C.1	RESPONSE TO INADEQUATE CORE COOLING
FR-C.2	RESPONSE TO POTENTIAL LOSS OF CORE COOLING
FR-C.3	RESPONSE TO SATURATED CORE COOLING CONDITIONS
FR-I.1	RESPONSE TO PRESSURIZER FLOODING
FR-I.2	RESPONSE TO LOW SYSTEM INVENTORY
FR-I.3	RESPONSE TO VOIDS IN REACTOR VESSEL
FR-H.1	RESPONSE TO LOSS OF SECONDARY HEAT SINK
FR-H.2	RESPONSE TO LOW STEAM GENERATOR LEVEL
FR-H.3	RESPONSE TO LOSS OF NORAML STEAM DUMP CAPABILITY
FR-Z.1	RESPONSE TO CONTAINMENT ABOVE DESIGN PRESSURE
FR-Z.2	RESPONSE TO HIGH CONTAINMENT PRESSURE
FR-Z.3	RESPONSE TO HIGH CONTAINMENT RADIATION LEVEL
FR-Z.4	RESPONSE TO HIGH HYDROGEN CONCENTRATION IN CONTAINMENT
FR-Z.5	RESPONSE TO CONTAINMENT FLOODING

- (1) SUBCRITICALITY (S-SERIES)
- (2) RCS INTEGRITY (P-SERIES)
- (3) CORE COOLING (C-SERIES)
- (4) RCS INVENTORY (I-SERIES)
- (5) CORE HEAT SINK (H-SERIES)
- (6) CONTAINMENT INTEGRITY (Z-SERIES)

SUBCRITICALITY





STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

EMERGENCY INSTRUCTION E-O REACTOR TRIP OR SAFETY INJECTION

A. PURPOSE

The purpose of this guideline is to verify proper response of the automatic protection systems following actuation of a REACTOR TRIP or SAFETY INJECTION; and to assess plant conditions and identify the appropriate recovery guideline.

B. SYMPTOMS: (1)

I. Following are symptoms of a reactor trip:

- a. Any reactor trip annunciator lit
- b. Rapid decrease in neutron level indicated by nuclear instrumentation
- c. All shutdown and control rods are fully inserted. Rod bottom lights are lit
- d. Rapid decrease in unit load to zero power

II. Following are symptoms of reactor trip and safety injection:

- a. Any SI annunciator lit
- b. SI pumps in service
- c. [Enter other plant specific symptoms]

(1) Plant should modify this typical list to be consistent with plant features.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

NOTE • *Circled numbers show IMMEDIATE ACTION steps.*
• *Foldout page should be open.*

①

Verify Reactor Trip:

- All rod bottom lights - LIT
- All rod position indicators - ZERO
- Neutron flux - DECREASING

a. Manually trip reactor. IF reactor will NOT trip, THEN go to ECA-1, ANTICIPATED TRANSIENT WITHOUT SCRAM.

②

Verify Turbine Trip:

- All turbine stop valves - CLOSED

• Manually trip turbine.

③

Verify AC Emergency Busses Energized:

- AC emergency bus voltage - NORMAL

IF NOT energized, THEN go to ECA-2, LOSS OF ALL AC POWER, STEP 3.

④

Check If SI Is Actuated:

- a. [Enter plant specific means]

IF NOT actuated, THEN go to ES-0.1, REACTOR TRIP RECOVERY.

⑤

Verify Feedwater Isolation:

- a. Flow control valves - CLOSED
- b. Flow control bypass valves - CLOSED
- c. Feedwater isolation valves - CLOSED
- d. Steam generator blowdown isolation valves - CLOSED

- a. Manually close valves.
- b. Manually close valves.
- c. Manually close valves.
- d. Manually close valves.

⑥

Verify Containment Isolation Phase A:

- a. Isolation phase A valves - CLOSED (1)

a. Manually close valves.

⑦

Verify AFW Pumps Running:

- a. Motor-driven pump breaker indicator lights - LIT
- b. Turbine-driven pump steam supply valves - OPEN

a. Manually start pumps.

b. Manually open valves.

(1) Enter plant specific list.

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
8	Verify AFW Valve Alignment: a. AFW valves - PROPER EMERGENCY ALIGNMENT ⁽¹⁾	a. Manually open or close valves as appropriate.
9	Verify SI Pumps Running: a. Charging/SI pump breaker indicator lights - LIT b. High-head SI pump breaker indicator lights - LIT c. Low-head SI pump breaker indicator lights - LIT	a. Manually start pumps. b. Manually start pumps. c. Manually start pumps.
10	Verify SI Valve Alignment: a. SI valves - PROPER EMERGENCY ALIGNMENT ⁽¹⁾	a. Manually open or close valves as appropriate.
11	Verify CCW Pumps Running: a. CCW pump breaker indicator lights - LIT	a. Manually start pumps.
12	Verify Service Water Pumps Running: a. Service water pump breaker indicator lights - LIT	a. Manually start pumps.
13	Verify Containment Ventilation Isolation: a. Damper indicator lights - CLOSED	a. Manually close damper.

[Appropriate steps for verification of other essential equipment as required by the specific plant design should be placed after step 13.]

(1) Enter plant specific list.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

Caution If SI flow cannot be verified, symptoms should be monitored for FR-C.1, INADEQUATE CORE COOLING.

14

Verify SI Flow:

- | | |
|---|--|
| <ul style="list-style-type: none"> a. Charging/SI pump flow indicator - CHECK FOR FLOW b. IF RCS pressure is less than <u>(1)</u> psig, THEN check high-head SI pump flow indicators - CHECK FOR FLOW c. IF RCS pressure is less than <u>(2)</u> psig, THEN check low-head SI flow indicators - CHECK FOR FLOW | <ul style="list-style-type: none"> a. Manually start pumps and align valves as appropriate. b. Manually start pumps and align valves as appropriate. c. Manually start pumps and align valves as appropriate. |
|---|--|

Caution Do not throttle AFW flow until the water level is above the top of the U-tubes.

15

Verify AFW Flow:

- | | |
|---|--|
| <ul style="list-style-type: none"> a. AFW flow indicators - CHECK FOR FLOW | <ul style="list-style-type: none"> a. IF AFW flow NOT verified, THEN go to FR-H.1, LOSS OF SECONDARY HEAT SINK. |
|---|--|

16

Verify RCS Heat Removal:

- | | |
|--|--|
| <ul style="list-style-type: none"> a. RCS average temperature - DECREASING TO <u>(3)</u> °F | <ul style="list-style-type: none"> a. Dump steam: <ul style="list-style-type: none"> 1) Manually open condenser steam dump valves. <li style="text-align: center;">—OR— 2) Manually open steam generator PORVs. |
|--|--|

(1) Enter plant specific shutoff pressure of high-head SI pumps.

(2) Enter plant specific shutoff pressure of low-head SI pumps.

(3) Enter temperature for programmed no-load temperature.

E-O

REACTOR TRIP OR SAFETY INJECTION (Cont.)

Basic

1 Sept. 1981

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
17	<p>Check Containment Pressure:</p> <p>a. Pressure has remained below <u>(1)</u> psig</p> <p>b. Pressure has NOT gone ABOVE <u>(2)</u> psig</p>	<p>a. <u>IF</u> pressure has remained below <u>(1)</u> psig, <u>THEN</u> verify main steam isolation valves closed. <u>IF NOT</u> closed, <u>THEN</u> manually close valves.</p> <p>b. <u>IF</u> pressure has gone above <u>(2)</u> psig, <u>THEN</u>:</p> <p>1) Verify containment spray initiated. <u>IF NOT</u> initiated, <u>THEN</u> manually initiate.</p> <p>2) Verify containment isolation phase B initiated. <u>IF NOT</u> initiated, <u>THEN</u> manually initiate.</p> <p>3) Stop all RCPs.</p>
18	<p>Check RCS Pressure:</p> <p>a. Pressure - GREATER THAN <u>(3)</u> PSIG</p> <p>b. Pressure - STABLE or INCREASING</p>	<p>a. <u>IF</u> less than <u>(3)</u> psig, <u>THEN</u> go to step 27.</p> <p>b. <u>IF</u> decreasing, <u>THEN</u> go to step 27.</p>
19	<p>Check Containment Temperature:</p> <p>a. Containment temperature - NORMAL</p>	<p>a. <u>IF</u> high, <u>THEN</u> go to step 27.</p>
20	<p>Check Containment Pressure:</p> <p>a. Containment pressure - NORMAL</p>	<p>a. <u>IF</u> high, <u>THEN</u> go to step 27.</p>
21	<p>Check Containment Radiation:</p> <p>a. Containment radiation - NORMAL</p>	<p>a. <u>IF</u> high, <u>THEN</u> go to step 27.</p>
22	<p>Check Containment Recirculation Sump Level:</p> <p>a. Containment recirculation sump level - NORMAL</p>	<p>a. <u>IF</u> high, <u>THEN</u> go to step 27.</p>

(1) Enter plant specific Hi-2 pressure setpoint.

(2) Enter plant specific Hi-3 pressure setpoint.

(3) Enter plant specific low pressure reactor trip setpoint.

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
23	Check Steam Generator Blowdown Radiation: a. Radiation - NORMAL	a. <u>IF</u> high, <u>THEN</u> go to step 27.
24	Check Condenser Air Ejector Radiation: a. Radiation - NORMAL	a. <u>IF</u> high, <u>THEN</u> go to step 27.
25	Check If SI Can Be Terminated: a. RCS pressure - GREATER THAN 2000 PSIG AND INCREASING b. Pressurizer level - GREATER THAN <u>(1)</u> % c. RCS subcooling - GREATER THAN <u>(2)</u> °F d. Secondary heat sink: 1) Total AFW flow to non-faulted steam generators - GREATER THAN <u>(3)</u> GPM -OR- 2) Wide range level in at least one non-faulted steam generator - GREATER THAN <u>(4)</u> %	a. DO NOT TERMINATE SI. Go to step 27. b. DO NOT TERMINATE SI. Go to step 27. c. DO NOT TERMINATE SI. Go to step 27. d. <u>IF</u> neither condition is satisfied, <u>THEN</u> DO NOT TERMINATE SI. Go to step 27.
26	Terminate SI: a. Go to ES-0.3, SI TERMINATION FOLLOWING SPURIOUS SI	

(1) Enter plant specific no-load value.

(2) Enter sum of temperature and pressure measurement system errors translated into temperature using saturation tables.

(3) Enter plant specific value derived from background document.

(4) Enter plant specific value which is above top of steam generator U-tubes.

E-O

REACTOR TRIP OR SAFETY INJECTION (Cont.)

Basic

1 Sept. 1981

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
27	<p>Check If RCS Depressurization Can Be Stopped:</p> <p>a. Pressurizer spray valves - CLOSED</p> <p>b. Pressurizer PORVs - CLOSED</p>	<p>a. Manually close valves.</p> <p>b. Manually close valves. <u>IF</u> any valve cannot be closed, <u>THEN</u> manually close its block valve.</p>

Caution Seal injection flow should be maintained to all RCPs.

28	<p>Check If RCPs Should Be Stopped:</p> <p>a. SI running - CHECK FOR FLOW OR PUMP BREAKER INDICATOR LIGHTS LIT</p> <ul style="list-style-type: none"> • Charging/SI <p style="text-align: center;">-OR-</p> <ul style="list-style-type: none"> • High-head SI <p>b. RCS pressure - EQUAL TO OR LESS THAN <u>(1)</u> PSIG</p> <p>c. Stop All RCPs</p>	<p>a. DO NOT STOP RCPs. Go to step 29.</p> <p>b. DO NOT STOP RCPs. Go to step 29.</p>
----	--	---

(1) Enter plant specific value, derived from background document.

E-O

REACTOR TRIP OR SAFETY INJECTION (Cont.)

Basic

1 Sept. 1981

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
29	<p>Check For Secondary Integrity:</p> <p>a. All steam generator pressures – APPROXIMATELY EQUAL</p> <p>b. All steam generator pressures – GREATER THAN (1) PSIG</p>	<p>a. IF pressure 100 psi lower in one steam generator than the others, THEN go to E-2, LOSS OF SECONDARY COOLANT.</p> <p>b. IF any steam generator pressure less than (1) psig, THEN go to E-2, LOSS OF SECONDARY COOLANT.</p>
30	<p>Check For RCS Integrity:</p> <p>a. Containment pressure – NORMAL</p> <p>b. Containment radiation – NORMAL</p> <p>c. Containment recirculation sump level – NORMAL</p>	<p>a. IF high, THEN go to E-1, LOSS OF REACTOR COOLANT.</p> <p>b. IF high, THEN go to E-1, LOSS OF REACTOR COOLANT.</p> <p>c. IF high, THEN go to E-1, LOSS OF REACTOR COOLANT.</p>
31	<p>Check For RCS To Secondary Integrity:</p> <p>a. Condenser air ejector radiation – NORMAL</p> <p>b. Steam generator blowdown radiation – NORMAL</p>	<p>a. IF high, THEN go to E-3, STEAM GENERATOR TUBE RUPTURE.</p> <p>b. IF high, THEN go to E-3, STEAM GENERATOR TUBE RUPTURE.</p>

(1) Enter plant specific value corresponding to low steam pressure SI setpoint.

REACTOR TRIP OR SAFETY INJECTION (Cont.)

Basic

1 Sept. 1981

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
32	<p>Continue To Evaluate Plant Conditions:</p> <p>a. Monitor critical safety function status trees</p> <p style="text-align: center;">-AND-</p> <p>b. Continue with this guideline</p>	
33	<p>Check RCS Hot Leg Temperatures:</p> <p>a. IF at least one RCP is running - HOT LEG TEMPERATURE STABILIZES AT APPROXIMATELY <u>(1)</u> °F</p> <p>b. IF RCPs are NOT running- HOT LEG TEMPERATURE STABILIZES AT APPROXIMATELY <u>(2)</u> °F</p>	<p>a. IF temperature is decreasing in an uncontrolled manner, THEN close main steamline isolation valves and bypass valves.</p> <p>b. IF temperature is decreasing in an uncontrolled manner, THEN close main steamline isolation valves and bypass valves.</p>
34	<p>Check Steam Generator Levels:</p> <p>a. Narrow range level - GREATER THAN <u>(3)</u> %</p> <p>b. Throttle AFW flow to maintain narrow range level at <u>(4)</u> %.</p>	<p>a. IF less than <u>(3)</u> %, THEN maintain full AFW flow until narrow range level is greater than <u>(3)</u> %.</p>
35	<p>Check PRT Conditions-NORMAL.</p>	<p>IF PRT conditions abnormal, THEN evaluate cause of abnormal conditions.</p>

(1) Enter temperature for programmed no-load temperature.

(2) Enter temperature corresponding to expected hot leg temperature on natural circulation.

(3) Enter plant specific value showing level just in the narrow range including allowances for normal channel accuracy, post-accident transmitter errors and reference leg process errors.

(4) Enter plant specific value corresponding to no-load steam generator level including allowances for post-accident transmitter errors and reference leg process errors.

STEP

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

36

Check If Low-Head SI Pumps Should Be Stopped:

a. RCS pressure - GREATER THAN ⁽¹⁾ PSIG AND STABLE OR INCREASING

b. Reset SI

c. Stop low-head SI pumps and place in standby

a. IF RCS pressure low or decreasing, THEN return to step 28.

Caution If RCS pressure drops below ⁽¹⁾ psig, the low-head SI pumps must be manually restarted to supply water to the RCS.

37

Rediagnose Plant Conditions:

a. Return to step 18.

-- END --

(1) Enter plant specific shutoff head of low-head SI pumps.

STAFF POSITION
ON HYDROGEN CONTROL
FOR LARGE DRY
CONTAINMENTS:
CALLAWAY PLANT, UNIT 1

T5 17-5-81

HYDROGEN CONTROL

- o STAFF POSITION FOR LARGE DRY CONTAINMENTS
- o CALLAWAY DESIGN

STAFF POSITION ON HYDROGEN
CONTROL FOR LARGE DRY CONTAINMENTS

- o 10 CFR 50.44
(5% METAL-WATER REACTION OR 5 X ECCS
CALCULATION)
- o CONSISTENT WITH FULL POWER LICENSING OF
N. ANNA 2, SALEM 2, FARLEY 2, TMI-1 RESTART
- o PROPOSED INTERIM RULE NOT NOW IMPOSED

CALLAWAY DESIGN

- o 2.5 MILLION FT³ CONTAINMENT FREE VOLUME
- o TMI-2 TYPE EVENT (30-50% METAL-WATER REACTION)
GIVES 6-10% HYDROGEN
- o WELL BELOW DETONATION LIMIT
- o DESIGN PRESSURE 60 PSI, FAILURE PRESSURE >120 PSI

- o CAN ACCOMMODATE PRESSURE FROM HYDROGEN
COMBUSTION

- o POST-TMI IMPROVEMENTS REDUCE LIKELIHOOD OF
ACCIDENT

STAFF POSITION ON HYDROGEN CONTROL

FOR LARGE DRY CONTAINMENTS

PENDING THE RULEMAKING PROCEEDINGS CALLED FOR IN ITEM II.B.8 OF THE TMI ACTION PLAN, NUREG-0660, THE STAFF IS NOT NOW IMPOSING ANY NEW REQUIREMENTS I.E., BEYOND 10 CFR 50.44, FOR HYDROGEN CONTROL IN LARGE DRY CONTAINMENTS. THE STAFF COMPLETED ITS REVIEWS FOR THE FULL POWER LICENSING OF NORTH ANNA 2, SALEM 2, FARLEY 2, AND TMI-1 (RESTART) WITHOUT IMPOSING ANY NEW REQUIREMENT FOR HYDROGEN CONTROL. THIS POSITION WAS BASED ON THE STAFF'S VIEW THAT LARGE DRY CONTAINMENTS HAD SUFFICIENT CAPABILITY TO ACCOMMODATE HYDROGEN COMBUSTION SO THAT NO NEW REQUIREMENTS NEEDED TO BE IMPOSED, PENDING THE RULEMAKING PROCEEDING ON DEGRADED CORE COOLING.

IN THE PROPOSED RULE PORTION OF THE INTERIM RULE, (SECY-81-245A), THE STAFF PROPOSES TO REQUIRE THAT CERTAIN SPECIFIC ANALYSES BE PERFORMED FOR ALL LARGE DRY CONTAINMENTS TO ASSURE THAT CONTAINMENT INTEGRITY AND SAFE SHUTDOWN WILL NOT BE JEOPARDIZED BY HYDROGEN RELEASES FROM THE POSTULATED DEGRADED CORE ACCIDENTS.

HYDROGEN CONTROL

J. O. Cermak, Manager of Nuclear Safety - SNUPPS


T5 11-5-81

HYDROGEN CONTROL SYSTEM

- ° REDUNDANT HYDROGEN RECOMBINERS
- ° REDUNDANT HYDROGEN MIXING SYSTEM
- ° REDUNDANT HYDROGEN MONITORING
SUBSYSTEM
- ° BACKUP HYDROGEN PURGE SUBSYSTEM

SOURCES OF HYDROGEN GAS IN
CONTAINMENT

- 5% ZIRCONIUM WATER REACTION
POST LOCA
- POST LOCA RADIOLYTIC DECOMPOSITION
OF WATER
- POST LOCA CORROSION OF METALS AND
PAINTS



SNUPPS

FIGURE 6.2.5-2

HYDROGEN VOLUME CONCENTRATION IN
CONTAINMENT WITH ONE RECOMBINER
OPERATING AT ONE DAY

HYPOTHETICAL CASE

LARGE AMOUNTS
OF HYDROGEN IN
DRY CONTAINMENT

CONTAINMENT VOLUME - $2.5 \times 10^6 \text{ FT}^3$

75% METAL WATER REACTION CASE

RESULTS

- ° 12.5% HYDROGEN BY VOLUME IN CONTAINMENT
- ° CONSTANT VOLUME AND ADIABATIC DEFLAGRATION
OF HYDROGEN YIELDS PRESSURE INCREASE OF
60 PSI (75 PSIA)
- ° DESIGN PRESSURE OF CONTAINMENT - 75 PSIA

CONCLUSION

PEAK PRESSURE FROM HYDROGEN BURN EQUALS
CONTAINMENT DESIGN PRESSURE

75% METAL WATER REACTION CASE WITH WORST CASE LOCA

ASSUMPTION

HYDROGEN BURN OCCURS AT TIME OF PEAK CONTAINMENT PRESSURE FROM LOCA (47.3 PSIG AT 134 SECONDS).

RESULTS

• PEAK PRESSURE IN CONTAINMENT IS APPROXIMATELY 125 PSIA.

• ULTIMATE STATIC FAILURE PRESSURE FOR CONTAINMENT IS APPROXIMATELY 175 PSIA.

CONCLUSION

FOR WORST CASE LOCA AND 75% METAL WATER REACTION, PEAK PRESSURE IN CONTAINMENT IS APPROXIMATELY 50 PSI BELOW ULTIMATE STATIC FAILURE PRESSURE.




FIGURE 2
VOLUME % HYDROGEN IN CONTAINMENT
VS % METAL-WATER REACTION




FIG. 3. PRESSURE AND TEMPERATURE AFTER HYDROGEN-AIR COMBUSTION, CONSTANT VOLUME AND ADIABATIC

DECAY HEAT REMOVAL SYSTEM

F. Schwoerer, Technical Director - SNUPPS

T6 11-3-81

FUNCTIONAL REQUIREMENTS FOR COLD SHUTDOWN

1. HEAT REMOVAL AT HOT STANDBY
2. BORATION OF RCS
3. COOLDOWN OF RCS
4. DEPRESSURIZATION OF RCS
5. RHR OPERATION