Appendix A

NOTICE OF VIOLATION

Union Electric Company Docket No. 50-483

Based on the inspection conducted on August 30 through September 2, 1977, it appears that certain of your activities were in noncompliance with NRC requirements, as noted below. This item is an infraction.

Contrary to 10 CFR 50, Appendix B, Criterion XIII, SNUPPS PSAR Paragraph 3.12 and ANSI N45.2.2 Paragraph 6.4.2, the inspector determined on September 1, 1977, that insulation resistance readings of the motors for Room Coolers, Units 10 A & B; 12A & B; 13A & B had not been determined on a periodic basis.

8111100812 811106
PDR ADOCK 05000483
T PDR