

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NOS. 50-282 AND 50-306

NORTHERN STATES POWER COMPANY

NOTICE OF ISSUANCE OF AMENDMENTS TO FACILITY  
OPERATING LICENSES

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment Nos. 20 and 14 to Facility Operating License Nos. DPR-42 and DPR-60, issued to the Northern States Power Company (the licensee), which revised Technical Specifications for operation of Unit Nos. 1 and 2 of the Prairie Island Nuclear Generating Plant (the facilities) located in Goodhue County, Minnesota. The amendments are effective as of their date of issuance.

The amendments revised the Technical Specifications for the facilities to remove the requirement for conducting a liquid penetrant test of the reactor vessel head cladding during the first 40-month inspection period.

The application for the amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendments. Prior public notice of these amendments was not required since the amendments do not involve a significant hazards consideration.


8111110938 770505  
PDR ADOCK 05000282  
P PDR

The Commission has determined that the issuance of these amendments will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of these amendments.

For further details with respect to this action, see (1) the application for amendments dated March 31, 1977, (2) Amendment Nos. 20 and 14 to License Nos. DPR-42 and DPR-60, respectively, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., and at The Environmental Conservation Library of the Minneapolis Public Library, 300 Nicollet Mall, Minneapolis, Minnesota 55401. A single copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 18th day of April, 1977.

FOR THE NUCLEAR REGULATORY COMMISSION



Don K. Davis, Acting Chief  
Operating Reactors Branch #2  
Division of Operating Reactors