	LICENSEE EVENT REPORT
	CONTROL BLOCK: [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] [
0 1 7 8	N C B E P 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 5 EXPENSE CODE 14 15 LICENSE NUMBER 5 25 26 LICENSE TYPE 30 57 CAT 58
0 1 8	REPORT L 6 0 5 0 - 0 3 2 5 0 1 10 11 1 8 1 0 3 8 1 9  EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10  During plant operation the primary containment oxygen concentration exceeded the
0 3	<4% by volume specification. Within 5 hours the concentration was reduced to within j
0 4	specifications. This event did not affect the health and safety of the public.
0 5	
06	
[0]0]	
LOIA	Technical Specification 3.6.6.3, 6.9.1.9b
7 8	9 SYSTEM CAUSE CAUSE COMP. VALVE
0 9 7 8	CODE SUBCODE S
	The component   Taken   Action   Future   Taken   Action   Actio
1 0	A failure to maintain a sufficient supply of make up inerting nitrogen needed to
1 1	maintain the primary containment atmosphere <4% oxygen by volume caused this event.
1 2	The nitrogen storage facility was replenished and the primary containment oxygen
1 3	concentration was reduced to <4% by volume. Appropriate procedures were revised and
1 4	involved personnel have been counseled in order to help prevent future similar events.
	FACILITY SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32  E 28 0 9 9 29 NA A 31 Operational Event
	9 10 12 13 44 45 46  ACTIVITY CONTENT AMOUNT OF ACTIVITY (35)    Z   (33)   Z   (34)
7 8	9 10 11 44 45 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
7 8	0 0 0 3) Z 38 NA NA 80
1 8	NUMBER DESCRIPTION (41) NA
7 8	9 11 12 80 LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION 43
1 9 7 8	Z 42 NA 80
	PUBLICITY ISSUED DESCRIPTION 45
91111	68 69 80.5
PDR A	DOCK 05000325 PDR 1. J. Pastva, Jr. PHONE: 919-457-9521