LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | T N S N P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT NO

0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 2 7 (7) | 1 0 2 9 8 1 (8) | 1 1 1 0 8 1 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 With Unit 1 in Mode 1 and Unit 2 in Mode 4 at 1900 CST on 10/29/81, the Auxiliary
0 3 Building Gas Treatment System (ABGTS) was declared inoperable due to the possibility of
0 4 a seismic event causing a direct path through a pipe chase on the "A1" wall at
0 5 elevation 685 from the Auxiliary Building to the environment. Under this condition, the
0 6 ABGTS may not maintain the required negative ¼" pressure. This event placed the
0 7 units in the action statement of LCO 3.7.8.1 and 3.0.3. There was no effect upon
0 8 public health and safety. Previous occurrences - none.

0 9 SYSTEM CODE A A (11) | CAUSE CODE B (12) | CAUSE SUBCODE A (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 1 | — | SEQUENTIAL REPORT NO. 1 2 5 | / | OCCURRENCE CODE 0 1 | REPORT TYPE T | — | REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 During review of Preoperational Test Report 2-PT-703, it was determined that the
1 1 possibility of releases from the Auxiliary Building to the environment due to a seismic
1 2 event through this pipe chase was overlooked during initial design. The 3 ft. x 3 ft.
1 3 pipe chase opening was sealed with RTV foam and the Auxiliary Building Gas Treatment
1 4 System declared operable at 2345 on 10/29/81.

5 FACILITY STATUS E (28) | % POWER 0 2 8 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY C (31) | DISCOVERY DESCRIPTION (32) Review of Special Test

6 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

7 PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

8 PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A

9 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION N/A

PUBLICITY ISSUED N (43) | DESCRIPTION (45) N/A

8111170483 811110
PDR ADOCK 05000327
S PDR

NRC USE ONLY

Name of Preparer H. R. Rogers /M. R. Harding Phone: (615) 842-8317