NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M I P A L 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 5 5 (7) | 1 0 0 6 8 1 (8) | 1 1 0 5 8 1 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During routine surveillance of radiation monitors, it was determined
03 that RIA 2316 was inoperable. This monitor provides containment isolation
04 signal during refueling operations. Redundant monitor was operable.
05 RIA 2316 required to be operable during refueling per TS 3.8.1. No
06 threat to public health or safety existed. Reportable per TS 6.9.2.B.2.
07
08

09 | SYSTEM CODE I B (11) | CAUSE CODE E (12) | CAUSE SUBCODE A (13) | COMPONENT CODE I N S T R U (14) | COMP. SUBCODE E (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 1 — SEQUENTIAL REPORT NO. 0 4 3 — OCCURRENCE CODE 0 3 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN C (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0 0 0 0 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER V 1 1 5 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Cause not positively identified. Detector was replaced; subsequent checks
11 revealed no problems with replaced detector. Intermittent cable connec-
12 tion problems are suspected. A review will be made of other area monitors
13 using same type of cable connections to determine if replacement or modi-
14 fication is necessary.

15 | FACILITY STATUS H (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Routine Surveillance

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

8111190411 811105
PDR ADOCK 05000255
S PDR

16