



DOCKETED
USNRC

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

'81 OCT 29 P4:38

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of)	
PACIFIC GAS AND ELECTRIC COMPANY)	Docket No. 50-275
Diablo Canyon Nuclear Power Plant)	Docket No. 50-323
Units Nos. 1 and 2)	(Full Power Proceedings)

APPLICANT PACIFIC GAS AND ELECTRIC COMPANY'S
ANSWERS TO JOINT INTERVENORS'
SECOND SET OF INTERROGATORIES

INTERROGATORY NO. 29:

Explain the present Applicant position on Joint
Intervenors' contention 10, regarding pressurizer heater
design, and state each and every fact on which that position
is based.

ANSWER TO INTERROGATORY NO. 29:

It is PGandE's position that the pressurizer
heaters and associated controls are not required to be
classified as "components important to safety" and therefore

*DSOS
50/11*

1 are not required to meet all safety grade design criteria.
2 However, the pressurizer heater design associated with the
3 capability of obtaining power from the onsite emergency
4 power supply meets GDC 10, 14, 15, 17 and 20 of Appendix A
5 to 10CFR50. Therefore, PGandE believes the method that has
6 been used to connect the pressurizer heaters to the onsite
7 emergency power supply is fully adequate.

8 PGandE's position is based on the fact that the
9 design of the pressurizer heaters meets the NRC regulatory
10 requirements including those arising from post TMI lessons
11 learned, specifically NUREG-0737.

12
13
14
15 INTERROGATORY NO. 30:

16 Does the current position differ from the position
17 of the Applicant in any prior proceedings? If so, identify
18 the proceeding(s), explain the prior position, and explain
19 the basis for the change in position.

20
21 ANSWER TO INTERROGATORY NO. 30:

22 No.
23
24
25
26

1 INTERROGATORY NO. 31:

2 Identify any officers or employees of, or
3 consultants to, the Applicant who dissent from the present
4 Applicant position on Joint Intervenors' contention 10.
5 Explain the reasons for which any such person dissents.
6

7 ANSWER TO INTERROGATORY NO. 31:

8 None.
9
10
11

12 INTERROGATORY NO. 32:

13 Identify the specific sections and page numbers of
14 the FSAR for Diablo Canyon and the NRC Staff's SER and SER
15 Supplements for Diablo Canyon, which are relied upon in
16 formulating the Applicant position on Joint Intervenors'
17 contention 10.
18

19 ANSWER TO INTERROGATORY NO. 32:

20 SER Supplement 14, Section II.E.3.1, "Emergency
21 Power Supply for Pressurizer Heaters," pages 2-19 through
22 2-21.
23
24
25
26

1 INTERROGATORY NO. 33:

2 Identify all sections and page numbers of the
3 FSAR, SER, and SER Supplements which contain subject matter
4 pertaining to Joint Intervenors' contention 10.
5

6 ANSWER TO INTERROGATORY NO. 33:

7 Applicant objects to this interrogatory. The
8 FSAR, SER and SER Supplements consist of literally thousands
9 of pages. Joint Intervenors are more capable than anyone
10 else of going through those documents and making a
11 judgmental decision as to whether any section or page
12 contains subject matter pertaining to their own contention.
13
14
15

16 INTERROGATORY NO. 34:

17 The Staff has recognized that the "maintenance of
18 natural circulation capability is important to safety (and)
19 depends on the maintenance of pressure control . . . (which)
20 is normally achieved through the use of pressurizer
21 heaters." NUREG-0578, p. A-2.

22 (a) Do you agree?

23 (b) Explain why pressurizer heaters and their associated
24 controls are not classified as "components important to
25 safety," as discussed in GDC 17 and the Introduction to
26 Appendix A to CFR Part 50.

1 ANSWER TO INTERROGATORY NO. 34:

2 (a) Yes.

3 (b) The plant design, including operational prac-
4 tice (training, procedures, etc.), provides alternative
5 and reliable methods of maintaining pressure control,
6 and therefore maintaining natural circulation, which
7 use systems and components designed to safety grade re-
8 quirements. Therefore, the pressurizer heaters and
9 associated controls are not classified "important to
10 safety."

11 Further, there are no NRC regulations or
12 requirements that provide that the pressurizer heaters
13 and their associated controls ought to be classified
14 "important to safety." The NRC Staff, on page A-2,
15 NUREG-0578, states ". . . there is a need to consider
16 the upgrading of those pressurizer heaters and
17 associated controls . . . to a safety grade
18 classification. . . ." The NRC Staff further states,
19 on page A-2 of NUREG-0578, "In the short term, designs
20 should be upgraded to provide the operator with the
21 capability to maintain natural circulation at hot
22 standby through the use of pressurizer heaters when
23 offsite power is not available." This last statement
24 has become a requirement as identified in item II.E.3.1
25 of NUREG-0737, the document that identified those

26 ///

1 TMI-related actions that the NRC Commissioners have
2 approved for implementation.

3 Pressurizer heaters and associated controls
4 meet both the requirements of item II.E.3.1 and GDC 17
5 in terms of emergency on-site power supplies for the
6 pressurizer heaters. Item II.E.3.1 does not require
7 the pressurizer heaters or associated controls to be
8 designed to safety grade requirements; in fact item
9 II.E.3.1 states, "Being non-Class IE loads, the
10 pressurizer heaters must be automatically shed from the
11 emergency power sources. . . ."

12 The NRC Staff's characterization of the
13 pressurizer heaters as non-Class IE loads, by
14 definition, precludes them from being classed as
15 components "important to safety."
16
17
18

19 INTERROGATORY NO. 35:

20 Explain in detail whether and in what manner the
21 following design criteria would be met with respect to the
22 pressurizer heater and its associated controls.

- 23 (a) GDC 22 (diversity)
24 (b) GDC 2 and 4 (seismic and environmental qualification)
25 (c) GDC 10 (automatic initiation)
26 (d) GDC 3 and 22 (separation and independence)

1 ANSWER TO INTERROGATORY NO. 35:

2 The applicable General Design Criteria (G.D.C.) of
3 Appendix A to 10CFR Part 50, including GDC 2, 3, 4, 10, and
4 22 are met by the design of the pressurizer including its
5 associated components, such as the heaters. In particular,
6 application of these criteria is made to assure the
7 following:

- 8 1. that the pressure boundary of the pressurizer is not
9 jeopardized by penetrations in the pressurizer vessel
10 for the external electrical connections to the heaters
11 that are located inside the pressurizer, and
- 12 2. that when the heaters are loaded onto the emergency
13 electrical power buses, the separation and independence
14 of separate trains of this vital distribution system
15 are not violated by the hard wired electrical
16 connection to the heaters.

17 The pressurizer heaters in performing the function
18 of maintaining pressure in the pressurizer are not required
19 to terminate or mitigate an accident including a small break
20 LOCA. Therefore, the above GDCs do not apply to this
21 specific function.

22
23
24
25
26

1 INTERROGATORY NO. 36:

2 Specify precisely under what conditions the
3 pressurizer heaters will be relied upon at Diablo to:

- 4 (a) regulate and/or control pressure;
5 (b) initiate and/or maintain natural circulation;
6 (c) mitigate the consequences of inadequate core cooling;
7 (d) stabilize the reactor in post-accident conditions;
8 (e) any other functions performed by the pressurizer
9 heaters.

10
11 ANSWER TO INTERROGATORY NO. 36:

- 12 (a) The pressurizer heaters are used to establish
13 and maintain a saturated condition with a steam bubble
14 in the pressurizer. They assist in maintaining
15 pressurizer pressure at a nominal value and prevent
16 reactor trip as a result of pressure variations caused
17 by design transients. During steady state operation,
18 the pressurizer pressure control system normally
19 controls only the proportional heaters to compensate
20 for minor pressure fluctuations. The proportional
21 heaters will continuously operate at a low level to
22 compensate for the continuous spray rate (approximately
23 1 gpm) and pressurizer heat losses.
- 24 (b) Pursuant to a postulated loss of offsite
25 power, the pressurizer heaters can be used to enhance
26 natural circulation conditions by maintaining Reactor

1 Coolant System (RCS) until offsite power is restored
2 but are not required for this function. The primary
3 function of the heaters is to assist in maintaining RCS
4 pressure control by compensating for pressurizer heat
5 losses.

6 (c) Procedures for mitigating the consequences of
7 an event that could result in inadequate core cooling
8 do not require the use of the pressurizer heaters.

9 (d) Following design basis accidents in which the
10 safety injection (SI) system is manually or
11 automatically initiated, operation of the pressurizer
12 heaters is re-established to restore saturated
13 conditions in the pressurizer after safety injection
14 has been terminated and normal charging and letdown has
15 been restored. Following anticipated events in which
16 reactor trip is manually or automatically initiated,
17 the pressurizer heaters are used to return the RCS to
18 normal operating conditions.

19
20
21
22 INTERROGATORY NO. 37:

23 Assuming inoperability of the pressurizer heaters,
24 specify in detail each and every means, system, and/or
25 component available at Diablo Canyon to perform the
26 functions listed in Interrogatory No. 36 under the

1 conditions described in your response to that interrogatory.
2 State each and every fact upon which you base your
3 contention that such other means, systems, and/or components
4 can adequately perform the functions listed.

5
6 ANSWER TO INTERROGATORY NO. 37:

7 (a) If the pressurizer heaters are assumed to be
8 lost during normal operation, the normal charging and
9 letdown system would be used to control RCS pressure
10 until the heaters can be restored. Calculations which
11 have been performed indicate that several hours exist
12 prior to the time at which the heat losses via the
13 pressurizer result in RCS hot leg saturation. If the
14 heaters cannot be restored prior to the time of hot leg
15 saturation, continued effective primary to secondary
16 heat transfer can be ensured by maintaining the steam
17 generator water level at the nominal setpoint either by
18 use of the main feed system or the auxiliary feedwater
19 system. The option of maintaining RCS pressure at the
20 nominal value by using either the normal charging
21 system (if available) or the safety grade safety
22 injection system is also available.

23 (b) The method for maintaining natural
24 circulation conditions without pressurizer heaters is
25 similar to that discussed in 37(a). The major
26 distinction is that the heat losses via the pressurizer

1 are less for the natural circulation case due to the
2 loss of driving head for the pressurizer spray (thus no
3 spray flow will enter the pressurizer) because the
4 Reactor Coolant Pumps (RCPs) are not running. As a
5 result, a much longer period of time exists prior to
6 obtaining saturation conditions in the hot leg of the
7 RCS. As in 37(a), the operator also has the option of
8 maintaining RCS nominal pressure by using the normal
9 charging system or the safety grade safety injection
10 system.

11 (c) Since the pressurizer heaters are not used in
12 operating procedures for inadequate core cooling, no
13 alternate means are needed to mitigate the consequences
14 of inadequate core cooling.

15 (d) If the pressurizer heaters are not available
16 following an anticipated operational occurrence or a
17 design basis accident, the operator can use either the
18 normal charging and letdown system or the high head
19 safety injection system to maintain or restore RCS
20 pressure at the nominal value. Adoption of one of the
21 two pressure control modes in conjunction with
22 maintaining an effective heat sink in the secondary of
23 steam generator via the auxiliary feedwater system will
24 ensure that the system can be stabilized following a
25 postulated accident.
26

1 INTERROGATORY NO. 38:

2 Specify precisely each and every way in which the
3 pressurizer heaters and associated controls at Diablo Canyon
4 do not meet the safety-grade design criteria set forth in
5 Appendix A to 10 C.F.R. Part 50, and list each design
6 criteria not complied with.

7
8 ANSWER TO INTERROGATORY NO. 38:

9 The answer to interrogatory 44 indicates that the
10 pressurizer heaters and associated controls are in
11 compliance with all applicable NRC requirements and are
12 therefore also in compliance with all applicable safety
13 grade design criteria of Appendix A to 10CFR50, specifically
14 10, 14, 15, 17 and 20 as noted in item II.E.3.1 of
15 NUREG-0737 and GDC 2, 3, 4, 10 and 22 as listed in the
16 answer to interrogatory 35.

17
18
19
20
21
22
23
24
25
26

1 INTERROGATORY NO. 39:

2 Describe in detail what changes, if any, have been
3 made in the design, construction, installation, or operation
4 of the pressurizer heaters and associated controls at Diablo
5 Canyon since the TMI-2 accident in March 1979. With respect
6 to any changes or alterations, specify how, if at all, they
7 are expected or intended to enhance the reliability of the
8 components and/or safe operation of the plant, and state
9 each and every fact upon which your response is based.

10
11 ANSWER TO INTERROGATORY NO. 39:

12 As required by NUREG-0660 and 0737, the following
13 changes have been made since March 1979:

14 (A) Two circuit breakers were added -- one on each ESF bus
15 G and H to provide the capability to supply two heater
16 groups with emergency power.

17 (B) Two transformer switches were added to isolate the
18 above heater groups from either the offsite or the
19 emergency power source.

20 (C) Necessary interconnecting power and control wiring were
21 added.

22 (D) Wattmeters were installed indicating the power demand
23 of the heater groups which can be connected to the ESF
24 buses.

25 Operating Procedure OP A-4A:V was written to
26 incorporate design modifications to Pressurizer Heater

1 Groups No. 1-2 and 1-3, and it provides for transfer of
2 either Pressurizer Heater Group 1-2 or 1-3 from a non-vital
3 source. This procedure addresses the loading limitation of
4 the diesel generator to assure reliability is not degraded.
5 Specific guidance is given for shedding selected loads, as
6 required, from the vital bus to maintain the diesel
7 generator within its load capability.

8 These changes provide additional availability and
9 reliability of the power source supplying the pressurizer
10 heaters, which can reduce the number of challenges to the
11 Emergency Core Cooling System by facilitating natural
12 circulation until offsite power is restored.

13
14
15

16 INTERROGATORY NO. 40:

17 Describe in detail what you consider to be the
18 implications, if any, of the experience at TMI-2 in March
19 1979 with respect to the design, installation, maintenance,
20 and/or operation of the pressurizer heaters and associated
21 controls at Diablo Canyon. State each fact upon which your
22 response is based.

23 ///
24 ///
25 ///

26

1 ANSWER TO INTERROGATORY NO. 40:

2 PGandE agrees with the NRC Staff that the capabil-
3 ity to maintain pressure control in the reactor coolant sys-
4 tem is an important safety aspect, and that this capability
5 should be available during anticipated operational occur-
6 rences. To enhance this capability and provide additional
7 availability and reliability to the pressurizer heater
8 system, the capability of providing power to the pressurizer
9 heaters from the on-site emergency bus has been provided at
10 the DCPD. Reactor operations personnel have been provided
11 training and procedures related to the use of the on-site
12 emergency bus to provide power to the pressurizer heaters.
13

14 INTERROGATORY NO. 41:

15 With respect to the pressurizer heaters and
16 associated controls at Diablo Canyon, specify in detail:

- 17 (a) their precise location in Units 1 and 2;
18 (b) the precise specifications to which they were ordered
19 and/or designed and any differences between the design
20 specifications on the one hand and the heaters and
21 associated controls as installed on the other;
22 (c) their manufacturer;

23 ///

24 ///

25 ///

26

1 (d) the precise location of all seismic-related supports,
2 hangers, snubbers, etc., which are attached to, relate
3 to, or in any way could affect operation of the
4 heaters, associated controls, and/or associated cables,
5 electrical or otherwise;

6 (e) the precise polar position and elevation and coordinate
7 location with respect to the center of the containment
8 at which the cables for the pressurizer heaters cross
9 the annulus in Diablo Canyon, Unit 1.

10
11 ANSWER TO INTERROGATORY NO. 41:

12 (a) The location of the pressurizer heater Class
13 1E equipment for Unit 1 is as follows:

14 (1) 480 volt vital breakers 52-1G-72 and
15 52-1H-74 are located in the Auxiliary Building, Area H,
16 Elevation 115'-0", in the 480 Volt Vital Switchgear
17 Rooms 1G and 1H, on the East wall.

18 (2) The control switches for the 480 volt
19 vital breakers are located in the Auxiliary Building,
20 Area H, Elevation 140'-0", in the control room, on
21 control console CC1.

22 The location of the pressurizer heater Class
23 1E equipment for Unit 2 are found in locations
24 comparable to the Unit 1 equipment.

25 ///

26 ///

1 (b) The pressurizer heater Class 1E equipment
2 specifications can be found in the following documents:

3 (1) The specifications for the 480 volt
4 circuit breakers and enclosures can be found on
5 Purchase Order No.'s 4R-40053 and 4R-45511 for Unit 1
6 and Unit 2 respectively.

7 (2) The Class 1E cable used for connection
8 between the 480 volt vital breaker and bus
9 specifications can be found on Purchase Order No.
10 4R-0703.

11 (3) The specifications for the vital control
12 switches were purchased as part of the Nuclear Steam
13 Supply System and can be found in specification 8700.

14 (4) The support structure specifications for
15 the 480 volt vital breakers can be found on PGandE
16 drawing 050053, detail 34. All equipment was purchased
17 and installed in accordance with specifications.

18 Pressurizer heaters for Units 1 and 2 were
19 manufactured in accordance with Westinghouse Equipment
20 Specification 676440, Rev. 4 and Addendum 677231,
21 Rev. 0.

22 (c) Presssurizer heaters were manufactured by
23 Weigand.

24 (d) The pressurizer heaters Class 1E equipment
25 seismic supports are limited to the 480 volt vital
26 breaker enclosure supports which are located in the

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26

Auxiliary Building, Area H, Elevation 115'-0", in the 480 Volt Vital Switchgear 1G, 1H, 2G and 2H Rooms.

(e) The pressurizer heater power cables cross the annulus of the containment for Unit 1 in three basis groups:

(1) Group 1 runs from penetration 37E via tray EJB from a polar position of 256° and an elevation of 120'-6" crossing the annulus and ending at a polar position of 333° and an elevation of 128'-0".

(2) Group 2 runs from penetration 34E via trays EJC, EJCA and EJCB from a polar position of 250° and an elevation of 120'-6" crossing the annulus and ending at a polar position of 330° and an elevation 113'-0".

(3) Group 3 runs from penetration 1E via trays DJ, DJA and DJB from a polar position of 200° at an elevation of 120'-6" crossing the annulus and ending at a polar position of 60° (DJA) and 57° (DJB) and an elevation of 113'-0".

1 INTERROGATORY NO. 42:

2 List and describe in detail all analyses and tests
3 conducted by you, your agents, or your consultants with
4 respect to the pressurizer heaters and associated controls.

5 Specify:

- 6 (a) the person or entity conducting the analyses or tests;
7 (b) the purpose(s) of the analyses or tests;
8 (c) the range of test conditions or conditions assumed in
9 the analyses;
10 (d) the specifications of the components tested or
11 analyzed;
12 (e) the results of the tests or analyses;
13 (f) any other tests or analyses planned to be conducted
14 prior to full power operation.

15
16 ANSWER TO INTERROGATORY NO. 42:

17 As required by the Westinghouse specification, the
18 following tests were performed by the supplier on the
19 pressurizer heaters:

- 20 (1) Continuity test
21 (2) High Potential test
22 (3) Radiography - full length examination in
23 two planes ninety (90) degrees apart
24 (4) Megger Resistance test

25
26

1 INTERROGATORY NO. 43:

2 State whether you contend that the pressurizer
3 heaters and associated controls at Diablo Canyon should be
4 classified as important to safety and required to meet all
5 applicable safety-grade design criteria, and state each and
6 every fact upon which your response is based.

7
8 ANSWER TO INTERROGATORY NO. 43:

9 The response to Interrogatory 36 discussed in
10 detail the conditions under which the pressurizer heaters
11 are assumed to operate during normal operation, design
12 transients and following post accident conditions.
13 Furthermore, the response to Interrogatory 37 specified the
14 equipment that is available to the operator to utilize in
15 lieu of using the pressurizer heaters for RCS pressure
16 control.

17 To summarize the above two responses, the
18 pressurizer heaters provide only one of a number of methods
19 for controlling RCS pressure. The other methods utilize
20 safety grade components. Therefore, the pressurizer heaters
21 need not be classified as important to safety.

22
23
24
25
26

1 INTERROGATORY NO. 44:

2 Describe what modifications would have to be made
3 in the Diablo Canyon pressurizer heaters and associated
4 controls to bring them into compliance with all applicable
5 safety-grade design criteria. Estimate the minimum time
6 period necessary to make those modifications, and state each
7 and every fact upon which your estimate is based.

8

9 ANSWER TO INTERROGATORY NO. 44:

10 The pressurizer heaters and associated controls
11 are presently in compliance with all applicable existing NRC
12 rules and regulations. In addition, the design and
13 installation of the pressurizer heaters and associated
14 controls have been reviewed and accepted by the NRC Staff as
15 noted on pages 2-19 through 2-21 of Supplement 14 of the
16 Diablo Canyon SER.

17 Since the pressurizer heaters and associated
18 controls are in compliance with NRC requirements, and are in
19 compliance with safety-grade design criteria of Appendix A
20 to 10CFR50, 10, 14, 15, 17 and 20, as required by item
21 II.E.3.1 of NUREG-0737, no modifications are required.

22

23

24

25

26

1 INTERROGATORY NO. 45:

2 Specify precisely (a) which Emergency Operating
3 Procedures for Diablo Canyon include the use of pressurizer
4 heaters and (b) which require that the heaters be switched
5 to the on-site power supplies.
6

7 ANSWER TO INTERROGATORY NO. 45:

8 (a) The following DCPD Emergency Operating
9 Procedures include the use of pressurizer heaters:

10 EP OP-0, REACTOR TRIP WITH SAFETY INJECTION

11 EP OP-1, LOSS OF COOLANT ACCIDENT

12 EP OP-2, LOSS OF SECONDARY COOLANT

13 EP OP-3A, STEAM GENERATOR TUBE RUPTURE

14 EP OP-4, LOSS OF ELECTRICAL POWER

15 EP OP-8, CONTROL ROOM INACCESSIBILITY

16 EP OP-13, MALFUNCTION OF REACTOR PRESSURE CONTROL
17 SYSTEM

18 EP OP-23, NATURAL CIRCULATION OF REACTOR COOLANT

19 EP OP-44, GASEOUS VOIDS IN THE RCS.

20 (b) The following DCPD Emergency Operating
21 Procedures direct the operator to transfer a
22 pressurizer heater group to a vital power supply for
23 use, as required, to maintain RCS pressure.

24 EP OP-4, LOSS OF ELECTRICAL POWER

25 EP OP-8, CONTROL ROOM INACCESSIBILITY
26

1 INTERROGATORY NO. 46:

2 Explain the present Applicant position on Joint
3 Intervenors contention 12, regarding valve design, and state
4 each and every fact on which that position is based.
5

6 ANSWER TO INTERROGATORY NO. 46:

7 The Reactor Coolant System at Diablo Canyon Power
8 Plant Unit 1 contains three block valves and three relief
9 valves. All of the block valves, as well as their
10 instruments and controls, have been classified as components
11 important to safety and have been designed and fabricated to
12 meet all safety-grade design criteria. In addition, two of
13 the three relief valves and their associated circuitry have
14 been classified as components important to safety and meet
15 all safety-grade design criteria. The remaining relief
16 valve, which does not meet all safety-grade design criteria,
17 was installed to provide 100% local rejection without trip-
18 ping the reactor. It provides no safety related function.

19 The DCPD relief valves, block valves and
20 associated instruments and controls have been designed and
21 fabricated to meet all applicable requirements.
22 Furthermore, there has been a long history of successful
23 operation of relief and block valves representative of DCPD
24 valves under full power operation at other similar plants.
25 Therefore, these valves have been demonstrated to be capable
26 of functioning under required operating conditions.

1 Westinghouse has performed analyses to show that,
2 even if all of the relief valves, block valves and their
3 associated controls and instruments had failed during full
4 power operation, core uncovering would not occur and public
5 health and safety would not be endangered.

6
7
8

9 INTERROGATORY NO. 47:

10 Does the current position differ from the position
11 of the Applicant in any prior proceedings? If so, identify
12 the proceeding(s), explain the prior position, and explain
13 the basis for the change in position.

14

15 ANSWER TO INTERROGATORY NO. 47:

16 No.

17
18
19

20 INTERROGATORY NO. 48:

21 Identify any officers or employees of, or
22 consultants to, the Applicant who dissent from the present
23 Applicant position on Joint Intervenors' contention 12.
24 Explain the reasons for which any such person dissents.

25 ///

26 ///

1 ANSWER TO INTERROGATORY NO. 48:

2 None.

3
4
5
6 INTERROGATORY NO. 49:

7 Identify the specific sections and page numbers of
8 the FSAR for Diablo Canyon and the NRC Staff's SER and SER
9 Supplements for Diablo Canyon, which are relied upon in
10 formulating the Applicant position on Joint Intervenors'
11 contention 12.

12
13 ANSWER TO INTERROGATORY NO. 49:

14 The following FSAR sections are identified:

- 15 3.1 Conformance with AEC General Design Criteria
16 3.2 Classification of Structures, Components and Systems
17 3.6 Criteria for Protection Against Dynamic Effects
18 Associated with a Postulated Rupture of Piping
19 3.9 Mechanical Systems and Components
20 5.2 Integrity of the Reactor Coolant System Boundary
21 15.1 Condition I-Normal Operation and Operational Transients

22 The following section of SER Supplement 15 is
23 identified:

- 24 Appendix B: Environmental Qualification of Safety-Related
25 Electrical Equipment
26

1 INTERROGATORY NO. 50:

2 Identify all sections and page numbers of the
3 FSAR, SER, and SER Supplements which contain subject matter
4 pertaining to Joint Intervenors' contention 12.

5
6 ANSWER TO INTERROGATORY NO. 50:

7 Applicant objects to this interrogatory. See
8 response to Interrogatory number 33.

9
10
11
12 INTERROGATORY NO. 51:

13 Does the Applicant agree that proper operation of
14 PORVs, associated block valves and the instruments and
15 controls for these valves is essential to mitigate the
16 consequences of accidents? Explain your response fully.

17
18 ANSWER TO INTERROGATORY NO. 51:

19 The applicant agrees that proper operation of a
20 PORV, associated block valve and the instruments and
21 controls for the necessary valves is essential to mitigate
22 the consequence of accidents.

23 The accident analyses presented in the DCPD Safety
24 Analysis Report demonstrate that the pressurizer power
25 operated relief valves (PORV) are not required to actuate
26 automatically on a pressure setpoint to mitigate the

1 consequences of the accidents, i.e., the licensing criteria
2 are met with or without automatic PORV opening when
3 requested. However, postulated transients have been
4 analyzed since TMI which require that the operator be
5 capable of manually opening and/or closing the PORV's. For
6 such postulated transients, the proper operation of a PORV
7 or block valve is essential.

8 For the case of an inadvertently stuck open PORV,
9 the operator has been trained in the use of an Emergency
10 Procedure describing the operations that must be implemented
11 to take the plant to a safe shutdown condition. Once the
12 operator closes the associated PORV block valve, the plant
13 can immediately be restored to normal plant conditions.
14
15
16

17 INTERROGATORY NO. 52:

18 Does the Applicant agree that failures of these
19 valves, instruments and controls can cause or aggravate a
20 LOCA? Explain your response fully.
21

22 ANSWER TO INTERROGATORY NO. 52:

23 The Applicant agrees that it is possible to
24 postulate scenarios in which failures of the PORV's and
25 their instruments and controls can result in a small break
26 LOCA. An inadvertent opening of a pressurizer PORV results

1 in a breach of the RCS pressure boundary, necessitating the
2 actuation of the Emergency Core Cooling System (ECCS) to
3 mitigate the accident consequences. Even though the DCPD
4 design provides the operator with the capability to open
5 and/or close the PORV's with safety grade circuitry, the
6 ECCS system is designed to mitigate the consequences of a
7 postulated failure of the PORV's to close.
8
9
10

11 INTERROGATORY NO. 53:

12 Provide the justification for the failure to
13 classify PORVs and associated block valves and their
14 respective instruments and controls as "components important
15 to safety," requiring compliance with safety-grade design
16 criteria.
17

18 ANSWER TO INTERROGATORY NO. 53:

19 All block valves (and their instruments and
20 controls) associated with the PORVs are classified as
21 safety-related. Two of the three PORVs are classified as
22 safety-related although they are not required to be such.
23 Operation of only one PORV is necessary to fulfill the
24 required safety function. To insure operation of one PORV,
25 redundant devices are provided. Therefore, the third PORV
26 ///

1 need not be classified safety-related. Additional discus-
2 sions have been provided in response to Interrogatories 46
3 and 51.
4
5
6

7 INTERROGATORY NO. 54:

8 Explain how the motive and control components of
9 the PORVs and their associated block valves and the vital
10 instruments shall be supplied by the on-site emergency power
11 source when offsite power is not available without degrading
12 the capacity, capability and reliability of emergency power
13 in violation of GDC 17.
14

15 ANSWER TO INTERROGATORY NO. 54:

16 Normal plant instrument air supply (motive power)
17 to each redundant valve is provided with a dedicated high
18 pressure nitrogen backup system capable of operating the
19 valves 140 times. This backup system is classified as
20 safety-related and is not dependent on any external power.

21 Power for control components of the three PORV's
22 is provided from three, Class 1E, 125 V DC distribution
23 panels. The distribution panels are redundant to each
24 other. Power for motive and control for the three
25 associated block valves is provided from three, Class 1E,
26 480V AC motor control centers, each redundant to each other.

1 The total electrical design for these valves meets GDC 17.
2 Therefore, the capacity, capability and reliability of the
3 emergency power will not be degraded in the event of loss of
4 offsite power.

5
6
7
8 INTERROGATORY NO. 55:

9 How have the devices through which motive and
10 control power components for the PORVs and their associated
11 block valves are connected to emergency buses been
12 qualified in accordance with safety-grade requirements?
13

14 ANSWER TO INTERROGATORY NO. 55:

15 The devices through which motive and control power
16 components for the PORVs and their associated block valves
17 are connected to emergency buses have been qualified in
18 accordance with applicable safety-grade requirements as
19 follows:

20 Control and power wiring subjected to a harsh
21 environment have been environmentally qualified for the
22 environment to which they could be subjected.

23 Circuit breaker panel boards and motor
24 control centers have been seismically qualified.
25
26

1 INTERROGATORY NO. 56:

2 With respect to the valves, instruments, and
3 controls cited in contention 12, list each and every General
4 Design Criterion in Appendix A to 10 C.F.R. Part 50 which is
5 not complied with, and describe precisely in what respects
6 those valves, instruments, and controls do not comply.
7

8 ANSWER TO INTERROGATORY NO. 56:

9 With respect to the valves, DCPD complies with
10 General Design Criteria 1, 14, 15 and 30. No other General
11 Design Criterion applies.

12 The instruments and controls associated with the
13 PORV's and block valves comply with all applicable safety
14 grade criteria of Appendix A to 10CFR50.
15
16
17

18 INTERROGATORY NO. 57:

19 Describe precisely each and every function of the
20 PORVs at Diablo Canyon, and for each such function, specify
21 in detail the operating conditions in which the PORVs would
22 be relied upon to perform that function.
23

24 ///

25 ///

26 ///

1 ANSWER TO INTERROGATORY NO. 57:

2 The Diablo Canyon power-operated relief valves
3 have three functions which are not safety-related.

- 4 1. prevent reactor trip on high pressure by limiting high
5 pressure transients beyond the capability of the
6 pressurizer sprays.
7 2. minimize the operation of the spring loaded safety
8 valves.
9 3. vent non-condensable gases from the pressurizer to
10 proper operation of the pressure control system.

11 They have one safety-related function:

12 Provide cold overpressure protection on
13 startup and shutdown to maintain pressure below the
14 limits specified in Section 3/4.4.9 of the Technical
15 Specifications.

16 The PORVs would be expected and have been
17 qualified, but are not required, to perform all of the above
18 functions in conditions ranging from normal operation to:

- 19 1. the Hosgri Seismic Event;
20 2. the loss of coolant accident as described in the FSAR,
21 and
22 3. the main steam line break inside containment.

23 The latter two conditions would not pertain to low
24 pressure operation.

1 INTERROGATORY NO. 58:

2 Describe precisely each and every function of the
3 block valves at Diablo Canyon, and for each such function,
4 specify in detail the operating conditions in which the
5 block valves would be relied upon to perform that function.
6

7 ANSWER TO INTERROGATORY NO. 58:

8 The Diablo Canyon block valves have two functions:

- 9 1. isolate leaking PORV until maintenance can be
10 performed, and
11 2. isolate a stuck open PORV until the plant can be
12 shutdown.

13 Both of these functions are required to occur in a
14 normal operating environment, since operating procedures
15 direct the operator to close these valves and isolate the
16 PORV before significant reactor coolant can escape to the
17 containment. These valves have been qualified to function
18 in such environment and also during and after the Hosgri
19 Seismic Event.
20

21
22
23 INTERROGATORY NO. 59:

24 Specify precisely which Emergency Operating
25 Procedures for Diablo Canyon include the use of (a) PORVs
26 and (b) block valves.

1 ANSWER TO INTERROGATORY NO. 59:

2 The following DCPD Emergency Operating Procedures
3 specify the use of Pressurizer PORV's and/or PORV block
4 valves:

5 EP OP-0, REACTOR TRIP WITH SAFETY INJECTION

6 EP OP-1, LOSS OF COOLANT ACCIDENT

7 EP OP-2, LOSS OF SECONDARY COOLANT

8 EP OP-3A, STEAM GENERATOR TUBE RUPTURE

9 EP OP-4, LOSS OF ELECTRICAL POWER

10 EP OP-5, REACTOR TRIP WITHOUT SAFETY INJECTION

11 EP OP-13, MALFUNCTION OF REACTOR PRESSURE CONTROL
12 SYSTEM

13 EP OP-22, EMERGENCY SHUTDOWN

14 EP OP-38, ANTICIPATED TRANSIENT WITHOUT TRIP

15
16
17
18 INTERROGATORY NO. 60:

19 Describe in detail what modifications would have
20 to be made in the PORVs, block valves, instruments, and
21 controls referred to in contention 12 to bring them into
22 compliance with all applicable safety-grade design criteria.
23 Estimate the minimum period necessary to make those
24 modifications, and state each and every fact upon which your
25 estimate is based.

26 ///

1 ANSWER TO INTERROGATORY NO. 60:

2 The necessary power operated relief valves,
3 associated block valves, and the instruments and controls
4 for these valves presently comply with all applicable
5 safety-grade design criteria and therefore no modifications
6 are required.

7
8
9
10 INTERROGATORY NO. 61:

11 Describe in detail the current status of the EPRI
12 valve performance testing program. In your response, state:

13 (a) when the relief and safety valve testing will be
14 completed;

15 (b) under what conditions (e.g., transition flow, full
16 water flow, saturated steam, etc.) have the relief and
17 safety valves been tested to date;

18 (c) whether any of the relief and safety valves tested have
19 failed, suffered galling, or been in any way damaged
20 during the testing, and, if so, describe in detail the
21 circumstances of such occurrences;

22 (d) why the relief and safety valve testing program
23 completion date has been delayed and when the program
24 is now scheduled to be completed;

25 (e) whether an EPRI block valve testing program is planned
26 and, if so, when it will be completed;

- 1 (f) other than the block valve failures discussed at the
2 Diablo Canyon low power test hearing in May 1981,
3 whether any of the block valves tested have failed,
4 suffered galling, or been in any way damaged during the
5 testing, and, if so, describe in detail the
6 circumstances of such occurrences;
- 7 (g) whether PGandE has submitted to the NRC a correlation
8 or other evidence to substantiate that the valves
9 tested in the EPRI program demonstrate the
10 functionability of the relief and safety valves
11 installed at Diablo Canyon, and, if so, describe that
12 correlation or other evidence in detail;
- 13 (h) to what extent, if at all, the control circuitry,
14 piping, and supports associated with the Diablo Canyon
15 relief and safety valves have been qualified, and, if
16 so, describe precisely how they have been qualified and
17 the results of any related tests or analyses;
- 18 (i) when the "correlation" referred to in subpart (g) of
19 this interrogatory will be submitted to the NRC.
- 20

21 ANSWER TO INTERROGATORY NO. 61:

22 The Applicant objects to this interrogatory on the
23 basis of relevancy. The EPRI valve performance testing
24 program is clearly outside the scope of this contention,
25 which concerns the classification of power operated relief
26 valves, block valves and associated circuitry, and

1 compliance with design criteria. The EPRI test program was
2 litigated in the low power hearings which resulted in a
3 license being issued.
4
5
6

7 INTERROGATORY NO. 62:

8 On August 19, 1981, an emergency planning exercise
9 for Diablo Canyon was held in San Luis Obispo. Based on
10 your involvement in that exercise and your knowledge of the
11 involvement of other persons, officials, agencies, or other
12 entities, describe the exercise in detail and include in
13 your response at least the following information:

- 14 (a) a detailed description of the exercise scenario
15 employed, including the simulated events, time period
16 and locations involved;
- 17 (b) the number of persons participating in the drill
18 including the specific company, agency, or other entity
19 represented, if any, and the extent and nature of their
20 involvement;
- 21 (c) (1) the number of PGandE personnel assumed or deemed to
22 have been evacuated during the course of the exercise;
23 (2) the number of PGandE employees actually evacuated,
24 and (3) when such evacuation was begun and when
25 completed;

26 ///

- 1 (d) (1) the number of non-PGandE persons (e.g., members of
2 the public) assumed or deemed to have been evacuated
3 and/or sheltered during the course of the exercise,
4 (2) the number of such persons actually evacuated
5 and/or sheltered, and (3) when such evacuation was
6 begun and when completed;
- 7 (e) (1) the number of ambulances assumed or deemed to have
8 been utilized during the course of the exercise and
9 (2) the number of ambulances actually utilized;
- 10 (f) (1) the number of simulated injured persons assumed or
11 deemed to have been transported to and treated at
12 French Hospital during the course of the exercise and
13 (2) the number of simulated injured persons actually
14 transported and treated at French Hospital;
- 15 (g) (1) the number of simulated injured persons assumed or
16 deemed to have been transported to and treated at
17 St. Francis Hospital in San Francisco during the course
18 of the exercise and (2) the number of simulated injured
19 persons actually transported to and treated at
20 St. Francis Hospital.
- 21 (h) (1) the number of residences and/or households in San
22 Luis Obispo and Santa Barbara Counties assumed or
23 deemed to have been contacted during the exercise,
24 (2) the number and location of such residences and/or
25 households actually contacted, and (3) the time period
26 required to contact such residences and/or households;

- 1 (i) (1) the number of automobiles assumed or deemed to have
2 utilized Highway 101 as an evacuation route during the
3 course of the exercise and (2) the number of
4 automobiles which actually utilized Highway 101 as an
5 evacuation route;
- 6 (j) (1) the number of persons or automobiles assumed or
7 deemed to have utilized Highway 1 as an evacuation
8 route during the course of the exercise and (2) the
9 number of persons or automobiles which actually
10 utilized Highway 1 as an evacuation route;
- 11 (k) (1) the number of persons or automobiles assumed or
12 deemed to have utilized Avila Road as an evacuation
13 route during the course of the exercise and (2) the
14 number of persons or automobiles which actually used
15 Avila Road as an evacuation route;
- 16 (l) (1) the number of persons assumed or deemed to have
17 been notified of a radiological emergency occurring at
18 Diablo Canyon during the course of the exercise,
19 (2) the number and location of persons actually
20 notified of such emergency, and (3) the time period
21 required to complete such notification;

22 ///
23 ///
24 ///
25
26

- 1 (m) (1) the number of emergency response personnel (i.e.,
2 law enforcement, fire, health, park, military,
3 monitoring, etc.) assumed or deemed to have been
4 mobilized and/or dispatched during the course of the
5 exercise and (2) the number of such personnel actually
6 mobilized and/or dispatched;
- 7 (n) (1) the protective actions assumed or deemed to have
8 been taken within the plume exposure pathway EPZ by
9 public officials, emergency response personnel, and
10 members of the public during the course of the exercise
11 and (2) the protective actions actually taken by such
12 persons within the area specified;
- 13 (o) (1) the protective actions assumed or deemed to have
14 been taken within the ingestion pathway EPZ by public
15 officials, emergency response personnel, and members of
16 the public during the course of the exercise and
17 (2) the protective actions actually taken by such
18 persons within the area specified;
- 19 (p) (1) the number and locations of radiological monitoring
20 samplings assumed or deemed to have been taken during
21 the course of the exercise and (2) the number and
22 location of such samplings actually taken;
- 23 (q) (1) the number of persons involved in the exercise and
24 (2) the number of persons reasonably expected to be
25 involved in an actual radiological emergency at Diablo
26 Canyon;

- 1 (r) (1) the number of automobile accidents or collisions,
2 if any, assumed or deemed to have occurred on main
3 evacuation routes during the course of the exercise and
4 (2) the number of such accidents or collisions
5 reasonably expected to occur in the event a full scale
6 evacuation is ordered in response to an actual
7 radiological emergency at Diablo Canyon;
- 8 (s) (1) the types and quantities of emergency response
9 equipment (e.g., communications equipment, respiratory
10 equipment, protective clothing, monitoring equipment,
11 vehicles, helicopters, signs, placards, medical
12 equipment, etc.) assumed or deemed to be available or
13 to have been used during the course of the accident and
14 (2) the types and quantities of such equipment actually
15 available or used;
- 16 (t) (1) the number of media personnel present and inquiries
17 from the public received during the course of the
18 exercise and the number of such personnel likely to be
19 received in the event of an actual radiological
20 emergency at Diablo Canyon;
- 21 (u) the names of all local and state officials, agencies,
22 offices, and/or other entities actually notified as
23 part of the exercise, by telephone or otherwise,
24 regarding the simulated emergency at Diablo Canyon; the
25 approximate time of each such notification; the precise
26 language of the notification message; the name of the

1 person who notified such officials and/or agencies; the
2 names of each person who received the notice; and the
3 time period required to complete notification of all
4 such persons.

5
6 ANSWER TO INTERROGATORY NO. 62:

7 (a) A detailed description of the exercise
8 scenario utilized on August 19, 1981 has been provided.
9 Reference discovery document EPNG 59753 - Diablo Canyon
10 Power Plant Emergency Preparedness Exercise Scenario.

11 (b) The following major entities to the best of
12 our knowledge participated in the August 19, Exercise:

- 13 1) Pacific Gas and Electric Company
- 14 2) County of San Luis Obispo and supporting agencies
15 identified in the SLO County Nuclear Power Plant
16 Emergency Response Plan including:
 - 17 a) Chairman, County Board of Supervisors
 - 18 b) Emergency Services Director
 - 19 c) County Health Agency/County Health Officer
 - 20 d) Environmental Health Director
 - 21 e) Air Pollution Control District
 - 22 f) Agricultural Commissioner
 - 23 g) County Public Information Officer
 - 24 h) County Social Services
 - 25 i) Red Cross
 - 26 j) County Engineer

- 1 k) County Fire Department
- 2 l) County General Services
- 3 m) County Counsel
- 4 n) County Superintendent of Schools
- 5 o) County Sheriff
- 6 p) Area Fire and Rescue Coordinator
- 7 g) County Technical Services
- 8 3) City of Morro Bay
- 9 4) State Office of Emergency Services
- 10 5) Other State Agencies

11 The number of persons participating in the
12 exercise representing these various entities varied
13 from several to approximately 200. The extent and
14 nature of their involvement is defined in the agencies
15 various emergency plans and standard operating
16 procedures. These are discoverable documents.

17 (c) (1) During the course of the exercise,
18 approximately 250 PGandE personnel were assumed to have
19 evacuated.

20 (2) During the exercise on August 19, 1981,
21 11 PGandE employees were actually evacuated.

22 (3) The evacuation began at 9:05 a.m. and
23 was completed by 11:00 a.m.

24 (d) (1) Approximately 53,000 non-PGandE persons
25 were assumed to have been evacuated and/or sheltered
26 during the course of the exercise.

1 (2) The number of persons actually evacuated
2 and/or sheltered during the exercise was 45. These
3 persons were evacuated from Montada de Oro State Park.

4 (3) The evacuation began at 10:15 a.m. The
5 evacuees arrived at Camp Roberts at 10:15 a.m. They
6 were released at 2:30 p.m. and were returned to Montana
7 de Oro at 4:00 p.m.

8 Note: Additional evaucation capability was
9 demonstrated when plant security personnel
10 turned away substantial numbers of
11 construction workers reporting for work
12 during the exercise.

13 (e) (1) During the course of the exercise, two
14 (2) ambulances were assumed to have been utilized.

15 (2) One ambulance was actually utilized
16 during the course of the exercise.

17 (f) (1) During the course of the exercise, one
18 (1) person was assumed transported to French Hospital.

19 (2) One simulated injured person was
20 actually transported and treated at French Hospital.

21 (g) (1) During the course of the exercise, no
22 simulated injured persons was assumed transported to
23 and treated at St. Francis Hospital.

24 (2) No simulated injured persons were
25 actually transported to and treated at St. Francis
26 Hospital.

- 1 (h) (1) None.
- 2 (2) None.
- 3 (3) Not applicable: Ref (2) above.
- 4 (i) (1) Approximately 3,100 vehicles were
5 assumed to have utilized Highway 101 as an evacuation
6 route during the course of the exercise.
- 7 (2) Approximately 45 persons (1 Bus)
8 actually utilized Highway 101 as an evacuation route
9 during the exercise.
- 10 (j) (1) Approximately 1500 vehicles were assumed
11 to have utilized Highway 1 as an evacuation route
12 during the course of the exercise.
- 13 (2) Approximately 45 persons (1 Bus)
14 actually utilized Highway 1 as an evacuation route
15 during the exercise.
- 16 (k) (1) Approximately 1200 vehicles were assumed
17 to have utilized Avila Road as an evacuation route
18 during the course of the exercise.
- 19 (2) Approximately 4 vehicles actually used
20 Avila Road as an evacuation route.
- 21 (l) (1) Millions of persons were assumed to have
22 been notified of a radiological emergency occurring at
23 Diablo Canyon during the course of the exercise.
- 24 (2) Hundreds of thousands of people
25 throughout the country were actually notified of such
26 an emergency.

1 (3) Notification was completed over a period
2 of a few hours.

3 (a) (1) The number of emergency response
4 personnel assumed or deemed to have been mobilized
5 and/or dispatched during the course of the exercise is
6 unknown.

7 (2) The number of such personnel actually
8 mobilized and/or dispatched is unknown.

9 (n) (1) Protective actions assumed or deemed to
10 have been taken within the plume exposure LPZ by public
11 officials, emergency response personnel, and members of
12 the public during the course of the exercise included
13 evacuation, recommendations to administer potassium
14 iodide pills to place livestock on stored feed.

15 (2) Some evacuation measures were actually
16 demonstrated. Recommendations were made to administer
17 potassium iodide pills and to place livestock on stored
18 feed.

19 (o) (1) Protective actions assumed or deemed to
20 have been taken within the ingestion pathway EPZ by
21 public officials, emergency response personnel, and
22 members of the public during the course of the exercise
23 included county announcements restricting reentry into
24 the evacuated area pending completion of ingestion
25 pathway studies.

26 ///

1 (2) No protective actions were actually
2 taken by such persons within the area specified.

3 (p) (1) See answer to Part (2) of this question.

4 (2) Approximately forty-eight (48) ambient,
5 particulate or deposition radiation samplings were
6 actually taken (i.e., instruments deployed,
7 calculations made, etc.) at various locations as
8 dictated by meteorological conditions and plume
9 dispersal, during the August 19, 1981 exercise.

10 The compressed timeframe required by the
11 exercise resulted in a lesser number of radiation
12 samplings than would result in an actual radiological
13 accident.

14 (q) (1) Approximately 400-500 persons were
15 involved in the exercise.

16 (2) Approximately 400-500 persons can
17 reasonably be expected to be involved in an actual
18 radiological emergency at Diablo Canyon.

19 (r) (1) One automobile accident was assumed to
20 have occurred on main evacuation routes during the
21 course of the exercise.

22 ///

23 ///

24 ///

25

26

1 (2) It is impossible to predict the number
2 of such accidents reasonably expected to occur in the
3 event of a full scale evacuation is ordered in response
4 to an actual radiological emergency at Diablo Canyon.
5 The scope of the evacuation area has not been defined
6 e.g.,: LPZ, 1 Sector or multiple sector evacuations.

7 (s) (1) Applicant objects to this question on
8 the basis that it is (a) impossible to answer, (b)
9 overly broad, (c) not fully within the knowledge of the
10 answering party and (d) not designed to lead to
11 admissible evidence.

12 (t) (1) Approximately 20-30 media personnel were
13 present during the August 19, 1981 exercise. Inquiries
14 from the public were few in number. It is impossible
15 to predict the number of such personnel likely to be
16 present and inquiries from the public likely to be
17 received in the event of an actual radiological
18 emergency at Diablo Canyon. Such a response would be
19 dependent upon many variables including the scope,
20 extent, duration of the accident as well as the
21 significance of other breaking newsworthy events.

22 (u) All major entitled participating in the
23 August 19, 1981, exercise were contacted following the
24 appropriate emergency plans and standard operating
25 procedures. Communications logs and in some instances
26 tape recordings of conversations were recorded to

1 document major events. This material has been
2 submitted for discovery.

3
4 INTERROGATORY NO. 63:

5 Based on your involvement in the August 19, 1981
6 emergency planning exercise and your knowledge of the
7 involvement of other persons, officials, agencies, or other
8 entities in that exercise, provide a detailed chronology of
9 all actions taken by the participants in connection with the
10 exercise, and include in that chronology at least the
11 following information:

- 12 (a) the time each action was taken;
- 13 (b) the name of the person taking the action;
- 14 (c) the office, agency, or other entity represented by that
15 person;
- 16 (d) any problems or difficulties encountered by that person
17 in taking the action;
- 18 (e) the location of the action, including, for example,
19 point of origin and point of destination;
- 20 (f) any equipment (i.e., vehicles, walkie-talkie, radio,
21 protective clothing, etc.) utilized in taking the
22 action;
- 23 (g) the consequences resulting from the action.

24 ///
25 ///
26 ///

1 ANSWER TO INTERROGATORY NO. 63:

2 A detailed chronology of all actions taken by the
3 participants in connection with the exercise in the level of
4 detail requested is not available. The following documents
5 have been provided for discovery and to some extent will
6 contain particular information regarding specific emergency
7 response actions in light of the very broad, general content
8 of this request.

9 DOCUMENT NUMBER

10	EPPI-0090023	EPPI-0090062	EPGP-0095193
	EPPI-0090024	EPPI-0090120	EPPO-0095628
11	EPPI-0090032	EPPI-0090142	EPPI-0095705
	EPPI-0090062	EPAD-0092221	EPCE-0095764
12	EPPI-0090104	EPPI-0093859	EPCE-0095765
	EPPI-0090120	EPPI-0093864	EPCE-0095766
13	EPPI-0090142	EPPI-093865	EPCE-0095767
	EPNP-0083334	EPPI-0093866	EPCE-0095836
14	EPED-0086113	EPPI-0094072	EPPI-0096005
	EPNP-0088768	EPPI-0094073	EPDC-0096115
15	EPPI-0090023	EPPI-0094074	EPDC-0096112
	EPPI-0090024	EPPI-0094075	EPDC-0096128
16	EPPI-0090032	EPPI-0094078	EPDC-0096145
	EPPI-0090033	EPPI-0094082	EPDC-0096161
17	EPPI-0090034	EPPI-0094083	EPPI-0096637
	EPPI-0090045	EPPI-0094084	EPPI-0096639

18
19
20
21 INTERROGATORY NO. 64:

22 Explain in detail how the exercise included such
23 things as

- 24 (a) simulated casualties;
25 (b) offsite fire department assistance;
26 (c) rescue of personnel;

- 1 (d) use of protective clothing;
2 (e) deployment of radiological monitoring teams; and
3 (f) public information and notification activities.
4

5 ANSWER TO INTERROGATORY NO. 64:

6 (a) The exercise scenario provided one simulated
7 casualty, a broken leg, when a worker slipped and fell
8 while exiting the reactor containment building. Two
9 additional simulated casualties were provided, by the
10 exercise scenario, when the ambulance transporting the
11 broken leg victim was involved in an automobile
12 accident. All three casualties simulated
13 unconsciousness due to the ambulance accident.

14 (b) The California Department of Forestry (CDF)
15 participated in a communications capability check
16 during the exercise. All other offsite fire fighting
17 assistance was simulated during the exercise.

18 (c) The broken leg victim was carried out of the
19 reactor containment building by a first aid team using
20 a stretcher. Ambulance accident victims were assisted
21 by medics from a simulated second ambulance.

22 (d) The first aid teams that assisted injured,
23 contaminated personnel wore anti-contamination
24 clothing. Fire fighting teams wore standard fire
25 fighting protective clothing and associated equipment
26 such as respirators.

1 (e) The onsite radiological monitoring team was
2 deployed, in accordance with radiological monitoring
3 procedures, by Technical Support Center personnel. The
4 three offsite radiological monitoring teams, including
5 the mobile environmental monitoring laboratory, were
6 deployed by Emergency Operations Facility personnel in
7 accordance with their Standard Operating Procedures.

8 (f) Public information was disseminated through
9 the joint PGandE/County Public Information Center/Media
10 Center. Public notification is the responsibility of
11 San Luis Obispo County officials and was simulated
12 through the use of SLO County Emergency Plan
13 implementing procedures.

14
15
16
17 INTERROGATORY NO. 65:

18 State how, if at all, the August 19 exercise
19 simulated and/or tested for the complicating effects of a
20 major earthquake on emergency response capability at Diablo
21 Canyon.

22
23 ANSWER TO INTERROGATORY NO. 65:

24 The August 19, 1981, accident scenario did not
25 incorporate an earthquake incident.
26

1 INTERROGATORY NO. 66:

2 State what, if any, critical emergency response
3 equipment (i.e., vehicles, communications systems and lines,
4 monitoring equipment, notification sirens, etc.) were
5 assumed to fail during the course of the August 19 exercise.
6

7 ANSWER TO INTERROGATORY NO. 66:

8 No critical emergency response equipment was
9 assumed to fail during the course of the August 19 exercise.
10
11
12

13 INTERROGATORY NO. 67:

14 State what, if any, evacuation routes
15 (a) for the site and
16 (b) for the plume exposure pathway EPZ
17 were assumed to be fully or partially blocked during the
18 course of the August 19 exercise.
19

20 ANSWER TO INTERROGATORY NO. 67:

21 (a) None.
22 (b) None.
23
24
25
26

1 INTERROGATORY NO. 68:

2 In light of the information and experience gained
3 from the August 19 exercise, what revisions, changes, or
4 alterations, if any, will be made in the following documents
5 prior to full power operation of Diablo Canyon:

- 6 (a) the Diablo Canyon on-site emergency plan and emergency
7 procedures;
- 8 (b) the San Luis Obispo County emergency and evacuation
9 plans;
- 10 (c) the State of California emergency plan;
- 11 (d) the San Luis Obispo County Sheriff's "plan" (Board
12 Exh. 5 at Diablo Low Power Test hearing).

13
14 ANSWER TO INTERROGATORY NO. 68:

15 On October 15, 1981, representatives from FEMA,
16 San Luis Obispo County, California State Office of Emergency
17 Services, and NRC Region V met in Sacramento to review FEMA
18 findings and recommendations identified following the
19 August 19 exercise. A draft open item action list was
20 established on responsibilities assigned for closure.
21 Activities are now in progress to finalize this document,
22 including task completion schedules. This document will be

23 ///

24 ///

25 ///

26

1 furnished as a supplement to PGandE's response to the
2 request for production of documents.

3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26


Respectfully submitted,

MALCOLM H. FURBUSH
PHILIP A. CRANE, JR.
RICHARD F. LOCKE
Pacific Gas and Electric Company
P.O. Box 7442
San Francisco, California 94120
(415) 781-4211

ARTHUR C. GEHR
Snell & Wilmer
3100 Valley Center
Phoenix, Arizona 85073
(602) 257-7288

BRUCE NORTON
Norton, Burke, Berry & French, P.C.
3216 N. Third Street
Suite 300
Phoenix, Arizona 85012-2699
(602) 264-0033


Attorneys for
Pacific Gas and Electric Company

By 
for Bruce Norton

DATED: October 26, 1981.


JOINT INTERVENORS' SECOND SET OF
INTERROGATORIES AND REQUEST
FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 46-50, 51, 52, 53, 60, 61 . Said
answers are true and correct to the best of my knowledge
and belief.



G. C. Wu

Subscribed and sworn to
before me this 26th day
of October, 1981.



Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of
California



My Commission expires January 28, 1985


JOINT INTERVENORS' SECOND SET OF
INTERROGATORIES AND REQUEST
FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 29-38, 40, 42, 43, 44, 56 . Said
answers are true and correct to the best of my knowledge
and belief.



C. O. Coffey

Subscribed and sworn to
before me this 26th day
of October, 1981.


Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of
California



My Commission expires January 28, 1985

JOINT INTERVENORS' SECOND SET OF
INTERROGATORIES AND REQUEST
FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 57, 58. Said
answers are true and correct to the best of my knowledge
and belief.

J. J. McCracken

J. J. McCracken

Subscribed and sworn to
before me this 26th day
of October, 1981.

Theodora Cooke


Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of
California




My Commission expires January 28, 1985

JOINT INTERVENORS' SECOND SET OF
INTERROGATORIES AND REQUEST
FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 45, 59. Said
answers are true and correct to the best of my knowledge
and belief.


W. H. Fujimoto

Subscribed and sworn to
before me this 26th day
of October, 1981.



Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of
California

SEAL

My Commission expires January 28, 1985


JOINT INTERVENORS' SECOND SET OF
INTERROGATORIES AND REQUEST
FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 62, 63, 64, 65, 66, 67, 68. Said
answers are true and correct to the best of my knowledge
and belief.



R. J. McDevitt

Subscribed and sworn to
before me this 26thday
of October, 1981.



Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of
California



My Commission expires January 28, 1985

JOINT INTERVENORS' SECOND SET OF
INTERROGATORIES AND REQUEST
FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 62, 63, 64, 65, 66, 67, 68 . Said
answers are true and correct to the best of my knowledge
and belief.

S. M. Skidmore

S. M. Skidmore

Subscribed and sworn to
before me this 26th day
of October, 1981.


Theodora Cooke (SEAL)

Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of
California


My Commission expires January 28, 1985

JOINT INTERVENORS' SECOND SET OF
INTERROGATORIES AND REQUEST
FOR PRODUCTION OF DOCUMENTS
TO PACIFIC GAS AND ELECTRIC COMPANY

I have assisted in preparing the answers
to Interrogatories 39, 41, 54, 55. Said
answers are true and correct to the best of my knowledge
and belief.


J. E. Herbst

Subscribed and sworn to
before me this 26th day
of October, 1981.



Theodora Cooke, Notary Public
in and for the City and County
of San Francisco, State of
California



My Commission expires January 28, 1985

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

DOCKETED
USNRC

In the Matter of)
)
PACIFIC GAS AND ELECTRIC COMPANY)
)
Diablo Canyon Nuclear Power Plant,)
Units 1 and 2)
_____)

'81 OCT 29 P4:38
Docket No. 50-275
Docket No. 50-323
OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH
(Full Power Proceedings)

CERTIFICATE OF SERVICE

The foregoing document(s) of Pacific Gas and Electric Company has (have) been served today on the following by deposit in the United States mail, properly stamped and addressed:

Judge John F. Wolf
Chairman
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mrs. Sandra A. Silver
1760 Alisal Street
San Luis Obispo, California 93401

Judge Glenn O. Bright
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Gordon Silver
1760 Alisal Street
San Luis Obispo, California 93401

Judge Jerry R. Kline
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

John Phillips, Esq.
Joel Reynolds, Esq.
Center for Law in the Public Interest
10203 Santa Monica Drive
Los Angeles, California 90067

Mrs. Elizabeth Apfelberg
C/o Nancy Culver
192 Luneta Drive
San Luis Obispo, California 93401

David F. Fleischaker, Esq.
P. O. Box 1178
Oklahoma City
Oklahoma 73101

Janice E. Kerr, Esq.
Public Utilities Commission
of the State of California
5246 State Building
350 McAllister Street
San Francisco, California 94102

Arthur C. Gehr, Esq.
Snell & Wilmer
3100 Valley Bank Center
Phoenix, Arizona 85073

Mrs. Raye Fleming
1920 Mattie Road
Shell Beach, California 93449

Bruce Norton, Esq.
Norton, Burke, Berry & French, P.C.
3216 N. Third Street
Suite 300
Phoenix, Arizona 85012-2699

Mr. Frederick Eissler
Scenic Shoreline Preservation
Conference, Inc.
4623 More Mesa Drive
Santa Barbara, California 93105

Chairman
Atomic Safety and Licensing
Board Panel
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Chairman
Atomic Safety and Licensing
Appeal Panel
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Secretary
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attn.: Docketing and Service Section

William J. Olmstead, Esq.
Bradley W. Jones, Esq.
Office of Executive Legal Director
BETH 042
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Richard B. Hubbard
MHB Technical Associates
1723 Hamilton Avenue, Suite K
San Jose, California 95125

Mr. Carl Neiberger
Telegram Tribune
P. O. Box 112
San Luis Obispo, California 93402


Herbert H. Brown, Esq.
Lawrence Coe Lanpher, Esq.
Christopher B. Hanback, Esq.
Hill, Christopher & Phillips
1900 M Street, N.W.
Washington, D. C. 20036

Byron S. Georgiou, Esq.
Legal Affairs Secretary
Governor's Office
State Capitol
Sacramento, California 95814

Judge Thomas S. Moore
Chairman
Atomic Safety and Licensing
Appeal Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Judge W. Reed Johnson
Atomic Safety and Licensing
Appeal Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Judge John H. Buck
Atomic Safety and Licensing
Appeal Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555


Philip A. Crane, Jr.
Attorney
Pacific Gas and Electric Company

Date: October 26, 1981