

NUCLEAR REGULATORY COMMISSION

ORIGINAL

In the Matter of:

HOUSTON LIGHTING & POWER COMPANY )

Allens Creek Nuclear Generating )  
Station, Unit 1 )

DOCKET NO. 50-466CP


DATE: November 18, 1981

PAGES: 20276 thru 20407

AT: Houston, Texas

TRO1  
S  
O/I



ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

8111250219 811118  
PDR ADOCK 05000466  
PDR

## UNITED STATES OF AMERICA

1  
2 BEFORE THE  
3 NUCLEAR REGULATORY COMMISSION

4 In the Matter of )  
5 )  
6 HOUSTON LIGHTING & POWER )  
COMPANY ) Docket No. 50-466 CP  
7 Allens Creek Nuclear Generating )  
Station, Unit 1 )

8  
9 Advocacy Auditorium  
10 South Texas College of Law  
11 1303 San Jacinto Street  
Houston, Texas

12 Wednesday,  
November 18, 1981

13 PURSUANT TO ADJOURNMENT, the above-entitled  
14 matter came on for further hearing at 9:00 a.m.

## 15 APPEARANCES:

16 Board Members:

17 SHELDON J. WOLFE, Esq., Chairman  
18 Administrative Judge  
Atomic Safety and Licensing Board Panel  
19 U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

20 GUSTAVE A. LINENBERGER  
21 Administrative Judge  
Atomic Safety and Licensing Board Panel  
22 U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

23 DR. E. LEONARD CHEATUM  
24 Administrative Judge  
Route 3, Box 350A  
25 Watkinsville, Georgia 30677

1 APPEARANCES: (continued)

2 For the NRC Staff:

3 LEE DEWEY, Esq.

4 -and-

5 STEPHEN SOHINKI, Esq.

6 U. S. Nuclear Regulatory Commission

7 Washington, D. C. 20555

8 For the Applicant - Houston Lighting & Power Company:

9 J. GREGORY COPELAND, Esq.

10 Baker & Botts

11 One Shell Plaza

12 Houston, Texas 77002

13 ROBERT CULP, Esq.

14 Lowenstein, Reis, Newman, Axelrad & Toll

15 1025 Connecticut Avenue, N. W.

16 Washington, D. C. 20037

17 For the Intervenor:

18 JOHN F. DOHERTY

19 4327 Alconbury

20 Houston, Texas 77012

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

I N D E X

	VOIR				BOARD	
	<u>DIRECT</u>	<u>DIRE</u>	<u>CROSS</u>	<u>REDIRECT</u>	<u>RECROSS</u>	<u>EXAM.</u>
1						
2	<u>WITNESSES</u>					
3	PETER P. STANCAVAGE					
4	-and-					
5	STEVEN A. HUCIK					
6	(A Panel)					
7	By Mr. Culp	20,283				
8	By Mr. Doherty		20,288			
9	By Mr. Doherty			20,298		
10	MELVYN WEINGART					
11	(Recalled)					
12	-and-					
13	STEVEN A. HUCIK					
14	(Recalled)					
15	(A Panel)					
16	By Mr. Copeland	20,340				
17	By Mr. Doherty		20,342			
18	By Judge Linenberger					20,365
19	By Mr. Doherty			20,374		
20	STEVEN A. HUCIK					
21	(Recalled)					
22	By Mr. Copeland	20,380				
23	By Mr. Doherty		20,382			
24	By Judge Linenberger					20,404
25						

P R O C E E D I N G S

9:00 a.m.

1  
2  
3 JUDGE WOLFE: In attendance this morning are  
4 Messrs. Copeland and Culp representing Applicant; Mr.  
5 Doherty is here; and Messrs. Sohinki and Dewey are here  
6 representing the Staff.

7 With regard to this coming Friday, the Board  
8 will recess at about 3:00 Friday afternoon. We would like  
9 to make our aircraft flight back to Washington, D. C. So  
10 all parties are duly notified.

11 Mr. Culp.

12 MR. CULP: Your Honor, at this time the  
13 Applicant would call to the stand Mr. Peter Stancavage  
14 and Mr. Steven Hucik to testify on Doherty Contention 5 on  
15 suppression pool uplift.

16 Mr. Stancavage is to your left; Mr. Hucik is  
17 to your right. I ask that they be sworn at this time.

18 JUDGE WOLFE: Would you please rise and raise  
19 your hands.

20 Whereupon,

21 PETER P. STANCAVAGE

22 and

23 STEVEN A. HUCIK

24 were duly sworn and were examined and testified as  
25 follows:

1 MR. CULP: Your Honor, we have prefiled this  
2 testimony on Doherty Contention 5, but it also includes  
3 Mr. Hucik's testimony on Doherty Contention 34, which is  
4 hydrogen monitoring.

5 MR. DOHERTY: Excuse me. That's TexPirg 34.

6 MR. CULP: Excuse me, Mr. Doherty. That's  
7 TexPirg 34 on hydrogen monitoring. We would proceed with  
8 only suppression pool uplift at this time, but since the  
9 testimony is together, I believe it would be easier just  
10 to put the entire testimony into the record at this point,  
11 and then we will proceed with cross-examination of  
12 suppression pool uplift, and after the completion of that,  
13 we would go to Mr. Hucik's testimony on hydrogen monitoring.

14 JUDGE WOLFE: All right.

15 MR. CULP: Mr. Hucik will also be joined by  
16 Mr. Weingart on the issue of hydrogen monitoring.

17 JUDGE WOLFE: All right.

18 The testimony of -- what I have before me --  
19 is the combined testimony of Messrs. Stancavage and Hucik  
20 relating to Doherty Contention 5 and TexPirg Contention  
21 34, with regard to that testimony -- and more specifically,  
22 with regard to that testimony as to TexPirg Contention 34,  
23 that is not similar to the Weingart testimony, in which  
24 Mr. Hucik is going to join. Is that correct? They're  
25 dissimilar?

1 MR. CULP: They are separate pieces of testi-  
2 mony.

3 JUDGE WOLFE: They are separate pieces, yes.

4 MR. CULP: Yes, sir.

5 JUDGE WOLFE: How are we to handle this  
6 again, to incorporate? You're going to offer the complete  
7 testimony of Stancavage and Hucik with regard to Doherty  
8 5 and TexPirg 34; is that correct?

9 MR. CULP: Yes, sir.

10 JUDGE WOLFE: At this time?

11 MR. CULP: At this time.

12 JUDGE WOLFE: But there will be no cross-  
13 examination on TexPirg Contention 34 until Mr. Weingart  
14 and Mr. Hucik are together as a panel?

15 MR. CULP: That is correct.

16 JUDGE WOLFE: Now, how shall we handle any  
17 voir dire, if necessary?

18 MR. CULP: Well, I would suggest we limit the  
19 voir dire of Mr. Hucik only to suppression pool uplift.

20 JUDGE WOLFE: All right.

21 MR. CULP: Then later when Mr. Weingart is on  
22 the stand, we can have voir dire with respect to hydrogen  
23 monitoring.

24 JUDGE WOLFE: All right.

25 And then there will be no cross-examination on

1 TexFirm 34 until Weingart and Hucik are on as a panel.

2 All right.

3 MR. CULP: One other point, Mr. Chairman, before  
4 we get started. Mr. Hucik's statement of professional  
5 qualifications is attached to the testimony that we have  
6 filed by Mr. Hucik on Doherty Contention 17, which is the  
7 SRV reliability.

8 That testimony appears following Transcript  
9 Page 16,146. Mr. Hucik has not testified on SRV reliability  
10 at this time. Yet, his professional qualifications are  
11 attached to that testimony.

12 JUDGE CHEATUM: Diagrams are always helpful.

13 JUDGE WOLFE: Yes. I have a note with regard  
14 to Mr. Hucik's testimony. It was incorporated into the  
15 record on August 26.

16 Mr. Hucik was in Taiwan at that time. And that  
17 testimony with regard to Doherty Contention 17 is subject  
18 to voir dire, and as I recall, any motion to strike, if  
19 need be.

20 All right.

21 MR. CULP: Mr. Chairman, one other point, hope-  
22 fully to clarify matters. In the testimony which these  
23 witnesses will identify, there is a question that appears  
24 on the bottom of Page 1 and an answer that appears on the  
25 top of Page 2.



1-5

1 That question and answer assumed that Mr.  
2 Hucik had previously testified in this proceeding. At this  
3 time I would like to delete that question and answer, since  
4 Mr. Hucik has not testified on SRV reliability, and I would  
5 like to reword the next question to state as follows:  
6 "Is the statement of your professional qualifications  
7 attached to your testimony on Doherty Contention 17 regard-  
8 ing the reliability of SRV safety/relief valves?"

9 And the answer remains the same: "Yes."

10 JUDGE WOLFE: All right. We will strike the  
11 question beginning at the bottom of Page 1 of the testimony  
12 of Messrs. Stancavage and Hucik and carried over to Page  
13 2, and the answer to that question will also be stricken,  
14 at the top of Page 2.

15 And the first question then appearing at the  
16 top of Page 2 will be as amended by Mr. Culp.

17 MR. CULP: Thank you, Your Honor.

18 DIRECT EXAMINATION

19 BY MR. CULP:

20 Q Gentlemen, do each of you have before you a  
21 document entitled "Direct Testimony of Peter P. Stancavage  
22 and Steven A. Hucik Regarding: (1) Doherty Contention No.  
23 5 - Suppression Pool Uplift and (2) TexPirg Contention" --  
24 and that should be "34" instead of "40" -- "Hydrogen  
25 Monitoring"?

1-6

1 BY WITNESS STANCAVAGE:

2 A. Yes.

3 BY WITNESS HUCIK:

4 A. Yes.

5 Q. Was this testimony prepared by you or under  
6 your supervision?

7 BY WITNESS STANCAVAGE:

8 A. Yes.

9 BY WITNESS HUCIK:

10 A. Yes.

11 Q. Mr. Stancavage, beginning with you, do you have  
12 any corrections or additions to make to this testimony?

13 BY WITNESS STANCAVAGE:

14 A. No, I do not.

15 Q. Attached to the direct testimony is an affi-  
16 davit which you previously filed in this proceeding, which  
17 has been labelled Attachment PPS-1; is that correct?

18 BY WITNESS STANCAVAGE:

19 A. Yes, that is correct.

20 Q. Do you have any corrections or additions to  
21 the affidavit?

22 BY WITNESS STANCAVAGE:

23 A. Yes. At this time my job is Principal Engineer  
24 in Reactor Performance Analysis, instead of Manager of  
25 Containment Engineering.

1 That appears on the first page of PPS-1.

2 JUDGE WOLFE: Again, Mr. Stancavage, your change  
3 in position is what now?

4 WITNESS STANCAVAGE: My current position is  
5 Principal Engineer in Reactor Performance Analysis, in-  
6 stead of Manager of Containment Engineering.

7 MR. DOHERTY: Your Honor, I don't have that  
8 on my PPS-1.

9 MR. CULP: Well, Mr. Doherty, it's Attachment 1  
10 to Mr. Stancavage's affidavit.

11 MR. DOHERTY: Okay, thank you. My confusion  
12 is resolved.

13 BY MR. CULP:

14 Q Mr. Stancavage, if you will turn to Attachment  
15 PPS-1, the affidavit itself, I believe that you also  
16 state that you are Manager of Containment Engineering. I  
17 guess you would want to make the same change on the affi-  
18 davit.

19 BY WITNESS STANCAVAGE:

20 A Yes, I would.

21 Q Are there any other corrections or additions  
22 to make?

23 BY WITNESS STANCAVAGE:

24 A Yes. The statement, "I have been employed in  
25 this capacity for 12 years," should be, "I have been

1-8

1 employed in this capacity for 14 years."

2 Q All right. Any other corrections?

3 BY WITNESS STANCAVAGE:

4 A No, I have no other corrections.

5 Q Mr. Hucik, do you have any corrections or  
6 additions that you would like to make to your testimony?

7 BY WITNESS HUCIK:

8 A Yes, sir. On page 1 of the testimony my  
9 name should be spelled S-t-e-v-e-n.

10 Q In the caption of the testimony?

11 BY WITNESS HUCIK:

12 A In the caption of the testimony and on Page 2,  
13 there's a small typo between Lines 19 and 20, the word  
14 should be "boundary."

15 And the only other correction is the changes  
16 in those questions that have already been completed rela-  
17 tive to the previous testimony.

18 Q With those corrections that each of you have  
19 made, is the testimony true and correct to the best of your  
20 knowledge and belief?

21 BY WITNESS STANCAVAGE:

22 A Yes, it is.

23 BY WITNESS HUCIK:

24 A Yes.

25 Q Do each of you adopt this as your testimony in

1-9

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

this proceeding?

BY WITNESS STANCAVAGE:

A. Yes.

BY WITNESS HUCIK:

A. Yes.

MR. CULP: Your Honor, at this time I move that the testimony identified by these witnesses, including the affidavit of Mr. Stancavage, which is attached to the testimony, be incorporated into the record as if read.

JUDGE WOLFE: Any objection?

MR. SOHINKI: No objection, Mr. Chairman.

JUDGE WOLFE: Any objection?

MR. DOHERTY: I'd like to take each witness on voir dire, Your Honor.

JUDGE WOLFE: All right.

- - -

## VOIR DIRE

1  
2 BY MR. DOHERTY:

3 Q Well, can you give us a little more breakdown  
4 of those first 11 years with General Electric, Mr. Stan-  
5 cavage?

6 BY WITNESS STANCAVAGE:

7 A Yes. My first three years at General Electric  
8 were spent in an engineering training program, which con-  
9 sisted of a series of six-month assignments under the  
10 supervision of senior engineers in various nuclear and  
11 mechanical engineering disciplines, including containment  
12 safety evaluations, radiological evaluations and nuclear  
13 fuel performance evaluations.

14 The next five years were spent in developing  
15 models of nuclear reactor risks, in evaluating radiological  
16 consequences of reactor accidents, and developing models  
17 of radiation released from fuel due to reactor scram and  
18 depressurization.

19 And the next three years before I became a  
20 manager in Containment Engineering were spent as a  
21 technical leader in Containment Engineering where I worked  
22 on various aspects of containment load definition,  
23 including pool swell phenomenon, chugging, condensation  
24 oscillation, safety/relief valve loads, pressure and  
25 temperature calculations.

1-11

1 Q Did you analyze loading criteria for pool  
2 swell?

3 BY WITNESS STANCAVAGE:

4 A Yes, I did.

5 Q Did you develop any ...

6 BY WITNESS STANCAVAGE:

7 A I'm sorry, I didn't understand your question.

8 Q I didn't ask it yet. I'm sorry.

9 Did you develop any experimental programs with  
10 regard to pool swell?

11 BY WITNESS STANCAVAGE:

12 A No, I did not directly develop any experimental  
13 programs. Rather, I analyzed the data from the programs  
14 to develop the pool swell parameters.

15 Q Was your pool swell work entirely with the  
16 Mark III?

17 BY WITNESS STANCAVAGE:

18 A No, my pool swell work also extended to Mark I  
19 and Mark II containments.

20 Q About how much of your efforts were devoted  
21 to Mark III containments?

22 BY WITNESS STANCAVAGE:

23 A I'd say about three-quarters of my effort was  
24 devoted to Mark III pool swell.

25 Q As a Technical Leader -- I think that's the term

1-12

1 you used -- were you supervising personnel?

2 BY WITNESS STANCAVAGE:

3 A Yes, I was.

4 Q How large a staff did you supervise?

5 BY WITNESS STANCAVAGE:

6 A The number of staff varied from two to seven.

7 Q Were you the -- as a Technical Leader on these  
8 issues, were you part of a team working on the suppression  
9 pool as a safety system, or were you directing that effort?

10 BY WITNESS STANCAVAGE:

11 A I was both part of a team of people who were  
12 looking at the experimental and analytical models to pre-  
13 dict pool swell, and I was also directing people in ac-  
14 complishing various subtasks which led up to the complete  
15 definition of pool swell.

16 Q Have you written any of the PSAR for the Allens  
17 Creek plant? Has that been any part of your work?

18 BY WITNESS STANCAVAGE:

19 A No, I have not.

20 Q Have you authored any GE publications on pool  
21 swell?

22 BY WITNESS STANCAVAGE:

23 A I participated in writing parts of Appendix  
24 3-B to GESSAR in the areas of pool swell, as well as other  
25 load definitions.



1 Q You say to GESSAR?

2 BY WITNESS STANCAVAGE:

3 A GESSAR.

4 Q Okay. You mean the --

5 BY WITNESS STANCAVAGE:

6 A Yes.

7 Q Right. Do you consider any of your work with  
8 regard to risk analysis and the radiological consequences  
9 of accidents related to this issue?

10 BY WITNESS STANCAVAGE:

11 A Yes, I do. Risk analysis relates to this  
12 issue, in the sense of being able to employ mathematical,  
13 statistical and engineering judgment to the selection of  
14 margins which are appropriate to bound experimental con-  
15 ditions.

16 Radiological evaluations investigated  
17 phenomena like pool swell, chugging and condensation  
18 oscillation with regard to its effect on the scrubbing  
19 aspects of the suppression pool for iodine.

20 Q Okay. Mr. Hucik, I'd like to ask some questions  
21 of you now. Do you work with Mr. Stancavage, sir?

22 BY WITNESS HUCIK:

23 A Yes, I have in the past worked with Pete.

24 Q At the time -- currently, though, do you work  
25 together on --

1 BY WITNESS HUCIK:

2 A No, not currently.

3 Q Has he been your supervisor at times?

4 BY WITNESS HUCIK:

5 A Yes, he was my supervisor.

6 Q I see you say that your current unit is  
7 responsible for load definitions. When you say "load  
8 definitions," is that essentially calculating the load, or  
9 what is that? If it's not, what is --

10 BY WITNESS HUCIK:

11 A Really what it means is -- it's taking the test  
12 data, using any analytical models that might be appropriate  
13 with that test data to come up with a specification -- or  
14 as we call it, a load definition -- that is used by the  
15 plant for design.

16 JUDGE LINENBERGER: Does this include time-  
17 dependence loads?

18 WITNESS HUCIK: Yes.

19 JUDGE LINENBERGER: Thank you.

20 BY MR. DOHERTY:

21 Q What is the "Mark III Containment Loads  
22 Report"?

23 BY WITNESS HUCIK:

24 A The "Mark III Containment Loads Report" is  
25 the final document that is used to actually specify all the

1 loads for the Mark III containment system. It also is  
2 incorporated into the GESSAR document as Appendix 3-B.  
3 It's basically the same document.

4 Q Is that still in progress or is it complete?

5 BY WITNESS HUCIK:

6 A That is complete.

7 Q I see. So you're no longer associated with  
8 that; is that right?

9 BY WITNESS HUCIK:

10 A Pardon.

11 Q You're no longer associated with that?

12 BY WITNESS HUCIK:

13 A The "Containment Loads Report" itself is  
14 complete, and it's an issued document.

15 JUDGE LINENBERGER: Well, Mr. Hucik, repeating  
16 Mr. Doherty's question in a slightly different context,  
17 is this considered a completed task, or will there be  
18 continuing reviews to determine whether it needs updating?

19 WITNESS HUCIK: Yes, right now we're involved  
20 with the NRC in actually the review of that document. It's  
21 formally being reviewed under GESSAR, Appendix 3-B. Since  
22 they're the same document, it is currently undergoing  
23 review and any revision, if necessary.

24 JUDGE LINENBERGER: Thank you.

25 /

1-16

1 BY MR. DOHERTY:

2 Q You state you were also responsible for the  
3 analysis of Caroso SRV test data. Is that a Mark III  
4 system?

5 BY WITNESS HUCIK:

6 A No, that's a Mark II system.

7 Q Used to support the SRV load reduction defined  
8 in the final Mark III containment loads report. Was there  
9 some aspect of this that you feel applies to a Mark III  
10 system like Allens Creek?

11 BY WITNESS HUCIK:

12 A Yes, there are several things that make the  
13 Caroso test data from the Mark II totally applicable to  
14 the Mark III containment system, in terms of SRV's. Number  
15 one, the safety/relief valves used are essentially similar.  
16 And, number two, the SRV lines and the geometry of those  
17 lines is also very similar to the Mark III geometry.

18 Number three, the quencher -- the actual  
19 device at the end of the discharge line that's in the  
20 suppression pool is essentially the same as used in the  
21 Mark III containment system.

22 Therefore, the phenomenon -- the loads are  
23 essentially the same as you would see in Mark II or Mark  
24 III.

25 Q So then you feel that your experience with the

1 Caroso Mark II does give you expertise to discuss the  
2 Mark III at Allens Creek?

3 BY WITNESS HUCIK:

4 A Yes.

5 Q Now, when you say that you provide support  
6 to the Mark III customers, does that mean you did cal-  
7 culations that assist their construction work?

8 BY WITNESS HUCIK:

9 A Yes. If a particular project or plant comes  
10 in with some request for, say, some plant unique analysis  
11 associated with something slightly different from their  
12 plant from what we've analyzed, we provide that analysis  
13 to them. We call that the support, or answering any  
14 questions that they may have pertaining to the loads and  
15 their definitions.

16 Q Did you present any presentations to the NRC?  
17 Have you been involved in any of those? I notice the last  
18 complete paragraph there says, "Made presentations on  
19 licensing basis to U. S. Regulatory Agencies."

20 BY WITNESS HUCIK:

21 A Yes, I've made many presentations to the  
22 Nuclear Regulatory Commission, as well as the ACRS  
23 Advisory Committee on Reactor Safeguards pertaining to con-  
24 tainment loads, in particular Mark III.

25 Q Have you ever authored any publications in

1-18

1 professional journals?

2 BY WITNESS HUCIK:

3 A. No, I have not.

4 Q. What is the most extensive study you've made  
5 of any one problem in the Mark III containment?

6 BY WITNESS HUCIK:

7 A. There might be several. One that's very much  
8 related to Mark III, is I looked at the early Mark I and  
9 Mark II containment systems and did some pool swell model-  
10 ing for the Mark I and Mark II, based on data for Mark  
11 III.

12 I also did my Master's thesis at the University  
13 of California at Berkeley on safety/relief valve operation,  
14 in terms of pool dynamic loads.

15 Q. Did you have one of those types of programs  
16 that Mr. Stancavage mentioned, a couple of years of  
17 different areas --

18 BY WITNESS HUCIK:

19 A. Yes. As a matter of fact, I went through the  
20 engineering program myself. I had a series of five rota-  
21 tions in many different areas, including a couple of  
22 rotations in the containment analysis area and testing  
23 areas.

24 I also spent two years as a supervisor for that  
25 particular program.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

MR. DOHERTY: Okay. No further questions,  
Your Honor.

No objections.

JUDGE WOLFE: Absent objection, the testimony  
of Messrs. Peter Stancavage and Steven Hucik with regard  
to Doherty Contention 5 and with regard to -- at this  
time -- TexPirg Contention 34 are incorporated into the  
record as if read.

(Applicant Testimony of Peter P. Stancavage  
and Steven A. Huckin on Doherty Contention No. 5 and  
TexPirg Contention 34 follows.)

- - -

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of	§	
	§	
HOUSTON LIGHTING & POWER COMPANY	§	Docket No. 50-466
	§	
(Allens Creek Nuclear Generating Station, Unit 1)	§	
	§	

DIRECT TESTIMONY OF PETER P. STANCAVAGE  
AND STEPHEN A. HUCIK REGARDING:

- (1) DOHERTY CONTENTION NO. 5 - SUPPRESSION POOL UPLIFT
- (2) ~~TEXPIRG~~ <sup>34</sup> CONTENTION ~~40~~ - HYDROGEN MONITORING

10 Q. Mr. Stancavage, have you reviewed your prior  
11 affidavit on Doherty Contention No. 5, which affidavit is  
12 attached hereto as Attachment PPS-1?

13 A. Yes, I have.

14 Q. Are the statements contained therein still true  
15 and correct?

16 A. Yes, they are.

17 Q. Mr. Stancavage, what are the dynamic capabilities of  
18 the HCU modules during LOCA pool swell loads?

19 A. The HCU modules are designed to withstand loads  
20 associated with response spectra peaks in excess of 15 g  
21 vertically and 5.9 to 11.9 g horizontally. As indicated in  
22 the testimony of Dragos A. Nuta, the HCU modules will not be  
23 damaged by the hydrodynamic forces associated with the  
vertical water swell postulated to occur during a LOCA.

24 ~~Q. Mr. Hucik, have you previously given testimony in~~



~~this proceeding?~~

~~A. Yes, I presented testimony in connection with  
Doherty Contention 17, regarding the reliability of safety  
relief valves.~~

Q. Is the statement of your professional qualifications  
attached to ~~that~~ <sup>your</sup> ~~prior~~ testimony ~~still correct?~~ <sup>on Doherty Contention 17</sup>  
~~regarding the reliability of SRV safety/relief valves?~~

A. Yes.

Q. Mr. Hucik, directing your attention to page 32 of  
the Board's Order of September 1, 1981, can you state whether  
there is a possibility for simultaneous actuation of safety  
relief valves on pool swell?

A. The Allens Creek Nuclear Generating Station BWR  
uses a General Electric sixth generation, boiling water  
reactor nuclear steam supply system equipped with 19 safety  
relief valves. The purpose of these valves is to relieve  
pressure from the reactor pressure vessel venting steam to  
the suppression pool where it will be condensed by the pool  
water. The valves open after receiving a signal that the  
reactor pressure is higher than normal.

A sudden break of a high energy pipe in the reactor  
coolant pressure boundary of the nuclear steam supply  
system will cause the pool swell phenomenon if the break  
size is large enough. Small breaks do not release sufficient  
energy into the drywell to cause pool swell.

For a break large enough to produce the pool swell

phenomenon, the pressure in the reactor vessel decreases rapidly due to the flow of high energy fluid from the break in the reactor coolant pressure boundary. This drop in reactor pressure ensures that the safety relief valves remain closed throughout the first few seconds when the pool swell phenomenon occurs. Thus, we do not consider the actuation of safety relief valves at the same time as pool swell.

Q. Mr. Hucik, at page 21 of its September 1, 1981 Order, the Board asked several questions regarding the hydrogen monitoring system for Allens Creek. Could you please address those questions?

A. Most of the questions have been thoroughly answered by Mr. Weingart's testimony; however, I can add certain information from GE's perspective. First, as to the question of incomplete convective circulation, Section 6.2.5 of GBSSAR II demonstrates that post LOCA conditions in containment promote natural convection such that effective mixing of the containment atmosphere is accomplished. The principal reasons are as follows:

(1) heat transfer mechanism:

heat source (the suppression pool) at the bottom and heat sinks (containment wall) at the top and the sides will create unstable conditions due to buoyancy forces

(2) mass transfer mechanism:

additional density gradient due to changing hydrogen concentration near the pool surface will reinforce the thermally induced convective currents.

The convective circulation in the containment, when established, will be directed upwards near the drywell wall and downward along the containment wall. The hydrogen recombiners when in operation will not interfere with this pattern because of their location near the top of the drywell. In fact, the additional heat source they represent will reinforce it. The calculations presented in GESSAR II show that extremely small temperature and concentration differences ( $2.6 \times 10^{-5} \text{ }^\circ\text{F}$  and  $4.3 \times 10^{-6} \%$ , respectively) are sufficient to create a turbulent free convection regime in the containment.

Based on these considerations we conclude that the hydrogen concentration in the air supplied to the hydrogen recombiners will be at or very near the bulk concentration and the convective circulation will not be detrimental to the efficiency of these recombiners.

Second, as to the conservatism of the alarm set point, Figure 1 shows a typical hydrogen concentration time history in a Mark III Containment following a recirculation line Design Basis Accident (DBA). The analysis is based on the very conservative assumptions of Reg. Guide 1.7. At the time when the containment  $\text{H}_2$  concentration reaches 3% ( $\sim 17$  days), the rate of hydrogen evolution from the suppression pool due to radiolysis is less than 1 SCFM. (It actually drops to

1 that rate in 3 days). That translates to a H<sub>2</sub> concentration  
2 rise of 0.1%/day. With a nominal recombiner warm-up time of  
3 3 hrs. there is more than enough time for the operator to  
4 activate a back-up system in case one fails.  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of

HOUSTON LIGHTING & POWER COMPANY )

(Allens Creek Nuclear Generating )  
Station, Unit No. 1) )

Docket No. 50-466

AFFIDAVIT OF PETER P. STANCAVAGE

State of California  
County of Santa Clara

I, Peter P. Stancavage, Manager of Containment Engineering, within in the Domestic BWR Projects Department of General Electric Company, of lawful age, being first duly sworn, upon my oath certify that the statements contained in the attached pages and accompanying exhibits are true and correct to the best of my knowledge and belief.

Executed at San Jose, California,  
July 29, 1980.

Peter P. Stancavage

Subscribed and sworn to before me this 29<sup>th</sup> day of July, 1980.

Ruthe M. Kinnamon  
NOTARY PUBLIC IN AND FOR SAID  
COUNTY AND STATE

My commission expires March 28 of 1981.



175 Center Ave., San Jose, CA 95125

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of	§	
	§	
HOUSTON LIGHTING & POWER COMPANY	§	Docket No. 50-466
	§	
(Allens Creek Nuclear Generating Station, Unit No. 1)	§	
	§	
	§	

Affidavit of Peter P. Stancavage

My name is Peter Stancavage. I am employed by General Electric Company as a nuclear and mechanical engineer. I have been employed in this capacity for ~~12~~<sup>14</sup> years. A statement of my experience and qualifications is set out in Attachment 1.

I. Introduction

The purpose of this affidavit is to address Mr. Doherty's Contention 5 which alleges that the control rod drive mechanism hydraulic control units (HCU) and the transversing in-core probe (TIP) may be damaged by the hydrodynamic forces of a high vertical water swell in the suppression pool following a loss-of-coolant accident (LOCA).<sup>1/</sup>

---

<sup>1/</sup> LOCA is the sudden break of a high-energy pipe in the reactor coolant pressure boundary of the nuclear steam supply system. The largest possible break is the break of a main steam line.

## II. Description of the Mark III Containment and Pool Swell Phenomena

The Allens Creek Nuclear Generating Station design uses a General Electric sixth generation boiling water reactor nuclear steam supply system with a third generation pressure suppression containment system. (This combination bears the name BWR/6--Mark III.) The basic Mark III containment design is shown in the attached diagram (Exhibit 1). The reactor primary system is surrounded by a cylindrical concrete drywell structure which is in turn surrounded by the primary containment. At the base of the drywell a series of horizontal open-ended pipes (vents) in three rows connects the drywell to the containment. The vents are submerged in an annular pool of water that is retained by a weir wall inside the drywell. Any steam released in the drywell from a postulated pipe break will be forced through the horizontal vents into the suppression pool where it will be condensed by the pool water.

Almost immediately following a postulated LOCA, the drywell is pressurized by reactor steam, and a mixture of steam and air is directed to the suppression pool through the horizontal vents. The rapid increase in drywell pressure will accelerate the water initially standing in the weir annulus and horizontal vents. Immediately following the

clearing of standing water in any vent, drywell air and steam will form a bubble at the vent exit. This bubble will expand and depressurize to the local hydrostatic pressure. These bubbles cause an upper displacement of the pool water above the vents. The bubbles rise relative to the pool water, reducing the thickness of the water ligament or film above the bubbles. When the bubbles break through the water surface, a froth is formed which rises further before falling back into the suppression pool. The initial motion of the water film and the subsequent motion of the froth create impact and drag loads on equipment and platforms located above the pool surface. The entire process is referred to as "pool swell."<sup>2/</sup>

The pool swell loads on structures and components above the suppression pool have been evaluated in more than fifty full-scale and subscale experiments as part of the

---

<sup>2/</sup> Safety relief valve (SRV) actuation also introduces air into the pool as the released steam displaces the smaller air volume occupying the blowdown lines. However, SRV pool swell does not exist. Extensive in-plant tests, laboratory tests and an understanding of the phenomena involved in SRV discharge demonstrate that there is no pool swell due to this discharge. An understanding of the phenomena is acquired from scaling laws and analytical models of the SRV discharge. Full-scale in-plant tests were conducted at Monticello, Caroso, Tokai, KKB, KKP and Fukushima-6. Laboratory tests were also conducted by General Electric, KWV and CNEW. All these tests confirm that SRV pool swell does not occur.



Mark III test program conducted by the General Electric Company. From this information, loads are selected and used in the design of the ACNGS plant by the architect-engineer and in General Electric's analysis to qualify equipment supplied by General Electric.

III. Mark III Test Program

Immediately following the introduction of the BWR/6--Mark III, the General Electric Company started an extensive experimental and analytical effort to confirm the Mark III design. The purpose of the Mark III Confirmatory Test Program was to confirm the analytical methods used to predict the drywell and containment responses following a LOCA and to obtain information on the hydrodynamic loads that are generated in the vicinity of the suppression pool during a LOCA.

The General Electric Mark III containment pressure suppression testing program was initiated in 1971 with a series of small-scale tests. The test apparatus consisted of small-scale simulations of the reactor pressure vessel, drywell, suppression pool and horizontal vents. A total of sixty-seven blowdown runs were made. The purpose of these tests was to determine the behavior of the horizontal vents and to obtain data for determining the acceleration of the

water in the test section vents during initial clearing. This information was used to establish an analytical model for predicting vent system performance in Mark III and the resulting drywell pressure response.

In November 1973, testing in the Mark III Pressure Suppression Test Facility (PSTF) began. The PSTF consists of an electrically heated steam generator connected to a simulated drywell which can be heated to prevent steam condensation within its volume during the simulated blowdowns. The drywell is modeled as a cylindrical vessel having a 10-foot diameter and 26-foot height. A 6-foot diameter vent duct passes from the drywell into the suppression pool and connects to the simulated vent system. Pool baffles are used to simulate a scaled or full-scale sector of a Mark III suppression pool.

The full-scale PSTF testing performed between November 1973 and February 1974 obtained data for the confirmation of the analytical model. In March 1974 pool swell tests were performed in the PSTF. These full-scale tests involved air blowdown into the drywell and suppression pool to identify bounding pool swell impact loads and breakthrough elevation, i.e., that elevation at which the water slug begins to break up and impact loads are significantly reduced. Impact load data were obtained on selected targets located above the pool. In June of 1974, after the PSTF vent and pool system

was converted to 1/3-scale, four series of tests were performed to provide transient data on the interaction of pool swell with flow restrictions above the suppression pool surface.

The next series of 1/3-scale testing, which began in January, 1975, measured local impact pressures and total loads for typical small structures located over the pressure suppression pool including I-beams, pipes, and grating. Data from this test series expanded the data base from the full-scale air tests. A further series of 1/3-scale tests was added in June, 1975, to obtain comparable data on pool swell velocity and breakthrough elevation to the full-scale air tests.

The emphasis in the testing described above was directed at the evaluation of the pool swell phenomena. Each test run consisted of a simulation of the postulated blowdown transient. Various postulated break sizes up to two times the Design Basis Accident for the containment were tested. Data were recorded at selected locations around the test facility suppression pool throughout the blowdown so that the hydrodynamic conditions associated with each phase of the blowdown are known and are available for selecting appropriate design loading conditions. General Electric has used this data to develop hydrodynamic loading conditions in

the GE Mark III reference plant pressure suppression containment system during the postulated LOCA.

#### IV. Pool Swell Loadings

Equipment and platforms, like the HCU, the HCU floors and the TIP, located in the containment annulus region above the pool surface experience pool swell induced dynamic loads, the magnitude of which are dependent upon both the location and the geometry of the surface exposed. The pool swell phenomenon occurs in two phases: "bulk" pool swell followed by a "froth" pool swell. Bulk pool swell imparts two different loads on exposed structures and components: impact loads and drag loads. The froth stage of pool swell contributes only a drag load.

##### A. Impact Loads

The PSTF air test data show that after the pool has risen approximately 1.6 times vent submergence below normal pool level (12 feet), the slug thickness has decreased to 2 feet or less and the impact loads are significantly reduced. For evaluating the time at which impact occurs at various elevations in the containment annulus, the maximum water surface velocity of 40 feet/second is assumed because this value bounds all the test data and analysis. The basis for the loading specification is the PSTF air test impact data. These tests involved charging the reactor simulator with 1000 psia air and blowing down through an orifice. Instrumented

targets located over the pool provided the impact data.

For structures above the 18-foot elevation, the conservative froth impingement load is 15 psig based on data generated during the PSTF air test series. Again, this impingement load is applied uniformly to all structures.

B. Drag Loads

In addition to the impact loads, structures that experience bulk pool swell are also subject to drag loads as the pool water flows past them. Drag loads are calculated assuming a velocity of 40 feet/second between the pool surface and HCU floors.

C. Design of HCUs for Pool Swell Loads

Large platforms or floors will completely stop the rising pool, and thus incur larger loadings. For this reason, the HCU platform is located above the bulk pool swell zone. The GE Confirmatory Test Program indicates that pure bulk pool swell terminates at levels much lower than 18 feet above the suppression pool. Consequently, General Electric advises the architect-engineer to use 18 feet as the elevation of bulk pool swell with a linear transition from water to froth in the space of 18 feet to 19 feet above the normal pool surface. Therefore, for design application, the impact of water from bulk pool swell is applied conservatively at or below elevations

of 19 feet above the surface of the suppression pool. The structures above this elevation experience an impulsive loading followed by a pressure differential loading. The impulsive load is due to the momentum of the froth which is decelerated by the structure. The pressure differential is based on an analysis of the transient pressure in the space between the pool surface and the HCU floor resulting from the froth flow through the approximately 1500 square feet vent area at this elevation. General Electric test results are the basis for the froth impingement load of approximately 15 psi lasting for 100 msec. An 11 psi froth flow pressure differential lasting for three seconds is based on an analysis of transient pressure in the space between the pool surface and the HCU floor. The approximate value of 11 psi is from a calculation which assumes that the density of the flow through the annulus restriction is a homogenous mixture of the top 9 feet of the suppression pool (i.e.,  $18.8 \text{ lb}_m/\text{ft}^3$ ). This is a conservative density assumption confirmed by the GE one-third scale test which shows an average density of approximately  $10 \text{ lb}_m/\text{ft}^3$ . The analytical model used to simulate the HCU floor flow pressure differential has also been compared with test data. These tests indicate HCU floor pressure differential is more realistically in the 3 to 5 psig range.

Vibratory response of the HCU floor to the froth impingement would subsequently transmit a load to the HCU

modules. The magnitude of this load for Allens Creek will be computed by the architect-engineer in a plant unique dynamic analysis to assure that it does not exceed the dynamic qualification of the HCU's by General Electric.

D. Design of the TIP for Pool Swell Loads

General Electric PSTF tests demonstrate that for structures such as the TIP station, which is located approximately six feet above the suppression pool surface, pool swell impact loads are not experienced. The TIP station does experience a drag load and a "bubble" load. Bubble pressure load occurs when the air in the drywell is driven through the vents and forms air bubbles in the suppression pool prior to bulk pool swell. The pressure of these bubbles is then exerted on the wetted surfaces around the suppression pool.


PSTF data also establish that the TIP station would experience a maximum drag load of 11 psid and a 21.8 psid bubble pressure load. The TIP system itself is protected from the loads by cantilever structures which extend beneath the surface of the suppression pool and are specifically designed by the architect-engineer to absorb this loading.

In a larger sense, the issue of pool swell loading on the TIP station is a red herring. The TIP is a movable radiation source used to calibrate the Local Power Range Monitors when the reactor is shut down. It is not designed or

used to perform any safety function whatsoever. Consequently, its ability to survive a LOCA environment, including pool swell loading, has no importance save an economic effect which pales in comparison to the other consequences of such an accident.



EXHIBIT 1



*Mark III Reactor Building*

ATTACHMENT 1

PROFESSIONAL QUALIFICATIONS  
PETER P. STANAVAGE  
MANAGER - CONTAINMENT ENGINEERING


Mr. Stancavage has more than 13 years of Engineering experience with General Electric in the Nuclear Energy Group.

Mr. Stancavage is now the ~~Manager of Containment~~ *Principal Engineer in Reactor Performance Analysis* Engineering, a position he has held for more than two years.

His first eleven years with GE included a variety of Engineering jobs among which were three years in Containment Engineering, Radiological Evaluations and Nuclear Engineering.

Mr. Stancavage received his Master's Degree from M.I.T. in Nuclear Engineering. He completed his undergraduate work at U.S. Military Academy (West Point).

HYDROGEN CONCENTRATION ( MOLE FRACTION )



HYDROGEN CONCENTRATION ( MOLE FRACTION )

TIME ( HOURS )

1 MR. CULP: Your Honor, at this time the witnesses  
2 are tendered for cross-examination on Doherty Contention 5.

3 JUDGE WOLFE: All right.

4 Staff?

5 MR. SOHINKI: We have no questions, Mr. Chair-  
6 man.

7 JUDGE WOLFE: Mr. Doherty?

8 CROSS-EXAMINATION

9 BY MR. DOHERTY:

10 Q You give some results there on Page 1 at Line  
11 19. What is the source of that information, Mr. Stan-  
12 cavage?

13 BY WITNESS STANCAVAGE:

14 A The source of the information is a series of  
15 tests that were conducted by General Electric on the HCU  
16 modules. These tests were done on a shaker table, which is  
17 subjected to vertical and horizontal accelerations to  
18 investigate the mechanical capabilities of the HCU  
19 modules.

20 Q Well, did you ever really find out what the load  
21 they could withstand was, or did that -- I'm not saying  
22 you personally did. You have given some figures there,  
23 "in excess of" -- and you stopped apparently, didn't run  
24 any higher. Do you see what I mean?

25 /

1-21

1 BY WITNESS STANCAVAGE:

2 A Yes, I think I understand your question.

3 The capability, in terms of being able to with-  
4 stand loads, is somewhat higher than the numbers given  
5 here. But these numbers can be used as the maximum  
6 capability, if you will, or the design limit beyond which  
7 one should not go without further evaluation.

8 Q Are you saying they're safe?

9 BY WITNESS STANCAVAGE:

10 A They're safe. For example, take the 15 g's  
11 vertically, that was specified as an input to the test, that  
12 the test go at least 15 g's of vertical acceleration. And  
13 because of the way the test was conducted, the accelera-  
14 tions were slightly in excess of 15 g's.

15 But the test specifications said to qualify  
16 this equipment to 15 g's vertically, and so that's what the  
17 test accomplished. And, therefore, the capability has  
18 been demonstrated to 15 g's.

19 Q When you say g, I have some difficulty with  
20 that. That's sort of a force of sudden movement; is that  
21 right?

22 How do you explain the g? That's not a pounds  
23 per square inch type of measurement, is it?

24 BY WITNESS STANCAVAGE:

25 A No, it is not. A g is an acceleration. It's

1-22

1 32.2 feet per second per second.

2 Q Uh-huh.

3 BY WITNESS STANCAVAGE:

4 A A mass subjected to an acceleration would give  
5 a force, according to Newton's second law, F equals mass  
6 times the acceleration.

7 So if I were to put a mass of one pound in a  
8 field of one g, then it would weigh one pound.

9 If I were to put it in a field of two g's, it  
10 would equivalently weigh two pounds.

11 And a pound can be thought of as a measure of  
12 force. So it's not a sudden acceleration, like a car start-  
13 ing from stop, moving suddenly.

14 It's more of a steady vibratory kind of motion  
15 at a level corresponding to 15 times the force of gravity.

16 Q Okay. I guess the source of my problem is  
17 that I'm not used to thinking of myself as subject to  
18 gravity, but I am.

19 BY WITNESS STANCAVAGE:

20 A Okay.

21 MR. COPELAND: You had better hope so.

22 MR. DOHERTY: Not everyone is all the time,  
23 but --

24 BY MR. DOHERTY:

25 Q Now, you also made a statement with regard to

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 Mr. Nuta's testimony, I guess -- his conclusions. Do you  
2 have any other source for that, besides Mr. Nuta's con-  
3 clusions?

4 BY WITNESS STANCAVAGE:

5 A. No, I do not.

6 Q. It was General Electric who did the test you  
7 spoke of a moment ago?

8 BY WITNESS STANCAVAGE:

9 A. Yes, it was.

10 Q. You did those?

11 BY WITNESS STANCAVAGE:

12 A. Not me personally, but General Electric Company  
13 did the test, yes.

14 Q. Can these also be called vibratory response  
15 loads that you've given here? Is that a term for that?  
16 Is that an interchangeable term?

17 BY WITNESS STANCAVAGE:

18 A. Yes, that is a good term to use for it.

19 Q. So you testified a minute ago, I believe, that  
20 General Electric did the measurements?

21 BY WITNESS STANCAVAGE:

22 A. Yes, that's correct.

23 Q. And you're going to give them to Ebasco or  
24 to HL&P to give to Ebasco?

25 /

1 BY WITNESS STANCAVAGE:

2 A Yes, that's correct.

3 Q That's the chain.

4 At this time does General Electric approve of  
5 that itself as a -- Well, let's put it this way. Do they  
6 believe -- Does General Electric believe that these  
7 loads will result in no damage to HCU's or non-acceptable  
8 damage to any -- Well, let's just leave it there.

9 MR. CULP: Your Honor, I'm going to object to  
10 that question, because I don't understand it.

11 MR. DOHERTY: Well, maybe it's bordering on  
12 repetition, and that's what makes it a little bit lacking --  
13 hard to understand.

14 The question I'm trying to get at is part of  
15 what I think the Board had some inquiries about with regard  
16 to this contention; and that is, was the -- were these  
17 now called vibratory responses acceptable to General  
18 Electric.

19 Did they find them suitable? That's what I'm  
20 trying to find out.

21 MR. CULP: Are you referring specifically, Mr.  
22 Doherty, to the loads that the HCU modules can withstand?

23 MR. DOHERTY: Yes.

24 MR. CULP: And you're asking whether GE  
25 finds these acceptable?



1-25

1 MR. DOHERTY: Yes.

2 MR. CULP: Okay.

3 WITNESS STANCAVAGE: Yes, GE finds the 15 g  
4 vertical acceleration load acceptable for the HCU modules,  
5 based on the tests that we conducted on the HCU modules.

6 BY MR. DOHERTY:

7 Q The horizontal loads as well?

8 BY WITNESS STANCAVAGE:

9 A Yes, and the horizontal loads as well.

10 Q I guess we need to turn to you, Mr. Hucik, on  
11 Page 2. I'm trying to think ... did you actually cal-  
12 culate any probabilities that there could be a simultaneous  
13 actuation of any -- well, a simultaneous occurrence of a  
14 loss-of-coolant accident and an opening of a relief valve?

15 BY WITNESS HUCIK:

16 A I haven't personally calculated those prob-  
17 abilities, but I believe those probabilities have been  
18 given to the NRC staff. I just do not know them off the  
19 top of my head. They're very low.

20 Q I see.

21 BY WITNESS HUCIK:

22 A Very low.

23 Q Do you know if the only way that's seen as  
24 possible is just bad timing, unfortunate timing where the  
25 SRV -- unrelated to the loss-of-coolant accident -- pops?

1-26

1 I mean, is that your understanding of the whole --

2 BY WITNESS HUCIK:

3 A That would be the only way because you could  
4 not get them going simultaneously, mechanistically.

5 Q I see.

6 The high energy pipe is sort of looked at as  
7 a pressure reliever. It's sort of like a pressure relief  
8 valve itself, isn't it?

9 BY WITNESS HUCIK:

10 A That's correct.

11 Q Now -- Well, if the reactor is undergoing a  
12 pressure -- Let me ask you this: How much -- What is  
13 the operating pressure of the reactor, to your knowledge?

14 BY WITNESS HUCIK:

15 A The operated pressure is normally around 1040  
16 to 1050 psig.

17 Q And then how much additional pressure is there  
18 until the first safety/relief valve opens? It's not a  
19 great amount --

20 BY WITNESS HUCIK:

21 A I believe for Allens Creek it's 1103 psig.  
22 There's about 50 to 60 psi delta between the operating  
23 pressure.

24 Q So the only way that you -- in theory then,  
25 there would only be that short band or small band that would

1 be critical in a sort of hypothetical sense of a weakened  
2 pipe -- a cracked pipe, giving as pressure was rising?  
3 In other words, normal you said was ten -- something on the  
4 order of thousand -- and there would be no reason for the  
5 pipe to go at any specific time, if it were running  
6 normally. It would just go whenever it was ready to go.

7 BY WITNESS HUCIK:

8 A. That's correct.

9 Q. So the only way that increasing pressure would  
10 be contributory would be just that short band of 60 or  
11 so?

12 BY WITNESS HUCIK:

13 A. Well, any break of the line would actually send  
14 a decompression of the system. So it would tend to drop  
15 the pressure in --

16 Q. Right.

17 But in terms of a pipe which could stand normal  
18 pressure, but was just -- you know, could just stand  
19 slightly above it, the only time where you could get a  
20 critical situation of pressurizing, but not reaching the  
21 set valve -- the relief valve point would be in that  
22 band of 60, right?

23 Do you follow me?

24 BY WITNESS HUCIK:

25 A. Yes. The pressure can rise in the system up to

1-28

1 the point of 60 psi before the valve opens, yes. It can  
2 rise in that area.

3 Q Are there any -- What are some of the  
4 durations which would be required for pressure to rise  
5 that 60 pounds? Are they short times or long times,  
6 typically?

7 BY WITNESS HUCIK:

8 A It would probably depend on the type of  
9 transient that were occurring in the system as to how  
10 fast the pressure rise is in the system.

11 Those different transients are normally  
12 evaluated for the plant, and the pressure rise rates are  
13 given.

14 Q And do you have any ballpark figures on the  
15 durations?

16 BY WITNESS HUCIK:

17 A Depending on the transient it might be several  
18 seconds, I believe.

19 Q Uh-huh. So that critical time would be a very  
20 short space of time.

21 Now, how rapidly does this depressurization  
22 start in a loss-of-coolant event? How quickly is this  
23 pressure expected to drop?

24 BY WITNESS HUCIK:

25 A It's basically instantaneous. It's a sonic wave

1 that would be traveling backwards to depressurize the  
2 system.

- - -

1-29  
✓

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

-1 1 Q I have a little problem with this one area  
ed 2 of the reactor. There's a head above the shroud, or the  
3 shroud head, and then is there a space that connects the  
4 area above the shroud and the annulus for the jet pumps?  
5 Is that an open area? It's not sealed off, is it?

6 BY WITNESS HUCIK:

7 A I believe outside the annulus, that's fairly  
8 well open, to try and drain off any of the water that  
9 comes off of the wet steam as the steam is dried in the  
10 upper shroud region.

11 Q What do you have in mind at line 22? You  
12 say, "Small breaks do not release sufficient energy."

13 Is there sort of a dividing line in terms  
14 of pipe size there?

15 BY WITNESS HUCIK:

16 A In terms of pool swell, you have to get a  
17 large air bubble formed underneath the pool, okay, and  
18 that air bubble comes from the drywell air that's  
19 initially in the drywell; and you have to get that being  
20 interjected underneath the pool in a very rapid period of  
21 time.

22 Only the large breaks, like the steam line  
23 break which we analyze for, has a sufficient energy rate  
24 of steam into the drywell to force the air out under the  
25 pool and lift it in a pool swell fashion.

1 Small breaks do not pressurize the drywell  
2 fast enough to really vent that air sufficiently fast  
3 enough to get a rise of the pool water.

4 It kind of bubbles the air through with the  
5 steam and you get condensation of the steam and the air  
6 sort of bubbles to the surface for the smaller breaks.

7 Q You said main steam line. Are there any other  
8 lines?

9 BY WITNESS HUCIK:

10 A That could cause pool swell?

11 Q Yes.

12 BY WITNESS HUCIK:

13 A The other large line that's in the system is  
14 the recirculation line, okay, and that has been evaluated  
15 and we find that the steam line actually bounds the  
16 conditions between those two large break lines.

17 Q I see.

18 JUDGE LINENBERGER: Sir, perhaps for further  
19 clarification of this point, let's assume the integrity of  
20 the main steam line piping, but would you indicate how  
21 many SRV's would have to actuate in order to produce a  
22 significant pool swell phenomenon? Would one do it?

23 WITNESS HUCIK: No. Basically, the problem  
24 there is it's the amount of air that's carried over from  
25 the drywell that causes pool swell, and in the case of a

1 Mark III containment, the drywell line is somewhere around  
2 230,000 to 240,000 cubic feet of air, and that's what  
3 causes the pool swell phenomenon.

4 In a safety/relief valve discharge line, the  
5 air in that line is typically between 50 and 60 cubic  
6 feet.

7 So the total volume of air there is about  
8 what, six or seven hundred cubic feet total, and that's  
9 a much smaller volume than the 260,000 cubic feet which  
10 would cause pool swell.

11 In tests that we've seen in plants, with even  
12 one safety/relief valve going off, there's basically no  
13 noticeable pool swell at all.

14 There might be a change in the water level  
15 for an actuation of maybe an inch or so, but nothing  
16 more than that.

17 JUDGE LINENBERGER: Thank you.

18 BY MR. DOHERTY:

19 Q Moving on into the affidavit, I think the  
20 rest of this is with regard to the other contention, so  
21 there's kind of a tracking we have to do here.

22 The affidavit of Mr. Stancavage.

23 I notice you filed this in 1980. Have there  
24 been any significant developments in this area since that  
25 time?



-4 1 BY WITNESS STANCAVAGE:

2 A No, I don't think there have been any  
3 significant developments.

4 Q Okay. Now, going to page 2, Mr. Stancavage,  
5 there's a description of events following a postulated LOCA  
6 there.

7 You say, "The drywell is pressurized by reactor  
8 steam, and a mixture of steam and air is directed to the  
9 suppression pool..." by the vents.

10 That air is all just drywell air, right, the  
11 kind you'd breathe if you stood in the drywell?

12 BY WITNESS STANCAVAGE:

13 A Yes, that's correct.

14 Q Does that air condense at all once it's  
15 pushed into the suppression pool, or does it just pretty  
16 much stay constant?

17 BY WITNESS STANCAVAGE:

18 A No, the air itself does not condense when it's  
19 in the suppression pool. It's not a condensable gas, and  
20 it rises to the surface of the pool.

21 Q So it's part of the swell?

22 BY WITNESS STANCAVAGE:

23 A Yes, it is actually the driving force for the  
24 slug of water which rides on top of the air bubble.

25 Q So it's the first material through the vents

1 pretty much?

2 BY WITNESS STANCAVAGE:

3 A I believe it would be fair to say that the  
4 mixture through the vents is more likely to be a homogeneous  
5 mixture of air and steam, but the steam itself will quickly  
6 be condensed in the colder suppression pool water, so that  
7 the driving mechanism for pool swell is primarily air.

8 Q Now, in the main steam line event, postulated  
9 break, is that steam line sort of high in the air in the  
10 drywell?

11 This is just a geography problem for me. It  
12 appears to me it's one of the high pipes.

13 BY WITNESS STANCAVAGE:

14 A Yes, it is relatively high in the drywell,  
15 near the reactor vessel.

16 Q In the loading, then, through the vents and  
17 out to the -- well, do you assume that there's an equal  
18 discharge around the 360-degree vent wall or whatever  
19 that's called (I forget the term for it), the wall that  
20 holds the vents? Do you assume that there's a pushing  
21 out uniformly?

22 BY WITNESS STANCAVAGE:

23 A Yes, that's an assumption that's made, that  
24 there's a uniform vent clearing, and air flows through  
25 all the vents uniformly.

1 Q What about the steam?

2 BY WITNESS STANCAVAGE:

3 A And the steam, also, flows through the vents  
4 in a uniform way.

5 Q Has there been any testing on that assumption?

6 BY WITNESS STANCAVAGE:

7 A Yes, there has been testing on that  
8 assumption.

9 The most recent tests with Mark III  
10 configuration was a one-ninth scale multi-vent test which  
11 had three rows of three columns of vents, and differences  
12 were looked for in terms of pressures and flow rates  
13 through the vents and around the vents during pool swell  
14 to detect if there were any imbalances.

15 The conclusions were reached that essentially  
16 the flow was uniform through the vents.

17 Q You said it was a one-ninth scale?

18 BY WITNESS STANCAVAGE:

19 A Yes.

20 Q That means in total dimensions, everything  
21 was one-ninth, right?

22 BY WITNESS STANCAVAGE:

23 A Yes.

24 Q But was it a 360-degree?

25

//

1 BY WITNESS STANCAVAGE:

2 A No, it was not 360-degree.

3 Q So you are still postulating sort of that since  
4 it behaved uniformly through whatever section that was of  
5 the 360 degrees, it would be the same for 360?

6 BY WITNESS STANCAVAGE:

7 A Yes, that's correct.

8 Q Okay. Now, is there any kind of way you can  
9 give me an idea of the amount of steam and air there is to  
10 go through? I know it would be pretty tough to give.  
11 The volume of that?

12 BY WITNESS STANCAVAGE:

13 A Is there any way -- I'm not sure I understand  
14 your question.

15 Would you ask it again?

16 Q Well, what is the volume of air and steam  
17 driven through the vents?

18 BY WITNESS STANCAVAGE:

19 A The volume of air driven through the vents  
20 is approximately 230,000 cubic feet.

21 Q That's air?

22 BY WITNESS STANCAVAGE:

23 A That's of air, and that's driven through the  
24 vents within four or five seconds after the line break.

25 The volume of steam is somewhat larger than

-8 1 that. I cannot give you at this time an exact number for  
2 it, but during the first five seconds of the break it's  
3 smaller than the amount of air, and it increases as a  
4 function of time, because the reactor continues to  
5 discharge approximately 500,000 pounds of fluid through  
6 the break during the course of a loss of coolant accident.

7 Q Is the initial surge the highest surge, the  
8 highest blast through the vents, and the higher pool  
9 swell comes at the beginning then?

10 BY WITNESS STANCAVAGE:

11 A Yes. The pool swell comes within the first  
12 three seconds after the line break.

13 Q Yes, and is that the highest height of the  
14 pool swell experienced in that first three seconds, or --

15 BY WITNESS STANCAVAGE:

16 A Yes, that is correct.

17 Q -- from the discharge in those first three  
18 seconds?

19 BY WITNESS STANCAVAGE:

20 A Yes.

21 Q Were you here for Mr. Nuta's testimony  
22 yesterday by any chance?

23 BY MR. STANCAVAGE:

24 A No, I was not.

25 Q Were you there?

1 BY WITNESS HUCIK:

2 A. No, I was not either.

3 Q. He gave a measurement of, I think, it was  
4 22 feet, 5 inches of the height to the HCU platform from  
5 the water in the pool. He said that -- I believe the  
6 term was at normal level.

7 We asked him what -- if there were times when  
8 the water would be higher and the plant still operating.  
9 He had to decline on that.

10 Could you answer that? Do you know?

11 BY WITNESS STANCAVAGE:

12 A. Yes. There are times when the water level  
13 can vary from the normal water level by as much as three  
14 inches either above or below the normal water level.

15 Q. So it's just three inches?

16 BY WITNESS STANCAVAGE:

17 A. Yes, that's correct.

18 Q. I see. Now, if the -- I'm referring to page  
19 3 now of the affidavit, about in the middle. There's a  
20 discussion of impact on platforms and drag loads.

21 Would there be any drag loads on a platform  
22 that was a sheet, sheet metal type of platform, or a  
23 plate that was, you know, no holes? Would there be any  
24 drag loads at all?

25 //

1 BY WITNESS STANCAVAGE:

2 A Yes. There would be drag loads on a platform,  
3 whether it had holes in it or was a solid plate.

4 Q All right. Would those just be at the end of  
5 these platforms? Do you follow me?

6 BY WITNESS STANCAVAGE:

7 A No, I'm not sure.

8 Q Maybe I didn't understand what drag loads  
9 meant.

10 I thought that in order to have a drag load  
11 it had to pass somehow to have a drag load. How would it  
12 pass if it was a flat, no-hole platform.

13 BY WITNESS STANCAVAGE:

14 A Okay. I understood the platform you were  
15 postulating to be finite, have finite dimensions, so that  
16 the pool swell would actually flow around it.

17 Q Oh, I see, to get a drag load?

18 BY WITNESS STANCAVAGE:

19 A To get a drag load, yes. If there was total  
20 flow blockage, there would be no drag load as such.

21 Q Are either of you familiar enough with Allens  
22 Creek to verify that the platforms will give total flow  
23 blockage?

24 BY WITNESS STANCAVAGE:

25 A I'm not.

1 BY WITNESS HUCIK:

2 A I believe there's a requirement that at least  
3 at the HCU floor level there be a minimum opening area,  
4 which I believe Allens Creek has, for flow to go through.

5 Q But that minimum opening area would be just,  
6 what, every so often going around this annulus circle?  
7 There would be one every ten feet or something like that?

8 BY WITNESS HUCIK:

9 A Yes.

10 Q Is this typical of Mark III's at this point?

11 BY WITNESS HUCIK:

12 A Yes. All the Mark III's typically have floors  
13 with openings in various areas around that annular region  
14 of the containment pool.

15 Q The idea, though, is to place an HCU where  
16 there are no openings, though, is that right?

17 BY WITNESS HUCIK:

18 A In most plants, I think that's what they've  
19 done.

20 Q I see, and yet you can walk over the openings,  
21 if necessary?

22 BY WITNESS HUCIK:

23 A There's normally grating over the openings.

24 Q Okay. There's a description of the -- There's  
25 a description of testing at the foot of the text on page 3.



2-12 1 You mention "50 full-scale and subscale  
2 experiments." Is this testing over now, or is it still in  
3 progress? I mean, is there still more planned?

4 BY WITNESS STANCAVAGE:

5 A Are you referring to the safety/relief valve  
6 test discussed in the footnote on page 3?

7 Q No. I'm referring to the material just above  
8 it.

9 BY WITNESS STANCAVAGE:

10 A Oh, the pool swell, okay, the 50 full-scale  
11 and subscale experiments.

12 These pool swell experiments are complete.

13 Q I see. What stage is it at then? You have  
14 submitted your results to the NRC?

15 BY WITNESS STANCAVAGE:

16 A Yes, the results have all been submitted to the  
17 NRC.

18 Q I see. There's a statement at page 4 under  
19 Section III: "Immediately following the introduction of  
20 the BWR/6--Mark III, the General Electric Company started  
21 an extensive experimental and analytical effort to  
22 confirm the Mark III design."

23 Is that what you meant to say there? Is that...

24 BY WITNESS STANCAVAGE:

25 A Yes. I believe you just read the words that

1 are there.

2 Q Uh-huh.

3 BY WITNESS STANCAVAGE:

4 A That is what I meant to say.

5 Q Then it goes on to say, "The purpose of the...  
6 Confirmatory Test Program was to confirm the analytical  
7 methods used to predict the drywell and containment  
8 responses."

9 What I want to ask is were there any predictions  
10 at that time of the hydrodynamic loads on the HCU's?

11 BY WITNESS STANCAVAGE:

12 A As far as I understand the development of the  
13 dynamic loads on the HCU, there were no predictions for  
14 pool swell loads on the hydraulic control units prior to  
15 the conduct of these tests.

16 - - -  
17  
18  
19  
20  
21  
22  
23  
24  
25

-14 1 Q Okay. When you say "confirm" here, does that  
2 mean a use of an entirely different assessment technique  
3 working toward the same results, or does that mean redoing,  
4 sort of checking?

5 BY WITNESS STANCAVAGE:

6 A Well, let me ask, do you mean the "confirm"  
7 in the first sentence or in the second sentence?

8 Q Yes, in the first.

9 BY WITNESS STANCAVAGE:

10 A In the first sentence. The confirmation in  
11 the first sentence refers to the fact that this Mark III  
12 design was a departure from the Mark I and Mark II  
13 designs in that it employed horizontal vents, and  
14 engineering judgment suggested that this would work; and  
15 experimental and analytical efforts were undertaken to  
16 confirm that engineering judgment.

17 Q Okay.

18 JUDGE LINENBERGER: Sir, perhaps you can  
19 clarify that language in that same sentence.

20 When you talk about "introduction of the  
21 BWF/6--Mark III," I have interpreted that to mean  
22 introduction of the design concept, not introduction of a  
23 product line.

24 Is that the context in which you mean that?

25 WITNESS STANCAVAGE: Yes, that would probably

1 be a better way to say it.

2 The idea was first proposed, and then before  
3 the designed product line was actually offered, the  
4 concept was verified analytically and experimentally.

5 JUDGE LINENBERGER: Thank you.

6 BY MR. DOHERTY:

7 Q Now, you mention "small-scale tests" in the  
8 next paragraph. Were these prior to -- well, was this  
9 the one-ninth scale type of test you mentioned a while ago?

10 BY WITNESS STANCAVAGE:

11 A No. These tests were actually smaller than  
12 one-ninth scale.

13 Well, maybe you know the scale.

14 BY WITNESS HUCIK:

15 A I believe the scaling in those was about  
16 one-twelfth on those small-scale tests.

17 Q Was that one-twelfth of a thousand-megawatt  
18 plant? Is that your recollection?

19 BY WITNESS HUCIK:

20 A Yes.

21 Q That was in '71.

22 When was the Mark III first marketed?

23 BY WITNESS STANCAVAGE:

24 A I believe that was done in 1972.

25 Q Okay. I think at the next page you spoke of

-16 1 the Pressure Suppression Test Facility and the drywell  
2 modeling.

3 Is the drywell ten feet in diameter at that  
4 or is the Pressure Suppression Test Facility ten feet in  
5 diameter?

6 I had a little problem with that in  
7 understanding that.

8 BY WITNESS STANCAVAGE:

9 A The drywell in the Pressure Suppression Test  
10 Facility is ten feet in diameter. The drywell itself in  
11 an actual Mark III plant is a much larger diameter.

12 Q About 25 feet, at least, isn't it?

13 BY WITNESS STANCAVAGE:

14 A I believe the diameter in a Mark III plant is  
15 on the order of 80 feet, 80 to 100 feet.

16 Q Okay. Well, in the March '74 tests that you  
17 mention in the last paragraph on page 5, were there any  
18 attempts to locate the vibratory loads on equipment in  
19 those tests?

20 BY WITNESS STANCAVAGE:

21 A No, the vibratory loads were not directly  
22 investigated during those tests.

23 What was investigated primarily was the  
24 behavior of the water as it rose in the air space above  
25 the suppression pool to determine how high the water went,

-17 1 how thick the water ligament was and what the characteristics  
2 of the impact loads were.

3 Q How many full-scale tests were done?

4 BY WITNESS STANCAVAGE:

5 A I don't remember.

6 Q How much is the impact load reduced if there's  
7 a change of a water ligament to a froth, roughly?

8 BY WITNESS STANCAVAGE:

9 A Roughly, the load goes from approximately  
10 100 psi for a full water slug to about 15 psi for a froth  
11 load. So it's a factor of seven.

12 Q Well, does the Pressure Suppression Test  
13 Facility give a complete replica in these aspects as of  
14 an Allens Creek plant?

15 BY WITNESS STANCAVAGE:

16 A Yes, it does.

17 Q How do you actually measure these impacts?  
18 Do you have some kind of a gimmick up there that it can  
19 hit, that water can hit? Is that how you do this?

20 I don't -- I've never been in such a place,  
21 so....

22 BY WITNESS STANCAVAGE:

23 A Yeah, there's a metal plate that was put  
24 above the pool at various locations, and two kinds of  
25 data were collected.

-18 1 One was from pressure transducers mounted on  
2 the lower placing part of the plate to catch the actual  
3 direct pressure measurements and a more accurate measurement  
4 of the integral load on the plate itself was from a load  
5 cell which is like a scale on the back end of the plate  
6 that captured the total force imposed on the plate by the  
7 rising water.

8 Q It's interesting, but at the bottom of 5 and  
9 at the top of 6, you say they converted this facility to  
10 one-third scale and then ran tests to determine if -- well,  
11 apparently, there were some given floor restrictions above  
12 the pool.

13 That's the way I interpret that, that there  
14 are, at least in parts of the annulus, some flow  
15 restrictions.

16 BY WITNESS STANCAVAGE:

17 A Yes, there were flow restrictions in the test,  
18 trying to simulate what typical configurations of Mark III  
19 plants might be with flow restrictions near the area  
20 at which the maximum pool swell would be expected.

21 Q Are the HCU's above any of these places, to  
22 your knowledge, where there's a restriction you're just  
23 talking about?

24 BY WITNESS STANCAVAGE:

25 A The actual HCU modules are mounted on the floor

-19 1 and the floor is the restricted -- or the area of the  
2 annulus that is restricted.

3 So the HCU modules are in that sense above  
4 the area that's restricted.

5 Q Well, when you say to me "flow restrictions,"  
6 I think of something that slows down flow but doesn't stop  
7 it.

8 I think in yesterday's testimony Mr. Nuta  
9 said there were some cantilevered concrete platforms  
10 above -- close to the surface of the pool, but above it,  
11 of course, which would produce a flow restriction in the  
12 event of a pool swell, and it seemed as if that was  
13 planned that way, that that was desirable.

14 Here, I think -- well, are you saying here that  
15 a flow restriction might include a totally enclosing floor  
16 above a section of the pool?

17 BY WITNESS STANCAVAGE:

18 A Yes. In those flow restriction tests that  
19 we did, the actual roof of the facility was covered over,  
20 except for an area like an entrance hatchway, which had  
21 a variable area depending on how far the sliding panel was  
22 moved back.

23 This was actually considerably above the pool  
24 surface.

25 Q Now, are the platforms secured to the -- they



-20 1 are secured to the drywell; is that right?

2 BY WITNESS STANCAVAGE:

3 A I'm not sure about that.

4 BY WITNESS HUCIK:

5 A I believe so.

6 Q Are they secured at the other end to the  
7 containment shell?

8 MR. CULP: Your Honor, I'm going to object to  
9 any more questions along this line.

10 It seems we explored this to a great extent  
11 with Mr. Nuta yesterday, and now I don't understand why  
12 Mr. Doherty is asking these witnesses the same questions.

13 MR. DOHERTY: I think it's appropriate on  
14 occasion to ask the same question of several witnesses to  
15 see if they agree.

16 JUDGE WOLFE: Objection overruled.

17 BY MR. DOHERTY:

18 Q Do you want me to repeat the question, or do you  
19 have it in mind enough.

20 BY WITNESS HUCIK:

21 A I believe for Allens Creek the HCU floors are  
22 attached somewhat at the drywell and cantilevered out and  
23 do not attach specifically at the containment wall.

24 Q I see. Well, I've never seen an HCU, so....  
25 Are these movable devices, typically, or are they fixed to

1 the platform?

2 BY WITNESS STANCAVAGE:

3 A. I don't know how they are attached.

4 Q. Do you know if they are attached or are not  
5 attached?

6 BY WITNESS STANCAVAGE:

7 A. No, I don't.

8 Q. You can help him, if you know the answer?

9 BY WITNESS HUCIK:

10 A. Yeah, I believe they are attached to the floor  
11 to keep them stationary.

12 Q. I see. I think I know what you mean, but in  
13 the last paragraph of 6 you said, "Various" -- the paragraph  
14 on page 6, the latter part.

15 You said, "Various postulated break sizes up  
16 to two times the Design Basis Accident for the containment  
17 were tested."

18 Is that the main steam line break?

19 BY WITNESS STANCAVAGE:

20 A. Yes, that is two times the main steam line  
21 break.

22 Q. So you just postulated a main steam pipe  
23 double sized?

24 BY WITNESS STANCAVAGE:

25 A. Yes.

1 Q Okay, and is the pool uniform in width? It  
2 appears to be in diagrams.

3 BY WITNESS STANCAVAGE:

4 A Yes, it is.

5 Q On page 7 there's a discussion of impact loads  
6 and a discussion of the slug thickness. How is the slug  
7 thickness measured in an impact load test, or is it?

8 BY WITNESS STANCAVAGE:

9 A The slug thickness is measured by a series of  
10 level probes, which are electrical contacts that behave  
11 differently when they are wet than when they are dry.

12 They are spaced closely enough -- close enough  
13 together in a vertical direction so that one can tell from  
14 the electrical readings how thick the slug is.

15 They will be dry down to a certain point. Then  
16 they will be wet where the slug is, and then they will be  
17 dry again, and the interval over which they are wet is  
18 approximately the ligament thickness or the slug thickness.

19 Q Now, just reading that, are you saying there  
20 that after the pool has risen approximately 19.2 feet, we  
21 are down to two foot or less slug thickness?

22 BY WITNESS STANCAVAGE:

23 A I'm confused by what you said. It sounded like  
24 you said when the pool swell has reached 19 feet, the  
25 slug thickness is two feet or less; is that correct?

1 Q Yes. When the swell is 19 feet above the  
2 level of the water in normal conditions.

3 BY WITNESS STANCAVAGE:

4 A No. It's when the pool is about 12 feet above  
5 the original height of the pool surface that the ligament  
6 has dropped to two feet in thickness.

7 Q Well, your statement there says, "After the  
8 pool has risen approximately 1.6 times vent submergence  
9 below normal."

10 I would take that to mean you would multiply  
11 12 by 1.6.

12 BY WITNESS STANCAVAGE:

13 A Oh, okay. The vent submergence below water  
14 level, normal pool water level, is 7.5 feet, and 7.5 times  
15 1.6 is 12.

16 Q Uh-huh, okay. So that's what the 12 refers to.

17 Okay. So then the last ten feet approximately  
18 is where this ligament is expected to break up?

19 BY WITNESS STANCAVAGE:

20 A Yes.

21 Q You mention a figure of 40 foot per second as  
22 bounding test data, and so I take it that's the most rapid  
23 surface velocity observed?

24 BY WITNESS STANCAVAGE:

25 A Yes. Forty feet per second is the highest pool

1 swell velocity observed.

2 Q How many observations were there? Can you  
3 give me an idea?

4 BY WITNESS STANCAVAGE:

5 A I'm not sure.

6 Do you know?

7 BY WITNESS HUCIK:

8 A I believe there were a total of 213 different  
9 tests, total.

10 Q Two hundred and thirteen.

11 Was 40 foot per second observed frequently?

12 BY WITNESS HUCIK:

13 A I believe the velocities ranged as low as 20  
14 feet on up to around 40 feet per second, so there was  
15 quite a range.

16 We varied the size and other parameters, so  
17 you'd get many different conditions.

18 - - -  
19  
20  
21  
22  
23  
24  
25

-1  
ed

1 JUDGE LINENBERGER: Mr. Doherty, perhaps you  
2 can, if you would, give us a feeling for how this line  
3 of questioning goes to either the -- how it goes to the  
4 support of the contention?

5 I'm just having a bit of curiosity here about  
6 it.

7 MR. DOHERTY: Well, I'm trying to understand  
8 what their impact load -- I'm trying to get at the strength  
9 of some of the input into their impact load calculations.

10 I think it's a good question to ask, when  
11 someone gives you a bounding sort of thing, to ask is  
12 that a measurement that you -- well, I think it's good  
13 to ask, first of all, how many times did you observe,  
14 you know, to get that.

15 And then to go into, well, did you hit 39  
16 feet per second 212 times or something of that order, and  
17 maybe 20 foot per second once.

18 JUDGE LINENBERGER: Well, I guess I don't  
19 see how that's critiqueing their calculations.

20 True, you are getting at a --

21 MR. DOHERTY: I'm sorry, I can't hear you.

22 JUDGE LINENBERGER: -- phenomenological  
23 understanding -- I say you are getting a phenomenological  
24 understanding of what things might be going on here, but  
25 you've said the purpose is to critique their analysis, and

-2  
1 I just -- I don't quite see how that's coming out of your  
2 line of questioning; but pray, continue. I just was hoping  
3 for some guidance here on what you were trying to get at.

4 MR. DOHERTY: Well, I am going on the  
5 assumption that the velocity of the pool would have a --  
6 would be a sensible input into impact loading.

7 I may be wrong about that. I don't know  
8 for sure.

9 JUDGE LINENBERGER: Excuse me, sir, but --

10 MR. DOHERTY: Perhaps you can set me straight.

11 JUDGE LINENBERGER: You haven't demonstrated  
12 that these gentleman haven't given any consideration to  
13 such a matter, nor have you even asked them whether they  
14 did it.

15 So if that's your concern, there's a pretty  
16 direct way to kind of pin it down.

17 Well, I'm sorry. You conduct your cross as  
18 you see fit.

19 BY MR. DOHERTY:

20 Q Well, would the maximum water surface velocity  
21 be a factor in determining the impact loads?

22 BY WITNESS STANCAVAGE:

23 A Yes, they would. The water impact velocity  
24 is a major determinant of impact load.

25 Q In this testing, has there been any source of

-3 1 similar testing done for other industrial, or whatever,  
2 type -- in other words, of experiments?

3 In other words, have you been the first people  
4 to ever try to really measure this kind of thing? Were  
5 you confronted with a totally strange situation when people  
6 started to tell you that you were going to have to  
7 measure these things?

8 JUDGE CHEATUM: Mr. Doherty, how does that  
9 question further your cause, any answer to that question?

10 MR. DOHERTY: If they can tell --

11 JUDGE CHEATUM: The question is, what have  
12 they done to show this or that.

13 MR. DOHERTY: If they can tell me that, "We  
14 did extensive background research into hurricane impacts  
15 on docks and from there we were able to find out some  
16 long-term, well-known engineering theory which supports  
17 this," or if they have to say, "No one ever did it before,"  
18 then I think the Board has learned something.

19 JUDGE CHEATUM: What would that have to do  
20 with your contention?

21 MR. DOHERTY: That would show that the  
22 calculations are -- that everyone is new at this, that  
23 there's no other scientific source to look at for judging  
24 if this type of work is accurate or not.

25 I think it's a point worth getting.



1 JUDGE CHEATUM: Okay.

2 JUDGE LINENBERGER: F equal MA was new to  
3 Newton, but it survived pretty well. Just because they  
4 are pioneering -- and I don't know whether they were or  
5 not, but just because they are pioneering, how does that  
6 undercut them and the credibility of what they've done?

7 I guess that's my problem. That is the problem  
8 we are having here.

9 JUDGE WOLFE: Of if you could ask a question  
10 with regard to what you know about hurricane pressures or  
11 what have you, and ask them precisely if they took that  
12 into consideration in their testing, this might impeach  
13 their testimony or their testing abilities; but this sort  
14 of cross-examination, Mr. Doherty, is really without  
15 focus.

16 We'll listen to a little bit more of it and  
17 then are just going to have to terminate your cross-  
18 examination.

19 You are going to have to be more precise and  
20 dig in there and just don't ask educational questions. You  
21 should have educated yourself before you came in.

22 Put questions to these witnesses and test  
23 their testimony.

24 All right.

25 MR. DOHERTY: Your Honor, I'd like to take

-5 1 a break now.

2 JUDGE WOLFE: We'll recess until 10 of 11:00.

3 (Recess taken.)

4 JUDGE WOLFE: All right, Mr. Doherty.

5 BY MR. DOHERTY:

6 Q At the foot of 7, in the last sentence you  
7 speak about a reactor simulator and that it discharged  
8 air through an orifice.

9 Doesn't the reactor in the event of this  
10 accident, don't we get a discharge of air and steam  
11 through this orifice?

12 BY WITNESS STANCAVAGE:

13 A Actually, during the postulated accident one  
14 gets a discharge of steam and liquid through the break, and  
15 no air at all.

16 The air was used in the test to provide more  
17 driving force for the pool swell, because it does not  
18 condense in the pool water, instead of steam.

19 Q Was the orifice a vent size orifice, essentially?  
20 Was that part of the simulation in this test as well?

21 BY WITNESS STANCAVAGE

22 A I'm not sure what your question was.

23 Q The last word on page --

24 BY WITNESS STANCAVAGE:

25 A Orifice?

1 Q Orifice.

2 BY WITNESS STANCAVAGE:

3 A Yes.

4 Q Was that vent size?

5 BY WITNESS STANCAVAGE:

6 A Was that vent size?

7 Q Vent size.

8 BY WITNESS STANCAVAGE:

9 A No, that was break size. That was the orifice  
10 in the blowdown pipe which leads from the reactor vessel  
11 into the drywell.

12 Q At the top of 9, what's the "pressure  
13 differential loading" there? This is a pressure on the  
14 platform itself, just an air pressure?

15 BY WITNESS STANCAVAGE:

16 A Actually, this is an air pressure difference  
17 across an expanse of structure like a platform.

18 Q I see. The "1500 square foot vent area," is  
19 that an attempt to take all the 120 vents? Is that what  
20 that would be, the sum of those areas, of 120 vents?

21 BY WITNESS STANCAVAGE:

22 A No. The 1500 square foot or square feet of  
23 vent area is actually the open area of the floor at that  
24 point.

25 Q Okay. With regard to the Pressure Suppression

-7  
1 Test Facility, I believe you stated earlier that the  
2 vertical dimensions were all full scale; is that right?

3 BY WITNESS STANCAVAGE:

4 A. Yes, that is correct.

5 Q. Now, the horizontal dimensions, are they only  
6 different as regard to using a section rather than -- do  
7 they only differ because you've had to make a section rather  
8 than have an entire full-scale containment?

9 BY WITNESS STANCAVAGE:

10 A. No. They are also reduced from a full-scale  
11 section, if you will, with full-scale vents, so that the  
12 area is one-third of the full-scale area.

13 In other words, looking down at the top, the  
14 area is one-third of the full-scale area.

15 Q. So you don't have a 120-degree section, do you?

16 BY WITNESS STANCAVAGE:

17 A. No.

18 Q. Then I don't understand what you said.

19 BY WITNESS STANCAVAGE:

20 A. Okay. The one-third -- the length in the  
21 vertical direction is full scale, but the cross-sectional  
22 area is one-third the area of a full-scale section of  
23 equivalent angle.

24 Q. Okay. That would mean like you'd have one-  
25 third of the platform, for example?

1 BY WITNESS STANCAVAGE:

2 A. Yes, that's correct.

3 Q. Okay.

4 MR. DOHERTY: All right. No further questions  
5 of these gentlemen. Thank you very much -- on this issue.

6 JUDGE WOLFE: Redirect, Mr. Culp?

7 MR. CULP: I have no questions.

8 JUDGE WOLFE: Board questions?

9 JUDGE CHEATUM: I have no questions.

10 JUDGE LINENBERGER: No questions.

11 JUDGE WOLFE: Mr. Stancavage is to be  
12 excused permanently?

13 MR. CULP: Yes, sir.

14 JUDGE WOLFE: All right. You are excused,  
15 Mr. Stancavage.

16 (Witness Stancavage was excused.)

17 MR. COPELAND: We would like to recall  
18 Mr. Melvyn Weingart, Your Honor.

19 I do not recall whether Mr. Weingart was  
20 excused or not, so I would ask that he be resworn.

21 JUDGE WOLFE: Stand and raise your right hand.  
22 Whereupon,

23 MELVYN WEINGART

24 was recalled as a witness and, having been first duly  
25 sworn, was examined and testified as follows:

1 MR. COPELAND: As an initial matter, Your  
2 Honor, I would note his testimony has a typographical  
3 error and it should be "TexPirg A-34" instead of "A-40."

4 JUDGE WOLFE: "A-34"?

5 MR. COPELAND: Yes, sir.

6 DIRECT EXAMINATION

7 BY MR. COPELAND:

8 Q Mr. Weingart, do you have in front of you the  
9 "Direct Testimony of Melvyn Weingart Regarding Additional  
10 Contention TexPirg A-34 - Hydrogen Monitoring"?

11 BY WITNESS WEINGART:

12 A I do.

13 Q Was the document prepared by you or under your  
14 supervision and direction?

15 BY WITNESS WEINGART:

16 A It was.

17 Q Do you have any corrections to make?

18 BY WITNESS WEINGART:

19 A The only corrections I have are the ones you  
20 just identified, the reference to TexPirg A-40 is also  
21 noted on the first page on line 17 and on line 21, I guess  
22 it is. It should be A-34.

23 Q Is the testimony true and correct to the best  
24 of your knowledge and belief?

25 //

1 BY WITNESS WEINGART:

2 A Yes, it is.

3 Q Do you adopt it as your testimony in this  
4 proceeding?

5 BY WITNESS WEINGART:

6 A I do.

7 MR. COPELAND: Your Honor, at this time I would  
8 move that the direct testimony of Mr. Weingart on  
9 TexPirg Additional Contention 34 be incorporated into the  
10 record as if read.

11 JUDGE WOLFE: Any objection?

12 MR. DEWEY: No objection, Your Honor.

13 MR. DOHERTY: No objection, Your Honor.

14 MR. COPELAND: The witnesses are tendered for  
15 cross-examination, Your Honor.

16 I'm sorry, I jumped the gun on you.

17 JUDGE WOLFE: The testimony of Melvyn Weingart  
18 regarding TexPirg Additional Contention 34 is incorporated  
19 into the record as if read.

20 (Applicant's testimony of Melvyn Weingart  
21 concerning TexPirg Additional Contention A-34 follows:)

22 - - -

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of	§	
	§	
HOUSTON LIGHTING & POWER COMPANY	§	Docket No. 50-466
	§	
(Allens Creek Nuclear Generating	§	
Station, Unit 1)	§	

DIRECT TESTIMONY OF  
MELVYN WEINGART  
REGARDING ADDITIONAL CONTENTION  
TEXPIRG A-~~40~~<sup>34</sup> - HYDROGEN MONITORING

0 Q. Mr. Weingart, have you previously testified in this  
1 proceeding?

2 A. Yes. I testified in connection with that portion of  
3 TexPirg AC 36 (McCorkle 17) regarding charcoal adsorber  
4 fires and on Board Question 4A regarding combustible gas  
5 control.

6 Q. What is the purpose of this testimony?

7 A. The purpose of this testimony is to address TexPirg  
8 Contention A-~~40~~<sup>34</sup> regarding the adequacy of the Combustible  
9 Gas Control System being provided for ACNGS. It should be  
10 noted that my testimony presented on August 25, 1981, con-  
11 cerning Board Question 4A/Combustible Gas Control (Tr. 15986-  
12 15923) also addresses the hydrogen control concerns identified  
13 in TexPirg Contention A-~~40~~<sup>34</sup>. TexPirg Contention A-40 reads  
14 as follows:

15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
TexPirg contends that the Applicant monitoring of  
in containment building events during LOCA or similar  
events is not adequate to detect immediately the oc-  
currences of hydrogen explosions. That the recent



Three Mile Island incident shows that current approved containment building monitoring apparatus did not bring such an event to the attention of operators immediately, and that therefore the strong possibility existed that actions which would prevent a second hydrogen explosion were not taken. There is danger that hydrogen explosions will endanger TexPirg members because of the containment building during a LOCA is likely to contain radioactive gases which would be released from the building damaged even lightly by the explosion and in excess of 40 CFR.190 or 10 CFR 20.

Q. Is it accurate to compare the ACNGS Hydrogen Monitoring System to TMI?

A. No. The ACNGS Hydrogen Monitoring Subsystem (see PSAR Sections 6.2.5.2.2 and 7.5.1.4.2.11(d)) of the Combustible Gas Control System will be capable of withdrawing and analyzing samples from the ACNGS drywell and containment in order to provide sufficient information to the plant operators regarding hydrogen buildup inside the containment and drywell during accident conditions so that they can maintain the concentration of hydrogen below the flammability limit (4% by volume).

The hydrogen monitoring subsystem for ACNGS is significantly different than the system provided at TMI-2. To determine hydrogen concentration inside the containment at TMI-2, personnel had to go to the sample room, manually draw a sample of the containment atmosphere into a container, take the container to another area, and insert the content into a gas analyzer. As I will point out in the following discussion, the hydrogen monitoring system at ACNGS is substantially different.

Q. Can you answer the questions raised by the Board at pages 21 and 22 of the September 1 Order?

A. I believe the Board's questions can best be answered by describing the integrated combustible gas control system. The Hydrogen Monitoring Subsystem for ACNGS will be actuated from the Control Room after an accident and will then automatically provide a record over time of the hydrogen concentration at various locations within the containment and drywell for the operator's use in the Control Room. An alarm will actuate if the hydrogen analyzer detects a concentration of 3.0 volume percent. As indicated in Mr. Hucik's testimony, in connection with Doherty Contention 5, this alarm setting will provide adequate time to initiate the hydrogen control systems before the flammability limit (4% by volume) is reached.

The ACNGS Hydrogen Monitoring Subsystem, which is designed to the requirements of Regulatory Guide 1.7, will have the ability to obtain samples from various locations within the drywell and the containment. These points are selected to provide complete coverage of the drywell and containment. The system consists of two identical analyzer trains each powered from a different emergency bus, and each having the ability to monitor any of the sample points.

Redundant connections will be provided at each sampling location (one for each analyzer). The redundant analyzer equipment will be located in the Reactor Auxiliary Building approximately 135° apart. Readouts and control

capability will be provided in the Control Room.

The analyzer systems will be periodically calibrated (tested) using a 'zero' gas, i.e. a gas that does not contain hydrogen, and a span gas, i.e. a gas that contains a known hydrogen concentration. It should be noted that calibration can be accomplished remotely from the main control room. The sample withdrawal system will also be functionally tested on a periodic basis.

The Drywell-Containment Mixing Subsystem (see PSAR Section 6.2.5.2.3) is part of the Combustible Gas Control System. Its function is to dilute the hydrogen content in the drywell by mixing the drywell and containment atmospheres after LOCA. This safety related system is completely redundant with duplicate piping, equipment and instrumentation.

The mixing subsystem capacity is 500 cfm for each of the redundant subsystems. The compressor in each subsystem has the capability of transferring the containment atmosphere into the drywell and discharging it at sufficient pressure to depress the water level in the drywell weir, expose the drywell suppression pool vents and cause the air flow to exit through the vents. The hydrogen air mixture bubbles through the suppression pool and is then dispersed within the containment.

The ACNGS Mark III containment utilizes thermal convective mixing to assure that the hydrogen concentration throughout the containment is uniform. The mixing of the

containment atmosphere is further discussed by Mr. Hucik in his testimony. PSAR Section 6.2.5.3.3 describes the various analyses performed to demonstrate drywell and containment hydrogen mixing, and hydrogen redistribution from the drywell to the containment due to the operation of the Drywell-Containment Hydrogen Mixing Subsystem.

The Hydrogen Recombiner Subsystem (see PSAR Sections 6.2.5.1 and 6.2.5.2.4) will be manually activated from the Control Room as early as 24 hours following a design basis loss-of-coolant accident but before the hydrogen concentration in the containment reaches 3.5 volume percent, to ensure that the four volume percent is never exceeded following a design basis LOCA.

The Hydrogen Recombiner Subsystem consists of two redundant thermal units (such as the recombiners manufactured by Westinghouse Electric Corp.) located inside the containment; one at elevation 207.33 feet and the other at 232.25 feet, approximately 150° apart. The power supply panels are located in the Reactor Auxiliary Building at elevation 164.00 feet. Controls for the Hydrogen Recombiner are located in the Control Room.

Hydrogen recombination is a thermal process, using heat to cause recombination of the hydrogen and the oxygen in air to form water vapor. The recombiners for ACNGS utilize natural convection as the driving force to circulate containment atmosphere through equipment for

processing. The recombiners are designed to maintain containment hydrogen concentration below 4 percent by volume.

The subsystem consists of an inlet preheater section, a heater-recombination section and an exhaust chamber. When the recombining subsystem is initiated from the Control Room, the heating elements within the recombiner are energized, increasing the temperature of the recombination section. Containment atmosphere is drawn first into the preheater section at a controlled flow rate, then into the heater-recombination section where water vapor is formed due to the high temperature of approximately 1,150°F. Following the high temperature section, the hot water vapor/air mixture is cooled down to approximately 50°F above the ambient temperature in the containment.

There are no moving parts or piping between sections. The unit is completely enclosed and the internals are protected from impingement by containment spray. The inlet and outlet ports employ a louver arrangement to permit containment atmosphere to flow through the unit. In addition, a major advantage of this design is that there are no catalysts employed which could be subject to degradation by "poisoning".

The Westinghouse recombiner design has been thoroughly tested to assure their performance during post LOCA conditions. Westinghouse Document WCAP-9347 entitled "Qualification Testing for Model B Electric Hydrogen Recombiner"

dated July, 1978 and reports referenced therein, reports the results of the latest testing program for this type of recombiner. These test results confirm that the hydrogen recombiner of the size and type to be used at ACNGS will perform as indicated on PSAR Figure 6.2-29.

For testing purposes, each recombiner will be energized once every six months at 10KW for five minutes, to check the electronics and to apply voltage to all other electrical components. In addition, once a year, a heating test will be performed, allowing temperature to stabilize at operating conditions, to check calibration of the unit and proper operation of heaters.

The Containment Hydrogen Purge Sub-System, PSAR Section 6.2.5.2.5, (CHPSS) is a part of the Combustible Gas Control System and has the capability to purge the Containment atmosphere through the Stand-by Gas Treatment System (SGTS) at a sufficient rate (equivalent to the processing capability of the hydrogen recombiners) to control hydrogen concentration below 4% by volume. This post accident purge capability as a backup to the hydrogen recombiner is provided in accordance with Item C4 of Reg. Guide 1.7, Rev. 1 (September 1976). The CHPSS is designed to exhaust the air-hydrogen mixture from the Containment to the Shield Building Annulus for dilution and "hold-up" and replace it with filtered air. The Air-Hydrogen mixture in the annulus is then filtered through the SGTS before final release to the environment.

-11 1 MR. COPELAND: I will now tender them for  
2 cross-examination.

3 I thought I could do that in my sleep, but I  
4 guess it's....

5 (Laughter.)

6 JUDGE WOLFE: Mr. Sohinki?

7 MR. DEWEY: The Staff doesn't have any  
8 cross-examination, Your Honor.

9 JUDGE WOLFE: Mr. Doherty?

10 MR. DOHERTY: Yes, Your Honor. Thank you.

11 CROSS-EXAMINATION

12 BY MR. DOHERTY:

13 Q Mr. Hucik, part of this contention is -- you  
14 are submitting some, too, right? Okay.

15 At page 3 of the testimony, at line 21 you  
16 are listing some convection promoters, I guess we could  
17 call them, and one of them you listed is a containment  
18 wall.

19 Are you speaking of the steel shell or are you  
20 speaking of the --

21 BY WITNESS HUCIK:

22 A Yes, it's the steel shell of the containment  
23 building itself.

24 Q That's about an inch thick, isn't it?

25 //

1 BY WITNESS HUCIK:

2 A I believe it varies in thickness, but it averages  
3 about an inch and a half or so in thickness.

4 Q Is there any way the shield building can  
5 function the same way, to your knowledge?

6 BY WITNESS HUCIK:

7 A The shield building will act as a heat sink  
8 itself, yes.

9 Q Were any of these heat transfer mechanisms  
10 ever measured in any way?

11 BY WITNESS HUCIK:

12 A In some of the Pressure Suppression Test  
13 Facility work that's been done, you know, in the previous  
14 pool swell area, they have a simulated drywell wall there  
15 for our drywell vessel, and there were tests conducted  
16 where that drywell vessel was heated to about 300 degrees  
17 above the saturation temperature, and there were also  
18 tests run where it was not heated, and steam was injected  
19 into that vessel.

20 So there was a qualitative measure of the  
21 amount of condensation that steel structures will give for  
22 the type of environment that we would see.

23 So we've had some test data that we got  
24 indirectly that does support good condensation. There's  
25 also additional data in the industry that helps support



-13 1 that.

2 Q This is qualitative data, though?

3 BY WITNESS HUCIK:

4 A Yes, it was more qualitative. The tests were  
5 not directed at obtaining that information.

6 Q You also mention that there's a "mass transfer  
7 mechanism: additional density gradient due to changing  
8 hydrogen concentration near the pool surface."

9 First of all, does that mean that the hydrogen  
10 concentration will decrease near the pool surface?

11 BY WITNESS HUCIK:

12 A Yeah, basically, the hydrogen will come out  
13 of the pool surface, so your main concentration will be  
14 right at the pool surface level, and then as that diffuses  
15 and basically moves off with the air in that, the  
16 concentration will obviously drop from right at the pool  
17 surface where it emanates.

18 So there is a concentration gradient from the  
19 pool surface on up into the containment volume.

20 Q Okay. Now, how does a concentration gradient,  
21 how does that encourage movement, or does it?

22 BY WITNESS HUCIK:

23 A Well, the concentration gradient will  
24 effectively tend to mix the hydrogen gas. It moves -- you  
25 know, gases, ideal gases, will move from a high concentration

-14 1 to a lower concentration to try and reach equilibrium.

2 Q Yes.

3 BY WITNESS HUCIK:

4 A Therefore, at the high concentration levels  
5 near the pool surface, the hydrogen will tend to move  
6 off into lower concentration areas.

7 Q Okay. At line 15 you speak about "bulk  
8 concentration." Is that meant -- the term "bulk  
9 concentration" throws me.

10 Does that just mean the concentration of the  
11 whole containment?

12 BY WITNESS HUCIK:

13 A It's the total average, right.

14 Q Okay. There's a figure that you provided.  
15 Is that intended to show just the hydrogen from radiolysis  
16 and what happens to it?

17 BY WITNESS HUCIK:

18 A I believe this is the total hydrogen concentration  
19 in the wetwell and drywell, including the radiolysis.

20 Q I see. Now, in looking at this, my Figure 1  
21 says something about "Alto Lazio." Does yours?

22 BY WITNESS HUCIK:

23 A Yes.

24 Q Then it says, "Wetwell and Drywell Hydrogen  
25 Concentration Following DBA." Was there anything else

1 written there at all that I just didn't get?

2 It looks like there was something maybe --

3 BY WITNESS HUCIK:

4 A. No, that should be the full title there.

5 Q. That's the full title?

6 BY WITNESS HUCIK:

7 A. You have "Figure 1" in the left-hand corner  
8 that....

9 Q. Yes. What is your understanding of the  
10 conservative assumptions in Reg Guide 1.7, or very  
11 conservative assumptions?

12 BY WITNESS HUCIK:

13 A. A couple of the main conservative assumptions  
14 have to do with the release of the hydrogen from the core  
15 within the first two minutes.

16 That's an assumption that the Reg Guide 1.7  
17 states that you use in your analysis, and the second  
18 conservative assumption is the amount of cladding that's  
19 assumed to react with the water in the metal/water  
20 reaction which generates the hydrogen. That's normally  
21 five times the calculated metal/water reaction that is  
22 used in much of the Appendix K calculations for emergency  
23 core cooling system analysis.

24 So there's sufficient level of conservatism  
25 there in the amount of hydrogen and the rate of hydrogen

3-16

1 generation.

2 Q What's the source of Figure 1?

3 BY WITNESS HUCIK:

4 A Figure 1 is the result of an analytical model  
5 calculation of the hydrogen generation rates following  
6 the Reg Guide 1.7.

7 It's basically a computer plot of the  
8 analytical results.

9 JUDGE LINENBERGER: Excuse me, sir, but on  
10 that point, since we're discussing Figure 1, there's a  
11 solid curve and a curve -- or a collection of triangular,  
12 presumably data points.

13 Which representation stands for what? The  
14 solid curve first, what does it....

15 WITNESS HUCIK: That may go back to  
16 Mr. Doherty's question. I actually have another figure  
17 and there was something left off the title, so I'll change  
18 my statement earlier.

19 On the figure that I have, the triangles  
20 denote the wetwell region, which is the containment region,  
21 and the solid line denotes the drywell region.

22 So, yes, there was something left out of the  
23 title there. I'm sorry.

24 JUDGE LINENBERGER: Thank you.

25 //

3\_17  
1 BY MR. DOHERTY:

2 Q On the assumption with regard to the amount  
3 of hydrogen generated from the cladding, do you know,  
4 first of all, if the Reg Guide 1.7 you were using, do  
5 you know if that was one of the revisions?

6 BY WITNESS HUCIK:

7 A The Reg Guide that I have is Revision 2,  
8 dated November 1978, Reg Guide 1.7.

9 Q Does that assume 30 percent?

10 BY WITNESS HUCIK:

11 A Thirty percent for what?

12 Q Thirty percent of the cladding is oxidized?

13 BY WITNESS HUCIK:

14 A This revision tends to mention in terms of  
15 the amount of metal of the cladding surfaces. It doesn't  
16 necessarily state a percentage, as far as I can see.

17 Q It says 30 percent of the metal or what?

18 BY WITNESS HUCIK:

19 A It just says it goes to a certain depth of  
20 the metal.

21 Q Does it give a depth?

22 BY WITNESS HUCIK:

23 A Yes, it gives a depth of .00023 inches.

24 Q Okay. Mr. Weingart, I'm going to ask some  
25 questions from your testimony.

3-15  
1 On the hydrogen monitoring system on page 3,  
2 line 4, is it your understanding that the system sort of --  
3 well, I use the phrase lies in wait.

4 Is it your understanding that this system is  
5 passive until called upon?

6 BY WITNESS WEINGART:

7 A That's correct.

8 Q Is it tested? Do you know anything about  
9 testing of it?

10 BY WITNESS WEINGART:

11 A Yes, it's tested periodically to make sure  
12 that the components are functional from an operation  
13 standpoint.

14 Q Is the system in use in any other plant so  
15 that we might have an idea what the surveillance  
16 requirements are?

17 BY WITNESS WEINGART:

18 A These systems are installed in all the plants  
19 now.

20 Q What are the typical surveillance requirements;  
21 do you know those?

22 BY WITNESS WEINGART:

23 A They are periodically calibrated using a  
24 zero and a span gas.

25 They also energize the pumps that are associated

B-19  
1 with them, the removal system.

2 Q It's the period I'm interested in; do you  
3 know?

4 BY WITNESS WEINGART:

5 A The period, I believe, gets into a tech  
6 spec situation, whatever is required by the tech specs.

7 Q Okay.

8 BY WITNESS WEINGART:

9 A I'm not sure exactly how frequently it is  
10 tested, but it is tested.

11 Q Now, after an accident, you state there will  
12 be automatically provided a record over time.

13 Is this a paper record type of thing?

14 BY WITNESS WEINGART:

15 A Yes, we use recorders in the main control  
16 room.

17 Q Okay. There's a volume percent there which is  
18 an alarm set point, I guess you'd say.

19 Is this arranged so that it will alarm if the  
20 volume reaches three percent at any one place?

21 BY WITNESS WEINGART:

22 A That's correct.

23 Q Okay. How accurately is this device at  
24 hitting three percent?

25 //

3-21  
1 BY WITNESS WEINGART:

2 A Well, the accuracy is about two percent full  
3 scale.

4 Q Okay.

5 JUDGE LINENBERGER: And full scale corresponds  
6 to approximately what?

7 WITNESS WEINGART: Well, if you had zero to  
8 ten percent, it's accurate within two percent of the  
9 total scale.

10 JUDGE LINENBERGER: I understand the  
11 arithmetic, but what is proposed as the full-scale  
12 value for the instrumentation?

13 WITNESS WEINGART: What we are looking at  
14 right now is a dual range monitor. It hasn't fully been  
15 pinned down yet, but what we're looking at is possibly  
16 a zero to ten and a zero to thirty percent range.

17 A lot of the monitors that are going in now  
18 are zero to four percent. We haven't pinned down the  
19 low range yet.

20 JUDGE LINENBERGER: Thank you.

21 BY MR. DOHERTY:

22 Q Is there a sampling station at the top of  
23 the drywell above the reactor pressure vessel?

24 BY WITNESS WEINGART:

25 A Would you repeat that, please?



B-21

1           Q       All right. I wanted to know if one of the  
 2 stations, one of the alarm -- I don't know what you call  
 3 them -- things in the ceiling -- is above the reactor  
 4 pressure vessel in the drywell?

5 BY WITNESS WEINGART:

6           A       There's one in the vicinity of the top of  
 7 the drywell.

8                               - - -

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

4-1  
bm

1 JUDGE LINENBERGER: Mr. Weingart, with respect  
2 to Mr. Doherty's last question and as an aid to understand-  
3 ing your answer, can you perhaps refer to Exhibit 1 as-  
4 sociated with Mr. -- with the Stancavage/Hucik testimony  
5 which shows a line drawing.

6 WITNESS HUCIK: Figure 1.

7 JUDGE LINENBERGER: My Exhibit 1 does not look  
8 like what I see you showing there. Where is that?

9 WITNESS HUCIK: I've got it here.

10 JUDGE LINENBERGER: Well, perhaps the other  
11 figure you had is more appropriate. I'm just wondering  
12 where it occurs.

13 WITNESS WEINGART: The figure that I have was  
14 in Mr. Fields' testimony -- the Staff's testimony on the  
15 same subject. It's a PSAR figure.

16 JUDGE LINENBERGER: Mr. Doherty, please excuse  
17 the interruption, but I think it is important to find out  
18 what these locations are that you're asking about. And  
19 I haven't understood his answer to your question.

20 I want to get out a PSAR figure, and let's see  
21 if it's the same.

22 6.2-1.

23 WITNESS HUCIK: Do you want to borrow mine?

24 JUDGE LINENBERGER: Is it 6.2-1, a PSAR  
25 figure?

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

WITNESS WEINGART: I don't have a number. I just happened to bring the testimony from Mr. Fields along. I don't have the exact PSAR figure number.

(Witness Hucik hands document to Judge Linenberger.)

JUDGE WOLFE: Mr. Copeland, do you have that figure from the PSAR, 6.2-1? We'd like the witness to use that.

MR. COPELAND: I can go get it, Your Honor.

WITNESS HUCIK: You can borrow this one if you like.

MR. COPELAND: Your Honor, if we could take a short break, I think there's a figure in the PSAR that shows the actual location of the monitors, rather than try to mark up something.

JUDGE WOLFE: All right.

WITNESS WEINGART: It is a Chapter 7 figure.

JUDGE WOLFE: All right. We will have a short recess in place.

(Pause.)

MR. COPELAND: Your Honor, I have just distributed a partial copy of Figure 7.5-9(a) from the PSAR.

JUDGE LINENBERGER: Okay. I guess since I caused this hiatus, I should close the loop here. Before

1 I injected myself, Mr. Doherty had asked you, Mr. Weingart,  
2 about the location of -- well, my words would be -- the  
3 location of the uppermost intake station for the hydrogen  
4 monitoring system.

5 I'm not sure that Mr. Doherty phrased it as  
6 the uppermost. But with respect to Figure 7.5-9, can  
7 you say approximately where the uppermost intake station  
8 for the hydrogen monitoring system is located?

9 WITNESS WEINGART: Your Honor, I think he  
10 referenced the drywell specifically, if I'm not mistaken.

11 JUDGE LINENBERGER: He did reference the  
12 drywell?

13 MR. DOHERTY: Yes.

14 JUDGE LINENBERGER: Okay, fine.

15 WITNESS WEINGART: In response to that, you'll  
16 notice that there are three points in the top of the dry-  
17 well, number two, three and four.

18 JUDGE LINENBERGER: Yes.

19 WITNESS WEINGART: Those are three sample  
20 points at the top of the drywell area.

21 JUDGE LINENBERGER: All right. As long as I'm  
22 interrupting, just above the top of the RPV, there is a  
23 horizontal line drawn across the full diameter of the  
24 containment building.

25 Is there a sample point above that horizontal

1 line?

2 WITNESS WEINGART: Yes. Sample Point No. 5.

3 JUDGE LINENBERGER: No. 5. Thank you, sir.

4 I'll get out of this act right now. Sorry  
5 for the interruption, Mr. Doherty, but this, I think, will  
6 be helpful later.

7 BY MR. DOHERTY:

8 Q Now, above the RPV, but below that long hori-  
9 zontal line which goes almost -- it almost measures the --  
10 it looks like it measures the containment shell -- the  
11 diameter.

12 There is a line drawn which kind of resembles  
13 a wicket or a -- it's the only line between the representa-  
14 tion of the metal reactor head and the long horizontal  
15 line, and it is sort of a U-shape -- inverted U-shape.

16 Is that line a barrier to hydrogen or to any  
17 gas moving, or is that penetrated by --

18 BY WITNESS WEINGART:

19 A I'm sorry, I don't understand your question.

20 Q Perhaps I could show the witness the diagram --

21 JUDGE WOLFE: Yes, you may approach the wit-  
22 ness.

23 BY MR. DOHERTY:

24 Q It's Figure 7.5-9(a).  
25 /

4-5

1 BY WITNESS WEINGART:

2 A To the best of my knowledge, that is a solid  
3 area, but it does prevent a barrier.

4 Q Uh-huh.

5 JUDGE LINENBERGER: Mr. Weingart, can you  
6 identify for the record how that structure is designated?  
7 Is there a name for it or something, so that the record is  
8 clear here?

9 WITNESS WEINGART: There is a name for it. I  
10 think it is the drywell head.

11 MR. COPELAND: How about the drywell closure  
12 head?

13 WITNESS WEINGART: Drywell closure head.

14 JUDGE LINENBERGER: Fine, thank you.

15 BY MR. DOHERTY:

16 Q Do you believe that that space above the re-  
17 actor -- directly above the reactor that we've referred  
18 to could be adequately monitored by Stations 2, 3 and 4?

19 BY WITNESS WEINGART:

20 A I believe Station 2 would provide a fair moni-  
21 toring of that.

22 Q Do you believe that the gas located in that  
23 space could not reach four percent -- 4.0 volume percent  
24 before the alarm point of 3.0 volume percent were reached  
25 at Alarm Station 2?

4-6

1 BY WITNESS WEINGART:

2 A I would say that's probably correct.

3 Q What do you base this on, some experience of  
4 yours in this kind of thing or --

5 BY WITNESS WEINGART:

6 A I base this on the thorough mixing that's going  
7 on in that area -- a tremendous amount of convective mixing  
8 and what not. I would anticipate that any hydrogen that  
9 is in there will be thoroughly mixed with the drywell  
10 atmosphere via the purge blowers that are initiated ap-  
11 proximately 30 minutes after the -- one hour after the  
12 accident.

13 Q Do the purge blowers have direct fanning of  
14 this area?

15 BY WITNESS WEINGART:

16 A We are presently evaluating this particular  
17 item. The purge blowers in the present design discharge  
18 directly into the drywell from the containment.

19 There are several plants which take a bypass  
20 line up into this area, and we are in the -- or will be  
21 evaluating this during the FSAR phase to see that -- if we  
22 have a problem in this area.

23 If we do find that we have a stagnant area,  
24 we will modify our dischargers on our purge blowers. That  
25 is one option for correcting the problem.

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

4-7  
1 Q Okay. On page 4 you talk about the mixing  
2 subsystem. How many of these subsystems are there? Just  
3 one?

4 BY WITNESS WEINGART:

5 A No, there is a redundant system. There are  
6 two blowers.

7 Q You said, "The mixing subsystem capacity" --  
8 at Line 13 -- "is 500 cubic feet per minute for each ...  
9 system."

10 Does that mean that it can draw 500 cubic feet  
11 through itself, or what --

12 BY WITNESS WEINGART:

13 A Yes, it draws 500 cubic feet per minute from  
14 the containment and pressurizes the drywell at that rate.  
15 If you'll recall my last testimony, I described the  
16 system, which basically pressurizes the drywell to a high  
17 enough pressure to uncover the suppression pool vents  
18 and thus allow the drywell atmosphere to bubble through  
19 the suppression pool into the containment.

20 Q How long would it take for this pressure to  
21 build up, using this blower system, roughly?

22 BY WITNESS WEINGART:

23 A I don't have an exact number on that. If  
24 you'll refer to -- here we go again with figures --  
25 Figure 6.2-29 of the PSAR, it indicates that the containment



1 concentration starts to increase within the first few  
2 hours after the purge blowers are turned on, and the dry-  
3 well decreases in an associated amount.

4 So I would say you're talking in hours before  
5 you start to uncover the vents. That's my own opinion on  
6 this.

7 Q Are you the person from Ebasco who has to see  
8 that this is done, that these blowers and so forth can  
9 meet some kind of time criteria?

10 BY WITNESS WEINGART:

11 A The criteria for the blowers is set by, I  
12 believe, General Electric. It's a standard criteria -- 500  
13 cfm.

14 I do not directly procure the blowers, or  
15 specify the blowers.

16 Q Okay. Looking at Page 5, in previous -- well,  
17 in your testimony you mention at Line 14, " ... such as  
18 the recombiners manufactured by Westinghouse ...."

19 Do you know if the Westinghouse units are to be  
20 used?

21 BY WITNESS WEINGART:

22 A We have not purchased them yet, but that's the  
23 manufacturer from whom we intend to procure.

24 Q Is the one from whom you intend -- is that  
25 what you said?

4-9

1 BY WITNESS WEINGART:

2 A. Yes.

3 Q. Now you mention there power supply. Do you  
4 know the source of that power? Will that be off-site, or  
5 do you know anything about that?

6 MR. COPELAND: Object to the relevance of that,  
7 Your Honor.

8 MR. DOHERTY: Okay, I'll try again in a dif-  
9 ferent way.

10 - - -

4-10 1 BY MR. DOHERTY:

2 Q Will there be a way for the control room to  
3 know that there is power available to operate the re-  
4 combiners?

5 BY WITNESS WEINGART:

6 A Yes, there will be readouts in the control  
7 room.

8 Q When you say readouts, that will be a sort of  
9 system saying "Power adequate"?

10 BY WITNESS WEINGART:

11 A Well, you'll have temperature readouts on the  
12 unit. If the temperature is where it's supposed to be,  
13 then you know you have power to it.

14 Q Yes. But if you're not using it, will you know  
15 that it's available anyway?

16 BY WITNESS WEINGART:

17 A I'm not sure I understand your question.

18 Q Well, you know any electric appliance that  
19 doesn't have a pilot light or something, you assume will  
20 work, and then ever so often when it doesn't work, you  
21 don't know it until you try it.

22 BY WITNESS WEINGART:

23 A The recombiners are on emergency power supplies,  
24 both are diesels.

25 Q There will be two recombiners?

1 BY WITNESS WEINGART:

2 A That's correct.

3 Q Okay. At Page 6, you state that the unit is  
4 completely enclosed and the internals are protected from  
5 impingement by containment spray.

6 It's a small point, but the containment spray  
7 does no protecting, does it?

8 BY WITNESS WEINGART:

9 A Would you repeat that?

10 Q The containment spray itself isn't protecting  
11 this at all? In other words, the -- It almost reads  
12 "from impingement by containment spray." Is the contain-  
13 ment spray protected from impingement?

14 That's not what you mean?

15 BY WITNESS WEINGART:

16 A No, what I mean -- I don't want to put words  
17 in your mouth, but what I mean is when the containment  
18 spray is spraying in that area, it will not affect the  
19 operation of the recombiner by impinging on the recom-  
20 biner.

21 Q Well, is this recombiner -- it's a method of  
22 heating hydrogen. But is its covering itself extremely  
23 hot, to your knowledge?

24 BY WITNESS WEINGART:

25 A No, it's a steel --

4-12

1 Q Casing?

2 BY WITNESS WEINGART:

3 A Casing, yes.

4 Q So when the containment spray hits it, you  
5 don't see any problem with that?

6 BY WITNESS WEINGART:

7 A No.

8 Q -- spiriting up a reaction or anything.

9 Okay.

10 Do you still have Figure 6.2-29 there? Do you  
11 still have it out?

12 (No response.)

13 Now, do those tests -- Does that figure  
14 report the use of that system in a containment such as --  
15 the size of ACNGS?

16 BY WITNESS WEINGART:

17 A These curves are based on the containment --  
18 of a Mark III containment of the nature of Allens Creek.

19 Q And the size of Allens Creek?

20 BY WITNESS WEINGART:

21 A Yes.

22 Q Okay. Now, I note here that the containment  
23 hydrogen purge subsystem is a backup system; is that a  
24 fair --

25 /

4-13

1 BY WITNESS WEINGART:

2 A That's correct.

3 Q And if ever required, it would need this  
4 space between the shield building and the shell, right?

5 BY WITNESS WEINGART:

6 A The annulus.

7 Q Okay. Just what is the design pressure for  
8 that "hold-up" space?

9 BY WITNESS WEINGART:

10 A I'm not sure off the top of my head.

11 Q Okay.

12 MR. DOHERTY: I have no further questions.  
13 Thank you very much.

14 JUDGE WOLFE: Re-direct, Mr. Copeland?

15 MR. COPELAND: No, sir.

16 JUDGE WOLFE: Board questions?

17 JUDGE CHEATUM: I have no questions.

18 BOARD EXAMINATION

19 BY JUDGE LINENBERGER:

20 Q Gentlemen, is the hydrogen recombiner system  
21 of the Westinghouse type that you have been discussing  
22 intended to cope with hydrogen build-up subsequent to a  
23 core degradation accident?

24 BY WITNESS WEINGART:

25 A No, it is not.

1           Q       The TexPirg contention that presumably  
2 prompted this testimony talks almost exclusively about  
3 detecting hydrogen explosions and about the potential  
4 danger of hydrogen explosions.

5                   Now, I note that you gentlemen have not  
6 discussed hydrogen explosions at all. I put the following  
7 question, which either one of you may answer: Why is it  
8 that your testimonies do not go to the subject of hydrogen  
9 explosion?

10 BY WITNESS WEINGART:

11           A       The purpose of the systems is preventative  
12 in nature. In other words, we put the hydrogen analyzers  
13 in to detect the levels. We put the recombiners in and  
14 the purge systems to remove the hydrogen to prevent ex-  
15 plosions. We don't want explosions. We want to prevent  
16 them from happening by use of this equipment.

17                   That is the intent.

18           Q       Mr. Hucik, do you have anything to add to that?

19 BY WITNESS HUCIK:

20           A       No.

21           Q       All right, sir. That leaves a gap in my under-  
22 standing. You speak of this system as one designed to  
23 prevent a hydrogen explosion. My understanding of --  
24 perhaps faulty -- the nature of these Westinghouse re-  
25 combiners is such that I would be inclined to conclude that

4-15 1 if there were a core degradation event, let's say -- a  
2 power plant event leading to core degradation and as-  
3 sociated therewith interaction of fuel cladding with  
4 steam, that none of the systems you've talked about today  
5 would indeed prevent reaching an explosive condition.

6 So therein lies the hole. You've said these  
7 are to prevent explosion, and I think I see a regime of  
8 accident conditions where it would not so prevent.

9 Would you comment, please?

10 BY WITNESS WEINGART:

11 A These systems are designed based on the re-  
12 quirements of Regulatory Guide 1.7 and 10 CFR 50.44. The  
13 Staff of the NRC is presently in a rulemaking on what --  
14 on the degraded core situation.

15 HL&P has discussed in previous testimony what  
16 we call the post-accident inerting system, which is a  
17 design to handle the degraded core situation.

18 Q Therefore, it is not strictly correct to  
19 characterize the system that today's testimony is talking  
20 about as being one whose purpose is to prevent hydrogen  
21 explosions under all accident conditions; is that correct?

22 BY WITNESS WEINGART:

23 A That's correct.

24 The system we are talking about is based on  
25 the -- as I said before, the Reg Guide 1.7 requirements.



4-16 1 Q With respect to the recombiner, is there --  
2 given the temperature at which they're intended to  
3 operate -- and I don't remember whether you've mentioned  
4 that temperature or not -- but given the proposed operat-  
5 ing temperature for the recombiners, is there a minimum  
6 level of hydrogen concentration for which they do not  
7 work?

8 BY WITNESS WEINGART:

9 A They are designed to operate at -- initiating  
10 at about 3 1/2 percent. The lower the concentration of  
11 hydrogen, the less efficient they will be, as is any re-  
12 combiner.

13 Q Is it just that the efficiency slowly falls  
14 off, or is there a threshold concentration at which they  
15 start to work for the operating temperature proposed?

16 BY WITNESS WEINGART:

17 A Regarding these recombiners, I don't really  
18 know what the threshold is.

19 Q Well, do you know whether there is a threshold,  
20 even though you don't know where it is?

21 BY WITNESS WEINGART:

22 A Theoretically, if you heat oxygen and hydrogen  
23 up to 1150 degrees, you get complete recombination.

24 Q Even though the starting concentration of  
25 hydrogen were only one-hundredth of one percent?

4-17

1 BY WITNESS WEINGART:

2 A I said theoretically. I really don't know.

3 Q Okay, fine. Let's not dwell on that.

4 Your testimony indicated that there are two  
5 recombiners, and you gave elevations for them. The ele-  
6 vation of the upper one, I believe you gave as 232  
7 feet approximately.

8 BY WITNESS WEINGART:

9 A That's correct.

10 Q If I look at PSAR Figure 7.5-9 and compare it  
11 with PSAR Figure 1.2-8, I learn that Elevation 232 feet  
12 occurs very closely at the horizontal line shown on Figure  
13 7.5-9 located just above the drywell closure head.

14 Now, does that represent a level at which the  
15 upper recombiner is supported or mounted?

16 BY WITNESS WEINGART:

17 A I don't have the other figure that you're  
18 referring to.

19 I would --

20 Q Well, what is your understanding as to where  
21 the upper recombiner is located relative to Figure 7.5-9?

22 BY WITNESS WEINGART:

23 A It's up in the area that's broadly called  
24 the -- where it's indicated as RWCU pump area. It's up  
25 in that area.

4-18

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

They both are up in that area.

Q They both are?

BY WITNESS WEINGART:

A Yes.

Q Well, all right. I have -- excuse me, I'm not trying to nit-pick here, but your testimony at Page 5 gives the lower one at an elevation of 207 feet. And I have a PSAR Figure 1.2-8 that places 207 feet considerably below that RWCU pump area.

Now, is there -- Am I missing something, or has there been a change?

BY WITNESS WEINGART:

A I don't think you're missing anything. I think this drawing may be somewhat misleading. I don't have your other drawing, but they're both in the containment area.

The 207, I believe, is the operating deck of the containment, and the 232 is the elevation -- one elevation above the operating deck.

- - -

5-1  
ged  
1 BY JUDGE LINENBERGER:

2 Q Again, with respect to Figure 7.5-9, do all  
3 of those circled Arabic numbers represent sampling points?

4 BY WITNESS WEINGART:

5 A That's correct.

6 Q I want to just hold up for your glimpse at  
7 that distance Figure 1.2-8 of the PSAR just for the sake  
8 of illustrating that it shows tremendous structural  
9 complexities within the volume we're talking about and  
10 location of many items of equipment; and when I compare  
11 that with Figure 7.5-9, I get two differing feelings  
12 about how well hydrogen is going to mix or not mix.

13 Now, I think I've heard in discussions with  
14 Mr. Doherty an aspect of the situation that did not come  
15 through in the prefiled testimony; namely, in discussions  
16 with Mr. Doherty there was a discussion of purge blowers  
17 for the purpose of mixing or circulating hydrogen.

18 The impression I got from the testimony that  
19 was prefiled is that the problem is solved.

20 The impression I got from the purge blower  
21 discussion is the problem is still being looked at and  
22 it is yet to be determined whether there may be a problem  
23 in adequate mixing.

24 Now, have I misinterpreted? I don't want to  
25 put words in your mouth, but I get two different feelings

5-2 1 from what I've heard and what I've read.

2 BY WITNESS WEINGART:

3 A Let me try to clarify it.

4 Q All right, sir.

5 BY WITNESS WEINGART:

6 A The purge blowers are -- they are really not --  
7 they are for dilution of the hydrogen and transfer into  
8 the containment.

9 The specific area that was brought up as  
10 questionable is an area that is subject to some discussion  
11 or some additional consideration.

12 The sample points, the purge blower discharges  
13 as they are right now are based on GE standard plan, the  
14 locations and everything else.

15 We intend during the FSAR stage to fully  
16 evaluate the sample point locations, to fully evaluate  
17 the air flow patterns in the drywell, and if we find  
18 a particular spot that we have a problem with, we will  
19 take corrective action to rectify the problem.

20 The key here is that this work will be done  
21 during the operating license stage. It's something that  
22 we have to see the final product to fully evaluate all  
23 the sample point locations and do the air flow analyses  
24 that have to be done to determine whether or not we need  
25 a sample point in a given spot.

5-3  
1 Q All right. For just a moment, back to the  
2 subject of the two recombiners, will they -- is it  
3 intended that they both -- that operation of both of them  
4 be initiated simultaneously, or that they both function  
5 reasonably simultaneously, or is one a backup to the  
6 other?

7 BY WITNESS WEINGART:

8 A One is a backup to the other.

9 Q How is it decided which is the one that's  
10 the backup and which is the one that the button is pushed  
11 on in turn, since they are at two different elevations;  
12 or is this something yet to be determined?

13 BY WITNESS WEINGART:

14 A I would say that it's something to be  
15 determined. In my own mind, I don't think it really  
16 matters which one you turn on. Operator discretion.

17 Q Did I understand correctly -- let me check  
18 something -- that several hours are required for the  
19 recombiners to come to temperature, three hours warmup  
20 time?

21 BY WITNESS WEINGART:

22 A That's correct.

23 Q Well, I don't know what your analyses are  
24 going to show down the road a ways, but is the length of  
25 this warmup time something that can be, say, cut in half

5-4  
1 by just putting more electrical power to the recombiner,  
2 to bring them up to temperature faster, or is this --

3 BY WITNESS WEINGART:

4 A. No, I don't think that would do that, because  
5 the three hours is the length of time the manufacturer  
6 recommends.

7 You do have plenty of time to turn these  
8 recombiners on. You are not talking of a matter of hours  
9 or minutes until they are needed. You are talking days.

10 Q. For the non-degraded core --

11 BY WITNESS WEINGART:

12 A. Non-degraded core situation.

13 Q. -- situation.

14 JUDGE LINENBERGER: Thank you. That's all  
15 I have, Judge Wolfe.

16 JUDGE WOLFE: Cross on Board questions,  
17 Mr. Dewey?

18 MR. DEWEY: No, sir.

19 JUDGE WOLFE: Mr. Doherty?

20 RE-CROSS-EXAMINATION

21 BY MR. DOHERTY:

22 Q. I know the recombiner locations are not nailed  
23 down tight, but I'm wondering what it is in your judgment  
24 that makes you think it can be left to operator judgment  
25 which one to turn on, since there is the height difference

5-5 1 and that height isn't just height alone. There's also  
2 difference in objects.

3 BY WITNESS WEINGART:

4 A Mr. Doherty, the recombiners, the locations  
5 are really independent of how effective they are going to  
6 operate.

7 There's total -- there's a mixing condition  
8 in there and convective mixing and various thermal  
9 gradients are going to move that hydrogen around -- that  
10 air around in the containment.

11 In addition, the recombiners, due to the  
12 heat that the heaters generate within themselves, also  
13 fosters air movement.

14 So I don't see where there's any problem at  
15 all whether you turn on the one at the lower elevation or  
16 the one at the elevation above. They'll both function  
17 adequately.

18 Q So then what you are saying is that even  
19 though there may be barriers, these convective abilities  
20 will still be sufficient such that that large open area  
21 at the top above the horizontal line that we've talked  
22 about so much would still be reachable by one of the lower  
23 recombiners?

24 BY WITNESS WEINGART:

25 A Well, your area where the recombiners are



5-6

1 located themselves is up in that free area.

2 Q Well, isn't one not, though?

3 BY WITNESS HUCIK:

4 A Maybe I can try and clarify something here.

5 The Figure 1.2-8 that the Judge here mentioned, if I'm  
6 not mistaken, that picture may look fairly cluttered due  
7 to the fact that you are looking through one cut through  
8 the containment and they have, I believe, rotated a lot  
9 of the equipment into this view to look at it.

10 So if you were to really look at a 360-degree  
11 range of the containment, it would not be as cluttered as  
12 this drawing tends to show you; but there's a lot of  
13 equipment in there.

14 The elevation change here is not that critical,  
15 as he is saying, though.

16 - - -

17  
18  
19  
20  
21  
22  
23  
24  
25

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

6-1

bm

1 BY MR. DOHERTY:

2 Q Well, is there a solid 360-degree barrier  
3 above the drywell as a drywell top, sort of? Just from  
4 the drywell walls inward?

5 BY WITNESS WEINGART:

6 A No.

7 BY WITNESS HUCIK:

8 A No. That imaginary line on that PSAR Figure  
9 7.5-9(a) --

10 Q All right, we don't understand each other  
11 because that line is not what I'm referring to. There  
12 is a -- If you look at Figure 1.2-8, there is a drawing --  
13 There's drywell walls in there. It's apparently walls  
14 moving toward the center line, just one -- at the same  
15 elevation.

16 A It's -- It appears solid. Is that what  
17 you're saying is not solid, that -- It also appears on  
18 Figure 7.5-9(a) directly above the number four?

19 BY WITNESS HUCIK:

20 A Those are the drywell ceiling, and those are  
21 indeed solid.

22 Q Those are solid.

23 BY WITNESS HUCIK:

24 A It's the one up above that is not solid.

25 Q Yes. All right.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

MR. DOHERTY: Thank you.

JUDGE WOLFE: Redirect, Mr. Copeland?

MR. COPELAND: I'm afraid I didn't understand anything that just occurred. I have no redirect.

JUDGE WOLFE: Mr. Weingart is to be permanently excused?

MR. COPELAND: Yes, sir.

JUDGE WOLFE: All right. You're permanently excused, Mr. Weingart.

(Witness Weingart was excused.)

JUDGE WOLFE: We will recess until 1:30.

(Whereupon, at 12:15 p.m. the hearing was recessed, to reconvene at 1:30 p.m. of the same day.)

- - -

AFTERNOON SESSION

1:30 p.m.

1  
2  
3 JUDGE WOLFE: All right.

4 MR. COPELAND: Your Honor, over the lunch  
5 period we checked once again on the location of these  
6 hydrogen recombiners. And I would like to represent to  
7 the Board that Judge Linenberger was correct in his reading  
8 of the elevations.

9 And Mr. Weingart has checked the figures  
10 again, and you were correct in your determination that the  
11 elevations which show the recombiner to be outside of the  
12 RWCU area as shown on Figure 7.5-9(a).

13 That figure is just not very representative  
14 of what actually is in there.

15 At this time, Your Honor, we would like to  
16 move on to Mr. Hucik's testimony on SRV reliability.  
17 That testimony was previously incorporated into the  
18 record following Page 16,146 of the transcript on  
19 August 26, 1981.

20 Whereupon,

21 STEVEN A. HUCIK

22 resumed the stand as a witness and, having been previously  
23 duly sworn, was examined and testified further as follows:

24 MR. COPELAND: I will now ask Mr. Hucik if he  
25 has a copy of his testimony in front of him.

7-2 1 THE WITNESS: Yes, I do.

2 DIRECT EXAMINATION

3 BY MR. COPELAND:

4 Q Do you have any corrections you would like to  
5 make at this time, Mr. Hucik?

6 A No, I do not.

7 Q Are the answers provided therein by you true  
8 and correct to the best of your knowledge and belief?

9 A Yes, they are.

10 Q Do you now adopt those answers as your testi-  
11 mony in this proceeding?

12 A Yes, I do.

13 MR. COPELAND: I would move for the admission  
14 of his testimony now, Your Honor.

15 JUDGE WOLFE: It is my recollection that his  
16 testimony was incorporated in the record, subject to voir  
17 dire if necessary, and subject to a motion to strike, if  
18 any.

19 So it has already been incorporated, subject  
20 to the condition of voir dire or motion to strike. Do you  
21 have any voir dire?

22 MR. SOHINKI: No, sir.

23 JUDGE WOLFE: Mr. Doherty?

24 MR. DOHERTY: No, Your Honor, I have no voir  
25 dire.

JUDGE WOLFE: All right.

BY MR. COPELAND:

Q Mr. Hucik, as Judge Wolfe noted earlier this morning, you were not able to be here as originally scheduled because you were in Taiwan; is that correct?

A That is correct.

Q Could you explain what you were doing in Taiwan?

A Actually, the purpose of my trip to Taiwan was to monitor some safety/relief valve testing being done at the Kuosheng Nuclear Plant in Taiwan with the first Mark III containment system actually in operation down there.

The same valves, the same quencher system that's being used on Allens Creek was actually tested in the Kuosheng Plant, and that's what I was there for.

Q Did the results of those tests confirm the answers that you have provided in your testimony?

A Yes, it confirmed it.

MR. COPELAND: Thank you. I now tender the witness for cross-examination.

JUDGE WOLFE: Unless my recollection of the record is wrong and Mr. Hucik's testimony on Doherty Contention 17 was not incorporated into the record as if read, it is now incorporated into the record as if read.

7-4

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

All right. Cross?

MR. SOHINKI: No, sir, we have no questions.

JUDGE WOLFE: Mr. Doherty.

CROSS-EXAMINATION

BY MR. DOHERTY:

Q As your testimony now stands, the statements on -- that the Kuosheng SRV's were actually tested. What tests were these relief valves subjected to, please?

A Okay. During the normal start-up process of a reactor system, they cycle the valves to make sure the systems work correctly, the valves open fully and they also measure the flow rate through the valves.

In addition to the normal start-up testing that was performed in Kuosheng, the plant actually ran about a series of 43 different tests to measure pool boundary loads, accelerations, pool temperature transients and heat up due to extended discharges of the valves, so there was really a containment-loads type test.

Like I say, there were about 43 different tests that included a single valve going off, two valves going off simultaneously and up to four valves going off simultaneously.

Q Were these tests done at full power?

A These tests were done at about 50 to 60 percent power; the reactor pressure was almost at full pressure.

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

7-5

1 Q What would be full pressure at that unit?

2 Would it be --

3 A Reactor pressure was at about -- it varied  
4 between nine -- about approximately 970 psi to about 980  
5 psi with around 1000 to 1040 being full pressure operated.

6 Those valves have also been actuated at full  
7 power/full pressure. The plant is currently operating at  
8 full power, 100 percent power right now.

9 Q So -- Well, you say they have been actuated  
10 at full power. But that was not a test or --

11 A Yes, it was a test. They recently ran a test  
12 where they closed all the main steam isolation valves  
13 and monitored the transient reactor pressure rise and the  
14 number of valves that actuated, and they measured boundary  
15 pressures and accelerations during that test.

16 Q Were you present for that?

17 A I was not present for that.

18 Q I see.

19 A That was just recently run.

20 Q Uh-huh.

21 A The data, by the way, is no different than the  
22 original data that we obtained during the initial testing  
23 back in August.

24 Q That's August 1981?

25 A Yes.



7-6

1 JUDGE LINENBERGER: By the way, Mr. Hucik,  
2 prior testimony has a discrepancy in the spelling of  
3 that facility. What is the correct spelling?

4 THE WITNESS: The correct spelling is  
5 capital K-u-o-s-h-e-n-g.

6 JUDGE LINENBERGER: Thank you.

7 BY MR. DOHERTY:

8 Q Well, in your testimony -- and I'm starting  
9 on Page 5 of that testimony submitted back in July, I  
10 guess -- yes, July 20th.

11 You state that the quencher-- this is at Line  
12 16 -- are attached to the end of the safety/relief valve  
13 discharge piping.

14 Now, does that piping run straight from the  
15 safety/relief valve to the quencher? Is it one straight  
16 piece of pipe, or does it curve?

17 A It has got curves and bends in it as it goes,  
18 you know, from the valve itself down through the drywell  
19 and then over to the containment pool.

20 Q But you state here that the quencher are  
21 uniformly distributed in the suppression pool. By that  
22 do you mean they are distributed equidistant in the  
23 pool?

24 A Yes, I believe they're in a -- you know, a 360-  
25 degree arc. They are distributed uniformly around that

1 360-degree arc.

2 Q So there's the same arc between each one?

3 A Yes. The same distance from the drywell and  
4 wetwell walls, the same distance from the pool floor.

5 Q Okay.

6 MR. DOHERTY: May I approach the witness, Your  
7 Honor?

8 JUDGE WOLFE: Yes.

9 BY MR. DOHERTY:

10 Q Mr. Hucik, did I show you Figure 2.2-1 from  
11 the Containment Structures Design Report of December 2nd,  
12 1979, Revision 2 of Ebasco Services, which has a figure  
13 marked the PSAR and Figure 2.2-1 just now?

14 A Yes.

15 Q Now, do each of these sort of four-pointed  
16 stars represent a quencher?

17 A Yes, they do.

18 Q Now, if we count from the top -- imagine this  
19 is a clock for a minute -- if we count down to seven and  
20 then to the eighth and then to the ninth, would you say  
21 that the distance between the seventh and the eighth  
22 quencher is equal to the distance between the eighth and  
23 the ninth quencher?

24 A No, there is some difference.

25 Q Can you explain why the difference occurs?

7-8

1 A. That may be an arrangement where they're trying  
2 to fit the quencher. There may be other equipment or  
3 something in the pool at that region. That is basically,  
4 though, a very good uniform distribution implied by this  
5 drawing.

6 There are some minimum specs as far as dis-  
7 tance between quenchers that have been -- it looks like --  
8 accomplished with this arrangement. But that's more than  
9 adequate.

10 Q Well, wasn't your testimony earlier that they  
11 were equidistant apart?

12 A The testimony is really -- it says they are  
13 uniformly distributed in the pool, not necessarily equi-  
14 distant. But that's a very good uniform distribution of  
15 the quenchers.

16 That's only a slight difference.

17 Q All right. I'm going back to my table a  
18 minute. You can keep that there.

19 I want you to look at the figure a little  
20 longer. I know you're fairly familiar with this kind of  
21 thing.

22 Do you see any other places, other than that  
23 one I pointed out, where the quenchers are not the same  
24 distance apart?

25 MR. COPELAND: Well, Your Honor, I don't

1 understand what the relevance is of any further questions  
2 along that line. This witness has explained, in looking  
3 at it, that he thinks the distribution is uniform, as he  
4 has described it, and that there are minimum specifi-  
5 cations set on the distances between these.

6 And it seems to me that he has answered the  
7 question and provided as much information as could reason-  
8 ably be necessary.

9 MR. DOHERTY: I don't think he has answered  
10 this question. I'm trying to clarify the figure to some  
11 extent. I could supply the figure --

12 JUDGE WOLFE: Trying to what, please?

13 MR. DOHERTY: Trying to clarify the figure at  
14 this point.

15 JUDGE WOLFE: What figure?

16 MR. DOHERTY: Figure 2.2-1.

17 JUDGE WOLFE: Clarify it in what respect?

18 MR. DOHERTY: In what this term, "uniformly  
19 distributed" means.

20 JUDGE WOLFE: I thought the witness had al-  
21 ready indicated what he meant in his testimony by that.

22 MR. DOHERTY: I didn't believe that he had.  
23 He just said that was uniform distribution. He didn't  
24 say what the distribution was or -- We haven't  
25 established any more on the record about that.

7-10

1 He has said it's a good arrangement, I believe,  
2 and that's all.

3 MR. COPELAND: That's exactly the point. He  
4 has said that the arrangement that Mr. Doherty has  
5 shown him is a satisfactory, uniform distribution of those  
6 valves.

7 So what good does it do to nit-pick over  
8 whether one is a little bit more than another, in terms  
9 of distance between any two of them?

10 JUDGE WOLFE: I think if you're going to  
11 press in on the, quote, "uniform distribution" language,  
12 that before you go any farther, you ought to get that  
13 clarified.

14 It may not be necessary, once you get the wit-  
15 ness' meaning of the term, "uniform distribution," to go  
16 into whether there are any other quenchers that are  
17 farther distant from one another than Quenchers 1 through  
18 9 or whatever.

19 All right. I'll overrule the objection at  
20 this point. You may inquire of the witness as to his  
21 meaning of "uniform distribution."

22 MR. DOHERTY: Okay.

23 BY MR. DOHERTY:

24 Q What does that phrase, "uniform distribution,"  
25 mean then, since we've discovered that it doesn't mean

7-11  
1 purely equidistant by arc around there?

2 A Basically, if you look at all -- I believe  
3 there's what? 19 quencher here. They are situated very  
4 uniformly -- in other words, there are only two locations  
5 in the total arrangement where there is a difference in  
6 position relative to the two different quencher.

7 Those two locations are, in fact, 180 degrees  
8 apart, it looks like, so that's a uniform distribution of  
9 this total nonuniformity. So there is some uniformity  
10 there.

11 And, basically, you have a very excellent  
12 spacing of all the quencher along the -- you know, peri-  
13 meter of this drywell wall. So you want a very good ar-  
14 rangement to space them out. You want to meet the minimum  
15 requirements set down by GE specs that there be a certain  
16 distance between each quencher.

17 And that has been attained. And, therefore,  
18 with the number of quencher and the distance they've  
19 got, they've got a very good and uniform distribution of  
20 the energy into the pool.

21 Q Well, what is satisfactory in arranging  
22 these?

23 A "Satisfactory" would be that it meets the  
24 minimum requirements of the specifications that say you  
25 must have quencher separated by a certain distance,

7-12  
1 separated by the drywell wall at a certain distance, and  
2 those have all been met, plus an adequate distribution of  
3 those quenchers around the total circumference of the  
4 pool.

5 Q I gather then the specifications don't set  
6 that the quenchers be in the pool equidistance by arc,  
7 but rather just set a minimum distance; and it's up to the  
8 applicants to --

9 A That is correct.

10 Q -- to work those out.

11 Do you know for a fact that the minimum dis-  
12 tances are met for the Allens Creek plant?

13 A Based on this drawing, I can't tell at this  
14 point. There's actually not enough information on this  
15 drawing to be able to tell.

16 Q Yes, I was --

17 A But it looks in general like they are. I might  
18 add that many of the Mark III containments has a similar  
19 discontinuity.

20 JUDGE LINENBERGER: Mr. Doherty, I've got a  
21 little problem here. The record to this point, so far as  
22 I know, doesn't establish what it is that a quencher  
23 does.

24 And since the contention goes to the reliability  
25 of safety/relief valves, then the record further does not

7-13  
1 establish how distribution of quenchers, whose function we  
2 don't have in the record, is relevant to the reliability  
3 of safety/relief valves.

4 Now, maybe this doesn't bother you; but if  
5 the record stays this way, it's going to bother the  
6 Board.

7 MR. DOHERTY: Well, the contention, if I may  
8 read it -- although it has been called a reliability  
9 contention -- does have, essentially, a part which talks  
10 about loads.

11 And that's why this has come up at all and  
12 come up as 17, rather than as 5, which we talked about  
13 earlier and which was exclusively loads.

14 There is a part -- I'm trying to locate it  
15 now -- of Contention 17 that does talk about the loading.  
16 It isn't meant in the sense that the valve won't open.  
17 It's just poor contention writing, I guess you would  
18 say.

19 I don't have a copy of Contention 17 with  
20 me.

21 JUDGE LINENBERGER: Well, the Board does  
22 and had that in mind in our comment. And I guess I have  
23 to repeat myself that absent a determination that quencher  
24 distribution in function and location -- excuse me --  
25 the existence of quenchers with respect to function and



7-14 ✓  
1 location has not been established.

2 The relevance of your line of questioning is  
3 hard to comprehend.

4 MR. DOHERTY: May I ask the Board's permission  
5 to see the contention? I don't have a copy with me.  
6 We started on this three months ago, and it just hasn't  
7 stuck with me.

8 (Pause.)  
9 - - -  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

B-1  
ged

1 MR. DOHERTY: All right. Thank you.

2 BY MR. DOHERTY:

3 Q Well, why is it necessary to set minimums  
4 in the spacing of these?

5 A You are trying to prevent basically two  
6 things. Number one, you are trying to get an even  
7 distribution of the air bubbles that come out of the  
8 quencher arms so that they don't interact with each  
9 other if you have adjacent quenchers going off, and you  
10 are also trying to get a uniform spacing of the energy  
11 of the steam condensing mode of the quenchers.

12 Q Why are you trying to get a uniform distribution  
13 of the energy?

14 A The main purpose of that is to try to get more  
15 of the energy distributed into the pool region.

16 Q Well, what value would it be to have the  
17 energy distributed around the pool?

18 A To take advantage of more pool volume  
19 initially.

20 Q What advantage does more pool volume give  
21 you?

22 A It's able to keep the pool temperature cooler.

23 Q Would it also assist in distributing the force  
24 of the blowdown?

25 A Yes, that is also very true.

8-2 1 Q Is it possible to put these so close together  
2 that the force from the blowdown might damage the pool,  
3 following a poor construction practice?

4 MR. COPELAND: I object to that, Your Honor.  
5 I object to that question because it calls for  
6 speculation that bears no relationship to the facts in  
7 this case.

8 The witness has testified that they are  
9 indeed uniform in space. There's nothing to indicate that  
10 anybody is going to group them together any differently.

11 MR. DOHERTY: But he did not testify when I  
12 asked him if these were sufficiently far apart. I asked  
13 him if they were; he said he couldn't tell from the  
14 drawing.

15 So I think I have a right to ask him if  
16 indeed they are not spaced sufficiently far apart, if  
17 indeed they are not sufficiently placed far apart, what  
18 the hazard might be.

19 JUDGE LINENBERGER: Well, sir, in essence your  
20 most recent question could be interpreted to ask is there  
21 a way to redesign this system such that it could damage  
22 certain structures operating in a redesigned mode, and  
23 the problem the Board has here is it's not the obligation  
24 or the objective of the vendor to redesign things so that  
25 they will be destructive.

8-3 1 He has tried to design them in a way so that  
2 they won't cause a problem, and you are asking could he  
3 design it in a way that would cause a problem; and that  
4 seems to be a -- that's a question I have a hard time  
5 granting your prerogative to ask in this kind of  
6 proceeding.

7 You know, you can design a gun so that it  
8 will blow up before it will fire a bullet, but nobody  
9 tries to do that. So I'm curious how your question has  
10 meaning: Could it be designed so that it wouldn't work  
11 right.

12 As an aside here, I'll say if you'd let me  
13 design it, I'll guarantee you it won't work right, but  
14 that's not my business.

15 MR. DOHERTY: I have answered the objection.

16 JUDGE WOLFE: Sustained.

17 BY MR. DOHERTY:

18 Q Didn't you state a moment ago that you weren't  
19 certain if these quenchers were designed far enough apart  
20 to meet General Electric specifications?

21 A That's just based on the minimum amount of  
22 information that's contained on this drawing. Just from  
23 my judgment in looking at it, they look more than adequate.

24 You try and scale this drawing and look at  
25 some of the dimensions that are involved on that; it looks

3-4 1 more than adequate.

2 Q Can you tell for certain?

3 A Not specifically from this figure.

4 Q All right. What would happen in terms of  
5 loading if the GE tech specs or the GE specifications were  
6 not met?

7 MR. COPELAND: Your Honor, I'm going to object  
8 to that.

9 It seems to me that Mr. Doherty for some reason  
10 or other has gotten way off the point of the contention.

11 The point of the contention is the reliability  
12 of the safety/relief valves, not the location of those  
13 valves in the suppression pool, and how they -- how some  
14 error in location of those valves would affect the loads  
15 following a blowdown.

16 I guess it also goes back to Judge Linenberger's  
17 point, that quencher are nowhere mentioned in the  
18 contention.

19 MR. DOHERTY: I don't think there's any need  
20 to label the various components by name, such as quencher.  
21 Indeed, it isn't even certain that in 1979 there was such  
22 a thing as a quencher involved in the plant.

23 I think we're within the bounds of the  
24 contention to ask the question.

25 JUDGE WOLFE: May we have the question re-read,

8-5

1 please?

2 (Question read by reporter as follows:

3 "What would happen in terms of loading if  
4 the GE tech specs or the GE specifications were not met?"

5 (Bench conference:

6 JUDGE WOLFE: Sustain the objection. The  
7 question calls for speculation and is exceedingly vague,  
8 in the second place.

9 MR. DOHERTY: Your Honor, I move we strike  
10 the testimony beginning on page 6, line 17, and continuing  
11 to page 7 at line 15 as irrelevant to the contention.

12 That testimony has nothing to do with safety/  
13 relief valve reliability.

14 JUDGE WOLFE: This is beginning at line 14,  
15 page 5, through --

16 MR. DOHERTY: It looks like line 14, page 5,  
17 or line 13 1/2.

18 JUDGE WOLFE: Once again, beginning at line 14  
19 on page 5?

20 MR. DOHERTY: That's right.

21 JUDGE WOLFE: Through where?

22 MR. DOHERTY: Line 17, page 6.

23 (Bench conference.)

24 MR. DOHERTY: Excuse me, Your Honor. I meant  
25 line 16, page 7.

1 JUDGE WOLFE: All of page 6 then?

2 MR. DOHERTY: Yes.

3 MR. COPELAND: Well, Your Honor, I really don't  
4 understand Mr. Doherty's motion, because if you read the  
5 first sentence of the contention it says that, "The  
6 pressure following a LOCA and other events combined with  
7 a single or stuck relief valve may hit the suppression pool  
8 with sufficient force to crack the containment wall,"  
9 and as I read Mr. Hucik's testimony, he is saying in  
10 direct response to that, "GE has looked at those load  
11 combinations and demonstrated that that's no problem."

12 I don't understand how it could be any more  
13 responsive to the contention.

14 MR. DOHERTY: Well, the contention --

15 JUDGE WOLFE: The basis for your motion to  
16 strike? I guess that's first.

17 MR. DOHERTY: It's irrelevant, I believe. I  
18 believe the testimony is irrelevant to the contention.

19 (Bench conference.)

20 JUDGE WOLFE: The motion to strike is denied.

21 As I understand what the witness has said, he did show  
22 the relevancy of addressing the quencher in establishing  
23 that there is a nexus with the thrust of Doherty Contention  
24 17; namely, that the quencher has a definite purpose in  
25 serving to minimize the pressure of the force that might

1 be occasioned by a single or several stuck relief valves.

2 All right. Next questions.

3 BY MR. DOHERTY:

4 Q Mr. Hucik, has a BWR ever been damaged by a  
5 stuck-open relief valve, to your knowledge, in the United  
6 States or in Europe or in the world?

7 A There have been instances of stuck-open relief  
8 valves, but I don't know of -- what do you mean by  
9 "damage"?

10 Q Well, I was asking you to kind of use that  
11 word. Have you ever heard of an event at the Vergassen  
12 plant?

13 A Yes.

14 Q Was there, in your opinion, any damage to the  
15 pressure suppression in that plant?

16 A Yes, there was some damage to that containment.

17 Q What type of containment was it?

18 A That's a German design and it was, I believe,  
19 a pressure suppression style containment. It was not a  
20 Mark III design. It did not have quenchers.

21 It had a straight down pipe.

22 Q Was it like the Mark II design?

23 A No. Mark II's have either quenchers of the  
24 same style that Allens Creek has, or they have another  
25 style quencher called a T-quencher, which is basically a



1 T on the end of a line with many holes.

2 Q You testified you thought there might be some  
3 equipment in the suppression pool a moment ago.

4 Do you know for a fact if there's any equipment  
5 in the pool of Allens Creek?

6 A Yes. There are some suction lines for  
7 different systems, some discharge lines for testing  
8 different systems, the other quenchers themselves in the  
9 pool.

10 Q Is there a suction line for the emergency core  
11 cooling system?

12 A Yes.

13 Q Is it your understanding that that water is  
14 drawn upon as a source at want?

15 MR. COPELAND: Object to the relevance, Your  
16 Honor.

17 MR. DOHERTY: Well, the contention says that  
18 there will be danger to the public if the suppression pool  
19 is damaged by blowdown from a stuck-open relief valve.

20 He says that there are some structures in the  
21 pool. One of them turns out to be the emergency core  
22 cooling system, which is necessary for the protection of  
23 the public, and that's the reason I think it's relevant.

24 MR. COPELAND: I don't think you have recollected  
25 properly what the contention says, Mr. Doherty.

1 It says, "The SRV may hit the suppression pool  
2 with sufficient force to permit the escape of radioactive  
3 gases by causing cracks in the containment building wall."

4 It is very specific as to where you have  
5 alleged the damage will occur.

6 MR. DOHERTY: I still think it is relevant to  
7 protection of the public to take it from there.

8 JUDGE WOLFE: Take what from where?

9 MR. DOHERTY: I think it's still relevant.

10 JUDGE WOLFE: To include --

11 MR. DOHERTY: I don't think I have to include  
12 exactly which wall or that sort of thing. I think it's  
13 within the bounds of the contention, because the contention  
14 speaks of damage from SRV actuation that Applicant would  
15 be on notice that even though it might not crack the wall,  
16 it might do something else hazardous, so they should --

17 JUDGE WOLFE: And your something else?

18 MR. DOHERTY: Damage to the ECCS suction in  
19 the suppression pool.

20 JUDGE LINENBERGER: Excuse me, Mr. Chairman,  
21 but literally then, Mr. Doherty, it seems to me that you  
22 may be amending the scope of your contention by this line  
23 of cross-examination in going from damage to structures now  
24 to damage to components in the suppression pool.

25 Is that what you're shifting over to now?

1 I am just asking for a clarification here. Are  
2 you switching emphasis now from the contention's emphasis  
3 on structural damage to now an emphasis on damage to  
4 components in the suppression pool?

5 MR. DOHERTY: Yes.

6 JUDGE LINENBERGER: I see.

7 (Bench conference.)

8 JUDGE WOLFE: Objection sustained. The  
9 question is outside the scope of the contention, the  
10 specific wording and scope of the contention.

11 BY MR. DOHERTY:

12 Q Now, you refer at the foot of page 6 to the  
13 automatic depressurization system as pertinent to the  
14 contention, and then you don't seem to develop or say  
15 anything more about the ADS.

16 Is that a system that just opens one valve?

17 A No. Actually, the automatic depressurization  
18 system is the opening of either seven or eight valves to  
19 depressurize the reactor.

20 MR. COPELAND: Which is described on page 7,  
21 Mr. Doherty.

22 THE WITNESS: It is eight valves, by the way.

23 BY MR. DOHERTY:

24 Q But in general, is the load smaller -- does the  
25 load decrease as the number of valves simultaneously

8-11 1 actuated increases?

2 A. No. The load is actually greater for more  
3 valves than for a single valve, and that is specified in  
4 the design.

5 Q. I mean, factually that's known?

6 A. Yes.

7 Q. And is that part of the work at Kuosheng?

8 A. The data to show that the loads increase for  
9 multiple valves, two or more, was demonstrated at Kuosheng  
10 and also at Caroso.

11 It was shown, though, that the increase in the  
12 loading due to multiple valves, the test data shows that  
13 we are more conservative; in other words, our values are  
14 greater than actually seen in the test data.

15 There was not too great of an increase in the  
16 test data relative to what we predict for design.

17 MR. DOHERTY: Okay. No further questions.  
18 Thank you very much, Mr. Hucik.

19 JUDGE WOLFE: Redirect, Mr. Copeland?

20 MR. COPELAND: Just one second, Your Honor.

21 (Pause.)

22

- - -

23

24

25

9-1  
ged  
1 MR. DOHERTY: May I approach the witness,  
2 Your Honor.

3 JUDGE WOLFE: Certainly.

4 MR. COPELAND: No questions, Your Honor.

5 JUDGE WOLFE: Board questions?

6 JUDGE CHEATUM: I have none.

7 JUDGE LINENBERGER: Only one question.

8 BOARD EXAMINATION

9 BY JUDGE LINENBERGER:

10 Q Mr. Hucik, it's not clear with respect to  
11 the subject of quencher whether each safety/relief valve  
12 is associated with a single quencher or whether all  
13 safety/relief valves communicate to a common manifold that  
14 all quencher exhaust from.

15 Now, which is the situation?

16 A Each safety/relief valve has its own discharge  
17 line and its own single quencher, and they do not  
18 communicate at all.

19 JUDGE LINENBERGER: All right. Thanks.

20 No further questions.

21 JUDGE WOLFE: Any cross in light of the  
22 one Board question?

23 MR. DOHERTY: No, sir.

24 JUDGE WOLFE: Is the witness to be excused?

25 MR. COPELAND: Yes, sir.

9-2 1 JUDGE WOLFE: The witness is excused permanently.

2 (The witness was excused.)

3 JUDGE WOLFE: I understand this is the last  
4 witness for today?

5 MR. COPELAND: That's correct.

6 JUDGE WOLFE: We will recess until -- unless  
7 there are other matters?

8 MR. COPELAND: There is another matter, since  
9 we have time, and that relates to something concerning me  
10 a great deal, and that is a motion we filed for the  
11 joint briefing schedule.

12 It's couched in terms of starting that  
13 schedule when the record closes in this case, and I'm  
14 worried, in light of the Board's order on the Quadrex  
15 Report that the record -- well, that the Board may  
16 construe that as leaving the record open until that matter  
17 is resolved one way or another.

18 I would like it understood that we could  
19 start the briefing schedule when we conclude the hearings  
20 in December.

21 It seems to me that there is nothing unfair  
22 about that, that whatever anybody is going to -- whatever  
23 Mr. Doherty is going to do in terms of filing his motion  
24 and the work associated therewith, will be done before  
25 the hearings end in December.

9-3  
1 I am worried about, you know, having a  
2 situation where it takes several weeks to get a ruling on  
3 that order and several weeks if we had to bring a witness  
4 back, several weeks to get a hearing set down and a time  
5 to file testimony.

6 I mean, I can visualize losing a month to  
7 two months from the time we end the hearings in December  
8 before we resolve that, and I just don't think there's  
9 any reason not to go ahead and start the briefing schedule,  
10 because certainly, any equitable adjustment in the  
11 briefing schedule that would need to be made because of  
12 whatever came out of that could be done.

13 I would like to get that matter cleared up.

14 JUDGE LINENBERGER: By briefing schedule  
15 here, we assume you are talking about the schedule for  
16 proposed findings?

17 MR. COPELAND: Yes, sir.

18 MR. DOHERTY: Well, Your Honor, I know  
19 Judge Linenberger wants to talk, but I have foreseen  
20 that scenario myself and I would like to request, though,  
21 that if we do have any hearings beyond the December 7th  
22 day that the briefers, that is, the parties, get one  
23 extra day for each day we have hearings.

24 MR. COPELAND: I have no objection to that.  
25 That's what I meant by an equitable adjustment in the

9-4

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

schedule, Your Honor.

For example, if we spent two days in hearings between December and the end of January or sometime in that time period, I would certainly agree that Mr. Doherty ought to be given another two days on the end of his 65 days for his findings of fact and conclusions of law to be filed. But I don't think we ought to wait until the end of January to start the whole briefing schedule. That seems to me to be clearly uncalled for.

(Bench conference.)

JUDGE WOLFE: We will take that under consideration, Mr. Copeland, and let you know as soon as we can.

MR. COPELAND: All right, sir.

JUDGE WOLFE: We will recess until 9:00 a.m. in the morning.

(Whereupon, at 2:25 p.m., the hearing was adjourned, to reconvene at 9:00 a.m., Thursday, November 19, 1981.)

- - -



This is to certify that the attached proceedings before the  
NUCLEAR REGULATORY COMMISSION

in the matter of: HOUSTON LIGHTING & POWER COMPANY

Date of proceedings: 18 November 1981

Docket Number: 50-466 CP

Place of proceedings: Houston, Texas

were held as herein appears, and that this is the original  
transcript thereof for the file of the Commission.

Mary L. Bagby  
Official Reporter (Typed)

Mary L. Bagby  
Official Reporter (Signature)