

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

① | ② | ③ | ④ | ⑤
 7 8 9 14 15 25 26 30 57 58
 C O F S V I | 0 0 - 0 0 0 0 0 - 0 0 | 4 1 1 2 0 | | | |
 LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT 58

CON'T
 ① | ② | ③ | ④ | ⑤ | ⑥ | ⑦ | ⑧ | ⑨
 7 8 60 61 68 69 74 75 80
 REPORT SOURCE | DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

① ② | On 3 occasions during the period from October 17, 1981 to November 3, 1981, 4 class
 ① ③ | one snubbers were inoperable. This is a degraded mode of LCO 4.3.10 and is reportable
 ① ④ | per FSV Technical Specification AC 7.5.2(b)2. VSS-111 was found overextended and
 ① ⑤ | inoperable. BFS-414E, BFS-417E, and CRS-317 were taken out of service to allow welding
 ① ⑥ | of support steel. There was no accompanying occurrence. Related Reports: RO 81-026,
 ① ⑦ | 81-038, 81-051, 81-056, 81-059. No affect on public health or safety.

① ⑧ | _____ 80
 7 8 9
 SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE
 ⑨ | ⑩ | ⑪ | ⑫ | ⑬ | ⑭ | ⑮ | ⑯
 H B | E | B | S U P P O R T | D | Z
 LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
 ⑰ | ⑱ | ⑲ | ⑳ | ㉑ | ㉒
 0 1 | 8 1 | 0 6 4 | 0 3 | L | 0
 ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
 ㉓ | ㉔ | ㉕ | ㉖ | ㉗ | ㉘ | ㉙ | ㉚ | ㉛
 B Z | Z | Z | 0 0 0 0 | Y | N | A | T 2 0 7

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ㉜

① ⑩ | Event 1: VSS-111 snubber was over extended due to thermal growth and was adjusted
 ① ⑪ | for proper movement. The snubber was rebuilt and tested, then returned to service.
 ① ⑫ | This is the first snubber of the surveillance period and does not change the surveil-
 ① ⑬ | lance interval. Cylinder Atlanta T-J 2½" Type AE411-2.5-5 Racine valve. Event 2 and
 ① ⑭ | 3: 3 class one snubbers were removed from service to allow welding of supports.

① ⑮ | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION
 ㉜ | ㉝ | ㉞ | ㉟ | ㊱
 E | 0 4 0 | N/A | A | Maintenance personnel observation
 ① ⑯ | ACTIVITY CONTENT | AMOUNT OF ACTIVITY | LOCATION OF RELEASE
 ㊲ | ㊳ | ㊴
 Z | Z | N/A | N/A
 ① ⑰ | PERSONNEL EXPOSURES | DESCRIPTION
 ㊵ | ㊶ | ㊷
 0 0 0 | Z | N/A
 ① ⑱ | PERSONNEL INJURIES | DESCRIPTION
 ㊸ | ㊹ | ㊺
 0 0 0 | | N/A
 ① ⑲ | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION
 ㊻ | ㊼ | ㊽
 Z | | N/A

① ⑳ | PUBLICITY ISSUED | DESCRIPTION
 ㊾ | ㊿ | ㊽
 N | | N/A
 8111250605 811116
 PDR ADOCK 05000267
 S PDR
 NRC USE ONLY
 (303) 785-2224

Charles Fuller

PH. 91 7-926