

LICENSEE EVENT REPORT

CONTROL BLOCK (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N J S G S 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

01 REPORT SOURCE 1 6 0 5 0 0 0 2 7 2 7 1 0 2 1 8 1 8 1 1 1 1 8 8 1 8

02 On October 21, 1981, while cycling Pressurizer Auxiliary Spray Line Isolation Valve LCV75 during surveillance, the pressure in the pressurizer dropped below 2205 PSIA for a total of five minutes. Action Statement 3.2.5.b was entered at 1820 hours, October 21, 1981.

09 SYSTEM CODE C B 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE V A L V E X 14 COMP SUBCODE F 15 VALVE SUBCODE D 16

10 Loss of pressure was due to excessive amount of time required to open and close Isolation Valve LCV75 because of an incorrect valve liftoff pressure setting allowing an excessive amount of makeup water to condense the steam bubble in the pressurizer. The valve liftoff pressure was set to the correct pressure. Action Statement 3.2.5.b was terminated at 1825 hours, October 21, 1981.

15 FACILITY STATUS E 28 % POWER 0 9 5 29 OTHER STATUS N/A 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Surveillance Test 32

16 ACTIVITY CONTENT Z 33 Z 34 AMOUNT OF ACTIVITY N/A 35 LOCATION OF RELEASE N/A 36

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION N/A 39

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION N/A 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION N/A 43

20 PUBLICITY ISSUED N 44 DESCRIPTION N/A 45

8112010534 811118 PDR ADOCK 05000272 PDR

NRC USE ONLY

NAME OF PREPARER Ken Whitcomb PHONE 609-935-0998