LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	Licensee Code (2)	W I K N P 1
01	License Number (3)	0 0 - 0 0 0 0 0 - 0 0
01	License Type (4)	4 1 1 1 1
01	CAT (5)	
CON'T 01	Report Source (6)	L
	Docket Number (7)	0 5 0 0 0 3 0 5
	Event Date (8)	0 5 0 7 8 1
	Report Date (9)	1 1 2 5 8 1

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During Surveillance Testing of the Pressurizer Level Channels, the level transmitter
03 to Channel LT 427 was found out of specification, low. The implication is that the
04 high level reactor trip relay would not have tripped the reactor at ≤ 90% level for
05 that channel. The redundant level channels were within specification. This event is
06 being reported as LER 81-14. Occurrences of excessive drift have been previously
07 reported.
08

System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
I A	X	Z	I N S T R U	T	Z

(17) LER/RO REPORT NUMBER

Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
8 1	—	0 1 4	/	0 3	X	—	1

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
E	X	Z	Z	0 0 0 0	N	N	N	B 0 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The Barton level transmitters fall within the scope of the equipment qualification
11 program (IEB 79-01B) and will be changed out as part of the long term upgrade of
12 transmitters. Because of redundancy of instrumentation for ESF activation no further
13 action is required at this time. (See LER 81-15/03X-2)
14

Line	Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
15	H	0 0 0	NA	B	Surveillance Testing

Line	Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
16	Z	Z	NA	NA

PERSONNEL EXPOSURES

Line	Number (37)	Type (38)	Description (39)
17	0 0 0	Z	NA

PERSONNEL INJURIES

Line	Number (40)	Description (41)
18	0 0 0	NA

LOSS OF OR DAMAGE TO FACILITY (43)

Line	Type (42)	Description
19	Z	NA

PUBLICITY

Line	Issued (44)	Description (45)
20	N	NA

8112040417 811125
PDR ADOCK 05000305
S PDR

NRC USE ONLY

NAME OF PREPARER D. J. Molzahn/J. J. Wallace PHONE: (414) 388-2560

GPO 917-926