

OFFSITE DOSE CALCULATION MANUAL

1.0 PURPOSE

The purpose of the Offsite Dose Calculation Manual (ODCM) is to provide the methods and parameters used to calculate offsite doses resulting from radioactive effluent releases, calculate effluent radiation monitor trip/alarm setpoints, and to conduct the environmental monitoring program. The methods used conform to the requirements of the Radiological Effluent Technical Specifications.

2.0 REFERENCES

2.1 Radiological Effluent Technical Specifications

2.2 Regulatory Guide 1.109

3.0 APPLICATION

The ODCM (Basis) forms the basis for the offsite dose calculations described in the liquid and gaseous waste procedures.

PMF
89-230

4.0 PROCEDURE

4.1 Offsite Dose Calculation Manual

Follow the methodology in the ODCM (Basis) to calculate offsite doses resulting from radioactive effluent releases and to calculate radiation monitor trip setpoints.

PMF
89-230

5.0 CONDENSED PROCEDURE

As described in the liquid and gaseous waste procedures.

6.0 CALCULATIONS

As described in Basis. The required calculations are also described
in the liquid and gaseous waste procedures.

| PMF
89-230

**NON-OPERATING COPY
FOR INFORMATION ONLY**

**CP-607
Page 1 of 1**

BASIS

**PMF
89-230**

OFFSITE DOSE CALCULATION MANUAL

(ODCM)

CALVERT CLIFFS NUCLEAR POWER PLANT

BALTIMORE GAS AND ELECTRIC COMPANY

Rev. 1

ODCM BASIS

PMF
89-191

TABLE OF CONTENTS

| <u>CONTENTS</u> | <u>PAGE</u> |
|--|-------------|
| 1.0 SETPOINTS. | 1 |
| 2.0 RADIOACTIVE LIQUID EFFLUENTS | 4 |
| 2.1 <u>Processing Equipment and Flow Paths</u> | 4 |
| 2.2 <u>Liquid Effluent Concentrations.</u> | 4 |
| 2.3 <u>Liquid Effluent Dose.</u> | 6 |
| 3.0 RADIOACTIVE GASEOUS EFFLUENTS. | 12 |
| 3.1 <u>Processing Equipment and Flow Paths</u> | 12 |
| 3.2 <u>Release Parameters.</u> | 12 |
| 3.3 <u>Gaseous Effluent Dose Rate.</u> | 13 |
| 3.4 <u>Gaseous Effluent Dose</u> | 15 |
| 3.5 <u>Camp Conoy/Visitors Center Dose Evaluation.</u> | 23 |
| 4.0 40 CFR 190 COMPLIANCE. | 24 |
| 5.0 RADWASTE SYSTEM MODIFICATIONS. | 25 |
| 6.0 ENVIRONMENTAL MONITORING | 27 |

ATTACHMENTS

NON-OPERATING COPY
FOR INFORMATION ONLY

CP-607
Page 1 of 1

ODCM BASIS

PMF
89-191

LIST OF ATTACHMENTS

- Attachment 1 Dose Factors For Noble Gases
- Attachment 2 Radioactive Effluent Monitoring Instrumentation
- Attachment 3 Radioactive Liquid Waste System
- Attachment 4 Liquid Effluents Dose Conversion Factors
- Attachment 5 Liquid Effluents - Adult Dose (Fish and Shellfish Pathway)
- Attachment 6 Radioactive Gaseous Waste System
- Attachment 7 Gaseous Effluents - Pathway Dose Parameters
- Attachment 8 Gaseous Effluents - Effective Dose Factors (Noble Gases)
- Attachment 9 Locations of Environment Sampling Sites
- Attachment 10 Map of Environmental Sampling sites (10 mile radius)
- Attachment 11 Map of Environmental Sampling Sites (2 mile radius)

Rev. 1

OFFSITE DOSE CALCULATION MANUAL

PMF
89-191

1.0 SETPOINTS

1.1 Liquid Effluents

1.1.1 In accordance with the requirements of Technical specification 3.3.3.10, alarm setpoints shall be established for the liquid effluent monitoring instrumentation to ensure that the concentration of radioactive material released in liquid effluents does not exceed the limits of 10CFR20, Appendix B, Table II, Column 2.

1.1.2 The setpoint shall be established taking credit for operation of the applicable number of circulating water pumps (normally a minimum of five (5)).

PMF
89-191

1.1.3 Setpoint shall be determined as follows:

$$SP = \frac{\sum (A_i \times \text{RMS Response}_i) \times \text{Dilution Water Flow Rate} + \text{Bkgd}}{\text{Discharge Flow Rate}}$$

Where:

SP = Setpoint (cpm)

A_i = Specific Activity ($\mu\text{Ci/ml}$) of radionuclide i . For liquid waste this mixture shall include Co-58 (45%), Cs-137 (15%), I-131 (15%), Ag-110m (10%), Cs-134 (5%), Co-60 (5%) and I-133 (5%). This mixture was derived from actual 1984, 1985, and 1986 liquid release data. The actual $\mu\text{Ci/ml}$ shall be determined using the appropriate MPC data as defined in 10CFR20, Appendix B, Table II, Column 2.

NON-OPERATING COPY
FOR INFORMATION ONLY

CP-607
Page 2 of 27

RMS Response $_i$ = Monitor sensitivity (cpm/ μ Ci/ml) for radionuclide i

Dilution Water Flow Rate = Dilution from circulating water pumps (normally 1E+06 gpm).

PMF-
89-191

Discharge Flow Rate = Maximum liquid effluent flow rate into circulating water (gpm).

- a. Liquid Waste (120 gpm)
- b. Steam Generator Blowdown (225 gpm per generator)

Bkgd = RMS background level (cpm)

1.1.4 If fewer than five (5) circulating water pumps are running in the conduit being discharged to, then a setpoint change should be initiated for monitored releases.

PMF-
89-191

1.1.5 Administrative controls shall be utilized to insure that 10CFR20 limits are not exceeded for the restrictive case where Iodine 131 represents 100% of the activity.

PMF-
89-191

1.2 Gaseous Effluents

1.2.1 In accordance with the requirements of Technical Specification 3.3.3.11, alarm setpoints shall be established for the gaseous effluent monitoring instrumentation to ensure that the dose rate due to radioactive materials released in gaseous effluents does not exceed 500 mrem/yr (total body) or 3000 mrem/yr (skin).

1.2.2 Setpoint shall be determined as follows:

$$SP = \sum \frac{(A_i \times \text{RMS Response}_i)}{(X/Q) \times (F)} + \text{Bkgd}$$

Rev. 1

2.2.2 Steam Generator Blowdown is normally discharged to the condensate system and recycled. Discrete volumes are occasionally discharged to the Chesapeake Bay in a batch form rather than a continuous type effluent.

2.2.3 Prior to discharge a grab sample of the waste stream(s) shall be collected and analyzed to verify compliance with 10CFR20 Appendix B, Table II, column 2.

$$\sum \frac{A_i}{MPC_i} \times \frac{\text{Discharge Flow Rate}}{\text{Dilution Water Flow Rate}} \leq 1$$

Where:

A_i = specific activity ($\mu\text{Ci}/\text{m}^3$) of isotope i from waste stream sample

MPC_i = 10CFR20 limit, Appendix B, Table II, Column 2 ($\mu\text{Ci}/\text{m}^3$)
(The soluble MPC shall be used if the radionuclide solubility state is unknown.)

Discharge Flow Rate = flow rate (gpm) of waste stream into circulating water.

Dilution Water Flow Rate = dilution from circulating water pumps
(normally $1\text{E}+06$ gpm)

| PMF-
| 89-191

2.2.4 Reactor Coolant and Miscellaneous Waste Tank Volumes shall be recirculated prior to sample collection to ensure a representative sample for analysis.

2.2.5 A liquid waste discharge permit shall be prepared for routine batch radioactive liquid releases. The permit shall document the release conditions and approvals, sample analysis results and compliance with the Radiological Effluent Technical Specifications.

2.2.6 If fewer than 5 circulating water pumps are running in the conduit being discharged to then the dilution flow should be reduced accordingly. PMF-89-191

2.2.7 In lieu of using the pre-release sample for post release accounting and monthly/quarterly analyses, a representative composite sample may be collected during the release and used for dose commitment and reporting requirements.

2.3 Liquid Effluent Dose

2.3.1 Technical Specification 3.11.1.2 limits the dose or dose commitment to members of the public from radioactive materials in liquid effluents from the Calvert Cliffs Nuclear Power Plant to:

- during any calendar quarter;
 - ≤ 3.0 mrem to total body
 - ≤ 10.0 mrem to any organ
- during any calendar year;
 - ≤ 6.0 mrem to total body
 - ≤ 20.0 mrem to any organ.

Dose due to liquid effluents may be calculated using the equations in Section 2.3.2 or 2.3.4.

2.3.2 Dose Commitment (Expanded Equation)

2.3.5 Dose Commitment (Justification for Simplified Approach)

The radioactive liquid effluents for the years 1986, 1987 and 1988 were evaluated to determine the dose contribution of the radionuclide distribution. This analysis was performed to evaluate the use of a limited dose analysis for determining environmental doses, providing a simplified method of determining compliance with the dose limits of Technical Specification 3.11.1.2. For the radionuclide distribution of effluents from Calvert Cliffs, the controlling organ is either the thyroid or the GI-LLI. The calculated thyroid dose is almost exclusively dictated by the radioiodine releases; the GI-LLI dose is primarily a function of the Co-58, Co-60, Nb-95, and Ag-110m releases. The radionuclides, Co-58, Co-60, Cs-134 and Cs-137 contribute essentially all of the calculated total body dose. The results of this evaluation are presented in Attachment (5).

| PMF
| 89-230

| PMF
| 89-230

For purposes of simplifying the details of the dose calculation, it is conservative to identify a controlling, dose significant radionuclide and limit the calculation to the use of the dose conversion factor for this nuclide. Multiplication of the total release (i.e., cumulative activity for all radionuclides) by this dose conversion factor provides for a conservative simplified dose calculation.

For the evaluation of the maximum organ dose, it is conservative to use the I-131 thyroid dose conversion ($1.02E+05$ mrem/hr per $\mu\text{Ci/ml}$, thyroid). The radionuclide Ag-110m has a higher dose conversion factor ($5.9E+05$ mrem/hr per $\mu\text{Ci/ml}$, GI-LLI). However, since Ag-110m releases are typically less than 5% of the total releases, it is conservative (while not being overly restrictive) to use the I-131 factor.

By this approach, the maximum organ dose will be routinely overestimated. For 1986, using the simplified conservative method would overestimate the maximum organ dose by a factor of 1.7; for 1987, the conservatism is a factor 2.4; and for 1988, a factor 2.7. For the total body calculation, the Cs-134 dose factor (1.33E+04 mrem/hr per $\mu\text{Ci/ml}$, total body) is the highest among the identified dominant nuclides. There are several reactor-generated radionuclides with higher values (e.g, Zn-65); however, in terms of an overall dose significance, the contribution of these nuclides will be minor, attributable to relative abundances in the effluent streams. For 1986, using this simplified conservative dose calculation would overestimate the total body dose by a factor of 4.7; for 1987, the conservatism in a factor of 2.8; and for 1988, a factor 2.5.

PMF
89-230

PMF
89-230

For evaluating compliance with the dose limits of Technical Specification 3.11.1.2, the following simplified equations may be used:

Total Body

$$D_{tb} = \frac{1.67E-02 \times V \times C}{CW} \text{ Cs-134} \times \sum A_i$$

Where :

D_{tb} = dose to the total body (mrem)

1.67E-02 = conversion factor (hr/min)

V = volume of liquid effluent released (gal)

CW = average circulating water discharge rate during release period (gal/min)

$C_{\text{Cs-134}}$ = 1.33E+04, total body ingestion dose conversion factor for Cs-134 (mrem/hr per $\mu\text{Ci/ml}$)

W = atmospheric dispersion parameter (X/Q or D/Q) to the controlling location.

PMF

89-230

X/Q = atmospheric dispersion for radiochemical particulates via the inhalation pathway and for tritium via all pathways (seconds/m³).

D/Q = atmospheric deposition for radioiodine and particulates (excluding tritium) via ingestion pathway. (m⁻²).

R_i = dose factor for radionuclide i, (mrem/yr per μCi/m³) or (m² - mrem/yr per μCi/sec) from Attachment 7 for each age group a and the applicable pathway p. Values for R_i were derived in accordance with the methods described in NUREG-0133.

Q_i = cumulative release over the period of interest for radionuclide i - I-131 or radioactive material in particulate form with half-life greater than 8 days ("μCi).

The controlling pathway and location for the CCNPP has been determined to be goat-milk pathway at 4800 meters, SSW. At this location the X/Q = 6.8E-8 seconds/m³ and the D/Q = 4.5E-10m⁻². The small amounts of tritium discharged from the plant main vents are not considered in offsite particulate dose assessments. This is justified because modeling evaluations show that the maximum expected doses would be several orders of magnitude below the regulatory limits.

PMF

89-230

3.4.4 Gaseous Dose - Radioiodine and Particulates (Simplified Equation)

In lieu of the individual radionuclide (I-131 and particulates) dose assessment as presented above, the following simplified dose calculational equation may be used for verifying compliance with the dose limits of T.S. 3.11.2.3.

$$D_{\max} = 3.17E-08 \times W \times R_{I-131} \times \sum \dot{Q}_i$$

Where:

D_{\max} = maximum organ dose (mrem)

R_{I-131} = I-131 dose parameter for the thyroid for the identified controlling pathway

= 1.27E+12, infant thyroid dose parameter with the controlling goat-milk pathway (m^2 - mrem/yr per $\mu Ci/sec$)

PMF
89-230

The ground plane exposure and inhalation pathways need not be considered when the above simplified calculation is used because of the overall negligible contribution of these pathways to the total thyroid dose. It is recognized that for some particulate radionuclides (e.g., Co-60 and Cs-137), the ground exposure pathway may represent a higher dose contribution than either the vegetation or milk pathway. However, use of the I-131 thyroid dose parameter for all radionuclides will maximize the organ dose calculation, especially considering that no other radionuclide has a higher dose parameter for any organ via any pathway than I-131 for the thyroid via the applicable vegetation or milk pathway.

N_i = the air dose factor due to beta emissions from each noble gas radionuclide i released

PMF
89-191

To determine the appropriate effective factors to be used and to evaluate the degree of variability, the atmospheric radioactive effluents for 3 years have been evaluated. Attachment 8 presents the results of this evaluation.

As demonstrated by the data in Attachment (8), the effective dose transfer factors vary little from year to year. The maximum observed variability from the average value is less than 10%. The variability is minor considering other areas of uncertainty and conservatism inherent in the environmental dose calculation models.

For evaluating compliance with the dose limits of Technical Specification 3.11.2.2, the following simplified equations may be used:

$$\dot{D}\delta = 3.17E-08 \times X/Q \times M_{eff} \times \sum \dot{Q}_i$$

$$\dot{D}\beta = 3.17E-08 \times X/Q \times N_{eff} \times \sum \dot{Q}_i$$

Where:

$\dot{D}\delta$ = air dose due to gamma emissions for the cumulative release of all noble gases (mrad)

$\dot{D}\beta$ = air dose due to beta emissions for the cumulative release of all noble gases (mrad)

X/Q = atmospheric dispersion to the controlling site boundary (sec/m³)

NON-OPERATING COPY
FOR INFORMATION ONLY

ATTACHMENT 5
ADULT DOSE CONTRIBUTIONS
FISH AND SHELLFISH PATHWAY

| Radionuclide | 1986 | | | 1987 | | | 1988 | | |
|----------------|--------|-------------------------------------|----------------------------|--------|-------------------------------------|----------------------------|--------|-------------------------------------|----------------------------|
| | Ci/yr | Total Body T.B. Dose Fraction | GI-LLI Dose Fraction | Ci/yr | Total Body T.B. Dose Fraction | GI-LLI Dose Fraction | Ci/yr | Total Body T.B. Dose Fraction | GI-LLI Dose Fraction |
| Co-58 | 0.4720 | 0.1269 | 0.0547 | 1.6600 | 0.0910 | 0.0907 | 0.4785 | 0.0453 | 0.0585 |
| Co-60 | 0.1240 | 0.0943 | 0.0383 | 0.1650 | 0.0256 | 0.0241 | 0.0331 | 0.0089 | 0.0108 |
| Nb-95 | 0.0386 | 0.0010 | 0.5539 | 0.0985 | 0.0005 | 0.6667 | 0.0317 | 0.0030 | 0.4799 |
| Ag-110m | 0.0572 | 0.0098 | 0.3211 | 0.0688 | 0.0024 | 0.1823 | 0.0721 | 0.0044 | 0.4275 |
| Cs-134 | 0.1170 | 0.3085 | 0.0003 | 0.8000 | 0.4328 | 0.0010 | 0.4478 | 0.4176 | 0.0013 |
| Cs-137 | 0.2590 | 0.4046 | 0.0006 | 1.1700 | 0.3746 | 0.0012 | 0.9308 | 0.5124 | 0.0022 |
| Total Fraction | | 0.9451 | 0.9689 | | 0.9269 | 0.9660 | | 0.9915 | 0.9802 |

ATTACHMENT 7 (CON'T)
GASEOUS EFFLUENTS - PATHWAY DOSE PARAMETERS
RIO, GRASS-GOAT-MILK PATHWAY DOSE FACTORS - INFANT
Units are m2*mrem/yr per $\mu\text{Ci}/\text{sec}$

| Nuclide | Bone | Liver | Tbody | Thyroid | Kidney | Lung | Gitract |
|---------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| H-3 | 0.000E+00 | 4.860E+03 | 4.860E+03 | 4.860E+03 | 4.860E+03 | 4.860E+03 | 4.860E+03 |
| C-14 | 3.230E+06 | 6.890E+05 | 6.890E+05 | 6.890E+05 | 6.890E+05 | 6.890E+05 | 6.890E+05 |
| NA-24 | 1.930E+06 |
| P-32 | 1.920E+11 | 1.130E+10 | 7.450E+09 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.600E+09 |
| CR-51 | 0.000E+00 | 0.000E+00 | 1.940E+04 | 1.260E+04 | 2.760E+03 | 2.460E+04 | 5.650E+05 |
| MN-54 | 0.000E+00 | 4.670E+06 | 1.060E+06 | 0.000E+00 | 1.040E+06 | 0.000E+00 | 1.720E+06 |
| MN-56 | 0.000E+00 | 3.850E-03 | 6.630E-04 | 0.000E+00 | 3.310E-03 | 0.000E+00 | 3.490E-01 |
| FE-55 | 1.760E+06 | 1.130E+06 | 3.030E+05 | 0.000E+00 | 0.000E+00 | 5.540E+05 | 1.440E+05 |
| FE-59 | 2.920E+06 | 5.110E+06 | 2.010E+06 | 0.000E+00 | 0.000E+00 | 1.510E+06 | 2.440E+06 |
| CO-57 | 0.000E+00 | 1.070E+06 | 1.750E+06 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.660E+06 |
| CO-58 | 0.000E+00 | 2.910E+06 | 7.270E+06 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 7.260E+06 |
| CO-60 | 0.000E+00 | 1.060E+07 | 2.500E+07 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.520E+07 |
| NI-63 | 4.190E+09 | 2.590E+08 | 1.450E+08 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.290E+07 |
| NI-65 | 4.210E-01 | 4.770E-02 | 2.170E-02 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.630E+00 |
| CU-64 | 0.000E+00 | 2.090E+04 | 9.680E+03 | 0.000E+00 | 3.540E+04 | 0.000E+00 | 4.290E+05 |
| ZN-65 | 6.660E+08 | 2.280E+09 | 1.050E+09 | 0.000E+00 | 1.110E+09 | 0.000E+00 | 1.930E+09 |
| ZN-69 | 0.000E+00 |
| BR-82 | 0.000E+00 | 0.000E+00 | 2.330E+07 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| BR-83 | 0.000E+00 | 0.000E+00 | 1.190E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| BR-84 | 0.000E+00 |
| BR-85 | 0.000E+00 |
| RB-86 | 0.000E+00 | 2.670E+09 | 1.320E+09 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 6.830E+07 |
| RB-88 | 0.000E+00 |
| RB-89 | 0.000E+00 |
| SR-89 | 2.640E+10 | 0.000E+00 | 7.580E+08 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 5.430E+08 |
| SR-90 | 2.550E+11 | 0.000E+00 | 6.500E+10 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.190E+09 |
| SR-91 | 6.180E+05 | 0.000E+00 | 2.240E+04 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 7.310E+05 |
| SR-92 | 3.760E+00 | 0.000E+00 | 3.620E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.050E+02 |
| Y-90 | 8.160E+01 | 0.000E+00 | 2.190E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.130E+05 |
| Y-91M | 0.000E+00 |
| Y-91 | 8.800E+03 | 0.000E+00 | 2.340E+02 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 6.310E+05 |
| Y-92 | 6.270E-05 | 0.000E+00 | 1.760E-06 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.200E+10 |
| Y-93 | 2.700E-01 | 0.000E+00 | 7.350E-03 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.130E+03 |
| ZR-95 | 8.190E+02 | 2.000E+02 | 1.420E+02 | 0.000E+00 | 2.150E+02 | 0.000E+00 | 9.940E+00 |
| ZR-97 | 4.790E-01 | 8.220E-02 | 3.760E-02 | 0.000E+00 | 8.290E-02 | 0.000E+00 | 5.240E+03 |
| NB-95 | 7.120E+04 | 2.930E+04 | 1.690E+04 | 0.000E+00 | 2.100E+04 | 0.000E+00 | 2.470E+07 |
| NB-97 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 4.440E-07 |
| MO-99 | 0.000E+00 | 2.540E+07 | 4.960E+06 | 0.000E+00 | 3.800E+07 | 0.000E+00 | 8.830E+06 |
| TC-99M | 3.230E+00 | 6.660E+00 | 8.570E+01 | 0.000E+00 | 7.160E+01 | 3.480E+00 | 1.930E+03 |
| TC-101 | 0.000E+00 |
| RU-103 | 1.040E+03 | 0.000E+00 | 3.490E+02 | 0.000E+00 | 2.170E+03 | 0.000E+00 | 1.270E+04 |
| RU-105 | 9.670E-04 | 0.000E+00 | 3.260E-04 | 0.000E+00 | 7.110E-03 | 0.000E+00 | 3.850E-01 |
| RU-106 | 2.280E+04 | 0.000E+00 | 2.850E+03 | 0.000E+00 | 2.700E+04 | 0.000E+00 | 1.730E+05 |
| RH-103M | 0.000E+00 |
| RH-106 | 0.000E+00 |
| AG-110M | 4.630E+07 | 3.380E+07 | 2.240E+07 | 0.000E+00 | 4.840E+07 | 0.000E+00 | 1.750E+09 |
| SB-124 | 2.510E+07 | 3.700E+05 | 7.790E+06 | 6.670E+04 | 0.000E+00 | 1.570E+07 | 7.750E+07 |
| SB-125 | 1.790E+07 | 1.740E+05 | 3.690E+06 | 2.250E+04 | 0.000E+00 | 1.130E+07 | 2.390E+07 |
| TE-125M | 1.810E+07 | 6.050E+06 | 2.450E+06 | 6.090E+06 | 0.000E+00 | 0.000E+00 | 8.620E+06 |

NON-OPERATING COPY
FOR INFORMATICS ONLY

ATTACHMENT 7 (CON'T)
GASEOUS EFFLUENTS - PATHWAY DOSE PARAMETERS
RIO, GRASS-GOAT-MILK PATHWAY DOSE FACTORS - INFANT
Units are m2*mrem/yr per μ Ci/sec

| Nuclide | Bone | Liver | Tbody | Thyroid | Kidney | Lung | Gitract |
|---------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| TE-127M | 5.050E+07 | 1.680E+07 | 6.120E+06 | 1.460E+07 | 1.240E+08 | 0.000E+00 | 2.040E+07 |
| TE-127 | 7.800E+02 | 2.610E+02 | 1.680E+02 | 6.350E+02 | 1.900E+03 | 0.000E+00 | 1.640E+04 |
| TE-129M | 6.710E+07 | 2.300E+07 | 1.030E+07 | 2.580E+07 | 1.680E+08 | 0.000E+00 | 4.010E+07 |
| TE-129 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.000E-08 |
| TE-131M | 4.050E+05 | 1.630E+05 | 1.350E+05 | 3.310E+00 | 1.120E+06 | 0.000E+00 | 2.750E+06 |
| TE-131 | 0.000E+00 |
| TE-132 | 2.520E+06 | 1.250E+06 | 1.170E+06 | 1.840E+06 | 7.820E+06 | 0.000E+00 | 4.620E+06 |
| I-130 | 4.320E+06 | 9.510E+06 | 3.820E+06 | 7.000E+08 | 1.040E+07 | 0.000E+00 | 2.040E+06 |
| I-131 | 3.270E+09 | 3.850E+09 | 1.690E+09 | 1.270E+12 | 4.500E+09 | 0.000E+00 | 1.370E+08 |
| I-132 | 1.710E+00 | 3.470E+00 | 1.230E+00 | 1.630E+02 | 3.870E+00 | 0.000E+00 | 2.810E+00 |
| I-133 | 4.460E+07 | 6.490E+07 | 1.900E+07 | 1.180E+10 | 7.630E+07 | 0.000E+00 | 1.100E+07 |
| I-134 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.210E-09 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| I-135 | 1.460E+05 | 2.900E+05 | 1.060E+05 | 2.600E+07 | 3.230E+05 | 0.000E+00 | 1.050E+05 |
| CS-134 | 1.090E+11 | 2.040E+11 | 2.060E+10 | 0.000E+00 | 5.250E+10 | 2.150E+10 | 5.540E+08 |
| CS-136 | 5.880E+09 | 1.730E+10 | 6.460E+09 | 0.000E+00 | 6.900E+09 | 1.410E+09 | 2.630E+08 |
| CS-137 | 1.540E+11 | 1.810E+11 | 1.280E+10 | 0.000E+00 | 4.850E+10 | 1.960E+10 | 5.650E+08 |
| CS-138 | 0.000E+00 |
| BA-139 | 5.450E-08 | 0.000E+00 | 1.580E-09 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.450E-06 |
| BA-140 | 2.890E+07 | 2.890E+04 | 1.490E+06 | 0.000E+00 | 6.870E+03 | 1.780E+04 | 7.110E+06 |
| BA-141 | 0.000E+00 |
| BA-142 | 0.000E+00 |
| LA-140 | 4.840E+00 | 1.910E+00 | 4.900E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.240E+04 |
| LA-142 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 6.250E-07 |
| CE-141 | 5.200E+03 | 3.170E+03 | 3.730E+02 | 0.000E+00 | 9.780E+02 | 0.000E+00 | 1.640E+06 |
| CE-143 | 4.800E+01 | 3.180E+04 | 3.630E+00 | 0.000E+00 | 9.270E+00 | 0.000E+00 | 1.860E+05 |
| CE-144 | 2.790E+05 | 1.140E+05 | 1.560E+04 | 0.000E+00 | 4.620E+04 | 0.000E+00 | 1.600E+07 |
| PR-143 | 1.790E+02 | 6.710E+01 | 8.890E+00 | 0.000E+00 | 2.490E+01 | 0.000E+00 | 9.470E+04 |
| PR-144 | 0.000E+00 |
| ND-147 | 1.060E+02 | 1.090E+02 | 6.660E+00 | 0.000E+00 | 4.190E+01 | 0.000E+00 | 6.890E+04 |
| W-187 | 7.350E+03 | 5.110E+03 | 1.770E+03 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.000E+05 |
| NP-239 | 4.360E+00 | 3.900E-01 | 2.210E-01 | 0.000E+00 | 7.780E-01 | 0.000E+00 | 1.130E+04 |

NON-OPERATING COPY
FOR INFORMATION ONLY

ATTACHMENT 7 (CON'T)
GASEOUS EFFLUENTS - PATHWAY DOSE PARAMETERS
RIO, GRASS-GOAT-MILK PATHWAY DOSE FACTORS - CHILD

Units are m²*mrem/yr per μCi/sec

| Nuclide | Bone | Liver | Tbody | Thyroid | Kidney | Lung | Gitract |
|---------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| H-3 | 0.000E+00 | 3.200E+03 | 3.200E+03 | 3.200E+03 | 3.200E+03 | 3.200E+03 | 3.200E+03 |
| C-14 | 1.650E+06 | 3.290E+05 | 3.290E+05 | 3.290E+05 | 3.290E+05 | 3.290E+05 | 3.290E+05 |
| NA-24 | 1.110E+06 |
| P-32 | 9.330E+10 | 4.370E+09 | 3.600E+09 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.580E+09 |
| CR-51 | 0.000E+00 | 0.000E+00 | 1.220E+04 | 6.790E+03 | 1.860E+03 | 1.240E+04 | 6.490E+05 |
| MN-54 | 0.000E+00 | 2.510E+06 | 6.690E+05 | 0.000E+00 | 7.050E+05 | 0.000E+00 | 2.110E+06 |
| MN-56 | 0.000E+00 | 1.570E-03 | 3.550E-04 | 0.000E+00 | 1.900E-03 | 0.000E+00 | 2.280E-01 |
| FE-55 | 1.450E+06 | 7.700E+05 | 2.390E+05 | 0.000E+00 | 0.000E+00 | 4.360E+05 | 1.430E+05 |
| FE-59 | 1.570E+06 | 2.530E+06 | 1.260E+06 | 0.000E+00 | 0.000E+00 | 7.350E+05 | 2.640E+06 |
| CO-57 | 0.000E+00 | 4.600E+05 | 9.320E+05 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.770E+06 |
| CO-58 | 0.000E+00 | 1.460E+06 | 4.460E+06 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 8.500E+06 |
| CO-60 | 0.000E+00 | 5.180E+06 | 1.530E+07 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.870E+07 |
| NI-63 | 3.560E+09 | 1.900E+08 | 1.210E+08 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.280E+07 |
| NI-65 | 1.990E-01 | 1.870E-02 | 1.090E-02 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.290E+00 |
| CU-64 | 0.000E+00 | 8.410E+03 | 5.080E+03 | 0.000E+00 | 2.030E+04 | 0.000E+00 | 3.950E-05 |
| ZN-65 | 4.960E+08 | 1.320E+09 | 8.220E+08 | 0.000E+00 | 8.330E+08 | 0.000E+00 | 2.320E+08 |
| ZN-69 | 0.000E+00 |
| BR-82 | 0.000E+00 | 0.000E+00 | 1.390E+07 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| BR-83 | 0.000E+00 | 0.000E+00 | 5.620E-02 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| BR-84 | 0.000E+00 |
| BR-85 | 0.000E+00 |
| RB-86 | 0.000E+00 | 1.050E+09 | 6.470E+08 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 6.770E+07 |
| RB-88 | 0.000E+00 |
| RB-89 | 0.000E+00 |
| SR-89 | 1.390E+10 | 0.000E+00 | 3.970E+08 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 5.380E+08 |
| SR-90 | 2.350E+11 | 0.000E+00 | 5.950E+10 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.190E+09 |
| SR-91 | 2.970E+05 | 0.000E+00 | 1.120E+04 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 6.550E+05 |
| SR-92 | 4.590E+10 | 0.000E+00 | 1.840E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 8.690E+01 |
| Y-90 | 3.860E+01 | 0.000E+00 | 1.030E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.100E+05 |
| Y-91M | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 7.800E-17 |
| Y-91 | 4.690E+03 | 0.000E+00 | 1.250E+02 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 6.250E+05 |
| Y-92 | 2.950E-05 | 0.000E+00 | 8.440E-07 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 8.520E-01 |
| Y-93 | 1.270E-01 | 0.000E+00 | 3.480E-03 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.890E+03 |
| ZR-95 | 4.610E+02 | 1.010E+02 | 9.030E+01 | 0.000E+00 | 1.450E+02 | 0.000E+00 | 1.060E+05 |
| ZR-97 | 2.260E-01 | 3.270E-02 | 1.930E-02 | 0.000E+00 | 4.690E-02 | 0.000E+00 | 4.950E+03 |
| NB-95 | 3.810E+04 | 1.480E+04 | 1.060E+04 | 0.000E+00 | 1.390E+04 | 0.000E+00 | 2.750E+07 |
| NB-97 | 0.000E+00 |
| MO-99 | 0.000E+00 | 9.950E+06 | 2.460E+06 | 0.000E+00 | 2.120E+07 | 0.000E+00 | 8.230E+06 |
| TC-99M | 1.550E+00 | 3.040E+00 | 5.040E+01 | 0.000E+00 | 4.420E+01 | 1.550E+00 | 1.730E+03 |
| TC-101 | 0.000E+00 |
| RU-103 | 5.150E+02 | 0.000E+00 | 1.980E+02 | 0.000E+00 | 1.300E+03 | 0.000E+00 | 1.330E+04 |
| RU-105 | 4.590E-04 | 0.000E+00 | 1.660E-04 | 0.000E+00 | 4.030E-03 | 0.000E+00 | 2.990E-01 |
| RU-106 | 1.110E+04 | 0.000E+00 | 1.380E+03 | 0.000E+00 | 1.500E+04 | 0.000E+00 | 1.720E+05 |
| RH-103M | 0.000E+00 |
| RH-106 | 0.000E+00 |
| AG-110M | 2.510E+07 | 1.690E+07 | 1.350E+07 | 0.000E+00 | 3.150E+07 | 0.000E+00 | 2.010E+09 |
| SB-124 | 1.300E+07 | 1.690E+05 | 4.570E+06 | 2.880E+04 | 0.000E+00 | 7.240E+06 | 8.150E+07 |
| SB-125 | 1.040E+07 | 8.050E+04 | 2.190E+06 | 9.670E+03 | 0.000E+00 | 5.820E+06 | 2.490E+07 |
| TE-125M | 8.850E+06 | 2.400E+06 | 1.180E+06 | 2.480E+06 | 0.000E+00 | 0.000E+00 | 8.540E+06 |

**NON-OPERATING COPY
FOR INFORMATION ONLY**

**ATTACHMENT 7 (CON'T)
GASEOUS EFFLUENTS - PATHWAY DOSE PARAMETERS
RIO, GRASS-GOAT-MILK PATHWAY DOSE FACTORS - CHILD**
Units are m2*mrem/yr per μ Ci/sec

| Nuclide | Bone | Liver | Tbody | Thyroid | Kidney | Lung | Gitract |
|---------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| TE-127M | 2.500E+07 | 6.720E+06 | 2.960E+06 | 5.970E+06 | 7.120E+07 | 0.000E+00 | 2.020E+07 |
| TE-127 | 3.670E+02 | 9.910E+01 | 7.880E+01 | 2.540E+02 | 1.050E+03 | 0.000E+00 | 1.440E+04 |
| TE-129M | 3.270E+07 | 9.130E+06 | 5.080E+06 | 1.050E+07 | 9.600E+07 | 0.000E+00 | 3.990E+07 |
| TE-129 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 7.340E-09 |
| TE-131M | 1.920E+05 | 6.640E+04 | 7.070E+04 | 1.370E+05 | 6.430E+05 | 0.000E+00 | 2.690E+06 |
| TE-131 | 0.000E+00 |
| TE-132 | 1.230E+06 | 5.420E+05 | 6.550E+05 | 7.900E+05 | 5.040E+06 | 0.000E+00 | 5.460E+06 |
| I-130 | 2.100E+06 | 4.250E+06 | 2.190E+06 | 4.680E+08 | 6.350E+06 | 0.000E+00 | 1.990E+06 |
| I-131 | 1.570E+09 | 1.570E+09 | 8.950E+08 | 5.210E+11 | 2.580E+09 | 0.000E+00 | 1.400E+08 |
| I-132 | 8.230E-01 | 1.510E+00 | 6.960E-01 | 7.020E+01 | 2.320E+00 | 0.000E+00 | 1.780E+00 |
| I-133 | 2.110E+07 | 2.610E+07 | 9.880E+06 | 4.850E+09 | 4.350E+07 | 0.000E+00 | 1.050E+07 |
| I-134 | 0.000E+00 |
| I-135 | 7.000E+04 | 1.260E+05 | 5.960E+04 | 1.120E+07 | 1.930E+05 | 0.000E+00 | 9.600E+04 |
| CS-134 | 6.790E+10 | 1.110E+11 | 2.350E+10 | 0.000E+00 | 3.450E+10 | 1.240E+10 | 6.010E+08 |
| CS-136 | 3.010E+09 | 8.280E+09 | 5.360E+09 | 0.000E+00 | 4.410E+09 | 6.580E+08 | 2.910E+08 |
| CS-137 | 9.670E+10 | 9.260E+10 | 1.370E+10 | 0.000E+00 | 3.020E+10 | 1.090E+10 | 5.800E+08 |
| CS-138 | 0.000E+00 |
| BA-139 | 2.560E-08 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.480E-06 |
| BA-140 | 1.410E+07 | 1.230E+04 | 8.210E+05 | 0.000E+00 | 4.010E+03 | 7.340E+03 | 7.120E+06 |
| BA-141 | 0.000E+00 |
| BA-142 | 0.000E+00 |
| LA-140 | 2.310E+00 | 8.090E-01 | 2.730E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.260E+04 |
| LA-142 | 4.770E-12 | 1.520E-12 | 4.770E-13 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.020E-07 |
| CE-141 | 2.620E+03 | 1.310E+03 | 1.940E+02 | 0.000E+00 | 5.730E+02 | 0.000E+00 | 1.630E+06 |
| CE-143 | 2.270E+01 | 1.230E+04 | 1.780E+00 | 0.000E+00 | 5.150E+00 | 0.000E+00 | 1.800E+05 |
| CE-144 | 1.950E+05 | 6.100E+04 | 1.040E+04 | 0.000E+00 | 3.380E+04 | 0.000E+00 | 1.590E+07 |
| PR-143 | 8.670E+01 | 2.600E+01 | 4.300E+00 | 0.000E+00 | 1.410E+01 | 0.000E+00 | 9.350E+04 |
| PR-144 | 0.000E+00 |
| ND-147 | 5.340E+01 | 4.320E+01 | 3.350E+00 | 0.000E+00 | 2.370E+01 | 0.000E+00 | 6.850E+04 |
| W-187 | 3.490E+03 | 2.070E+03 | 9.270E+02 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.900E+05 |
| NP-239 | 2.060E+00 | 1.480E-01 | 1.040E-01 | 0.000E+00 | 4.280E-01 | 0.000E+00 | 1.100E+04 |

NON-OPERATING COPY
FOR INFORMATION ONLY

ATTACHMENT 7 (CON'T)
GASEOUS EFFLUENTS - PATHWAY DOSE PARAMETERS
RIO, GRASS-GOAT-MILK PATHWAY DOSE FACTORS - TEEN
Units are m2*mrem/yr per μ Ci/sec

| Nuclide | Bone | Liver | Tbody | Thyroid | Kidney | Lung | Gitract |
|---------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| H-3 | 0.000E+00 | 2.030E+03 | 2.030E+03 | 2.030E+03 | 2.030E+03 | 2.030E+03 | 2.030E+03 |
| C-14 | 6.700E+05 | 1.340E+05 | 1.340E+05 | 1.340E+05 | 1.340E+05 | 1.340E+05 | 1.340E+05 |
| N-14 | 5.330E+05 |
| P-32 | 3.780E+10 | 2.340E+09 | 1.470E+09 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.180E+09 |
| CR-51 | 0.000E+00 | 0.000E+00 | 6.000E+03 | 3.330E+03 | 1.310E+03 | 8.560E+03 | 1.010E+06 |
| MN-54 | 0.000E+00 | 1.680E+06 | 3.330E+05 | 0.000E+00 | 5.010E+05 | 0.000E+00 | 3.440E+06 |
| MN-56 | 0.000E+00 | 9.010E-04 | 1.600E-04 | 0.000E+00 | 1.140E-03 | 0.000E+00 | 5.930E-02 |
| FE-55 | 5.790E+05 | 4.100E+05 | 9.570E+04 | 0.000E+00 | 0.000E+00 | 2.600E+05 | 1.780E+05 |
| FE-59 | 6.750E+05 | 1.580E+06 | 6.090E+05 | 0.000E+00 | 0.000E+00 | 4.970E+05 | 3.730E+06 |
| CO-57 | 0.000E+00 | 2.690E+05 | 4.520E+05 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 5.030E+06 |
| CO-58 | 0.000E+00 | 9.540E+05 | 2.200E+06 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.310E+07 |
| CO-60 | 0.000E+00 | 3.340E+06 | 7.510E+06 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 4.350E+07 |
| NI-63 | 1.420E+09 | 1.000E+08 | 4.810E+07 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.590E+07 |
| NI-65 | 8.130E-02 | 1.040E-02 | 4.730E-03 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 5.640E-01 |
| CU-64 | 0.000E+00 | 4.790E+03 | 2.250E+03 | 0.000E+00 | 1.210E+04 | 0.000E+00 | 3.710E+05 |
| ZN-65 | 2.530E+08 | 8.780E+08 | 4.090E+08 | 0.000E+00 | 5.620E+08 | 0.000E+00 | 3.720E+08 |
| ZN-69 | 0.000E+00 |
| BR-82 | 0.000E+00 | 0.000E+00 | 6.670E+06 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| BR-83 | 0.000E+00 | 0.000E+00 | 2.290E-02 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| BR-84 | 0.000E+00 |
| BR-85 | 0.000E+00 |
| RB-86 | 0.000E+00 | 5.670E+08 | 2.670E+08 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 8.400E+07 |
| RB-88 | 0.000E+00 |
| RB-89 | 0.000E+00 |
| SR-89 | 5.620E+09 | 0.000E+00 | 1.160E+08 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 6.690E+08 |
| SR-90 | 1.390E+11 | 0.000E+00 | 3.430E+10 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.900E+09 |
| SR-91 | 1.210E+05 | 0.000E+00 | 4.810E+03 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 5.480E+05 |
| SR-92 | 1.880E+00 | 0.000E+00 | 8.010E-02 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 4.790E+01 |
| Y-90 | 1.560E+01 | 0.000E+00 | 4.200E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.290E+05 |
| Y-91M | 0.000E+00 |
| Y-91 | 1.900E+03 | 0.000E+00 | 5.090E+01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 7.780E+05 |
| Y-92 | 1.200E-05 | 0.000E+00 | 3.480E-07 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.300E-01 |
| Y-93 | 5.160E-02 | 0.000E+00 | 1.410E-03 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.580E+03 |
| ZR-95 | 1.990E+02 | 6.260E+01 | 4.310E+01 | 0.000E+00 | 9.200E+01 | 0.000E+00 | 1.450E+05 |
| ZR-97 | 9.300E-02 | 1.840E-02 | 8.480E-03 | 0.000E+00 | 2.790E-02 | 0.000E+00 | 4.980E+03 |
| NB-95 | 1.690E+04 | 9.370E+03 | 5.160E+03 | 0.000E+00 | 9.080E+03 | 0.000E+00 | 4.010E+07 |
| NB-97 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 7.610E-09 |
| MO-99 | 0.000E+00 | 5.470E+06 | 1.040E+06 | 0.000E+00 | 1.250E+07 | 0.000E+00 | 9.800E+06 |
| TC-99M | 6.770E-01 | 1.890E+00 | 2.450E+01 | 0.000E+00 | 2.810E+01 | 1.050E+00 | 1.240E+03 |
| TC-101 | 0.000E+00 |
| RU-103 | 2.180E+02 | 0.000E+00 | 9.310E+01 | 0.000E+00 | 7.670E+02 | 0.000E+00 | 1.820E+04 |
| RU-105 | 1.880E-04 | 0.000E+00 | 7.290E-05 | 0.000E+00 | 2.370E-03 | 0.000E+00 | 1.520E-01 |
| RU-106 | 4.500E+03 | 0.000E+00 | 5.670E+02 | 0.000E+00 | 8.680E+03 | 0.000E+00 | 2.160E+05 |
| RH-103M | 0.000E+00 |
| RH-106 | 0.000E+00 |
| AG-110M | 1.160E+07 | 1.090E+07 | 6.650E+06 | 0.000E+00 | 2.090E+07 | 0.000E+00 | 3.070E+09 |
| SB-124 | 5.510E+06 | 1.020E+05 | 2.150E+06 | 1.250E+04 | 0.000E+00 | 4.810E+06 | 1.110E+08 |
| SB-125 | 4.380E+06 | 4.790E+04 | 1.030E+06 | 4.190E+03 | 0.000E+00 | 3.850E+06 | 3.410E+07 |
| TE-125M | 3.600E+06 | 1.300E+03 | 4.820E+05 | 1.010E+06 | 0.000E+00 | 0.000E+00 | 1.060E+07 |

NON-OPERATING COPY
FOR INFORMATION ONLY

ATTACHMENT 7 (CON'T)
GASEOUS EFFLUENTS - PATHWAY DOSE PARAMETERS
RIO, GRASS-GOAT-MILK PATHWAY DOSE FACTORS - TEEN

Units are m2*mrem/yr per μ Ci/sec

| Nuclide | Bone | Liver | Tbody | Thyroid | Kidney | Lung | Gitract |
|---------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| TE-127M | 1.010E+07 | 3.590E+06 | 1.200E+06 | 2.410E+06 | 4.100E+07 | 0.000E+00 | 2.520E+07 |
| TE-127 | 1.490E+02 | 5.290E+01 | 3.210E+01 | 1.030E+02 | 6.050E+02 | 0.000E+00 | 1.150E+04 |
| TE-129M | 1.330E+07 | 4.920E+06 | 2.100E+06 | 4.280E+06 | 5.550E+07 | 0.000E+00 | 4.980E+07 |
| TE-129 | 0.000E+00 |
| TE-131M | 7.890E+04 | 3.780E+04 | 3.150E+04 | 5.690E+04 | 2.940E+05 | 0.000E+00 | 3.030E+06 |
| TE-131 | 0.000E+00 |
| TE-132 | 5.130E+05 | 3.250E+05 | 3.060E+05 | 3.430E+05 | 3.120E+06 | 0.000E+00 | 1.030E+07 |
| I-130 | 8.990E+05 | 2.600E+06 | 1.040E+06 | 2.120E+08 | 4.010E+06 | 0.000E+00 | 2.000E+06 |
| I-131 | 6.450E+08 | 9.030E+08 | 4.850E+08 | 2.640E+11 | 1.560E+09 | 0.000E+00 | 1.790E+08 |
| I-132 | 3.480E-01 | 9.110E-01 | 3.270E-01 | 3.070E+01 | 1.430E+00 | 0.000E+00 | 3.970E-01 |
| I-133 | 8.690E+06 | 1.470E+07 | 4.500E+06 | 2.060E+09 | 2.590E+07 | 0.000E+00 | 1.120E+07 |
| I-134 | 5.180E-12 | 1.370E-11 | 4.930E-12 | 2.290E-10 | 2.160E-11 | 0.000E+00 | 1.810E-13 |
| I-135 | 2.960E+04 | 7.620E+04 | 2.820E+04 | 4.900E+06 | 1.200E+05 | 0.000E+00 | 8.440E+04 |
| CS-134 | 2.940E+10 | 6.930E+10 | 3.210E+10 | 0.000E+00 | 2.200E+10 | 8.410E+09 | 8.620E+08 |
| CS-136 | 1.330E+09 | 5.250E+09 | 3.530E+09 | 0.000E+00 | 2.860E+09 | 4.510E+08 | 4.230E+08 |
| CS-137 | 4.020E+10 | 5.340E+10 | 1.860E+10 | 0.000E+00 | 1.820E+10 | 7.060E+09 | 7.600E+08 |
| CS-138 | 0.000E+00 |
| BA-139 | 1.040E-08 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 9.310E-08 |
| BA-140 | 5.830E+06 | 7.140E+03 | 3.750E+05 | 0.000E+00 | 2.420E+03 | 4.800E+03 | 8.980E+06 |
| BA-141 | 0.000E+00 |
| BA-142 | 0.000E+00 |
| LA-140 | 9.760E-01 | 4.750E-01 | 1.260E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.730E+04 |
| LA-142 | 1.980E-12 | 8.780E-13 | 2.190E-13 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.670E-08 |
| CE-141 | 1.060E+03 | 7.110E+02 | 8.170E+01 | 0.000E+00 | 3.350E+02 | 0.000E+00 | 2.030E+06 |
| CE-143 | 9.230E+00 | 6.720E+03 | 7.500E-01 | 0.000E+00 | 3.010E+00 | 0.000E+00 | 2.020E+05 |
| CE-144 | 7.900E+04 | 3.270E+04 | 4.240E+03 | 0.000E+00 | 1.950E+04 | 0.000E+00 | 1.990E+07 |
| PR-143 | 3.500E+01 | 1.400E+01 | 1.740E+00 | 0.000E+00 | 8.130E+00 | 0.000E+00 | 1.150E+05 |
| PR-144 | 0.000E+00 |
| ND-147 | 2.180E+01 | 2.370E+01 | 1.420E+00 | 0.000E+00 | 1.390E+01 | 0.000E+00 | 8.530E+04 |
| W-187 | 1.440E+03 | 1.170E+03 | 4.110E+02 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.180E+05 |
| NP-239 | 8.390E-01 | 7.910E-02 | 4.390E-02 | 0.000E+00 | 2.480E-01 | 0.000E+00 | 1.270E+04 |

NON-OPERATING COPY
FOR INFORMATION ONLY

ATTACHMENT 7 (CON'T)
GASEOUS EFFLUENTS - PATHWAY DOSE PARAMETERS
RIO, GRASS-GOAT-MILK PATHWAY DOSE FACTORS - ADULT
Units are m2*mrem/yr per μ Ci/sec

| Nuclide | Bone | Liver | Tbody | Thyroid | Kidney | Lung | Gitract |
|---------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| H-3 | 0.000E+00 | 1.560E+03 | 1.560E+03 | 1.560E+03 | 1.560E+03 | 1.560E+03 | 1.560E+03 |
| C-14 | 3.630E+05 | 7.260E+04 | 7.260E+04 | 7.260E+04 | 7.260E+04 | 7.260E+04 | 7.260E+04 |
| NA-24 | 3.050E+05 |
| P-32 | 2.050E+10 | 1.270E+09 | 7.930E+08 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.310E+09 |
| CR-51 | 0.000E+00 | 0.000E+00 | 3.430E+03 | 2.050E+03 | 7.560E+02 | 4.560E+03 | 8.640E+05 |
| MN-54 | 0.000E+00 | 1.010E+06 | 1.920E+05 | 0.000E+00 | 3.000E+05 | 0.000E+00 | 3.090E+06 |
| MN-56 | 0.000E+00 | 5.080E-04 | 9.010E-05 | 0.000E+00 | 6.450E-04 | 0.000E+00 | 1.620E-02 |
| FE-55 | 3.260E+05 | 2.250E+05 | 5.260E+04 | 0.000E+00 | 0.000E+00 | 1.260E+05 | 1.290E+05 |
| FE-59 | 3.870E+05 | 9.090E+05 | 3.490E+05 | 0.000E+00 | 0.000E+00 | 2.540E+05 | 3.030E+06 |
| CO-57 | 0.000E+00 | 1.540E+05 | 2.550E+05 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.900E+06 |
| CO-58 | 0.000E+00 | 5.660E+05 | 1.270E+06 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.150E+07 |
| CO-60 | 0.000E+00 | 1.970E+06 | 4.340E+06 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.700E+07 |
| NI-63 | 8.070E+08 | 5.600E+07 | 2.710E+07 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.170E+07 |
| NI-65 | 4.440E-02 | 5.770E-03 | 2.630E-03 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.460E-01 |
| CU-64 | 0.000E+00 | 2.690E+03 | 1.260E+03 | 0.000E+00 | 6.770E+03 | 0.000E+00 | 2.290E+05 |
| ZN-65 | 1.650E+08 | 5.240E+08 | 2.370E+08 | 0.000E+00 | 3.500E+08 | 0.000E+00 | 3.300E+08 |
| ZN-69 | 6.240E-13 | 1.190E-12 | 8.290E-14 | 0.000E+00 | 7.750E-13 | 0.000E+00 | 1.790E-13 |
| BR-82 | 0.000E+00 | 0.000E+00 | 3.900E+06 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 4.470E+06 |
| BR-83 | 0.000E+00 | 0.000E+00 | 1.240E-02 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.790E-02 |
| BR-84 | 0.000E+00 |
| BR-85 | 0.000E+00 |
| RB-86 | 0.000E+00 | 3.110E+08 | 1.450E+08 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 6.140E+07 |
| RB-88 | 0.000E+00 |
| RB-89 | 0.000E+00 |
| SR-89 | 3.050E+09 | 0.000E+00 | 8.740E+07 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 4.890E+08 |
| SR-90 | 9.830E+10 | 0.000E+00 | 2.410E+10 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.840E+09 |
| SR-91 | 6.580E+04 | 0.000E+00 | 2.660E+03 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.130E+05 |
| SR-92 | 1.030E+00 | 0.000E+00 | 4.440E-02 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.030E+01 |
| Y-90 | 8.480E+00 | 0.000E+00 | 2.280E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 8.990E+04 |
| Y-91M | 0.000E+00 |
| Y-91 | 1.030E+03 | 0.000E+00 | 2.760E+01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 5.680E+05 |
| Y-92 | 6.510E-06 | 0.000E+00 | 1.900E-07 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.140E-01 |
| Y-93 | 2.800E-02 | 0.000E+00 | 7.720E-04 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 8.870E+02 |
| ZR-95 | 1.140E+02 | 3.640E+01 | 2.470E+01 | 0.000E+00 | 5.710E+01 | 0.000E+00 | 1.150E+05 |
| ZR-97 | 5.110E-02 | 1.030E-02 | 4.710E-03 | 0.000E+00 | 1.560E-02 | 0.000E+00 | 3.190E+03 |
| NB-95 | 9.900E+03 | 5.510E+03 | 2.960E+03 | 0.000E+00 | 5.440E+03 | 0.000E+00 | 3.340E+07 |
| NB-97 | 0.000E+00 |
| MO-99 | 0.000E+00 | 3.030E+06 | 5.760E+05 | 0.000E+00 | 6.860E+06 | 0.000E+00 | 7.020E+06 |
| TC-99M | 3.900E-01 | 1.100E+00 | 1.400E+01 | 0.000E+00 | 1.670E+01 | 5.400E-01 | 6.520E+02 |
| TC-101 | 0.000E+00 |
| RU-103 | 1.220E+02 | 0.000E+00 | 5.270E+01 | 0.000E+00 | 4.670E+02 | 0.000E+00 | 1.430E+04 |
| RU-105 | 1.030E-04 | 0.000E+00 | 4.060E-05 | 0.000E+00 | 1.330E-03 | 0.000E+00 | 6.290E-02 |
| RU-106 | 2.450E+03 | 0.000E+00 | 3.100E+02 | 0.000E+00 | 4.730E+03 | 0.000E+00 | 1.580E+05 |
| RH-103M | 0.000E+00 |
| RH-106 | 0.000E+00 |
| AG-110M | 6.990E+06 | 6.470E+06 | 3.840E+06 | 0.000E+00 | 1.270E+07 | 0.000E+00 | 2.640E+09 |
| SB-124 | 3.090E+06 | 5.840E+04 | 1.220E+06 | 7.490E+03 | 0.000E+00 | 2.410E+06 | 8.770E+07 |
| SB-125 | 2.450E+06 | 2.740E+04 | 5.840E+05 | 2.490E+03 | 0.000E+00 | 1.890E+06 | 2.700E+07 |
| TE-125M | 1.950E+06 | 7.080E+05 | 2.620E+05 | 5.880E+05 | 7.950E+06 | 0.000E+00 | 7.810E+06 |

NON-OPERATING COPY
FOR INFORMATION ONLY

ATTACHMENT 7 (CON'T)
GASEOUS EFFLUENTS - PATHWAY DOSE PARAMETERS
RIO, GRASS-GOAT-MILK PATHWAY DOSE FACTORS - ADULT
Units are m2*mrem/yr per μ Ci/sec

| Nuclide | Bone | Liver | Tbody | Thyroid | Kidney | Lung | Gitract |
|---------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| TE-127M | 5.490E+06 | 1.960E+06 | 6.690E+05 | 1.400E+06 | 2.230E+07 | 0.000E+00 | 1.840E+07 |
| TE-127 | 8.060E+01 | 2.890E+01 | 1.740E+01 | 5.970E+01 | 3.280E+02 | 0.000E+00 | 6.360E+03 |
| TE-129M | 7.250E+06 | 2.710E+06 | 1.150E+06 | 2.490E+06 | 3.030E+07 | 0.000E+00 | 3.650E+07 |
| TE-129 | 0.000E+00 |
| TE-131M | 4.330E+04 | 2.120E+04 | 1.770E+04 | 3.360E+04 | 2.150E+05 | 0.000E+00 | 2.100E+06 |
| TE-131 | 0.000E+00 |
| TE-132 | 2.870E+05 | 1.860E+05 | 1.740E+05 | 2.050E+05 | 1.790E+06 | 0.000E+00 | 8.790E+06 |
| I-130 | 5.110E+05 | 1.510E+06 | 5.950E+05 | 1.280E+08 | 2.350E+06 | 0.000E+00 | 1.300E+06 |
| I-131 | 3.560E+08 | 5.090E+08 | 2.920E+08 | 1.670E+11 | 8.720E+08 | 0.000E+00 | 1.340E+08 |
| I-132 | 1.960E-01 | 5.250E-01 | 1.840E-01 | 1.840E+01 | 8.360E-01 | 0.000E+00 | 9.860E-02 |
| I-133 | 4.760E+06 | 8.280E+06 | 2.520E+06 | 1.220E+09 | 1.440E+07 | 0.000E+00 | 7.440E+06 |
| I-134 | 0.000E+00 |
| I-135 | 1.670E+04 | 4.360E+04 | 1.610E+04 | 2.880E+06 | 6.990E+04 | 0.000E+00 | 4.920E+04 |
| CS-134 | 1.700E+10 | 4.030E+10 | 3.300E+10 | 0.000E+00 | 1.310E+10 | 4.330E+09 | 7.060E+08 |
| CS-136 | 7.840E+08 | 3.090E+09 | 2.230E+09 | 0.000E+00 | 1.720E+09 | 2.360E+08 | 3.520E+08 |
| CS-137 | 2.210E+10 | 3.030E+10 | 1.980E+10 | 0.000E+00 | 1.030E+10 | 3.420E+09 | 5.860E+08 |
| CS-138 | 0.000E+00 |
| BA-139 | 5.640E-09 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.000E-08 |
| BA-140 | 3.230E+06 | 4.050E+03 | 2.110E+05 | 0.000E+00 | 1.380E+03 | 2.320E+03 | 6.650E+06 |
| BA-141 | 0.000E+00 |
| BA-142 | 0.000E+00 |
| LA-140 | 5.380E-01 | 2.710E-01 | 1.990E+04 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.990E+04 |
| LA-142 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.640E-09 |
| CE-141 | 5.810E+02 | 3.930E+02 | 4.450E+01 | 0.000E+00 | 1.820E+02 | 0.000E+00 | 1.500E+06 |
| CE-143 | 5.020E+00 | 3.710E+03 | 4.110E-01 | 0.000E+00 | 1.630E+00 | 0.000E+00 | 1.390E+05 |
| CE-144 | 4.290E+04 | 1.790E+04 | 2.300E+03 | 0.000E+00 | 1.060E+04 | 0.000E+00 | 1.450E+07 |
| PR-143 | 1.910E+01 | 7.650E+00 | 9.450E-01 | 0.000E+00 | 4.410E+00 | 0.000E+00 | 8.350E+04 |
| PR-144 | 0.000E+00 |
| ND-147 | 1.130E+01 | 1.310E+01 | 7.820E-01 | 0.000E+00 | 7.640E+00 | 0.000E+00 | 6.270E+04 |
| W-187 | 7.870E+02 | 6.580E+02 | 2.300E+02 | 0.000E+00 | 0.060E+00 | 0.000E+00 | 2.160E+05 |
| NP-239 | 4.390E-01 | 4.320E-02 | 2.380E-02 | 0.000E+00 | 1.350E-01 | 0.000E+00 | 8.860E+03 |

ATTACHMENT 8

GASEOUS EFFLUENTS - EFFECTIVE DOSE FACTORS FOR NOBLE GASES

| Year | Total Body Effective Dose Factor K_{eff} (mrem/yr per $\mu\text{Ci}/\text{m}^3$) | Skin Effective Dose Factor (L+1.1M) (mrem/yr per $\mu\text{Ci}/\text{m}^3$) | Gamma Air Effective Dose Factor M_{eff} (mrad/yr per $\mu\text{Ci}/\text{m}^3$) | Beta Air Effective Dose Factor N_{eff} (mrad/yr per $\mu\text{i}/\text{m}^3$) |
|---------|--|---|---|---|
| 1986 | 3.3E+2 | 7.9E+2 | 3.9E+2 | 1.1E+3 |
| 1987 | 3.4E+2 | 8.1E+2 | 4.0E+2 | 1.1E+3 |
| 1988 | 3.9E+2 | 9.6E+2 | 4.5E+2 | 1.2E+3 |
| Average | 3.5E+2 | 8.5E+2 | 4.1E+2 | 1.1E+3 |

NON-OPERATING COPY
FOR INFORMATION ONLY

ATTACHMENT 9

LOCATIONS OF THE ENVIRONMENTAL SAMPLING
SITES FOR THE CALVERT CLIFFS NUCLEAR
POWER PLANT

| SITE | SAMPLE | SECTOR | DISTANCE * | | DESCRIPTION |
|------|----------------------------|--------|------------|-----|--|
| | | | KM | MI | |
| 1 | DR1 | NW | 0.6 | 0.4 | Onsite, Along Cliffs |
| 2 | DR2 | WNW | 2.7 | 1.7 | Rt. 765, Auto Dump |
| 3 | DR3 | W | 2.3 | 1.4 | Rt. 765, Giovanni's Tavern (Knotty Pine) |
| 4 | DR4 | WSW | 2.0 | 1.2 | Rt. 765, Across From White Sand |
| 5 | DR5 | SW | 2.4 | 1.5 | Rt. 765, at Johns Creek |
| 6 | DR6,A4 | SSW | 2.9 | 1.8 | Rt. 765, at Lusby |
| 7 | DR7,A1, Ib4,Ib5, Ib6 | S | 0.7 | 0.5 | Onsite, Before Entrance to Camp Conoy |
| 8 | DR8,A2 | SSE | 2.5 | 1.5 | Camp Conoy Road, at the Emergency Siren |
| 9 | DR9,A3 | SE | 2.6 | 1.6 | Bay Breeze Road |
| 10 | DR10 | NW | 6.4 | 4.0 | Calvert Beach Rd. & Decatur St. |
| 11 | DR11 | WNW | 6.6 | 4.1 | Dirt Rd, uff Mackall & Parran Roads |
| 12 | DR12 | W | 6.7 | 4.2 | Bowen & Mackall Rds. |
| 13 | DR13 | WSW | 6.1 | 3.8 | Mackall Rd, near Wallville |
| 14 | DR14 | SW | 6.4 | 4.0 | Rodney Point |
| 15 | DR15 | SSW | 6.2 | 3.9 | Mill Bridge & Turner Roads |

* From the Central Point Between the Two Containment Buildings.

NON-OPERATING COPY
FOR INFORMATION ONLY
ATTACHMENT 5 (CON'T)


LOCATIONS OF THE ENVIRONMENTAL SAMPLING
SITES FOR THE CALVERT CLIFFS NUCLEAR
POWER PLANT

| SITE | SAMPLE | SECTOR | DISTANCE * | | DESCRIPTION |
|------|-------------------------------|--------|------------|------|--|
| | | | KM | MI | |
| 16 | DR16 | S | 6.5 | 4.1 | Across from Appeal School |
| 17 | DR17 | SSE | 5.9 | 3.7 | Cove Point & Little Cove Point Roads |
| 18 | DR18 | SE | 7.1 | 4.5 | Cove Point |
| 19 | DR19 | NW | 4.4 | 2.8 | Long Beach |
| 20 | DR20 | NNW | 0.4 | 0.3 | Onsite, near shore |
| 21 | DR21, A5, Ib7, Ib8, Ib9 | WNW | 19.3 | 12.1 | At the Emergency Offsite Facility, off Route 231 |
| 22 | DR22 | S | 12.5 | 7.8 | Solomons Island |
| 23 | DR23 | ENE | 12.6 | 7.9 | Taylor's Island |
| 24 | Wa1, Ia1, Ia2 | NNE&NE | 0.2 | 0.1 | Discharge Vicinity |
| 25 | Wa2 | N | 0.3 | 0.2 | Discharge Area |
| 26 | Wb1 | FSE | 0.6 | 0.4 | Shoreline at Camp Conoy |
| 27 | Ib1, Ib2, Ib3 | SSE | 2.6 | 1.6 | Garden Plot off Bay Breeze Road |
| 28 | Ia4, Ia5 | N/A | N/A | N/A | Patuxent River |
| 29 | Ia3 | E | 0.9 | 0.6 | Camp Conoy |
| 30 | Ia6 | WNW | 10.7 | 6.7 | Kenwood Beach |

* From the Central Point Between the Two Containment Buildings.

NON-OPERATING COPY
FOR INFORMATION ONLY
ATTACHMENT 10

MAP OF ENVIRONMENTAL SAMPLING SITES
(10 MILE RADIUS)



**UPDATE TO PREVIOUS REPORTS
1ST AND 2ND HALF OF 1988**

TABLE 2A - REG GUIDE 1.21

CALVERT CLIFFS NUCLEAR POWER PLANT
EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT
FIRST HALF - 1988

LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

| A. FISSION AND ACTIVATION PRODUCTS | UNITS | 1ST QUARTER | 2ND QUARTER | EST. TOTAL ERROR, % |
|--|--------|-------------|-------------|---------------------|
| 1. Total Release (not including tritium, gases, alpha) | Ci | 7.40E-01 | 9.53E-01 | 2.16E+01 |
| 2. Average diluted concentration during period | uCi/ml | 1.24E-09 | 1.60E-09 | |
| 3. Percent of tech.spec.limit(1) | % | 4.60E-01 | 2.37E+00 | |
| 4. Percent of tech.spec.limit(2) | % | 2.30E-01 | 1.18E+00 | |
| 5. Percent of tech.spec.limit(3) | % | 6.28E-01 | 2.61E-01 | |
| 6. Percent of tech.spec.limit(4) | % | 3.14E-01 | 1.30E-01 | |
| B. TRITIUM | | | | |
| 1. Total Release | Ci | 1.40E+02 | 6.99E+01 | 1.81E+01 |
| 2. Average diluted concentration during period | uCi/ml | 2.35E-07 | 1.17E-07 | |
| 3. Percent of applicable limit(5) | % | 7.83E-03 | 3.90E-03 | |
| C. DISSOLVED AND ENTRAINED GASES | | | | |
| 1. Total Release | Ci | 9.48E-02 | 1.48E-01 | 2.00E+01 |
| 2. Average diluted concentration during period | uCi/ml | 1.59E-10 | 2.49E-10 | |

TABLE 2B - REG GUIDE 1.21

**CALVERT CLIFFS NUCLEAR POWER PLANT
EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT
FIRST HALF - 1988**

LIQUID EFFLUENTS

| NUCLIDES RELEASED | UNITS | CONTINUOUS MODE (1) | | BATCH MODE | |
|-------------------|-------|---------------------|-------------|-------------|-------------|
| | | 1ST QUARTER | 2ND QUARTER | 1ST QUARTER | 2ND QUARTER |
| Beryllium -7 | Ci | 0 | 0 | - | 7.97E-05 |
| Sodium -24 | Ci | 0 | 0 | 1.10E-05 | 1.04E-03 |
| Chromium -51 | Ci | 0 | 0 | 2.69E-05 | 8.10E-02 |
| Manganese -54 | Ci | 0 | 0 | 2.28E-03 | 4.78E-03 |
| Cobalt -57 | Ci | 0 | 0 | 6.17E-05 | 2.03E-04 |
| Cobalt -58 | Ci | 0 | 0 | 9.36E-02 | 3.32E-01 |
| Cobalt -60 | Ci | 0 | 0 | 5.31E-03 | 1.69E-02 |
| Iron -59 | Ci | 0 | 0 | - | 2.16E-04 |
| Strontium -89 | Ci | 0 | 0 | <2.88E-04 | 7.96E-04 |
| Strontium -90 | Ci | 0 | 0 | <4.23E-05 | 2.11E-04 |
| Zirconium -95 | Ci | 0 | 0 | - | 1.23E-02 |
| Niobium -95 | Ci | 0 | 0 | 1.31E-03 | 2.27E-02 |
| Niobium -97 | Ci | 0 | 0 | - | 5.83E-03 |
| Molybdenum -99 | Ci | 0 | 0 | - | 9.60E-05 |
| Technicium -99m | Ci | 0 | 0 | 6.52E-04 | 1.92E-03 |
| Ruthenium -103 | Ci | 0 | 0 | - | 2.86E-03 |
| Silver -108m | Ci | 0 | 0 | - | 1.84E-05 |
| Silver -110m | Ci | 0 | 0 | 1.51E-02 | 4.17E-02 |
| Tin -113 | Ci | 0 | 0 | - | 4.89E-04 |
| Antimony -124 | Ci | 0 | 0 | - | 1.62E-02 |
| Antimony -125 | Ci | 0 | 0 | 4.23E-02 | 8.47E-02 |

TABLE 2B - REG GUIDE 1.21 (Cont.)

CALVERT CLIFFS NUCLEAR POWER PLANT
EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT
FIRST HALF - 1988

LIQUID EFFLUENTS

| NUCLIDES RELEASED | UNITS | CONTINUOUS MODE (1) | | BATCH MODE | |
|-------------------|-------|---------------------|-------------|-------------|-------------|
| | | 1ST QUARTER | 2ND QUARTER | 1ST QUARTER | 2ND QUARTER |
| Tellurium -129 | Ci | 0 | 0 | - | 4.47E-05 |
| Tellurium -132 | Ci | 0 | 0 | 1.07E-05 | 6.64E-04 |
| Iodine -131 | Ci | 0 | 0 | 7.25E-02 | 1.60E-01 |
| Iodine -132 | Ci | 0 | 0 | 2.39E-05 | 1.68E-03 |
| Iodine -133 | Ci | 0 | 0 | 5.47E-03 | 7.63E-03 |
| Iodine -135 | Ci | 0 | 0 | 3.08E-04 | 9.29E-05 |
| Cesium -134 | Ci | 0 | 0 | 1.88E-01 | 5.35E-02 |
| Cesium -136 | Ci | 0 | 0 | 3.19E-03 | 8.74E-04 |
| Cesium -137 | Ci | 0 | 0 | 3.09E-01 | 1.02E-01 |
| Plutonium -140 | Ci | 0 | 0 | 1.99E-04 | 1.28E-04 |
| Cerium -141 | Ci | 0 | 0 | - | 5.74E-04 |
| Total For Period | Ci | 0 | 0 | 7.40E-01 | 9.53E-01 |

TABLE 2A - REG GUIDE 1.21

**CALVERT CLIFFS NUCLEAR POWER PLANT
EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT
SECOND HALF - 1988**

LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

| A. FISSION AND ACTIVATION PRODUCTS | UNITS | 3RD QUARTER | 4TH QUARTER | EST. TOTAL ERROR,% |
|--|--------------|--------------------|--------------------|---------------------------|
| 1. Total Release (not including tritium,gases,alpha) | Ci | 8.62E-01 | 8.96E-02 | 2.16E+01 |
| 2. Average diluted concentration during period | uCi/ml | 1.45E-09 | 1.51E-10 | |
| 3. Percent of tech.spec.limit(1) | % | 6.24E-01 | 2.09E-01 | |
| 4. Percent of tech.spec.limit(2) | % | 3.12E-01 | 1.04E-01 | |
| 5. Percent of tech.spec.limit(3) | % | 8.13E-01 | 4.86E-02 | |
| 6. Percent of tech.spec.limit(4) | % | 4.06E-01 | 2.43E-02 | |
| B. TRITIUM | | | | |
| 1. Total Release | Ci | 1.64E+02 | 2.50E+02 | 1.81E+01 |
| 2. Average diluted concentration during period | uCi/ml | 2.76E-07 | 4.20E-07 | |
| 3. Percent of applicable limit(5) | % | 9.20E-03 | 1.40E-02 | |
| C. DISSOLVED AND ENTRAINED GASES | | | | |
| 1. Total Release | Ci | 7.20E-02 | 5.92E-02 | 2.00E+01 |
| 2. Average diluted concentration during period | uCi/ml | 1.21E-10 | 9.95E-11 | |

TABLE 2B - REG GUIDE 1.21

**CALVERT CLIFFS NUCLEAR POWER PLANT
EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT
SECOND HALF - 1988**

LIQUID EFFLUENTS

| NUCLIDES RELEASED | UNITS | CONTINUOUS MODE | | BATCH MODE | |
|-------------------|-------|-----------------|-------------|-------------|-------------|
| | | 3RD QUARTER | 4TH QUARTER | 3RD QUARTER | 4TH QUARTER |
| Sodium -24 | Ci | (1) | (1) | 1.69E-04 | 1.02E-05 |
| Chromium -51 | Ci | (1) | (1) | 4.36E-03 | (2) |
| Manganese -54 | Ci | (1) | (1) | 1.23E-03 | 5.25E-04 |
| Cobalt -58 | Ci | (1) | (1) | 4.57E-02 | 7.18E-03 |
| Iron -59 | Ci | (1) | (1) | (2) | (2) |
| Cobalt -60 | Ci | (1) | (1) | 7.85E-03 | 3.07E-03 |
| Zinc -65 | Ci | (1) | (1) | (2) | (2) |
| Strontium -89 | Ci | (1) | (1) | 1.80E-03 | 7.99E-04 |
| Strontium -90 | Ci | (1) | (1) | <1.31E-04 | <1.07E-04 |
| Zirconium -95 | Ci | (1) | (1) | 1.71E-03 | 2.55E-03 |
| Niobium -95 | Ci | (1) | (1) | 5.02E-03 | 2.66E-03 |
| Niobium -97 | Ci | (1) | (1) | 1.15E-02 | 1.23E-04 |
| Technicium -99m | Ci | (1) | (1) | 1.02E-03 | 4.22E-05 |
| Ruthenium -103 | Ci | (1) | (1) | (2) | 1.50E-04 |
| Silver -110m | Ci | (1) | (1) | 1.36E-02 | 1.74E-03 |
| Tin -113 | Ci | (1) | (1) | 9.00E-04 | 7.78E-04 |
| Antimony -124 | Ci | (1) | (1) | 1.35E-03 | 2.92E-03 |
| Antimony -125 | Ci | (1) | (1) | 2.73E-02 | 1.53E-02 |
| Iodine -131 | Ci | (1) | (1) | 3.78E-02 | 9.00E-03 |
| Iodine -132 | Ci | (1) | (1) | 7.74E-06 | (2) |

TABLE 2B - REG GUIDE 1.21 (Cont.)

CALVERT CLIFFS NUCLEAR POWER PLANT
EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT
SECOND HALF - 1988

LIQUID EFFLUENTS

| NUCLIDES RELEASED | UNITS | CONTINUOUS MODE | | BATCH MODE | |
|-------------------|-------|-----------------|-------------|-------------|-------------|
| | | 3RD QUARTER | 4TH QUARTER | 3RD QUARTER | 4TH QUARTER |
| Iodine -133 | Ci | (1) | (1) | 1.06E-02 | 1.68E-03 |
| Iodine -135 | Ci | (1) | (1) | 2.67E-04 | (2) |
| Cesium -134 | Ci | (1) | (1) | 1.97E-01 | 9.27E-03 |
| Cesium -136 | Ci | (1) | (1) | 5.58E-04 | (2) |
| Cesium -137 | Ci | (1) | (1) | 4.92E-01 | 2.78E-02 |
| Barium -140 | Ci | (1) | (1) | (2) | 1.72E-05 |
| Cerium -141 | Ci | (1) | (1) | (2) | (2) |
| Cerium -144 | Ci | (1) | (1) | 2.74E-05 | 2.18E-03 |
| Lanthanum -142 | Ci | (1) | (1) | (2) | 1.66E-03 |
| Mercury -203 | Ci | (1) | (1) | (2) | 5.28E-05 |
| Total For Period | Ci | (1) | (1) | 8.62E-01 | 8.96E-02 |