

FEB 27 1990

Docket Nos. 50-334  
50-412

Duquesne Light Company  
ATTN: Mr. J. D. Sieber  
Vice President-Nuclear Group  
P. O. Box 7520  
Shippingport, Pennsylvania 15077

Gentlemen:

Subject: Combined Inspection Report Nos. 50-334/90-03 and 50-412/90-03

This letter refers to the routine safety inspection conducted by Mr. A. L. Della Greca of this office on January 22-26, 1990 at the Beaver Valley Power Station Units 1 and 2 in Shippingport, Pennsylvania. Mr. Della Greca discussed the findings of the inspection with Messrs. T. P. Noonan and W. S. Lacey of your staff at the conclusion of the inspection.

The areas examined during this inspection are described in the NRC Region I Inspection Report which is enclosed with this letter and included a review of your corrective actions for two previously identified issues. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Your corrective actions for one of the two unresolved items reviewed were acceptable. Therefore, that issue is closed. However, your corrective actions regarding the problems experienced with aluminum cables require further management attention and will be reviewed during a future NRC inspection.

No violations were identified during the inspection and no reply to this letter is required. Your cooperation with us in resolving the open issue in a timely manner is appreciated.

Sincerely,

Original Signed By:  
Jack R. Stroenider

Jacque P. Durr, Chief  
Engineering Branch  
Division of Reactor Safety

Enclosure: Inspection Report Nos: 50-334/90-03 and 50-412/90-03

OFFICIAL RECORD COPY

CIR BV 90-03 - 0001.0.0  
02/26/90

9003120559 900227  
PDR ADOCK 05000334  
Q FDC

IE:01 //

FEB 27 1990

Duquesne Light Company

2

cc w/encl:

J. J. Carey, Executive Vice President, Operations  
J. O. Crockett, General Manager, Corporate Nuclear Services  
W. S. Lacey, General Manager, Nuclear Operations  
N. R. Tonet, Manager, Nuclear Engineering  
T. P. Noonan, General Manager, Nuclear Operations  
S. C. Fenner, QA Manager  
K. D. Grada, Manager, Nuclear Safety  
H. R. Caldwell, General Superintendent, Nuclear Operations  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
Commonwealth of Pennsylvania

bcc w/encl:

Region I Docket Room (with concurrences)  
Management Assistant, DRMA (w/o encl)  
C. Cowgill, DRP  
P. Tam, NRR  
M. Conner, SALP Reports Only  
PAO (10) SALP Reports Only  
J. Dyer, EDO

RI:DRS *ADG*  
DellaGreca/rw

2/21/90

*cla*  
RI:DRS  
Anderson

2/22/90

*[Signature]*  
RI:DRS  
Durr

2/27/90

OFFICIAL RECORD COPY

CIR BV 90-03 - 0001.1.0  
02/21/90