

Nuclear

GPU Nuclear Corporation
Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

February 8, 1990

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Mail Station P1-127
Washington, D.C. 20555


Gentlemen:

Subject: Oyster Creek Nuclear Generating Station (OCNGS)
Docket No. 50-219
Detailed Control Room Design Review

The OCNGS Emergency Operating Procedures (EOPs) require the use of the Control Rod Drive (CRD) system as a make-up source to the reactor pressure vessel. While in this mode of operation, the operators are cautioned not to exceed a CRD pump flow of 150 gpm in order to avoid pump runout and trip.

By letter dated July 8, 1988, GPUN identified a Human Engineering Deficiency (HED 3) in that the CRD flow meters do not indicate the range of CRD flow required by the OCNGS EOPs. The identified resolution of the deficiency was to rerange the flow transmitters and indicators during the 13R outage. Further review has shown this to be ineffective for all system configurations and, as such, the flow transmitters and indicators will not be reranged. Monitoring of the CRD pump approach to runout will be accomplished by the use of local CRD pump discharge pressure indicators to be installed in 13R. If there are any questions, please contact M. W. Laggart at (201) 316-7968.

Very truly yours,


E. E. Fitzpatrick
Vice President &
Director, Oyster Creek

EEF/crb(C320477)
(cc's on next page)

2003130338 900208
PDR ADOCK 05000219
F FDC

GPU Nuclear Corporation is a subsidiary of the General Public Utilities Corporation

A003
10

cc: Regional Administrator
Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector
Oyster Creek Nuclear Generating Station

Mr. Alex Dromerick
U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555