Enclosure 6

SCRUBBING OF AEROSOLS BY WATER POOLS UNDER SEVERE ACCIDENT CONDITIONS

by

MATI MERILO

April 9, 1986 Bethesda, MD







OBJECTIVES

1.

- TO DETERMINE THE FRACTION OF FISSION PRODUCT AEROSOL WHICH ARE SCRUBBED FROM A GAS STREAM BY PASSING THROUGH POOLS OF WATER
- TO DEVELOP AND VALIDATE A PREDICTIVE CAPABILITY FOR POOL SCRUBBING (SUPRA) APPLICABLE TO SEVERE ACCIDENT CONDITIONS.

VARIABLES AFFECTING THE SCRUBBING OF AEROSOLS

- 1. INJECTOR GEOMETRY
- SPARGERS/ORIFICES
- DOWNCOMERS

2.

i Se

- HORIZONTAL VENTS
- 2. POOL CHARACTERISTICS
- SUBCODLING
- SUBMERGENCE
- IMPURITIES
- 3. CARRIER GAS
- COMPOSITION
- FLOWRATE
- 4. AEROSOL CHARACTERISTICS

- SIZE
- MORPHOLOGY
- SOLUBILITY



BVR, Mark-II primary and secondary con tainant

EXPERIMENTAL FACILITY

- AEROSOL GENERATION SYSTEM
- . WATER TANK AND INJECTION SYSTEM
- . MEASUREMENT SYSTEM







8.

POOL SUBCOOLING, (°K)



EXPERIMENTAL OBJECTIVES

TO MEASURE :

.

- 1. THE INJECTED MASS. MI
- 2. THE SCRUBBED MASS. Ms
- 3. THE ESCAPED MASS. No

AS A FUNCTION OF THE PARTICLE SIZE AND OTHER PARAMETERS OF THE SYSTEM.

DEFINITION: DECONTAMINATION FACTOR. DF

SUMMARY OF THE PHASE I SCRUBBING TEST MATRIX .

...

PARAMETER	EXPERIMENTAL RANGE		
INJECTION VELOCITY	0.24 - 7.1 m/s		
SUBMERGENCE	0.152 - 1.65 M		
POOL TEMPERATURE	293 - 395 K		
GAS TEMPERATURE ORIFICE DIAMETER	FIXED (1.27 CM)		
INJECTOR ORIENTATION	FIXED (HORIZONTAL)		
CONDENSIBLE/NONCONDENSIBLE RATIO	4.5 - 6.0 (G/cc)		
AFROSOL SIZE (MASS MEDIAN DIAMETER)	0.2 - 3.0 Jum		



SUBMERGENCE AEROSOL MATERIAL			B'	4'	8' Csl	
		Csl	SN	Csl		
FL	20 CFM		X(A)			
	50 CFM	x	X	X	X	
W	100 CFM		X			

(A) AS LOW A FLOW AS IS PRACTICAL

.

PHASE IIIA. SCRUBBING MATRIX



.

1.

INJECTED (----) AND ESCAPED (-----) AEROSOL SIZE DISTRIBUTIONS FOR TEST S41M AS DETERMINED BY THE APS (Mass Concentration Expressed in ng/m³)

ATERIAL CE, FT.		C4 DRI ARRANGE	FICE	LINE SOURCE		
EROSOL N	AIBMERGEN(15 CFM	25 CFM	37 CFM	62 CFM	
*	1.5			X	X	
Csl	5.5	X	X	X	X	
	11	x	x	X	X	
SN	11			X	X	

PHASE II SCRUBBING TEST MATRIX

CONFIGURATION/SPECIES CONSIDERED

- INJECTION CONFIGURATION:
 - ORIFICE TYPE (T-, X-QUENCHER, ETC.)
 - DOWNCOMER
 - · SIDE VENT
- SPECIES:

CONDENSIBLE:	STEAM (H20)
NONCONDENSIBLE:	AIR (A), HYDROGEN (H2), CARBON DIOXIDE
	(CO2) OR HELIUM (HE)
TRACE SPECIES:	ELEMENTAL IODINE (12)
	METHYL IODIDE (CH31)
AEROSOL:	20 SIZE BINS OF SINGLE MATERIAL OR LOG
	NORMAL SIZE DISTRIBUTION
	CONDENSIBLE: NONCONDENSIBLE: TRACE SPECIES: AEROSOL:

POOL CONDITIONS:
 SUBCOOLED
 SATURATED

AEROSOL REMOVAL MECHANISMS IN SUPRA

٠.

UPPER

NECHAMISM	INJECTION	BUBBLE RISE Zome	UPPER
CENTMENTATION		×	×
DEDITION DIFFISION	×	×	×
DI EERS I DPH/DRFS I S		×	×
CONVERTIVE DEPOSITION		×	×
THERMOPHORES IS		×	×
INERTIAL DEPOSITION	•		
- INTERNAL CIRCULATION	×	×	
- JET IMPACTION	×		

MECHANISM







a A

and a second

8-c0



..



SUSPENDED AEROSOL MASS IN CONTAINMENT



r



DECONTAMINATION FACTORS

.

PEACH BOTTON SEQUENCE TC

	STEADY STATE		DECAY			
	SPARGERS	DOWNCOMERS	TOTAL	SPARGERS	DOWNCOMERS	TOTAL
STRUCTURAL C _S 1 T _E 0 ₂ C _c 0H	4.18X10 ⁴ 5858 5753	649 909 1935 853	654 1455 1935 1601	2.17X10 ⁷ 6.37X10 ⁶ 6.24X10 ⁶	2.45X10 ⁵ 3.23X10 ⁵ 5.07X10 ⁵ 4.54X10 ⁵	2.47X10 ⁵ 5.63X10 ⁵ 5.07X10 ⁵ 9.25X10 ⁵
TOTAL	6778	657	687	7.13X10 ⁶	2.50X10 ⁵	2.62X10 ⁵

PEACH BOTTOM STATION BLACKOUT - TOVW

 \bigcirc

10 m

INITIATION	LOSS OF AC POWER
	DIESEL POWER FAILS
4.7 S	REACTOR SCRAMS DC POWER CONTROLS STEAM DRIVEN HPCI & RCIC
21.638 S	BATTERY POWER UNAVAILABLE
30.138 S	START OF CORE UNCOVERY
32,500 S	START OF AEROSOL GENERATION IN VESSEE START OF AEROSOL GENERATION IN VESSEE START
39,420 S	VESSEL FAILURE
39,479 S	OPEN WETWELL VENT AEROSOL TRANSPORT THROUGH DOWNCOMER
216.000 S	STOP CALCULATION
(60 HRS)	

*

in the second second



e e







DECONTAMINATION FACTORS

...

 \sim

PEACH BOTTOM SEQUENCE TOVW

	STEADY STATE			DECAY		
	SPARGERS	DOWNCOMERS	TOTAL	SPARGERS	DOWNCOMERS	TOTAL
STRUCTURAL CSI TEO2 CoOH	1.63X10 ⁵ 6.17X10 ⁵ 3.67X10 ⁵	207 2585 157 3242	208 3109 · 197 . 3323	3.23X10 ⁸ 3.85X10 ⁸ 6.68X10 ⁸	5.55×10 ⁴ 2.71×10 ⁵ 36,800 3.01×10 ⁵	5.58x10 ⁴ 3.27x10 ⁵ 36.800 3.09x10 ⁵
TOTAL	3.04X10 ⁵	233	235	1.49X10 ⁸	6.5×10 ⁴	6.68×10 ⁵

200 et

_{अ.स. स}र्थ के है

SUMMARY AND CONCLUSIONS

a si

-

- AND SIDE VENT GEOMETRIES, WATER POOLS ARE EFFECTIVE IN SCRUBBING AEROSOLS
- DOWNCOMER AND MULTIPLE ORIFICE EXPERIMENTS WILL
 BE COMPLETED THIS SPRING WITH SIMILAR RESULTS
 EXPECTED
- BEST-ESTIMATE SCENARIO CALCULATIONS INDICATE: EXTREMELY HIGH FISSION PRODUCT RETENTION IN THE PEACH BOTTOM SUPPRESSION POOL

17+ 12:50 d

BWR SUPPRESSION POOLS PROVIDE AN EFFECTIVE BARRIER TO FISSION PRODUCTS

Red.

Enclosure 7

ABB PRESENTATION TO THE USNRC STAFF ON THE SWEDISH CONTAINMENT VENTING IMPLEMENTATION PROGRAM

APRIL 25, 1989



FILTRA - MVSS

12.1

ARR Atom

. S

MULTI VENTURI SCRUBBER SYSTEM

KE 89-04-21



FILTRA - MVSS BWR FILTERED VENTING FLOW CAPACITY

• MANUAL VENTING DURING WATER FILLING OF CONTAINMENT. FLOW RATE 0,1 - 10 KG/S

• MANUAL VENTING OF DECAY POWER. FLOW RATE 6 KG/S

• AUTOMATIC VENTING DURING WATER FILLING OF CONTAINMENT. FLOW RATE 12 KG/S

• AUTOMATIC VENTING WITHOUT ANY MANUAL ACTIONS. FLOW RATE 12 KG/S





FILTRA - MVSS PWR FILTERED VENTING FLOW CAPACITY

O AUTOMATIC VENTING WITHOUT ANY MANUAL ACTIONS. FLOW RATE 13 KG/S



ARR Atom
FILTRA - MVSS

DESIGN PARAMETERS (BWR AND PWR)

O GAS MASS FLOW RATE 0,1 - 13 KG/S

o GAS COMPOSITION STEAM, N₂, H₂, O₂

o GAS TEMPERATURE 70 - 150 °C

o RUPTURE DISC 0,5 - 0,6 MPA

OPENING PRESSURE

• EARTHQUAKE, 0,1 GROUND ACCELERATION

0,15 G



ABB Atom

FILTRA - MVSS DESIGN PARAMETERS







ABB Atom

ABEA HITE INTE BEINEM

FILTRA - MVSS MAIN DATA

FILTER VESSEL DATA	BWR	PWR
DESIGN PRESSURE	0,3 MPA + HYDR	0,4 MPA + HYDR
TOTAL VOLUME	250 M ³	400 M ³
WATER VOLUME	180M ³	270 M ³
INSIDE DIAMETER	7 M	7 M
GRAVEL BED VOLUME	8 M ³	9 M ³

いたいとうないないであり

たいないないの



FILTRA - MVSS SYSTEM





FILTRA - MVSS SERVICE FUNCTIONS

O WATER FILLING AND DRAINAGE

O CHEMICAL DOSING

O WATER HEATING / COOLING

O WATER SAMPLING

O NITROGEN BLANKETING











SECTION A.A











ABB Atom







" **深**





VENTURICOLLECTION

OBJECT: TRANSFER OF PARTICLES AND SOLVABLE GASES FROM GAS TO LIQUID.





AREA WITH VELOCITY DIFFERENCE BETWEEN GAS AND DROPS.

COLLECTION EFFICIENCY FOR A GIVEN PARTICLE DEPENDS LARGELY ON AP OVER THE VENTURI.







COLLECTION PRINCIPLES

INERTIAL IMPACTION

INTERCEPTION DIFFUSION ELECTROSTATIC FORCES

このでいる 後期になる ため

de la

















SWEDISH FILTRA - MVSS VERIFICATION.

- CONDITIONS
- METHODS
- RESULTS





SWEDISH FILLING ...

CONDITIONS:

	PWR	BWR
BELIEF GAS FLOW, kg/s :	0,1/13	0,1/12
• TEMP, °C :	150	70/150
• AEROSOL DISTRIBUTION AMMD, μm σ _g	LOG - N 3 2	ORMAL
DECON. FACTORS AEROSOLS AND IODINE DESIGN GUARANTEE	: 1500 : 500	500 100

ABB ATOM – FIäkt



SWEDISH HILIHA - MIVSS VERIFICATION.

METHODS:

- FULL-SIZE SEGMENT.
- PROTOTYPICAL GEOMETRICS.
- PROTOTYPICAL FLOW CONDITIONS.
- PROTOTYPICAL AEROSOL.
- PROTOTYPICAL EVAPORATION.

- ANALYZE FULL-SIZE CONDITIONS (IF NOT GIVEN).

- REALIZE RELEVANT CONDITIONS IN LAB.
- MAKE LAB EXPERIMENT.

ABB ATOM - Flä



VERIFICATION.

METHODS:

ITEMS

1 AEROSOL GENERATION.
2 FULL SIZE SEGMENT.
3 FLOW MODELLING.
4 AEROSOL COLLECTION EXPTS.
5 EFFECT OF EVAPORATION.
6 SCRUBBER LIQUID REENTRAINMENT.
7 IODINE COLLECTION.







ABB ATOM - Fläkt













INPUT GEOMETRY INLET PRESSURE GAS COMFOSITION

SWEDISH FILIKA - WIYOU

VERIFICATION

CALCULATIONS: ~ 6.TWO-PHASE FLOW EQUATIONS / CONSTITUTIVE EQN.

<u>OUTPUT:</u> VENTURI GAS AND LIQUID FLOWS: M_L, M_G PRESSURES

FLOW MODELLING. RESULT OF EXPERIMENTS IN FULL-SCALE PROTOTYPICAL ARRANGEMENT.



VERIFICATION.

AEROSOL COLLECTION EXPERI-MENTS 2

RESULTS

- → Worst case acc. to calculations.
- Lowest possible pool (1 m submergence).

Measured decontamination factor:

Geometry #	PWR	BWR
	2701	889
1	1846	687
2	3194	776
3	2462	762
4	2402	835
5	2410	

NO negative effects of load transients or parallel nozzle operation.

ABB ATOM – Flä

EFFECT OF SCRUBBER LIQUID EVAPORATION

VERIFICATION

CHANGE IN GAS MOISTURE CONTENT

REAL PWR CASE : 4% REPRODUCED IN LAB : 9%



ABB ATOM - Fläkt



VERIFICATION.

SCRUBBER LIQUID RE-ENTRAINMENT

いいので、たい

X

112.212

What is contribution due to prolonged bubbling of hot, clean gas through system?

	Lab	Long-term ⁻ case
Scrubber liquid		
Solute conc., GIL	2	3
Evaporation (change in gas moisture)	2%	<2%

Measured emission of scrubber liquid solute.

5. x 10-11 kg/kg gas

~ 1 PPM of scrubber activity released during 10 day episode.

ABB ATOM - Flä



SWEDISH FILTRA - MVSS VERIFICATION.

high

IODINE ABSORBTION

Pate constant

even higher

 $I_2 + 2S_2O_3^{2} \rightarrow S_4O_6^{2} + 2I$

 $l_2 + l^- \rightarrow l_3^-$

 $I_3 + 2S_2O_3 \rightarrow S_2O_6^{-2} + 3I^-$

high

- System with infinite solubility.
- Rate of mass transfer given by physical processes.
- Then, gas absorbtion theory gives that:

$$DF = EXP(k_{G}A R T/Q_{G})$$

Add mass transfer in pool.






SWEDISH FILTRA - MVSS VERIFICATION

IODINE ABSORBTION. EXAMPLE OF ROOM TEMPERATURE ABSORBTION RESULTS





VERIFICATION.

 $\begin{aligned} & \text{ODINE ABSORBTION} \\ & \text{DF}_{tot} = \text{DF}(\text{VENTURI}) \\ & \text{X DF}(\text{RISE PIPE}) \\ & \text{X DF}(\text{POOL}) \end{aligned}$

ABB ATOM - Fläkt

DF_{tot} >

依

Conservative estimates of Swedish cases: BWR PWR 600 3500



.



in the second

SWEDISH FILTRA - MVSS VERIFICATION.

AEROSOL COLLECTION EXPERIMENTS

TEST CONDITIONS

inlet:	AA11	AA12
Gas flow rate, m ³ /s	0.090	0.093
Gas temperature	113	129
Pressure, kPa	153	150
Volume steam fraction	0.012	0.407
Saturation temperature, °C	17	87
Outlet:		
Gas flow rate, m ³ /s	0.096	0.061
Pool temperature, °C	23	32
Submergence of top of MVSS, m	1.67	1.77
Pressure, kPa	106	105
Volume steam fraction	0.024	0.044
DECONTAMINATION FACTOR	RS	
DF FROM AEROSOL CONC. (Impactor measurements)	ĂA11	AA12
Cs Mn I	25 000 1 500 19 000	31 000 3 800 55 000
ABB ATOM – Fläkt		

Enclosure 8

NUREG-0800 (Formerly NUREG-75/067)

and the second s



No. of Street, or other

Q

.

U.S. NUCLEAR REGULATORY COMMISSION STANDARD REVIEW PLAN OFFICE OF NUCLEAR REACTOR REGULATION

> Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants

Section No. <u>6.5.5</u> Revision No. <u>0</u>

Appendix No. _____ Revision No. _____

Branch Tech. Position _____ Revision No. _____

Date Issued December 1988

	FILING INSTRUCTIONS			
PAGES TO B	EREMOVED	NEW PAGES TO BE IN	ISERTED	
PAGENUMBER	DATE	PAGENUMBER	DATE	
None		Section 6.5.5 (New) 6.5.5-1 Rev. O Thru 6.5.5-5	December 1988	
	The U.S. Nuclear Regu Standard Review Plan, Office of Nuclear Reac for sale by the Nationa Service, Springfield, V	Natory Commission's NUREG-0800, propered by the stor Regulation, is available of Technical Information A 22161.		



13

U.S. NUCLEAR REGULATORY COMMISSION STANDARD REVIEW PLAN OFFICE OF NUCLEAR REACTOR REGULATION

6.5.5 PRESSURE SUPPRESSION POOL AS A FISSION PRODUCT CLEANUP SYSTEM

REVIEW RESPONSIBILITIES

Primary - Chemical Engineering Branch

Secondary - Plant Systems Branch Radiation Protection Branch

1. AREAS OF REVIEW

The pressure suppression pool is reviewed under this plan only when the applicant claims credit for fission product scrubbing and retention by the suppression pool. The pressure suppression pool and the drywell, when considered as a barrier to the release of fission products, are reviewed to assess the degree to which fission products released during postulated reactor accidents will be retained in the suppression pool. Leakage paths that allow fission products to bypass the pool are identified and reviewed, and the maximum fractional bypass leakage is obtained, for use in the evaluation of radiological dose consequences.

1. Fission Product Control Requirements

Sections of the applicant's safety analysis report (SAR) related to accident analyses, accident dose calculations, and fission product control are reviewed to establish whether or not fission product scrubbing of the drywell or reactor compartment atmosphere is claimed or required for mitigation of radiological consequences following a postulated accident.

2. Design Bases

The design bases for the fission product removal function of the suppression pool and the drywell or reactor compartment are reviewed to verify that they are consistent with the assumptions made in the accident evaluations of SAR Chapter 15.

Rev. 0 - December 1988

USNRC STANDARD REVIEW PLAN

Standard review plans are propered for the guidance of the Office of Nuclear Reactor Regulation staff responsible for the review of applications to construct and operate nuclear power plants. These documents are made available to the public as part of the Commission's policy to inform the nuclear industry and the general public of regulatory procedures and policies. Standard review plans are not substitutes for regulatory guides or the Commission's regulations and compliance with them is not required. The standard review plan sections are keyed to the Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants. Not all sections of the Standard Format have a corresponding review plan.

Published standard review plans will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience.

Comments and suggestions for improvement will be considered and should be sent to the U.S. Nuclear Regulatory Commission, Office of Nuclear Reactor Regulation, Washington, D.C. 20055. The methodology used in this SRP section is not intended for containment venting evaluation. Containment venting will be considered in the evaluation of pressure suppression pools as fission product cleanup systems when the Commission approves the final guidance on containment venting.

3. System Design

The information on the design of the suppression pool is reviewed to familiarize the reviewer with the expected temperature histories, depth of fission product entry expected during postulated accidents, and potential leakage paths through drywell penetrations.

4. Testing and Technical Specifications

The details of the applicant's proposed preoperational tests and, at the operating license stage, the surveillance requirements are reviewed to ensure that the pool depth and amount of leakage bypassing the pool are maintained consistent with the assumptions used in assessing the pool's effectiveness in fission product cleanup.

11. ACCEPTANCE CRITERIA

.

The acceptance criteria for the fission product cleanup function of the suppression pool are based on the relevant requirements of the following regulations:

- A. General Design Criterion 41 (Ref. 1) as it relates to the control of fission products following postulated accidents.
- B. General Design Criterion 42 (Ref. 2) as it relates to the periodic inspections of engineered safety features.
- C. General Design Criterion 43 (Ref. 3) as it relates to the periodic functional testing of engineered safety features.

Where it can be shown to be in compliance with these criteria, the suppression pool may be given appropriate credit for fission product scrubbing and retention (except for noble gases, for which no pool retention is allowed) in the staff's evaluation of the radiological consequences of design-basis accidents. Other assumptions concerning the release of radioactivity are to be taken from Regulatory Guide 1.3 (Ref. 4), except for Position C.1.f., which this SRP section replaces.

Specific criteria that must be met to receive credit include:

- The drywell and its penetrations must be designed to ensure that, even with a single active failure, all releases from the reactor core must pass into the suppression pool, except for small bypass leakage.
- 2. The bypass leakage assumed for purposes of evaluating fission product retention must be no less than that accepted in the review under SRP Section 6.2.1.1.C, and must be demonstrated in periodic tests by the license technical specifications also reviewed under that section.

6.5.5-2

Rev. 0 - December 1988

3. For plants that have already received a construction permit, the iodine retention calculated using this section must not be used to justify removal of the standby gas treatment or other filtered exhaust system from status as engineered safety features, and any change in plant design, proposed testing, surveillance or maintenance must be supported by considerations of lowered operator dose and other projected benefits. For such plants, the charcoal filters must be at least maintained to the minimum level of Table 2 in Regulatory Guide 1.52 (Ref. 5), Revision 2.

Acceptable methods for computing fission product retention by the suppression pool are given in subsection III, "REVIEW PROCEDURES."

While granting credit for suppression pool scrubbing in the calculations of accident doses, the acceptance criteria of containment leakage in SRP Section 6.2.1.1.C and the acceptance criteria of the engineered safety feature atmosphere cleanup systems in SRP Section 6.5.1 should still be met.

111. REVIEW PROCEDURES

....

1

1

The reviewer selects and emphasizes specific aspects of this SRP section as are appropriate for a particular plant. The judgment on which areas need to be given attention and emphasis in the review is based on a determination of whether the material presented is similar to that recently reviewed on other plants and whether items of special safety significance are involved.

The first step in the review is to determine whether or not the suppression pool is to be used for mitigating radiological consequences. If no credit is claimed for fission product removal in the accident analyses, no further review is required under this SRP section.

If the suppression pool is intended as an engineered safety feature for mitigation of radiological doses, then the reviewer estimates its effectiveness in removing fission products from fluids expelled from the drywell or directly from the pressure vessel through the depressurization system.

1. Pool Decontamination Factor

The decontamination factor (DF) of the pool is defined as the ratio of the amount of a contaminant entering the pool to the amount leaving. Decontamination factors for each fission product form as functions of time can be calculated by the SPARC code (Ref. 6). An applicant may use the SPARC code or other methods to calculate the retention of fission products within the pool, provided that these methods are described in the SAR adequately to permit review. If the time-integrated DF values claimed by the applicant for removal of particulates and elemental iodine are 10 or less for a Mark II or a Mark III containment, or are 5 or less for a Mark I containment, the applicant's values may be accepted without any need to perform calculations (Refs. 7 and 8). A DF value of one (no retention) should be used for noble gases and for organic iodides. The applicant should provide justification for any DF values greater than those given above.

If the SPARC code is used for the calculation of fission product decontamination, the review should be coordinated with the branch that is responsible for establishing the input parameters for the calculations.

. Pool Bypass Fraction

The fraction of the drywell atmosphere bypassing the suppression pool by leaking through drywell penetrations is obtained as a product of the review under SRP Section 6.2.1.1.C. If B is the bypass fraction and DF is the time-integrated pool decontamination factor, then the overall decontamination, D, to be used for accident dose calculations, may be taken as:

 $D = \frac{DF}{1 + B(DF-1)}$

The reviewer should clearly distinguish that fraction of B, which may be further treated by the standby gas treatment system, from that fraction of B which also bypasses the secondary containment building.

Other Containment Atmosphere Cleanup Systems

Drywell or containment spray systems for which fission product cleanup credit is claimed are reviewed under SRP Section 6.5.2, and credit for both suppression pool and spray cleanup can be given as a result of the separate reviews.

4. Technical Specifications

The technical specifications are reviewed to ensure that they require periodic inspection to confirm suppression pool depth and surveillance tests to confirm drywell leak tightness, consistent with the bypass fraction used in computing the overall decontamination.

IV. EVALUATION FINDINGS

The reviewer verifies that sufficient information has been provided by the applicant and that the review and any calculations support conclusions of the following type, to be included in the staff's safety evaluation report:

The staff has reviewed the fission product scrubbing function of the pressure suppression pool and finds that the pool will reduce the fission product content of the steam-gas mixture flowing through the pool following accidents that blow down through the suppression pool. The staff estimates that the pool will decontaminate the flow by a factor for molecular iodine vapor and by a factor of for partiof culate fission products. No significant decontamination of noble gases and organic iodides will occur in the pool. The system is largely passive in nature, and the active components are suitably redundant so that its fission product attenuation function can be accomplished assuming a single failure. The applicant's proposed program for preoperational and surveillance tests will ensure a continued state of readiness, and that bypass of the pool is unlikely to exceed the assumptions used in the dose assessments.

The staff concludes that the pressure suppression pool as a fission product cleanup system is acceptable and meets the requirements of General Design Criterion 41 with respect to the iodine removal function following a postulated loss-of-coolant accident, General Design Criterion 42 with respect to the capability for periodic

Rev. 0 - December 1988

2.

inspection of the system, and General Design Criterion 43 with respect to the capability for periodic testing of the system.

V. IMPLEMENTATION

The following guidance is provided to applicants and licensees about the staff's plans for using this SRP section.

Except in those cases in which the applicant proposes an acceptable alternative method for complying with the specified portions of the Commission's regulations, the methods described herein are to be used by the staff in its evaluation of conformance with Commission regulations.

Implementation of the acceptance criteria of subsection II and the review procedures in subsection III is as follows:

- (1) Operating plants and applicants for operating licenses pending at the date of issue of this SRP section need not comply with the provisions of this SRP section, but may do so voluntarily. ~.
- (2) Future applicants will be reviewed according to the provisions of this SRP section.

VI. REFERENCES

* 20

- 1. 10 CFR Part 50, Appendix A, General Design Criterion 41, "Containment Atmosphere Cleanup."
- 10 CFR Part 50, Appendix A, General Design Criterion 42, "Inspection of Containment Atmosphere Cleanup Systems."
- 10 CFR Part 50, Appendix A, General Design Criterion 43, "Testing of Containment Atmosphere Cleanup Systems."
- 4. U.S. Nuclear Regulatory Commission, Regulatory Guide 1.3, "Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss-of-Coolant Accident for Boiling Water Reactors."
- 5. U.S. Nuclear Regulatory Commission, Regulatory Guide 1.52, "Design, Testing, and Maintenance Criteria for Postaccident Engineered-Safety-Featured Atmosphere Cleanup System Air Filtration and Adsorption Units of Light-Water-Cooled Nuclear Power Plants."
- P. C. Owczarski, R. I. Shreck, and A. K. Postma, "Technical Bases and Users Manual for the Prototype of a Suppression Pool Aerosol Removal Code (SPARC)," U.S. Nuclear Regulatory Commission Report, NUREG/CR-3317, 1985.
- P. C. Owczarkski and W. K. Winegardner, "Capture of Iodine in Suppression Pools," 19th DOE/NRC Nuclear Air Cleaning Conference, Seattle, 1986.
- R. S. Denning et al., "Radionuclide Release Calculations for Selected Severe Accident Scenarios," U.S. Nuclear Regulatory Commission Report, NUREG/CR-4624, Volume 1, July 1986.

6.5.5-5

Rev. 0 - December 1988

	NUREC-080	NUREC-0800	
1. 3207 BIBLIOGRAPHIC DATA PREET	Section 6	Section 6.5.5, Rov. U	
INSTAUCTIONS ON THE REVERSE			
Standard Review Plan for the Review of Safety Analysis			
Reports for Nuclear Power Plants, LAR Edition,			
evision 0 to SAP Section 6.2, "Pressure Suppression :	S A DATE REPORT COMPLETED		
Fission Product Cleanup System"	Tierember	1988	
NUT HOR IL:	December	DATE REPORT ISSUED	
	MONTH	TEAN	
	January	1989	
SET DAMING DEGANIZATION NAME AND MAILING ADDRESS INTO TO COM	S PROJECT TASE MO	AE UNIT NUMBER	
Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D.C. 20555	5 FIG OR GRANT NUM	a 1*	
A STATE AND MANY AND MANY AND AND MANY AND ADDRESS (IMPART IN CASE)	THE TYPE OF REPORT		
PORSONING ONCANIESTION MADE AND DESCRIPTION OF THE POST OF THE POS			
	SRP Sectio	n (Guide)	
Same as above	. PERIOD COVERED		
This section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro water reactors.	bry guidance by oduct cleanup s	giving credit to systems in boiling	
This section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro water reactors.	bry guidance by bduct cleanup s	giving credit to systems in boiling	
This section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro water reactors.	ory guidance by oduct cleanup #	giving credit to systems in boiling	
This section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro water reactors.	ory guidance by oduct cleanup a	giving credit to systems in boiling	
This section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro water reactors.	ory guidance by oduct cleanup s	giving credit to systems in boiling	
This section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro water reactors.	bry guidance by oduct cleanup a	giving credit to systems in boiling	
This section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro water reactors.	bry guidance by oduct cleanup a	giving credit to hystems in boiling	
This section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro water reactors.	bry guidance by oduct cleanup a	giving credit to systems in boiling	
This section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro water reactors.	bry guidance by oduct cleanup a	giving credit to systems in boiling	
This section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro- water reactors.	bry guidance by	giving credit to systems in boiling " availablui" " statute " Unlimited " security classifi " unclassifi	
<pre>Rev. 0 to section clair, recoord connection dealers This section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro water reactors.</pre>	ory guidance by oduct cleanup #	ystems in boiling	
<pre>Rev. 0 to section clair, recoord connection dealers and the section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro water reactors.</pre>	bry guidance by	Unlimited "States in boiling "Availablut" Unlimited "States and Unlimited "The peri- Unclassifi "The peri- Unclassifi "The peri- Unclassifi	
This section resolved an inconsistency in NRC regulate pressure suppression pools as post-accident fission pro- water reactors.	ory guidance by oduct cleanup a	"giving credit to systems in boiling ""gratuat" Unlimited "security classifi (Tas aport unclassifi (Tas aport unclassifi (Tas aport) unclassifi	
Rev. 0 to section c.s.s. Proceeded contraction of the section resolved an inconsistency in NRC regulated pressure suppression pools as post-accident fission provater reactors. * Bocument and Vist -: strepontolicitations Standard Review Plan Pressure Suppression Pool Fission Product Cleanup • Environmentorie subto Taxet	bry guidance by	Unlimited "The paper Unlimited "The paper Unclassifi The paper Unclassifi	

Enclosure 9

NUREG/CR-4624 BMI-2139 Vol. 1

Radionuclide Release Calculations for Selected Severe Accident Scenarios

BWR, Mark I Design

.

Prepared by R. S. Denning, J. A. Gieseke, P. Cybulskis, K. W. Lee, H. Jordan, L. A. Curtis, R. F. Kelly, V. Kogan, P. M. Schumacher

5

Battelle's Columbus Division

Prepared for U.S. Nuclear Regulatory Commission

2607070706 2610

surprising and would not have been expected a priori. The high releases appear to be due to the coincidence of high debris temperatures and high gas generation rates. The other cases involved as high or higher temperatures and comparable or higher gas release rates. In the other cases, however, the temperatures at the time of peak gas generation were lower than in the base case. Peak gas generation is always predicted immediately after zirconium burnout and is the result of carbon oxidation by carbon dioxide.

The tellurium, strontium, and barium releases are high in all the cases considered and the differences between the cases do not appear to be particularly significant. The differences in the releases of the lanthanum and cerium groups confirm the sensitivity of the releases of the refractory species to the temperature and gas sparging history of the debris. The variations among these cases are believed to be representative of the uncertainties associated with such predictions.

The present sensitivity study was limited to a single scenario and, for reasons of consistency with other parts of the analysis, did not include variations in the initial temperature and composition of the debris. The latter could have greater influences on the predicted results.

6.3 Suppression Pool Decontamination

7<u>8</u> 10 The environmental fission product releases for a number of core meltdown accident sequences for the Peach Bottom Mark I BWR design have been assessed to serve as input to the forthcoming NRC risk reference document (NUREG-1150). A key factor in the Peach Bottom analyses is the evaluation of fission product scrubbing by the suppression pool; the latter was assessed by means of the SPARC computer code. In order to help quantify the uncertainties associated with the overall source term predictions, a limited set of sensitivity calculations has been performed with the SPARC code itself. These calculations were based on an ATWS scenario which involved core melting in an intact containment and assumed successful containment venting as the containment pressure was predicted to increase above the design level. The specific calculations performed and the results obtained are discussed below.

The accident scenario, including thermal hydraulics and fission product source terms to the containment, were based on the TC3 scenario previously considered. The variations considered in the SPARC sensitivity study were limited to changes in some of the input variables and the fixing or deactivation of some of the aerosol removal mechanisms. The specific cases considered are described below.

2.

- 1. The base case scenario is identical to the reference TC3 calculation except that the soluble fission product fraction was fixed at 50 percent. This was done to maintain consistency between the several runs of the sensitivity study. In the base case, the bubble size was taken as 0.75 cm in diameter, with an aspect ratio of 3:1. The centrifugal particle removal model was activated. For the flow through the spargers (in-vessel releases) a pool submergence of 12 ft was utilized; for the flow through the downcomers (ex-vessel releases) a submergence of 4 ft was assumed. Since SPARC does not permit the redefinition of the effective bubble size, the above bubble size was utilized for the entire sequence.
- 2. For the case intended to represent minimum pool scrubbing, the bubble size was taken to be 1.5 cm in diameter, with an aspect ratio of 1:1. (While the foregoing combination will indeed tend to reduce the calculated particle removal from the bubble, it may not be totally self-consistent insofar as the larger bubble would tend to be less spherical than the base case.) The soluble fraction was assumed to be zero, and the centrifugal circulation removal model was turned off for this case.
- 2a. Since the above case aimed at minimizing the pool decontamination factor was not totally self consistent, it was repeated with an aspect ratio of 3:1.
- 3. In the case intended to maximize particle removal by the suppression pool, the bubble size was taken to be 0.375 cm in diameter, with an aspect ratio of 6:1. The solubility factor was set at 100 percent, and centrifugal removal was activated.

The foregoing base case bubble size and assumed variation of a factor of two about the nominal value are believed to be representative of flows through the spargers. They may not be representative of the bubble sizes for flows through the Mark I downcomers. In order to assess the influence on predicted aerosol scrubbing of possibly much larger bubbles which could be encountered in downcomer flows, several additional cases were evaluated.

- 4. The case of very large bubbles was represented by a bubble diameter of 10 cm and an aspect ratio of 1:1. The solubility factor was again fixed at 50 percent, and the centrifugal removal mechanism was activated.
- 4A. A repeat of the above large bubble case except for the use of a more realistic aspect ratio of 6:1 for the large bubble size being considered.
- 5. As a further variation on the effect of bubble size, a case with a 1.5 cm bubble diameter, an aspect ratio of 3:1, zero particle solubility, and nominal centrifugal particle removal was evaluated.
- 5A. The above intermediate bubble size case was repeated assuming 50 percent solubility of the particles.

The time dependent aerosol mass flow into the suppression pool considered is illustrated in Figure 6.1; (average particle size as a function of time is given in Figure 6.2.). The mass flow at about 100 minutes comes from in-vessel and enters the pool through the spargers. The flow occurring after about 200 minutes is associated with the ex-vessel release of fission products and enters the pool through the downcomers. The later releases have been found to dominate the predicted consequences for the Peach Bottom design.

Ine predicted decontamination factors for the base case are illustrated in Figure 6.3. The overall decontamination factor for this case, defined as the mass of aerosol entering the pool divided by the mass of aerosol leaving the pool over the entire accident period, was calculated to be approximately 284. It is clear from the figure that the predicted decontamination factors for the flow through the spargers are much higher than those for the downcomer flows. The decontamination factors for the flow through the downcomers are considerably lower, but are still high enough in this case to provide substantial reduction in environmental source terms. The results for the minimum pool scrubbing case (Case 2) are illustrated in Figure 6.4. The overall decontamination factor for this case was approximately 3.4. This value is much lower than typically assessed and may



Tr.



1

CASE 1 DECONTAMINATION FACTORS



FIGURE 6.3. BASE CASE DECONTAMINATION FACTORS

CASE 2 DECONTAMINATION FACTORS



1

Calle Row

indeed represent an extreme case. Changing the aspect ratio from 1:1 to 3:1 with the other parameters the same (Case 2A) had a perceptible but negligible effect on the overall decontamination factor, as illustrated in Figure 6.5.

The high pool scrubbing case (Case 3) is illustrated in Figure 6.6; the overall decontamination factor for this case was about 61,300. For the conditions assumed here the pool is extremely effective for both the in-vessel as well as ex-vessel releases. The decontamination factor for both flow paths is seen to be limited at times to the hard-wired maximum of 100,000.

The calculated results for the very large bubble case (Case 4) are illustrated in Figure 6.7; the overall decontamination factor for this case is about 3.8. The dependence on bubble size is quite substantial. A repeat of this case except for a change to a more realistic aspect ratio of 6:1 for large bubbles (Case 4A, Figure 6.8) produced an overall decontamination factor of 43.

Figure 6.9 illustrates the predicted results for an intermediate (1.5 cm) bubble size, aspect ratio of 3:1, zero solubility, but including the centrifugal particle removal mechanism (Case 5). The overall decontamination factor for this case was predicted to be about 15. The predicted decontamination factors for the sparger flow are once again seen to be quite high, but are considerably lower for the downcomer flow. An additional case (Case 5A, Figure 6.10) with the solubility factor at 50 percent produced an overall decontamination factor of 71.

Table 6-4 summarizes the overall decontamination factors found in this study. The range of overall decontamination factor predicted in this study is perhaps greater than might have been expected. This is particularly true if one considers the fact that the aerosol particle size was not varied. The lowest decontamination factors observed are associated with flow through the Mark I downcomers. Comparison of the results for Cases 2A, 5, and 5A illustrate the effects of particle solubility and the centrifugal particle removal mechanisms. While Cases 2 and 2A indicate little effect of bubble aspect ratio under pessimistic scrubbing conditions, the results for Cases 4 and 4A indicate a significant effect of the aspect ratio for very large bubble sizes.

The results of the present sensitivity study, based on fixed source terms and accident thermal hydraulics, but considering possible uncertainties



DECONTAMINATION FACTOR

.

14. 11

Į.

CASE 3 DECONTAMINATION FACTORS

..



CASE 4 DECONTAMINATION FACTORS



CASE 4A DECONTAMINATION FACTORS

..



FIGURE 6.8. DECONTAMINATION FACTORS FOR LARGE ELLIPTICAL BUBBLES

CASE 5 DECONTAMINATION FACTORS



6-19

200 A

1.0

3

CASE 5A DECONTAMINATION FACTORS

.4



1

FIGURE 6.10. DECONTAMINATION FACTORS FOR INTERMEDIATE ELLIPTICAL BUBBLES INCLUDING CIRCULATION AND SOLUBLE PARTICLES 6-20

9.6

Case	Bubble Size (cm)	Aspect Ratio	Solubility (X)	Circulation (on/off)	Decontamination Factor
1	0.75	3:1	50	On	284
2	1.5	1:1	0	Off	3.4
2A	1.5	3:1	0	Off	2.4
3	0.375	6:1	100	On	£1 200
4	10.0	1:1	50	On	01,300
4A	10.0	6:1	50	00	3.8
5	1.5	3:1	0	00	43
5A	1.5	3:1	50	On	15 71

TABLE 6.4. SUMMARY OF OVERALL DECONTAMINATION FACTORS

in the SPARC input and modeling parameters indicate a high degree of sensitivity. This sensitivity is particularly noticeable for the ex-vessel releases which reach the suppression pool through the Mark I downcomers. While the base case decontamination factors are quite substantial, those for some of the bounding cases are quite low.

1. 2 p. 16 . 3 % .