

3/4.2 POWER DISTRIBUTION LIMITS

3/4.2.1 AVERAGE PLANAR LINEAR HEAT GENERATION RATE

LIMITING CONDITION FOR OPERATION

3.2.1 All AVERAGE PLANAR LINEAR HEAT GENERATION RATES (APLHGRs) for each type of fuel as a function of AVERAGE PLANAR EXPOSURE shall not exceed the limits shown in ~~Figures 3.2.1-1, 3.2.1-2, 3.2.1-3, 3.2.1-4, 3.2.1-5, 3.2.1-6, 3.2.1-7 and 3.2.1-8.~~ The limits of ~~Figures 3.2.1-1, 3.2.1-2, 3.2.1-3, 3.2.1-4, 3.2.1-5, 3.2.1-6, 3.2.1-7 and 3.2.1-8~~ shall be reduced to a value of 0.84 times the two recirculation loop operation limit when in single loop operation. specified in the COLR.

APPLICABILITY: OPERATIONAL CONDITION 1, when THERMAL POWER is greater than or equal to 25% of RATED THERMAL POWER. The limits specified in the COLR.

ACTION:

With an APLHGR exceeding the limits specified in the COLR. of ~~Figure 3.2.1-1, 3.2.1-2, 3.2.1-3, 3.2.1-4, 3.2.1-5, 3.2.1-6, 3.2.1-7 or 3.2.1-8~~, initiate corrective action within 15 minutes and restore APLHGR to within the required limits within 2 hours or reduce THERMAL POWER to less than 25% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.2.1 All APLHGRs shall be verified to be equal to or less than the limits determined from ~~Figures 3.2.1-1, 3.2.1-2, 3.2.1-3, 3.2.1-4, 3.2.1-5, 3.2.1-6, 3.2.1-7 and 3.2.1-8.~~ specified in the COLR.

- a. At least once per 24 hours,
- b. Within 12 hours after completion of a THERMAL POWER increase of at least 15% of RATED THERMAL POWER, and
- c. Initially and at least once per 12 hours when the reactor is operating with a LIMITING CONTROL ROD PATTERN for APLHGR.
- d. The provisions of Specification 4.0.4 are not applicable.

RECEIVED
MAY 05 1989
SDC

~~*The limits on Figures 3.2.1-7 and 3.2.1-8 are to be used only for manual calculations.~~