

Docket No. 50-336
B13473

Attachment 1

Millstone Nuclear Power Station, Unit No. 2
Proposed Change to Technical Specifications
Core Alteration

April 1990

9004250219 900410
PDR ADOCK 05000336
P FDC

DEFINITIONS

CORE ALTERATION

1.12 CORE ALTERATION shall be the movement or manipulation of fuel, CEAs, Neutron Sources, or Upper Guide Structure within the reactor pressure vessel with the vessel head removed and fuel in the vessel. Suspension of Core Alterations shall not preclude completion of movement of a component to a safe, conservative position.

SHUTDOWN MARGIN

1.13 SHUTDOWN MARGIN shall be the instantaneous amount of reactivity by which the reactor is subcritical or would be subcritical from its present condition assuming all full length control element assemblies (shutdown and regulating) are fully inserted except for the single assembly of highest reactivity worth which is assumed to be fully withdrawn.

IDENTIFIED LEAKAGE

1.14 IDENTIFIED LEAKAGE shall be:

- a. Leakage into closed systems, such as pump seal or valve packing leaks that are captured, and conducted to a sump or collecting tank, or
- b. Leakage into the containment atmosphere from sources that are both specifically located and known either not to interfere with the operation of leakage detection systems or not to be PRESSURE BOUNDARY LEAKAGE.

UNIDENTIFIED LEAKAGE

1.15 UNIDENTIFIED LEAKAGE shall be all leakage which is not IDENTIFIED LEAKAGE or CONTROLLED LEAKAGE.

PRESSURE BOUNDARY LEAKAGE

1.16 PRESSURE BOUNDARY LEAKAGE shall be leakage (except steam generator tube leakage) through a non-isolated fault in a Reactor Coolant System component body, pipe wall or vessel wall.

CONTROLLED LEAKAGE

1.17 CONTROLLED LEAKAGE shall be the water flow from the reactor coolant pump seals.