

Duke Power Company  
P.O. Box 33198  
Charlotte, N.C. 28242

Hal B. Tucker  
Vice President  
Nuclear Production  
(704)373-4531



**DUKE POWER**

April 19, 1990

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Subject: Catawba Nuclear Station, Units 1 and 2  
Docket Nos. 50-413 and 50-414  
Proposed Technical Specification Amendment  
Technical Specification 4.7.6

Gentlemen:

My December 21, 1987 letter to the NRC transmitted a proposed Technical Specification (TS) Amendment to Facility Operating License Nos. NPF-35 and NPF-32 for Catawba Units 1 and 2, respectively. The proposed change to 4.7.6.d, Control Room Area Ventilation System Surveillance Requirements, extended the carbon adsorber sampling frequency from 720 hours to 1440 hours. My letter dated July 14, 1989 updated the submittal by making additional changes to Technical Specifications 3.7.6.a, 4.7.6.c, 4.7.6.d, 4.7.6.f and 4.7.6.g seeking administrative clarifications and more conservative bypass leakage and methyl iodide penetration acceptance criteria.

This letter supplements my previous submittals by changing TS 4.7.6.c.2 and 4.7.6.d to read "Meets the laboratory testing criteria of ASTM D3803-86, Test Method "A". (Exception to test method "A" will be the use of 70% relative humidity instead of 95%, and a 4 inch carbon bed depth)."

This change is administrative and will ensure consistent laboratory testing of all ventilation systems at Catawba Nuclear Station. There will be no change to the current testing requirements for the Control Room Area Ventilation System which are not justified in my previous submittals. This change will meet the intent of Regulatory Guide 1.52.

Attached is a copy of the marked up pages from my July 14, 1989 submittal. The additional changes, as described have been marked on these pages.

Very truly yours,

Hal B. Tucker

MHH25/lcs

9004270010 900419  
PDR ADOCK 05000413  
P FDC

A001  
11

U. S. Nuclear Regulatory Commission

Page 2

April 19, 1990

cc: Mr. S. D. Ebnetter  
Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta St., NW Suite 2900  
Atlanta, Georgia 30323

Mr. W. T. Orders  
NRC Resident Inspector  
Catawba Nuclear Station

Mr. Heyward Shealy, Chief  
Bureau of Radiological Health  
S.C. Department of Health & Environmental Control  
2600 Bull Street  
Columbia, South Carolina 28201

American Nuclear Insurers  
c/o Dottie Sherman, ANI Library  
The Exchange, Suite 245  
270 Farmington Avenue  
Farmington, CT 06032

M & M Nuclear Consultants  
1221 Avenue of the Americas  
New York, New York 10020

INPO Records Center  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

Dr. K. N. Jabbour  
Office of Nuclear Regulation  
U. S. Nuclear Regulatory Commission  
One White Flint North  
Mail Stop 14H25  
Washington, D.C. 555