



GPU Nuclear Corporation
 Post Office Box 388
 Route 9 South
 Forked River, New Jersey 08731-0388
 609 971-4000
 Writer's Direct Dial Number:

April 25, 1990

U.S. Nuclear Regulatory Commission
 Attn: Document Control Desk
 Washington, D.C. 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
 Docket No. 50-219
 Response to Bulletin 89-02

The purpose of this letter is to confirm, as requested by the subject Bulletin, that the Oyster Creek Nuclear Generating Station does not utilize Anchor Darling Model S350W swing check valves with type 410SS bolts in any safety related application.

In addition, drawings for other manufacturer's check valves installed at Oyster Creek have been reviewed and it has been determined that Crane and Ohio Injector have designs similar to Model S350W, but do not use 410SS internal bolting.

Bulletin 89-02 does not apply to Oyster Creek because Oyster Creek does not have any Anchor Darling Model S350W check valves in safety related applications. Check valves of similar design used at Oyster Creek do not have 410SS internal bolting.

If further information is required, please contact Brenda DeMerchant, OC Licensing Engineer at (609) 971-4642.

Very truly yours,

E.E. Fitzpatrick
 Vice President and Director
 Oyster Creek

EEF/BDeM/jc

cc: Mr. Thomas Martin, Administrator
 Region 1
 U.S. Nuclear Regulatory Commission
 475 Allendale Road
 King of Prussia, PA 19406

NRC Resident Inspector
 Oyster Creek Nuclear Generating Station

Mr. Alexander Dromerick
 U.S. Nuclear Regulatory Commission
 Mail Station P1-137
 Washington, DC 20555

Sworn to and subscribed before me this
25th day of April, 1990

JUDITH M. CROWE
 Notary Public of New Jersey
 My Commission Expires 1-25-95

9005020001 900425
 PBR ADOCK 05000219
 PDC

IE 32
 110