



SONGS RADIOLOGICAL SURVEY

DATE 4/1/15TIME 10:30Page 1 of 1

UNIT	<u>N</u>	SURVEY REASON <input type="checkbox"/> Routine <input type="checkbox"/> Job Coverage <input type="checkbox"/> Pwr Entry _____ % <input type="checkbox"/> Post-Decon <input type="checkbox"/> Pre-Job <input type="checkbox"/> Shipment/Receipt <input type="checkbox"/> Source/Leak Test <input checked="" type="checkbox"/> Other <u>LEAD SURVEY</u>	SURVEY NO.	<u>150401-002</u>
AREA	<u>YD</u>		MO NO.	<u>A1209140001</u>
ELEV	<u>130</u>		REP NO.	<u>200278-5</u>
ROOM	<u>MESA</u>		EQUIP. ID.	<u>N/A</u>

NO.	SMEARS			MASSLINNS				
	β - γ	α	NO.	β - γ	α	NO.	Gross dpm	Hot Part. (Y/N)
1			16			A		
2			17			B		
3			18			C		
4			19			D		
5			20			E		
6			21			F		
7			22					
8	<u>N/A</u>		23	<u>N/A</u>				
9			24		<u>A</u>			
10			25					
11								
12								
13								
14								
15								

All items <1K Fixed AND <1K SMEARABLE.
 No magenta Paint on any item.
 Background for the Micro-REM was
 8 μ Rem/hr. No Dose Rates Above Background.
 100% of LEAD SURVEY.
 All smears were LESS THAN MDCR.
 BE-4 BACKGROUND WAS 23.5. MDCR-8
 BE-4 EFF. 16.5g

SURVEY CLASS	<input type="checkbox"/> Trend Pt.	<input type="checkbox"/> Component
<input type="checkbox"/> Boundary	<input checked="" type="checkbox"/> General Area	<input type="checkbox"/> Individual

SURVEY DESCRIPTION: LEAD BRICK INSPECTION AT THE MESA. W-44

REMARKS:

Instruments used			
Model	<u>MICROREM 2-1</u>	<u>BC4</u>	
Serial No.	<u>B498B</u>	<u>258969</u>	<u>380</u>

TECHNICIAN		SURVEY TYPE
Print	<u>Don Dickinson</u>	<input type="checkbox"/> Shutdown (S/D)
Sign	<u>[Signature]</u>	Reference Number
APPROVED BY		<u>SO123-VII-20.9</u>
Print	<u>[Signature]</u>	Form Number
Sign	<u>[Signature]</u>	SCE HP (2/3) 1259-1000
Approval Date:	<u>4-1-15</u>	Time: <u>15:00</u>
REV. 3 09/07		