



South Carolina Electric & Gas Company
P.O. Box 88
Jenkinsville, SC 29065
(803) 345-4040

John L. Skolds
Vice President
Nuclear Operations

February 23, 1993
Refer to: RC-93-0048

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION (VCSNS)
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
RESPONSE TO NRC BULLETIN 92-01
SPECIAL REPORT 92-005 (ONO 920050)
RESPONSE TO NRC BULLETIN 92-01 SUPPLEMENT 1
SPECIAL REPORT 92-005 SUPPLEMENT 1

During a review of the subject correspondence, submitted on 20 July 1992 and 15 September 1992 respectively, a discrepancy was noted in Table B of the attachment.

Enclosed are corrected Table B attachments for your file.

Should there be any questions, please contact Mr. R. J. Bouknight at (803) 345-4085.

Very truly yours,

John L. Skolds

RJB:smd
Enclosure

c: O. W. Dixon
R. R. Mahan
R. J. White
General Managers
G. F. Wunder
S. R. Hunt
NRC Resident Inspector
J. B. Knotts Jr.
Marsh & McLennan
Document Control Desk
INPO Records Center
NSRC
RTS (IE 920001)
File (818.05 & 818.08)

9303010237 930223
PDR ADDCK 05000395
Q PDR

TABLE B
Components Supplied Through Cable Tray 3088:

Equipment Number	Name	Safety Class
XFN0038A	Battery & Charging Room Air Handling Unit "A" Supply Fan	(NNS)
XFN0039A	Battery Room Exhaust Fan "A"	(NNS)
XES2001A	Speed Switch, Component Cooling Pump "A"	(SR)
XES2001C	Speed Switch, Component Cooling Pump "C"	(SR)
XPN7200A	Control Room Evacuation Panel	(SR)
XSW0001	Reactor Trip Switchgear	(SR)
XCA0001A	Power Control Rod Groups 1A, 1C, Shutdown Group 1A	(NNS)
XCX5201	Diesel Generator "A" Control Cubicle	(SR)
XPN5503	Diesel Generator "A" Relay & Terminal Panel	(SR)
XES0006	Diesel Generator "A" Starter DC Fuel Oil Pump	(SR)
XEX4201	Diesel Generator "A" Exciter Regulator Cubicle	(SR)
XPN5248	Relay & Isolation Fuse Panel	(SR)
XBC1A	DC Distribution Bus 1A Battery Charger	(SR)
XBC1A-1B	DC Distribution Bus 1A-1B Backup Battery Charger	(SR)
XPN5259	Isolation Fuse Panel	(SR)
XSW1DA	7.2 KV Switchgear, Bus 1DA	(SR)
XSW1DA1	ESF 480 Volt Unit Substation, Bus 1DA1	(SR)
XSW1DA2	ESF 480 Volt Unit Substation, Bus 1DA2	(SR)
XPN6011	Reactor Protection Under Frequency & Under Voltage Panel 1	(SR)
XPN7105	Main Control Board Termination Cabinet	(SR)

TABLE B
Components Supplied Through Cable Tray 3088:

Equipment Number	Name	Safety Class
XFN0038A	Battery & Charging Room Air Handling Unit "A" Supply Fan	(NNS)
XFN0039A	Battery Room Exhaust Fan "A"	(NNS)
XES2001A	Speed Switch, Component Cooling Pump "A"	(SR)
XES2001C	Speed Switch, Component Cooling Pump "C"	(SR)
XPN7200A	Control Room Evacuation Panel	(SR)
XSW0001	Reactor Trip Switchgear	(SR)
XCA0001A	Power Control Rod Groups 1A, 1C, Shutdown Group 1A	(NNS)
XCX5201	Diesel Generator "A" Control Cubicle	(SR)
XPN5503	Diesel Generator "A" Relay & Terminal Panel	(SR)
XES0006	Diesel Generator "A" Starter DC Fuel Oil Pump	(SR)
XEX4201	Diesel Generator "A" Exciter Regulator Cubicle	(SR)
XPN5248	Relay & Isolation Fuse Panel	(SR)
XBC1A	DC Distribution Bus 1A Battery Charger	(SR)
XBC1A-1B	DC Distribution Bus 1A-1B Backup Battery Charger	(SR)
XPN5259	Isolation Fuse Panel	(SR)
XSW1DA	7.2 KV Switchgear, Bus 1DA	(SR)
XSW1DA1	ESF 480 Volt Unit Substation, Bus 1DA1	(SR)
XSW1DA2	ESF 480 Volt Unit Substation, Bus 1DA2	(SR)
XPN6011	Reactor Protection Under Frequency & Under Voltage Panel 1	(SR)
XPN7106	Main Control Board Termination Cabinet	(SR)