

INDUSTRIAL PRETREATMENT  
QUARTERLY SELF-MONITORING RESULTS

Perry Nuclear Power Plant  
10 Center Rd.  
Perry, Ohio 44081

Permit No.: 1004911  
Report Date: 1/19/93  
Laboratory: Wadsworth/Alert

Date of Sample: 1/7 to 1/8/93  
Sample Location: Sewage Pump Station

Time of sample: 0930  
Name of Sampler: Greg Neuman


Laboratory Address: 1401 Shuffel Dr.  
North Canton OH 44720

Date of Analysis: 1/8 to 1/13/93  
Flow: 46,000 gpm

Name of Analyst: Shery Fazzio

PARAMETER	SAMPLE TYPE	EPA METHOD	ANALYSIS DATE	ANALYSIS RESULT
COD	Composite	410.2	1/11 to 1/12	380 mg/L
BOD	Composite	405.1	1/8 to 1/13	240 mg/L
TSS	Composite	160.2	1/11	160 mg/L
Silver	Composite	200.7	1/10 to 1/12	0.07 mg/L
pH	Composite	150.1	1/8	7.8 s.u.

I certify under penalty of law that I have personally examined and I am familiar with the information in this report and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in this report, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

  
Signature \_\_\_\_\_ Date 3/5/93 Title Vice President - Nuclear