DOCKET NO. 50 - 352

DATE JANUARY 14, 1992

NOTES: THERE WAS ONE LOAD DROP

COMPLETED BY PHILADELPHIA ELECTRIC COMPANY

KARL MECK

REPORTS SUPERVISOR BUSINESS UNIT

LIMERICK GENERATING STATION TELEPHONE (215) 327-1200 EXTENSION 3320

GREATER THAN 20% FOR RECIRC.

MOTOR GENERATOR SET BRUSH

CHANGE AND HPCI LEAK REPAIR

OPERATING STATUS

1. UNIT NAME: LIMERICK UNIT 1

2. REPORTING PERIOD: DECEMBER, 1992

- 3. LICENSED THERMAL POWER (MWT):
- 4. NAMEPLATE RATING (GROSS MWE):
- 5. DESIGN ELECTRICAL RATING (NET MWE):
- 6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 1092
- 7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 1055
- B. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
- 9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE):
- 10. REASONS FOR RESTRICTIONS, IF ANY:

	THIS MONTH	VR-TO-DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	744	8,784	60,624
12. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	6,240,4	47,549.2
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
14. HOURS GENERATOR ON-LINE	744.0	6,116.3	46,558.2
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWH)	2,400,475	19,744,549	141,733,465
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	796,610	6,475,200	45,976,140
18. NET ELECTRICAL ENERGY GENERATED (MWH)	767,553	6,229,061	44,040,517

PAGE 1 OF 2

3931019070