

Docket No. 50-213
B14391

Attachment 1
Haddam Neck Plant
Proposed Revision to Technical Specification

March 1993

9303190226 930316
PDR ADOCK 05000213
P PDR

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of less than or equal to L_a , 0.18 % by weight of the containment air per 24 hours at P_a , 39.6 psig, or
- b. A combined leakage rate of less than 0.60 L_a for all penetrations and valves subject to Type B and C tests, when pressurized to P_a .

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With either the measured overall integrated containment leakage rate exceeding 0.75 L_a or the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding 0.60 L_a , restore the overall integrated leakage rate to less than 0.75 L_a and the combined leakage rate for all penetrations subject to Type B and C tests to less than 0.60 L_a prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule, and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR Part 50 using ANSI N45.4-1972 (Total Time Method), ANSI 56.8 (Mass Point Method), or the Total Time Method from BN-TOP-1, Revision 1-1972, during the Type A and verification test.

- a. Three Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted at 40 ± 10 month intervals during shutdown at a pressure not less than P_a , 39.6 psig during each 10-year service period. The third test of each set shall be conducted during the shutdown for the 10-year plant inservice inspection;