

X244

NRC C/O DDC CTRL DSK, C. PATEL
DIRECTOR OF NUC. REACTOR REGULATION
U. S. NUC. REGULATORY COMMISSION
MAIL STATION P1-137

February 24, 1993

WASHINGTON
20555

DC

Attached are the recent revisions to the Offsite Dose Calculation Manual's (ODCM) Chapter 10 and Appendix F for Zion Station. Please complete the following manual update:

REMOVE

Zion Station Annex
Entire Chapter 10.
p. 10-i to 10-iv,
10-1 to 10-17

Zion Station Annex
Entire Appendix F
p. F-i to F-iv,
F-1 to F-23

INSERT

Zion Station Annex
Entire Chapter 10
Revision O.K. Jan. 1993
p. 10-i to 10-v,
10-1 to 10-19

Zion Station Annex
Entire Appendix F
Includes Rev. O.K.
p. F-i to F-iv,
F-1 to F-22

Please sign and date this control sheet and return to:

COMMONWEALTH EDISON COMPANY
c/o Document Control - Emergency Preparedness
1400 Opus Pl.- 5th Floor
Downers Grove, IL 60515
(708)663-6547

Your signature indicates you have verified that your control number is correct and you have updated your manual.

Signature

Date

9303240195 930131
PDR ADOCK 05000295
P PDR

ZEMERPLN/347/23

ADD. NEC/DREP/IRPBII

End.

ADD

ZION ANNEX INDEX

<u>PAGE</u>	<u>REVISION</u>
CHAPTER 10	
10-i	O.K
10-ii	O.K
10-iii	O.K
10-iv	O.K
10-v	O.K
10-1	O.K
10-2	O.K
10-3	O.K
10-4	O.K
10-5	O.K
10-6	O.K
10-7	O.K
10-8	O.K
10-9	O.K
10-10	O.K
10-11	O.K
10-12	O.K
10-13	O.K
10-14	O.K
10-15	O.K
10-16	O.K
10-17	O.K
10-18	O.K
10-19	O.K
10-20	O.K

CHAPTER 10

RADIOACTIVE EFFLUENT TREATMENT AND MONITORING

TABLE OF CONTENTS

	<u>PAGE</u>
10.1 AIRBORNE RELEASES	1
10.1.1 System Description	1
10.1.1.1 Waste Gas Holdup System	1
10.1.1.2 Ventilation Exhaust Treatment System	1
10.1.2 Radiation Monitors	1
10.1.2.1 Final Vent Stack Effluent Monitors	1
10.1.2.2 Auxiliary Building Vent Effluent Monitors	2
10.1.2.3 Containment Purge Effluent Monitors	2
10.1.2.4 Waste Gas Decay Tank Monitors	3
10.1.2.5 Condenser Air Ejector Monitors	3
10.1.2.6 Service Building Ventilation Monitor	3
10.1.2.7 Miscellaneous Ventilation Monitors	3
10.1.3 Alarm and Trip Setpoints	3
10.1.3.1 Setpoint Calculation	3
10.1.3.2 Release Limits	4
10.1.3.3 Release Mixture	5
10.1.3.4 Conversion Factors	5
10.1.3.5 HVAC Flow Rates	6
10.1.4 Allocation of Effluents from Common Release Points	7
10.1.5 Dose Projections for Batch Releases	7
10.2 LIQUID RELEASE	7
10.2.1 System Description	7
10.2.1.1 Lake Discharge Tanks	7
10.2.1.2 Turbine Building Fire Sump	7
10.2.2 Radiation Monitors	8
10.2.2.1 Lake Discharge Tank Monitors	8
10.2.2.2 Turbine Building Fire Sump Monitor	8
10.2.3 Alarm and Trip Setpoints	8
10.2.3.1 Setpoint Calculation	8

CHAPTER 10

RADIOACTIVE EFFLUENT TREATMENT AND MONITORING

TABLE OF CONTENTS (Cont'd)

10.2.3.2	Discharge Flow Rates	9
10.2.3.2.1	Lake Discharge Tank Discharge Flow Rate	9
10.2.3.2.2	Turbine Building Fire Sump Discharge Flow Rate	9
10.2.3.3	Release Limits	10
10.2.3.4	Release Mixture	10
10.2.3.5	Conversion Factors	10
10.2.3.6	Liquid Dilution Flow Rates	10
10.2.4	Allocation of Effluents from Common Release Points	10
10.2.5	Projected Concentrations for Releases	10
10.3	SOLIDIFICATION OF WASTE/PROCESS CONTROL PROGRAM	11

CHAPTER 10

LIST OF TABLES

<u>NUMBER</u>	<u>TITLE</u>	<u>PAGE</u>
10-1	Assumed Composition of the Zion Station Noble Gas Effluent	10-12
10-2	HVAC Exhaust Fan Capacities	10-13
10-3	Liquid Dilution Flow Pump Capacities	10-14

CHAPTER 10

LIST OF FIGURES

<u>NUMBER</u>	<u>TITLE</u>	<u>PAGE</u>
10-1	Simplified Gaseous Radwaste and Gaseous Effluent Flow Diagram	10-15
10-2	Simplified Liquid Radwaste Processing Diagram	10-17
10-3	Simplified Liquid Effluent Flow Diagram	10-18
10-4	Simplified Solid Radwaste Processing Diagram	10-19
10-5	Example NMC Monitor Response	10-20

CHAPTER 10

RADIOACTIVE EFFLUENT TREATMENT AND MONITORING

10.1 AIRBORNE RELEASES

10.1.1 System Description

A simplified gaseous radwaste and gaseous effluent flow diagram is provided in Figure 10-1. The principal release points for potentially radioactive airborne effluents are the two auxiliary building vent stacks (designated Unit 1 Vent Stack and Unit 2 Vent Stack in Figure 10-1). In the classification scheme of Section 4.1.4, each is classified as a ground level release point (see Table A-1 of Appendix A).

10.1.1.1 Waste Gas Holdup System

The waste gas holdup system is designed and installed to reduce radioactive gaseous effluents by collecting reactor coolant system off-gases from the reactor coolant system and providing for delay or holdup to reduce the total radioactivity by radiodecay prior to release to the environment. The system is described in Section 11.1.2.3 of the Zion FSAR.

10.1.1.2 Ventilation Exhaust Treatment System

Ventilation exhaust treatment systems are designed and installed to reduce gaseous radioiodine or radioactive material in particulate form in gaseous effluents by passing ventilation or vent exhaust gases through charcoal adsorbers and/or HEPA filters prior to release to the environment. Such a system is not considered to have any effect on noble gas effluents. The ventilation exhaust treatment systems are shown in Figure 10-1.

Engineered safety features atmospheric cleanup systems are not considered to be ventilation exhaust treatment system components.

10.1.2 Radiation Monitors

10.1.2.1 Final Vent Stack Effluent Monitors

Monitors 1RIA-PR49 (Unit 1) and 2RIA-PR49 (Unit 2) continuously monitor the final effluent from the auxiliary building vent stacks. Both vent stack monitors feature automatic isokinetic sampling and grab sampling.

In normal operation all three noble gas channels (low, mid-range, high) are on line and active. On a high alarm from the mid-and/or high range channels the particulate, iodine, low range noble gas and mid-range noble gas channels are isolated, and only the high range noble gas channel remains active.

No automatic isolation or control functions are performed by these monitors. On high alarm, the control room operator will notify the health physics group and reduce the release rate as appropriate. Because of the conservatism built into the setpoint calculations (Section 10.1.3), there is an adequate margin between the setpoint and release limit to accommodate this procedure.

Pertinent information on these monitors is provided in UFSAR Table 11.5-1.

10.1.2.2

Auxiliary Building Vent Effluent Monitors

Monitors IRT-PR25 (Unit 1), 2RT-PR25 (Unit 2) and ORE-0014 (common) continuously monitor the effluent from the auxiliary building vent stack.

No automatic isolation or control functions are performed by these monitors. On high alarm, the control room operator will notify the health physics group and reduce the release rate as appropriate. Because of the conservatism built into the setpoint calculations (Section 10.1.3) there is an adequate margin between the setpoint and release limit to accommodate this procedure.

Pertinent information on monitor ORE-0014 is provided in UFSAR Table 11.5-2.

10.1.2.3

Containment Purge Effluent Monitors

Monitors IRT-PR09 (Unit 1) and 2RT-PR09 (Unit 2) continuously monitor the effluent from the Unit 1 and Unit 2 containments, respectively. On high alarm, the monitors automatically initiate closure of the four air-operated butterfly valves (RV0001/2/3/4 purge valves for each unit).

Pertinent information on these monitors is provided in UFSAR Tables 11.5-1 and 11.5-2. Monitors 1(2)RIA-PR40 continuously monitor the Unit 1(2) atmosphere. On high alarm, the monitors automatically initiate closure of valves RV0001-RV0006 inclusive.

10.1.2.4 Waste Gas Decay Tank Monitors

Monitors ORT-PR10A/B continuously monitor the noble gas activity released from the gas decay tanks.

On high alarm, the monitors automatically initiate closure of the valve ORCV-WG014 thus terminating the release.

Pertinent information on these monitors is provided in UFSAR Table 11.5-2.

10.1.2.5 Condenser Air Ejector Monitors

Monitors 1RE-0015 and 2RE-0015 continuously monitor the condenser air ejector gas from Units 1 and 2, respectively. No control device is initiated by these channels.

Pertinent information on these monitors is provided in UFSAR Table 11.5-2.

10.1.2.6 Service Building Ventilation Monitor

Monitor ORT-PR22 continuously monitors noble gas activity in the service building ventilation system. No control device is initiated by this channel.

Pertinent information on this monitor is provided in UFSAR Table 11.5-2.

10.1.2.7 Miscellaneous Ventilation Monitors

Monitor ORT-PR18B continuously monitors noble gas activity in the ventilation exhaust from the auxiliary equipment room, computer room, laboratories, decontamination room and other miscellaneous areas. No control device is initiated by this channel.

Pertinent information on this monitor is provided in UFSAR Table 11.5-2.

10.1.3 Alarm and Trip Setpoints

10.1.3.1 Setpoint Calculation

The effluent noble gas monitor setpoints are conservatively based on the assumption that a release is occurring simultaneously for all seven gaseous release points at the maximum expected flow rate for each pathway. Furthermore, the setpoints are chosen such that an occurrence of simultaneous high alarms on all seven pathways would correspond to a station release rate of one half of the Technical Specification limit.

$$P_{MP} \leq 0.5 \times Q_{tv} \times 1/F^P \times K^P \times C^M \quad (10-1)$$

P_{MP} = Setpoint for monitor, M, on release path, P. [cpm]

0.5 = Factor to reduce release rate by 50%.

Q_{tv} = Total Allowed Release Rate, Vent Release [μ Ci/sec]

F^P = Flow rate through Release Path, P. [cc/sec]

K^P = Factor to apportion a fraction of the total release rate, Q_{tv} , to release path, P.

C^M = Conversion Factor for monitor, M [cpm per μ Ci/cc]

10.1.3.2

Release Limits

Alarm and trip setpoints of gaseous effluent monitors are established to ensure that the release rate limits of the Technical Specifications and 10 CFR 20 are not exceeded. The release limits are found by solving Equations 10-2 and 10-3 for the total allowed release rate of vent releases, Q_{tv} .

$$(1.11)Q_{tv} \sum (\bar{V}_i f_i) < 500 \text{ mrem/yr} \quad (10-2)$$

$$Q_{tv} \sum \{ (f_i) [\bar{L}_i (X/Q)_v \exp(-\lambda_i R/3600 u_v) + 1.11 V_i] \} < 3000 \text{ mrem/yr} \quad (10-3)$$

The summations are over noble gas radionuclides i.

f_i Fractional Radionuclide Composition

The release rate of noble gas radionuclide i divided by the total release rate of all noble gas radionuclides.

Q_{tv} Total Allowed Release Rate, Vent Release [μ Ci/sec]

The total allowed release rate of all noble gas radionuclides released as vent releases.

The remaining parameters in Equation 10-2 have the same definitions as in Equation A-8 of Appendix A. The remaining

parameters in Equation 10-3 have the same definition as in Equation A-9 of Appendix A.

Equation 10-2 is based on Equation A-8 of Appendix A and the 10 CFR 20 restriction on whole body dose rate (500 mrem/yr) due to noble gases released in gaseous effluents (see Section A.1.3.1 of Appendix A). Equation 10-3 is based on Equation A-9 of Appendix A and the 10 CFR 20 restriction on skin dose rate (3000 mrem/yr) due to noble gases released in gaseous effluents (see Section A.1.3.2 of Appendix A).

Equations 10-2 and 10-3 can each be solved for a value of Q_{tv} . The monitor alarm and trip setpoints will be established based on the equation which yields the smaller release limit, Q_{tv} . The exact settings are selected to ensure that 10 CFR 20 limits are not exceeded.

Calibration methods and surveillance frequency for the monitors will be conducted as specified in the RETS.

10.1.3.3

Release Mixture

In the determination of alarm and trip setpoints, the radioactivity mixture in exhaust air is assumed to have the radionuclide composition of Table 10-1. This mixture was conservatively chosen based on station isotopic release data averaged over a period of 7 years (1977 through June 1984).

10.1.3.4

Conversion Factors

The response curves used to determine the monitor count rates are chosen in order to best match the reference noble gas mix. Because Xe-133 and Xe-135 comprise 83.6% and 8.79% of this mix respectively, the Xe-133/Xe-135 90%/10% curves are used to ensure that the setpoints would be conservative with respect to quantity.

Example curves are shown in Figure 10-5.

10.1.3.5

HVAC Flow Rates

HVAC flow rates are computed for 1(2)RT-PR25, ORE-0014 and 1(2)RIA-PR49 based on the number of operating fans in the monitored flow path.

$$F_M = \sum_P \sum_i F_{ip} \times N_i \quad (10-4)$$

F_M = Total Flow In Monitored Flow Path [cc/sec]

F_{ip} = Flow from fan i in path p. [cc/sec]

N_i = Number of fans, in operation

The maximum flow for each fan is used for setpoint calculations because this maximizes the flow, and therefore minimizes the calculated monitor sensitivity which is conservative.

Pertinent data for the fans is provided in Table 10-2.

HVAC flows for the remaining monitors are conservatively fixed at upper bound values. They are listed below.

Monitor	Flow in cc/sec
ORT-PR10A/B	6.60E5
1(2)RE-0015	7.32E5
ORT-PR22	5.96E6
1RT-PR09A	1.65E6 (vent mode)
"	1.46E6 (mini-purge mode)
"	1.46E7 (purge mode)
2RT-PR09A	4.35E6 (vent mode)*
"	4.11E6 (mini-purge mode)
"	1.99E7 (purge-mode)
"	2.70E6 (routine, hot lab only)

*Flow greater than Unit 1 due to "hot lab" hood exhaust fan flow.

10.1.4 Allocation of Effluents from Common Release Points

Radioactive gaseous effluents released from the auxiliary building miscellaneous ventilation system and the gas decay tanks are comprised of contributions from both units. Under normal operating conditions, it is difficult to apportion the radioactivity between the units. Consequently, allocation normally is made evenly between units.

10.1.5 Dose Projections for Batch Releases

Projected doses are calculated before purging the containment or venting the waste gas decay tanks. Per procedure, a representative sample is obtained and analyzed, and the total release is calculated. Prior to the release the projected dose rate (in mrem/year) is calculated based on the assumption that the release is continuous for the entire year.

10.2 LIQUID RELEASES

10.2.1 System Description

A simplified liquid waste processing diagram is provided in Figure 10-2. A simplified liquid effluent flow diagram is provided in Figure 10-3.

The liquid radwaste treatment system is designed and installed to reduce radioactive liquid effluents by collecting the liquids, providing for retention or holdup, and providing for treatment by demineralizer for the purpose of reducing the total radioactivity prior to release to the environment. The system is described in Section 11.1.3 of the Zion FSAR.

10.2.1.1 Lake Discharge Tanks

There are two lake discharge tanks (0A and 0B, 30,000-gallon capacity each) which receive liquid waste before discharge to Lake Michigan.

10.2.1.2 Turbine Building Fire Sump

The turbine building floor and equipment drain tanks receive turbine building waste which is released to the fire sump for processing by the waste water treatment facility and ultimate discharge into Lake Michigan. The discharge constitutes a low level radioactive release.

10.2.2 Radiation Monitors

10.2.2.1 Lake Discharge Tank Monitors

Monitors ORT-PR04 and ORT-PR05 are used to monitor all releases from the lake discharge tanks. On high alarm, the monitor automatically initiates closure of a valve to prevent further releases. The valve is located over 250 feet downstream of the monitor to allow closure prior to exceeding release limits. The monitor setpoints are found by solving Equation 10-5 for release setpoint P.

Pertinent information on these monitors is provided in UFSAR Table 11.5-3.

10.2.2.2 Turbine Building Fire Sump Monitor

Monitor ORT-PR25 continuously monitors the discharge line from the fire sump pumps to the waste water treatment facility. On high alarm, the monitor automatically trips all of the fire sump pumps, thereby containing the liquid in the turbine building. The monitor setpoints are found by solving Equation 10-5 for release setpoint P.

Pertinent information on the monitor is provided in UFSAR Table 11.5-3.

10.2.3 Alarm and Trip Setpoints

10.2.3.1 Setpoint Calculation

Alarm and trip setpoints of liquid effluent monitors at the principal release points are established to ensure that the limits of the Technical Specifications and 10 CFR 20 are not exceeded in the unrestricted area. The monitor setpoints are found by solving Equation 10-5 for a conservative mixture of radionuclides found in liquid effluents.

$$P \leq K \times (C_{mpc})(F^d/F') \quad (10-5)$$

P Release Setpoint [μCi/mL]

The alarm setpoint for radioactivity to be released in liquid effluents.

C_{mpc} Maximum Permissible Concentration [μCi/mL]

F^d Dilution Flow Rate [gpm]

The flow rate of the radwaste dilution stream (condenser cooling water).

F' Discharge Flow Rate [gpm]

The flow rate from the lake discharge tank or fire sump as appropriate.

K Factor of conservatism.
 $K = 0.5$ for lake discharge tank
 $K = 1.0$ for for sump

10.2.3.2 Discharge Flow Rates

10.2.3.2.1 Lake Discharge Tank Discharge Flow Rate

Prior to each batch release, the water is recirculated, sampled, and analyzed.

The results of the analysis of the waste sample determine the discharge rate of each batch as follows:

$$F'_{max} = (C_{mpc})(F_{act}^d/C) \quad (10-6)$$

F'_{max} Maximum Permitted Discharge Flow Rate [gpm]

The maximum permitted flow rate from the lake discharge tank. [gpm]

F_{act}^d Actual Dilution Flow Rate [gpm]

The actual flow rate of the radwaste dilution stream (based on pump curves).

C Sample Radioactivity Concentration [$\mu\text{Ci/mL}$]

The concentration of radioactivity in the lake discharge tank based on measurements of a sample drawn from the tank.

C_{mpc} has the same definition as in Equation 10-5.

10.2.3.2.2 Turbine Building Fire Sump Discharge Flow Rate

This release path is a continuous discharge. Consequently, the release rate F' in Equation 10-6 is set equal to maximum design

capacity for the pumps on the effluent of the waste water treatment facility.

10.2.3.3 Release Limits

Release limits are determined from 10 CFR 20.

10.2.3.4 Release Mixture

The release mixture used for setpoint determination is the worst case radionuclide mix chosen on the basis of station isotopic analysis data reviewed for 1978.

10.2.3.5 Conversion Factors

The conversion factor for ORT-PR25 (fire sump monitor) is based on detector response curves for I131. The conversion factors for monitor ORT-PR04 and ORT-PR05 are based on detector response curves for Cs137.

10.2.3.6 Liquid Dilution Flow Rates

Dilution flow rates are computed based on the number of operating pumps in the flow path.

$$F^d = \sum_i F_i^d \times N_i \quad (10-7)$$

F^d = Dilution Flow Rate [gpm]

F_i^d = Dilution Flow Rate from pump i [gpm]

N_i = Number of pumps of type i operating

Pertinent flow data for the pumps is provided in Table 10-3.

10.2.4 Allocation of Effluents from Common Release Points

Radioactive liquid effluents released from the lake discharge tank and turbine building fire sump are comprised of contributions from both units. Under normal operating conditions, it is difficult to apportion the radioactivity between the units. Consequently, allocation is based on the unit discharge canal used for dilution.

10.2.5 Projected Concentrations for Releases

Projected concentrations are calculated before initiating liquid discharges. Per procedure, a representative sample is obtained and analyzed and the projected concentrations are

calculated using conservative dilution flows prior to release. Because the fire sump is a continuous release, it is sampled daily and isotopic analyses are performed weekly.

Doses due to liquid effluents are calculated as required by the RETS.

10.3

SOLIDIFICATION OF WASTE/PROCESS CONTROL PROGRAM

The process control program (PCP) contains the sampling, analysis, and formulation determination by which solidification of radioactive wastes from liquid systems is ensured.

Table 10-1

Assumed Composition of the Zion Station
Noble Gas Effluent

<u>Isotope</u>	<u>Percent of Effluent</u>
Ar-41	1.92E-1
Kr-83m	1.0E-4
Kr-85m	2.24E-1
Kr-85	5.50E-2
Kr-87	1.22
Kr-88	3.19
Kr-89	1.0E-4
Xe-131m	1.85
Xe-133m	7.56E-1
Xe-133	8.36E1
Xe-135m	1.03E-1
Xe-135	8.79
Xe-137	1.0E-4
Xe-138	4.37E-3

Note: Based on station isotopic release data averaged over 7 years (1977 through June 1984).



TABLE 10-2
HVAC EXHAUST FAN CAPACITIES

FAN	CC/SEC	CFM	CFH
<u>#1 Aux. Bldg.</u>			
OA Exh. Fan	3.16×10^7	6.70×10^4	4,020,000
OB Exh. Fan	3.16×10^7	6.70×10^4	4,020,000
OC Exh. Fan	3.16×10^7	6.70×10^4	4,020,000
<u>#2 Aux. Bldg.</u>			
OD Exh. Fan	3.16×10^7	6.70×10^4	4,020,000
OE Exh. Fan	3.16×10^7	6.70×10^4	4,020,000
OF Exh. Fan	3.16×10^7	6.70×10^4	4,020,000
<u>#1 Purge Exh.</u>			
1A Purge Fan	1.46×10^7	3.10×10^4	1,860,000
1B Purge Fan	1.46×10^7	3.10×10^4	1,680,000
H ² Purge Fan 1A	1.70×10^5	3.60×10^2	21,600
H ₂ Purge Fan 1B	1.75×10^5	3.40×10^2	22,200
<u>#2 Purge Exh.</u>			
2A Purge Fan	1.65×10^7	3.50×10^4	2,102,400
2B Purge Fan	1.72×10^7	3.65×10^4	2,188,800
H ₂ Purge Fan 2A	1.82×10^5	3.85×10^2	23,100
H ₂ Purge Fan 2B	1.75×10^5	3.71×10^2	22,260
Hot Lab Exh. OA	1.50×10^6	3.18×10^3	191,000
Hot Lab Exh. OB	1.18×10^6	2.51×10^3	150,600
<u>Misc. Exh.</u>			
Comp & Misc. Exh. OA	2.81×10^6	5.95×10^3	357,000
Comp & Misc. Exh OB	2.81×10^6	5.95×10^3	357,000
<u>Ser. Bldg.</u>			
Decon. Rm. Exh.	1.91×10^6	4.04×10^3	242,580
Welding Rm. Exh.	1.09×10^6	2.30×10^3	138,000
Sandblast Rm. Exh.	9.44×10^5	2.00×10^3	120,000
Cave Exh.	6.14×10^5	1.30×10^3	78,000
Machine Shop Exh.	1.42×10^6	3.00×10^3	180,000


TABLE 10-3
LIQUID DILUTION FLOW PUMP CAPACITIES

<u>PUMP</u>	<u>NUMBER OF PUMPS RUNNING</u>	<u>DILUTION FLOW</u>
CIRCULATING WATER	1	250,000 gpm
CIRCULATING WATER	2	530,000 gpm
CIRCULATING WATER	3	640,000 gpm
SERVICE WATER	1	13,500 gpm
SERVICE WATER	2	27,000 gpm
SERVICE WATER	3	40,500 gpm

UNIT 1 CONTAINMENT (TYPICAL)




DETAIL OF AUX BLDG CUBICLES




OFFSITE DOSE CALCULATION MANUAL
ZION COUNTY STATION


FIGURE 10-1
SIMPLIFIED GASEOUS RADWASTE AND
GASEOUS EFFLUENT FLOW DIAGRAM
(SHEET 2 OF 2)





SIMPLIFIED GASEOUS RADWASTE AND
GASEOUS EFFLUENT FLOW DIAGRAM
(SHEET 1 OF 2)






SI
APERTURE
CARD

Also Available On
Aperture Card

9303240195-02

OFFSITE DOSE CALCULATION MANUAL
ZION STATION



FIGURE 10-2
SIMPLIFIED LIQUID RADWASTE
PROCESSING DIAGRAM



LEGEND	
	LIQUID RAD MONITOR
	RADIATION MONITOR
	FLOW PATH
	CONTROL PATH
	NORMALLY CLOSED VALVE
NOTES	
1. FLOW = 0-735,000 GPM	
2. MAX FLOW = 44,000 GPM	
3. FLOW DETERMINED BY PUMP CURVES	

OFFSITE DOSE CALCULATION MANUAL ZION STATION

FIGURE 10-3
SIMPLIFIED LIQUID EFFLUENT FLOW DIAGRAM




OFFSITE DOSE CALCULATION MANUAL
ZION STATION

FIGURE 10-4

SIMPLIFIED SOLID RADWASTE
PROCESSING DIAGRAM

NMC MONITOR RESPONSE

- 1 - 100% Kr-85
 - 2 - 50% Xe-133/50% Kr-85
 - 3 - 67% Xe-133/33% Kr-85
 - 4 - 90% Xe-133/10% Kr-85
 - 5 - 100% Xe-133
- 1(2)RT-PR25
1(2)RT-PR09A
ORT-PR18B
ORT-PR10A
ORT-PR22



OFFSITE DOSE CALCULATION MANUAL
ZION STATION

FIGURE 10-5

EXAMPLE NMC MONITOR RESPONSE

ZION ANNEX INDEX

PAGE REVISION

APPENDIX F

F-i	O.K
F-ii	O.A
F-iii	O.A
F-iv	O.A
F-1	O
F-2	O.K
F-3	O.K
F-4	O.A
F-5	O.K
F-6	O.K
F-7	O.K
F-8	O.K
F-9	O.K
F-10	O.K
F-11	O.K
F-12	O.K
F-13	O.K
F-14	O.K
F-15	O.K
F-16	O.K
F-17	O.K
F-18	O.K
F-19	O.K
F-20	O.K
F-21	O.K
F-21a	O.K
F-22	O

APPENDIX F
STATION-SPECIFIC DATA FOR ZION
UNITS 1 AND 2

TABLE OF CONTENTS

		<u>PAGE</u>
F.1	INTRODUCTION	F-1
F.2	REFERENCES	F-1

APPENDIX F
LIST OF TABLES

<u>NUMBER</u>	<u>TITLE</u>	<u>PAGE</u>
F-1	Aquatic Environment Dose Parameters	F-2
F-2	Station Characteristics	F-3
F-3	Critical Ranges	F-4
F-4	Average Wind Speeds	F-5
F-5	Ü/Q and D/Q Maxima at or Beyond the Unrestricted Area Boundary	F-6
F-6	D/Q at the Nearest Milk Cow and Meat Animal Locations Within 5 Miles	F-7
F-7	Site Boundary Finite Plume Gamma Dose Factors for Selected Nuclides	F-8

APPENDIX F
LIST OF FIGURES

<u>NUMBER</u>	<u>TITLE</u>	<u>PAGE</u>
F-1	Unrestricted Area Boundary	F-23

APPENDIX F
STATION-SPECIFIC DATA FOR ZION
UNITS 1 AND 2

F.1 INTRODUCTION

This appendix contains data relevant to the Zion site. Included is a figure showing the unrestricted area boundary and values of parameters used in offsite dose assessment.

F.2 REFERENCES

1. Sargent & Lundy, Nuclear Safeguards & Licensing Division, Zion Calculation No. ZI-9-85, Rev. 0.

Table F-1
Aquatic Environment Dose Parameters

<u>Parameter</u> ^a	<u>Value</u>	<u>Comment</u> ^b
M ^w	1/60	A
M ^f	1	A
F ^w , cfs	F ^C (gpm)/448.86	A,B
F ^f , cfs	4.0E5	A
t ^f , hr ^c	24	
t ^w , hr ^d	5.5	

Limits on Radioactivity in Unprotected Outdoor Tanks^e

Outside Temporary Radioactive
Liquid Storage Tank $\leq 10 \text{ Ci}^f$

(per Technical Specification 3.11.5)

^a The parameters are defined in Section A.2.1 of Appendix A.

^b Comments:

A: Based on the Lake Michigan Model discussed in Section C.1.3.1.2 of Appendix C.

B: F^C is the average flow of condenser cooling water (gpm) during the period of discharge (either Unit 1 or 2). The constant 448.86 is the number of gpm per cfs.

^c t^f (hr) = 24 hr (all stations) for the fish ingestion pathway.

^d t^w (hr) = 5.5 hr (distance to Lake County intake is 1.1 mile; flow rate of 0.2 mph).

^e See Section A.2.4 of Appendix A.

^f Tritium and dissolved or entrained gases are excluded from this limit.

Table F-2
Station Characteristics

STATION: Zion Nuclear Power Station

LOCATION: Zion, Illinois

CHARACTERISTICS OF ELEVATED RELEASE POINT: Not Applicable (NA)

1) Release Height = _____ m 2) Diameter = _____ m
3) Exit Speed = _____ ms^{-1} 4) Heat Content = _____ KCal s^{-1}

CHARACTERISTICS OF VENT STACK RELEASE POINT

1) Release Height = 55.32 m^a 2) Diameter = 2.32 m
3) Exit Speed = 11.2 ms^{-1}^a

CHARACTERISTICS OF GROUND LEVEL RELEASE

1) Release Height = 0 m
2) Building Factor (D) = 57.6 m^a

METEOROLOGICAL DATA

A 250 ft Tower is Located 700 m NNW of elevated release point

Tower Data Used in Calculations

Release Point	Wind Speed and Direction	Differential Temperature
Elevated	(NA)	(NA)
Vent	125	250-35
Ground	35	250-35

^aUsed in calculating the meteorological and dose factors in Tables F-5, F-6, F-7. See Sections B.3 through B.6 of Appendix B.

Table F-3
Critical Ranges

Direction	Site Boundary ^a (m)	Nearest Resident ^b (m)	Nearest Dairy Farm Within 5 Miles ^c (m)
N	469	3900	None
NNE	475	d	None
NE	d	d	None
ENE	d	d	None
E	d	d	None
ESE	d	d	None
SE	d	d	None
SSE	d	d	None
S	433	2700	None
SSW	439	2700	None
SW	518	1900	None
WSW	671	1600	None
W	658	1500	None
WNW	893	1500	None
NW	847	1800	None
NNW	725	2600	None

^a Used in calculating the meteorological and dose factors in Tables F-5 and F-7. See Sections B.3 through B.6 of Appendix B.

^b 1988 annual survey, Teledyne Isotopes Midwest Laboratories.

^c 1988 milch animal census, Teledyne Isotopes Midwest Laboratories. Used in calculating the D/Q values in Table F-6.

^d Lake Michigan.

Table F-4
Average Wind Speeds

<u>Downwind Direction</u>	<u>Average Wind Speed (m/sec)^a</u>		
	<u>Elevated</u>	<u>Mixed Mode</u>	<u>Ground Level</u>
N	5.0		3.2
NNE	5.3		3.3
NE	5.8		4.1
ENE	5.6		3.9
E	5.7		3.9
ESE	5.1		3.3
SE	4.9		3.0
SSE	5.1		3.4
S	5.9		4.6
SSW	5.8		4.4
SW	5.1		4.0
WSW	5.2		4.6
W	5.1		4.4
WNW	4.8		3.7
NW	4.7		3.1
NNW	5.1		3.9

^aCalculated in Reference 1 of Section F.2 using formulas in Section B.1.3 of Appendix B. Based on Zion site meteorological data, January 1979 through December 1987.

Table F-5
X/Q and D/Q Maxima at or Beyond the Unrestricted Area Boundary

Downwind Direction	Mixed Mode (Vent) Release			Ground Level Release		
	Radius (meters)	X/Q (sec/m**3)	Radius (meters)	Radius (meters)	X/Q (sec/m**3)	D/Q (1/m**2)
N	469.	2.032E-06	469.	469.	9.548E-06	3.680E-08
NNE	475.	1.792E-06	475.	475.	1.004E-05	3.255E-08
NE	400.	*	400.	400.	*	*
ENE	400.	*	400.	400.	*	*
E	400.	*	400.	400.	*	*
ESE	400.	*	400.	400.	*	*
SE	400.	*	400.	400.	*	*
SSE	400.	*	400.	400.	*	*
S	433.	1.372E-06	433.	433.	7.058E-06	3.562E-08
SSW	439.	9.650E-07	439.	439.	5.768E-06	3.290E-08
SW	518.	4.590E-07	518.	518.	3.125E-06	1.625E-08
WSW	671.	2.311E-07	671.	671.	1.393E-06	8.964E-09
W	658.	2.394E-07	658.	658.	1.445E-06	8.440E-09
WNW	893.	1.427E-07	893.	893.	8.817E-07	4.789E-09
NW	847.	2.110E-07	847.	847.	1.310E-06	6.607E-09
NNW	725.	3.740E-07	725.	725.	2.038E-06	1.148E-08

Zion Site Meteorological Data 1/79 - 12/87

Note: Based on Reference 1 of Section F.2 and the formulas in Sections B.3 and B.4 of Appendix B.

^aUsed for beta air, beta skin, and inhalation dose pathways. See Sections A.1.2, A.1.3, and A.1.4.2 of Appendix A.

^bUsed for produce and leafy vegetable pathways. See Section A.1.4 of Appendix A.

*Not applicable--over Lake Michigan.

Table F-6
D/Q at the Nearest Milk Cow and Meat Animal Locations Within 5 Miles

Downwind Direction	Nearest Milk Cow Radius (meters)	Milk Cow Mixed Release	D/Q(1/m**2) Ground Release	Nearest Meat Animal Radius (meters)	Meat Animal Mixed Release	D/Q(1/m**2) Ground Release
N	8047.	1.142E-10	2.944E-10	8047.	1.142E-10	2.944E-10
NNE	8047.	1.030E-10	2.656E-10	8047.	1.030E-10	2.656E-10
NE	8047.	.	.	8047.	.	.
ENE	8047.	.	.	8047.	.	.
E	8047.	.	.	8047.	.	.
ESE	8047.	.	.	8047.	.	.
SE	8047.	.	.	8047.	.	.
SSE	8047.	.	.	8047.	.	.
S	8047.	1.358E-10	2.523E-10	8047.	1.358E-10	2.523E-10
SSW	8047.	1.374E-10	2.379E-10	8047.	1.374E-10	2.379E-10
SW	8047.	8.212E-11	1.515E-10	8047.	8.212E-11	1.515E-10
WSW	8047.	6.525E-11	1.255E-10	8047.	6.525E-11	1.255E-10
W	8047.	6.407E-11	1.145E-10	4828.	1.535E-10	2.855E-10
WNW	8047.	5.686E-11	1.063E-10	8047.	5.686E-11	1.063E-10
NW	8047.	7.529E-11	1.345E-10	6437.	1.116E-10	2.009E-10
NNW	8047.	9.871E-11	1.17E-10	8047.	9.871E-11	1.817E-10

Zion Site Meteorological Data 1/79 - 12/87

Note: Based on Reference 1 of Section F.2 of Appendix F and the formulas in Sections and B.4 of Appendix B.

*Not applicable--over Lake Michigan.

Table F-7
Site Boundary Finite Plume Gamma Dose Factors for Kr-83m

Downwind Direction	Unrestricted Area Bound (meters)	Mixed Mode(Vent) Radius (meters)	Release V (mrad/yr)	Release VBAR (uCi/sec)	Radius (meters)	Ground Level Release G (mrad/yr)	Release GBAR (uCi/sec)
N	469.	469.	2.083E-04	5.062E-05	469.	9.339E-04	2.269E-04
NNE	475.	475.	1.807E-04	4.390E-05	475.	9.509E-04	2.311E-04
NE	400.	400.	.	.	400.	.	.
ENE	400.	400.	.	.	400.	.	.
E	400.	400.	.	.	400.	.	.
ESE	400.	400.	.	.	400.	.	.
SE	400.	400.	.	.	400.	.	.
SSE	400.	400.	.	.	400.	.	.
S	433.	433.	1.458E-04	3.542E-05	433.	7.104E-04	1.725E-04
SSW	439.	439.	1.151E-04	2.797E-05	439.	6.071E-04	1.475E-04
SW	518.	518.	5.574E-05	1.354E-05	518.	3.385E-04	8.227E-05
WSW	671.	671.	3.032E-05	7.367E-06	671.	1.629E-04	3.957E-05
W	658.	658.	3.056E-05	7.425E-06	658.	1.657E-04	4.026E-05
WNW	893.	893.	1.812E-05	4.403E-06	893.	1.004E-04	2.439E-05
NW	847.	847.	2.674E-05	6.497E-06	847.	1.483E-04	3.603E-05
NNW	725.	725.	4.752E-05	1.155E-05	725.	2.306E-04	5.605E-05

Zion Site Meteorological Data 1/79 - 12/87

Note: Based on Reference 1 of Section F.2 of Appendix F and the formulas in Sections B.5 and B.6 of Appendix B.

*Not applicable--over Lake Michigan.

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Kr-85m

Downwind Direction	Unrestricted Area Bound (meters)	Mixed Model(Vent) Radius (meters)	Release V (mrad/yr)/(uci/sec)	Release VBAR (mrad/yr)/(uci/sec)	Radius (meters)	Ground Level Release G (mrad/yr)/(uci/sec)	GBAR (mrad/yr)/(uci/sec)
N	459.	469.	1.249E-03	1.032E-03	469.	3.995E-03	3.258E-03
NNE	475.	475.	1.110E-03	9.172E-04	475.	3.989E-03	3.250E-03
NE	400.	400.	.	.	400.	.	.
ENE	400.	400.	.	.	400.	.	.
E	400.	400.	.	.	400.	.	.
ESE	400.	400.	.	.	400.	.	.
SE	400.	400.	.	.	400.	.	.
SSE	400.	400.	.	.	400.	.	.
S	433.	433.	9.628E-04	7.978E-04	433.	3.136E-03	2.561E-03
SSW	439.	439.	8.568E-04	7.122E-04	439.	2.804E-03	2.293E-03
SW	518.	518.	5.038E-04	4.206E-04	518.	1.645E-03	1.348E-03
WSW	671.	671.	3.185E-04	2.667E-04	671.	8.367E-04	6.872E-04
W	658.	658.	3.128E-04	2.617E-04	658.	8.482E-04	6.963E-04
WNW	893.	893.	2.051E-04	1.719E-04	893.	5.554E-04	4.571E-04
NW	847.	847.	2.935E-04	2.459E-04	847.	8.008E-04	6.585E-04
NNW	725.	725.	4.801E-04	4.016E-04	725.	1.185E-03	9.730E-04

Zion Site Meteorological Data 1/79 - 12/87

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Kr-85

Downwind Direction	Unrestricted Area Bound (meters)	Mixed Mode(Vent) Radius (meters)	Release V (mrad/yr)/(uCi/sec)	Ground Level Release Radius (meters)	G (mrad/yr)/(uCi/sec)	GBAR
N	469.	469.	1.402E-05	469.	4.313E-05	3.640E-05
NNE	475.	475.	1.249E-05	475.	4.315E-05	3.642E-05
NE	400.	400.	.	400.	.	.
ENE	400.	400.	.	400.	.	.
E	400.	400.	.	400.	.	.
ESE	400.	400.	.	400.	.	.
SE	400.	400.	.	400.	.	.
SSE	400.	400.	.	400.	.	.
S	433.	433.	1.082E-05	433.	3.398E-05	2.868E-05
SSW	439.	439.	9.715E-06	439.	3.053E-05	2.576E-05
SW	518.	518.	5.829E-06	518.	1.805E-05	1.524E-05
WSW	671.	671.	3.737E-06	671.	9.147E-06	7.720E-06
W	658.	658.	3.664E-06	658.	9.329E-06	7.873E-06
WNW	893.	893.	2.425E-06	893.	6.158E-06	5.197E-06
NW	847.	847.	3.444E-06	847.	8.861E-06	7.479E-06
NNW	725.	725.	5.601E-06	725.	1.305E-05	1.101E-05

Zion Site Meteorological Data 1/79 - 12/87

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Kr-87

Downwind Direction	Unrestricted Area Bound (meters)	Mixed Model(Vent) Radius (meters)	V (mrad/yr)	Release VBAR (uCi/sec)	Radius (meters)	Ground Level Release G (mrad/yr)	GBAR (uCi/sec)
N	469.	469.	4.083E-03	3.526E-03	469.	1.194E-02	1.030E-02
NNE	475.	475.	3.638E-03	3.141E-03	475.	1.182E-02	1.020E-02
NE	400.	400.	*	*	400.	*	*
ENE	400.	400.	*	*	400.	*	*
E	400.	400.	*	*	400.	*	*
ESE	400.	400.	*	*	400.	*	*
SE	400.	400.	*	*	400.	*	*
SSE	400.	400.	*	*	400.	*	*
S	433.	433.	3.188E-03	2.753E-03	433.	9.319E-03	8.042E-03
SSW	439.	439.	2.882E-03	2.489E-03	439.	8.294E-03	7.158E-03
SW	518.	518.	1.737E-03	1.500E-03	518.	4.802E-03	4.144E-03
WSW	671.	671.	1.105E-03	9.544E-04	671.	2.485E-03	2.145E-03
W	658.	658.	1.086E-03	9.380E-04	658.	2.484E-03	2.144E-03
WNW	893.	893.	7.089E-04	6.124E-04	893.	1.620E-03	1.398E-03
NW	847.	847.	1.016E-03	6.776E-04	847.	2.339E-03	2.018E-03
NNW	725.	725.	1.646E-03	1.422E-03	725.	3.466E-03	2.991E-03

Zion Site Meteorological Data 1/79 - 12/87

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Kr-88

Downwind Direction	Unrestricted Area Bound (meters)	Mixed Mode Radius (meters)	Vent Release V (mrad/yr)/(uCi/sec)	Radius (meters)	Ground Level Release G (mrad/yr)/(uCi/sec)	GBAR
N	469.	469.	9.857E-03	469.	2.869E-02	2.486E-02
NNE	475.	475.	8.789E-03	475.	2.857E-02	2.475E-02
NE	400.	400.	.	400.	.	.
ENE	400.	400.	.	400.	.	.
E	400.	400.	.	400.	.	.
ESE	400.	400.	.	400.	.	.
SE	400.	400.	.	400.	.	.
SSE	400.	400.	.	400.	.	.
S	433.	433.	7.661E-03	433.	2.251E-02	1.950E-02
SSW	439.	439.	6.944E-03	439.	2.014E-02	1.746E-02
SW	518.	518.	4.228E-03	518.	1.180E-02	1.023E-02
WSW	671.	671.	2.722E-03	671.	6.046E-03	5.246E-03
W	658.	658.	2.671E-03	658.	6.106E-03	5.298E-03
WNW	893.	893.	1.763E-03	893.	4.018E-03	3.488E-03
NW	847.	847.	2.507E-03	847.	5.787E-03	5.022E-03
NNW	725.	725.	4.046E-03	725.	8.527E-03	7.398E-03

Zion Site Meteorological Data 1/79 - 12/87

*Not applicable--over Lake Michigan.

F-12

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Kr-89

Downwind Direction	Unrestricted Area Bound (meters)	Mixed Mode(Vent) Radius (meters)	Release V (mrad/yr)/(uCi/sec)	Release VBAR (mrad/yr)/(uCi/sec)	Radius (meters)	Ground Level Release G (mrad/yr)	Release GBAR (mrad/yr)/(uCi/sec)
N	469.	469.	5.171E-03	4.473E-03	469.	1.200E-02	1.037E-02
NNE	475.	475.	4.511E-03	3.903E-03	475.	1.066E-02	9.221E-03
NE	400.	400.	*	*	400.	*	*
ENE	400.	400.	*	*	400.	*	*
E	400.	400.	*	*	400.	*	*
ESE	400.	400.	*	*	400.	*	*
SE	400.	400.	*	*	400.	*	*
SSE	400.	400.	*	*	400.	*	*
S	433.	433.	4.618E-03	3.996E-03	433.	9.634E-03	8.330E-03
SSW	439.	439.	4.165E-03	3.603E-03	439.	8.417E-03	7.278E-03
SW	518.	518.	2.197E-03	1.901E-03	518.	4.032E-03	3.487E-03
WSW	671.	671.	1.160E-03	1.004E-03	671.	1.945E-03	1.682E-03
W	658.	658.	1.147E-03	9.929E-04	658.	1.835E-03	1.587E-03
WNW	893.	893.	5.673E-04	4.910E-04	893.	8.457E-04	7.314E-04
NW	847.	847.	8.765E-04	7.587E-04	847.	1.278E-03	1.105E-03
NNW	725.	725.	1.729E-03	1.496E-03	725.	2.580E-03	2.231E-03

Zion Site Meteorological Data 1/79 - 12/87

*Not applicable--over Lake Michigan.

F-13

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Kr-90

Downwind Unrestricted Direction Area Bound	Mixed Mode(Vent) Radius	Release V	Ground Level Release Radius	GBAR
(meters)	(meters)	(mrad/yr)/(uCi/sec)	(meters)	(mrad/yr)/(uCi/sec)
N	469.	9.956E-04	469.	1.150E-03
NNE	475.	9.477E-04	475.	9.696E-04
NE	400.	*	400.	*
ENE	400.	*	400.	*
E	400.	*	400.	*
ESE	400.	*	400.	*
SE	400.	*	400.	*
SSE	400.	*	400.	*
S	433.	1.426E-03	433.	1.738E-03
SSW	439.	1.208E-03	439.	1.463E-03
SW	518.	4.444E-04	518.	4.833E-04
WSW	671.	1.729E-04	671.	1.891E-04
W	658.	1.667E-04	658.	1.789E-04
WNW	893.	4.046E-05	893.	3.380E-05
NW	847.	5.538E-05	847.	2.908E-05
NNW	725.	1.911E-04	725.	1.555E-04

Zion Site Meteorological Data 1/79 - 12/87

*Not applicable---over Lake Michigan.

F-14

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Xe-131m

Downwind Direction	Unrestricted Area Bound (meters)	Mixed Mode(Vent) Radius (meters)	Release V (mrad/yr)/(uCi/sec)	VBAR (mrad/yr)/(uCi/sec)	Radius (meters)	Ground Level Release G (mrad/yr)/(uCi/sec)	GBAR (mrad/yr)/(uCi/sec)
N	469.	469.	1.905E-04	5.186E-05	469.	8.286E-04	2.504E-04
NNE	475.	475.	1.665E-04	5.430E-05	475.	8.472E-04	2.549E-04
NE	400.	400.	*	*	400.	*	*
ENE	400.	400.	*	*	400.	*	*
E	400.	400.	*	*	400.	*	*
ESE	400.	400.	*	*	400.	*	*
SE	400.	400.	*	*	400.	*	*
SSE	400.	400.	*	*	400.	*	*
S	433.	433.	1.345E-04	4.468E-05	433.	6.368E-04	1.934E-04
SSW	439.	439.	1.084E-04	3.708E-05	439.	5.513E-04	1.687E-04
SW	518.	518.	5.468E-05	1.966E-05	518.	3.136E-04	9.679E-05
WSW	671.	671.	3.075E-05	1.153E-05	671.	1.499E-04	4.687E-05
W	658.	658.	3.092E-05	1.150E-05	658.	1.546E-04	4.821E-05
WNW	893.	893.	1.899E-05	7.247E-06	893.	9.547E-05	3.023E-05
NW	847.	847.	2.776E-05	1.050E-05	847.	1.405E-04	4.425E-05
NNW	725.	725.	4.826E-05	1.784E-05	725.	2.156E-04	6.728E-05

Zion Site Meteorological Data 1/79 - 12/87

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Xe-133m

Downwind Direction	Unrestricted Area Bound (meters)	Mixed Radius (meters)	Mode (Vent) Y (mrad/yr)	Release VBAR (uCi/sec)	Radius (meters)	Ground Level G (mrad/yr)	Release GBAR (uCi/sec)
N	469.	469.	3.416E-04	1.865E-04	469.	1.313E-03	6.456E-04
NNE	475.	475.	3.007E-04	1.651E-04	475.	1.332E-03	6.501E-04
NE	400.	400.	*	*	400.	*	*
ENE	400.	400.	*	*	400.	*	*
E	400.	400.	*	*	400.	*	*
ESE	400.	400.	*	*	400.	*	*
SE	400.	400.	*	*	400.	*	*
SSE	400.	400.	*	*	400.	*	*
S	433.	433.	2.506E-04	1.408E-04	433.	1.018E-03	5.048E-04
SSW	439.	439.	2.117E-04	1.229E-04	439.	8.932E-04	4.483E-04
SW	518.	518.	1.156E-04	7.047E-05	518.	5.152E-04	2.621E-04
WSW	671.	671.	5.940E-05	4.388E-05	671.	2.520E-04	1.307E-04
W	658.	658.	6.885E-05	4.323E-05	658.	2.586E-04	1.336E-04
WNW	893.	893.	4.398E-05	2.819E-05	893.	1.638E-04	8.652E-05
NW	847.	847.	6.341E-05	4.035E-05	847.	2.390E-04	1.253E-04
NNW	725.	725.	1.065E-04	6.658E-05	725.	3.610E-04	1.867E-04

Zion Site Meteorological Data 1/79 - 12/87

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Xe-133

Direction	Downwind Unrestricted		Mixed Mode(Vent) Release		Ground Level Release		
	Area Bound	Radius	V	VBAR	Radius	G	GBAR
	(meters)	(meters)	(mrad/yr)/(uCi/sec)	(mrad/yr)/(uCi/sec)	(meters)	(mrad/yr)/(uCi/sec)	(mrad/yr)/(uCi/sec)
N	469.	469.	3.709E-04	2.363E-04	469.	1.412E-03	8.352E-04
NNE	475.	475.	3.266E-04	2.089E-04	475.	x	x
NE	400.	400.	x	x	400.	x	x
ENE	400.	400.	x	x	400.	x	x
E	400.	400.	x	x	400.	x	x
ESE	400.	400.	x	x	400.	x	x
SE	400.	400.	x	x	400.	x	x
SSE	400.	400.	x	x	400.	1.183E-03	7.042E-04
S	433.	433.	2.749E-04	1.792E-04	433.	1.099E-03	6.553E-04
SSW	439.	439.	2.337E-04	1.559E-04	439.	9.702E-04	5.846E-04
SW	518.	518.	1.278E-04	8.824E-05	518.	5.633E-04	3.433E-04
WSW	671.	671.	7.715E-05	5.465E-05	671.	2.779E-04	1.722E-04
W	658.	658.	7.644E-05	5.387E-05	658.	2.848E-04	1.759E-04
WNW	893.	893.	4.907E-05	3.511E-05	893.	1.820E-04	1.144E-04
NW	847.	847.	7.083E-05	5.045E-05	847.	2.647E-04	1.654E-04
NNW	725.	725.	1.188E-04	8.355E-05	725.	3.978E-04	2.459E-04

Zion Site Meteorological Data 1/79 - 12/87

*Not applicable--over Lake Michigan.

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Xe-135m

Downwind Unrestricted Direction Area Bound (meters)	Mixed Mode(Vent) Radius (meters)	Release V (mrad/yr)/(uCi/sec)	Release VBAR (mrad/yr)/(uCi/sec)	Ground Level Release Radius (meters)	G (mrad/yr)/(uCi/sec)	GBAR (mrad/yr)/(uCi/sec)
N	469.	2.366E-03	1.976E-03	469.	6.852E-03	5.693E-03
NNE	475.	2.093E-03	1.748E-03	475.	6.600E-03	5.482E-03
NE	400.	*	*	400.	*	*
ENE	400.	*	*	400.	*	*
E	400.	*	*	400.	*	*
ESE	400.	*	*	400.	*	*
SE	400.	*	*	400.	*	*
SSE	400.	*	*	400.	*	*
S	433.	1.896E-03	1.585E-03	433.	5.246E-03	4.361E-03
SSW	439.	1.697E-03	1.420E-03	439.	4.559E-03	3.793E-03
SW	518.	9.762E-04	8.182E-04	518.	2.487E-03	2.070E-03
WSW	671.	5.877E-04	4.929E-04	671.	1.323E-03	1.102E-03
W	658.	5.810E-04	4.873E-04	658.	1.274E-03	1.061E-03
WNW	893.	3.547E-04	2.977E-04	893.	7.789E-04	6.494E-04
NW	847.	5.237E-04	4.395E-04	847.	1.144E-03	9.537E-04
NNW	725.	8.818E-04	7.397E-04	725.	1.784E-03	1.486E-03

Zion Site Meteorological Data 1/79 - 12/87

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Xe-135

Downwind Direction	Unrestricted Area Bound (meters)	Mixed Mode(Vent) Radius (meters)	Release V (mrad/yr)/(uCi/sec)	Radius (meters)	Ground Level G (mrad/yr)/(uCi/sec)	Release G (mrad/yr)/(uCi/sec)
N	469.	469.	1.686E-03	469.	5.315E-03	4.484E-03
NNE	475.	475.	1.498E-03	475.	5.309E-03	4.478E-03
NE	400.	400.	.	400.	.	.
ENE	400.	400.	.	400.	.	.
E	400.	400.	.	400.	.	.
ESE	400.	400.	.	400.	.	.
SE	400.	400.	.	400.	.	.
SSE	400.	400.	.	400.	.	.
S	433.	433.	1.301E-03	433.	4.184E-03	3.531E-03
SSW	439.	439.	1.163E-03	439.	3.754E-03	3.169E-03
SW	518.	518.	6.885E-04	518.	2.214E-03	1.869E-03
WSW	671.	671.	4.379E-04	671.	1.126E-03	9.511E-04
W	658.	658.	4.296E-04	658.	1.144E-03	9.667E-04
WNW	893.	893.	2.830E-04	893.	7.530E-04	6.366E-04
NW	847.	847.	4.040E-04	847.	1.084E-03	9.163E-04
NNW	725.	725.	6.593E-04	725.	1.600E-03	1.351E-03

Zion Site Meteorological Data 1/79 - 12/87

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Xe-137

Downwind Direction	Unrestricted Area Bound (meters)	Mixed Mode Radius (meters)	Mode (Vent) V (mrad/yr)	Release VBAR (uCi/sec)	Radius (meters)	Ground Level G (mrad/yr)	Release GBAR (uCi/sec)
N	459.	459.	7.660E-04	6.493E-04	469.	1.897E-03	1.607E-03
NNE	475.	475.	6.673E-04	5.656E-04	475.	1.711E-03	1.450E-03
NE	400.	400.	.	.	400.	.	.
ENE	400.	400.	.	.	400.	.	.
E	400.	400.	.	.	400.	.	.
ESE	400.	400.	.	.	400.	.	.
SE	400.	400.	.	.	400.	.	.
SSE	400.	400.	.	.	400.	.	.
S	433.	433.	6.693E-04	5.673E-04	433.	1.497E-03	1.268E-03
SSW	439.	439.	5.998E-04	5.086E-04	439.	1.302E-03	1.103E-03
SW	518.	518.	3.198E-04	2.711E-04	518.	6.382E-04	5.407E-04
WSW	671.	671.	1.729E-04	1.466E-04	671.	3.149E-04	2.668E-04
W	658.	658.	1.710E-04	1.450E-04	658.	2.974E-04	2.520E-04
WNW	893.	893.	8.763E-05	7.430E-05	893.	1.447E-04	1.226E-04
NW	847.	847.	1.343E-04	1.139E-04	847.	2.191E-04	1.857E-04
NNW	725.	725.	2.582E-04	2.189E-04	725.	4.200E-04	3.559E-04

Zion Site Meteorological Data 1/79 - 12/87

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Xe-138

Downwind Direction	Unrestricted Area Bound (meters)	Mixed Mode(Vent) Radius (meters)	Release V (mrad/yr)/(uCi/sec)	Release VBAR (uCi/sec)	Radius (meters)	Ground Level Release G (mrad/yr)	Release GBAR (uCi/sec)
N	469.	469.	5.120E-03	4.416E-03	469.	1.421E-02	1.224E-02
NNE	475.	475.	4.542E-03	3.918E-03	475.	1.365E-02	1.175E-02
NE	400.	400.	.	.	400.	.	.
ENE	400.	400.	.	.	400.	.	.
E	400.	400.	.	.	400.	.	.
ESE	400.	400.	.	.	400.	.	.
SE	400.	400.	.	.	400.	.	.
SSE	400.	400.	.	.	400.	.	.
S	433.	433.	4.129E-03	3.562E-03	433.	1.088E-02	9.372E-03
SSW	439.	439.	3.727E-03	3.217E-03	439.	9.468E-03	8.155E-03
SW	518.	518.	2.169E-03	1.873E-03	518.	5.153E-03	4.439E-03
WSW	671.	671.	1.308E-03	1.130E-03	671.	2.749E-03	2.368E-03
W	658.	658.	1.295E-03	1.118E-03	658.	2.641E-03	2.276E-03
WNW	893.	893.	7.908E-04	6.831E-04	893.	1.612E-03	1.390E-03
NW	847.	847.	1.169E-03	1.010E-03	847.	2.370E-03	2.043E-03
NNW	725.	725.	1.959E-03	1.692E-03	725.	3.702E-03	3.190E-03

Zion Site Meteorological Data 1/79 - 12/87

*Not applicable--over Lake Michigan.

Table F-7 (Cont'd)
Site Boundary Finite Plume Gamma Dose Factors for Ar-41

Downwind Unrestricted Direction Area Bound (meters)	Mixed Mode(Vent) Radius (meters)	Release V (mrad/yr)/(uCi/sec)	Ground Level Release Radius (meters)	G (mrad/yr)/(uCi/sec)	GBAR (mrad/yr)/(uCi/sec)
N	469	6.355E-03	469	1.886E-02	1.607E-02
NNE	475	5.659E-03	475	1.875E-02	1.597E-02
NE	400	*	400	*	*
ENE	400	*	200	*	*
E	400	*	400	*	*
ESE	400	*	400	*	*
SE	400	*	400	*	*
SSE	400	*	400	*	*
S	433	4.941E-03	433	1.476E-02	1.257E-02
SSW	439	4.458E-03	439	1.316E-02	1.121E-02
SW	518	2.685E-03	518	7.664E-03	6.530E-03
WSW	671	1.713E-03	671	3.940E-03	3.357E-03
W	658	1.682E-03	658	3.961E-03	3.375E-03
WNW	893	1.103E-03	893	2.591E-03	2.207E-03
NW	847	1.576E-03	847	3.736E-03	3.183E-03
NNW	725	2.554E-03	725	5.528E-03	4.710E-03

Zion Site Meteorological Data 1/79 - 12/87

*Not applicable--over Lake Michigan.

