



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379-2000

Robert A. Fenech
Vice President, Sequoyah Nuclear Plant

March 24, 1993

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNITS 1 AND 2 -
DOCKET NOS. 50-327 AND 328 - FACILITY OPERATING LICENSES DPR-77 AND
DPR-79 - LICENSEE EVENT REPORT (LER) 50-327/92013, REVISION 1

The enclosed revised LER provides changes to the corrective actions concerning nonconservative mass and energy releases used to calculate the pressures in the main steam valve vaults during a main steam line break. This condition was originally reported on August 17, 1992, in accordance with 10 CFR 50.73(a)(2)(ii)(B) as a condition outside the design basis of the plant.

Revisions to the LER are annotated by vertical bars in the right-hand margin.

Sincerely,

Robert A. Fenech

Enclosure
cc: See page 2

9303290041 930324
PDR ADDCK 05000327
S PDR

U.S. Nuclear Regulatory Commission
Page 2
March 24, 1993

cc (Enclosure):

INPO Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339-3064

Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37379-3624

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-0199