



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PACIFIC GAS AND ELECTRIC COMPANY

DOCKET NO. 50-275

DIABLO CANYON NUCLEAR POWER PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 78
License No. DPR-80


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Pacific Gas & Electric Company (the licensee) dated December 22, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-80 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 78 , are hereby incorporated in the license. Pacific Gas & Electric Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Theodore R. Quay, Director
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 23, 1993



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PACIFIC GAS AND ELECTRIC COMPANY

DOCKET NO. 50-323

DIABLO CANYON NUCLEAR POWER PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 77
License No. DPR-82


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Pacific Gas & Electric Company (the licensee) dated December 22, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-82 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 77, are hereby incorporated in the license. Pacific Gas & Electric Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Theodore R. Quay, Director
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 23, 1993

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 78 TO FACILITY OPERATING LICENSE NO. DPR-80

AND AMENDMENT NO. 77 TO FACILITY OPERATING LICENSE NO. DPR-82

DOCKET NOS. 50-275 AND 50-323

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf pages are also included, as appropriate.

REMOVE

-
-
-
-
-
-
xxii
6-18

INSERT

Page 1 of 6
Page 2 of 6
Page 3 of 6
Page 4 of 6
Page 5 of 6
Page 6 of 6
xxii
6-18

APPENDIX A TO LICENSE NOS. DPR-80 AND DPR-82
DIABLO CANYON NUCLEAR POWER PLANT UNITS 1 AND 2 TECHNICAL SPECIFICATIONS (NUREG-1151)

LIST OF EFFECTIVE PAGES

<u>Page No.</u>	<u>Amendment No.</u>	<u>Page No.</u>	<u>Amendment No.</u>
Title Page	-	Title Page	-
i	-	Note	-
ii	67/66	B 2-1	71/70
iii	60/59	B 2-1a	71/70
iv	-	B 2-1b	60/59
v	71/70	B 2-2	-
vi	-	B 2-3	-
vii	67/66	B 2-4	37/36
viii	54/53	B 2-5	-
ix	73/72	B 2-6	-
x	66/65 #	B 2-7	72/71
xi	66/65 #	B 2-8	30/29
xii	72/71	B 2-9	30/29
xiii	67/66	Title Page	-
xiv	12/10	3/4 0-1	55/54
xv	54/53	3/4 0-2	57/56
xvi	-	3/4 0-3	-
xvii	-	3/4 1-1	72/71
xviii	67/66	3/4 1-2	-
xix	-	3/4 1-3	72/71
xx	-	3/4 1-4	10/8
xxi	68/67	3/4 1-5	-
xxii	78/77	3/4 1-6	-
xxiii	67/66	3/4 1-7	72/71
Title Page	-	3/4 1-8	72/71
1-1	-	3/4 1-9	72/71
1-2	73/72	3/4 1-10	-
1-3	67/66	3/4 1-11	-
1-4	-	3/4 1-12	72/71
1-5	67/66	3/4 1-13	72/71
1-6	67/66	3/4 1-14	-
1-7	45/44	3/4 1-15	45/44
1-7a	67/66	3/4 1-16	45/44
1-8	-	3/4 1-17	-
1-9	-	3/4 1-18	-
Title Page	-	3/4 1-19	-
2-1	60/59	3/4 1-20	72/71
2-2	60/59	3/4 1-21	45/44
2-3	-	3/4 1-22	45/44
2-4	72/71	3/4 2-1	45/44
2-5	72/71	3/4 2-2	45/44
2-6	30/29	3/4 2-3	45/44
2-7	72/71	3/4 2-4	12/10
2-8	72/71	3/4 2-5	71/70
2-9	72/71	3/4 2-6	71/70

APPENDIX A TO LICENSE NOS. DPR-80 AND DPR-82
DIABLO CANYON NUCLEAR POWER PLANT UNITS 1 AND 2 TECHNICAL SPECIFICATIONS (NUREG-1151)

LIST OF EFFECTIVE PAGES

<u>Page No.</u>	<u>Amendment No.</u>	<u>Page No.</u>	<u>Amendment No.</u>
3/4 2-7	71/70	3/4 3-28	72/71
3/4 2-8	71/70	3/4 3-29	51/50
3/4 2-9	71/70	3/4 3-30	72/71
3/4 2-10	71/70	3/4 3-31	72/71
3/4 2-11	71/70	3/4 3-32	61/60
3/4 2-12	71/70	3/4 3-33	70/69
3/4 2-13	71/70	3/4 3-34	61/60
3/4 2-14	71/70	3/4 3-35	61/60
3/4 2-15	71/70	3/4 3-36	55/54
3/4 2-16	60/59	3/4 3-37	70/69
3/4 2-17	60/59	3/4 3-38	55/54
3/4 2-18	37/36	3/4 3-39	70/69
3/4 2-19	37/36	3/4 3-40	55/54
3/4 2-20	63/62	3/4 3-41	55/54
3/4 2-21	37/36	3/4 3-42	-
3/4 2-22	72/71	3/4 3-43	-
3/4 3-1	-	3/4 3-44	55/54
3/4 3-2	55/54	3/4 3-45	-
3/4 3-3	72/71	3/4 3-46	-
3/4 3-4	61/60	3/4 3-47	-
3/4 3-5	61/60	3/4 3-48	-
3/4 3-6	4/2	3/4 3-49	-
3/4 3-7	61/60	3/4 3-50	-
3/4 3-8	72/71	3/4 3-51	-
3/4 3-9	-	3/4 3-52	-
3/4 3-10	61/60	3/4 3-53	-
3/4 3-11	72/71	3/4 3-54	55/54
3/4 3-12	48/47	3/4 3-55	55/54
3/4 3-13	61/60	3/4 3-56	-
3/4 3-13a	38/37	3/4 3-57	-
3/4 3-14	-	3/4 3-58	-
3/4 3-15	61/60	3/4 3-59	67/66
3/4 3-16	-	3/4 3-60	67/66
3/4 3-17	70/69	3/4 4-1	-
3/4 3-18	61/60	3/4 4-2	-
3/4 3-19	61/60	3/4 4-3	-
3/4 3-20	-	3/4 4-4	-
3/4 3-21	61/60	3/4 4-5	-
3/4 3-22	61/60	3/4 4-6	28/27
3/4 3-23	72/71	3/4 4-7	-
3/4 3-24	-	3/4 4-8	72/71
3/4 3-25	70/69	3/4 4-9	-
3/4 3-26	72/71	3/4 4-10	27/26
3/4 3-27	72/71	3/4 4-10a	27/26

APPENDIX A TO LICENSE NOS. DPR-80 AND DPR-82
DIABLO CANYON NUCLEAR POWER PLANT UNITS 1 AND 2 TECHNICAL SPECIFICATIONS (NUREG-1151)

LIST OF EFFECTIVE PAGES

<u>Page No.</u>	<u>Amendment No.</u>	<u>Page No.</u>	<u>Amendment No.</u>
3/4 4-11	-	3/4 6-5	-
3/4 4-12	-	3/4 6-6	-
3/4 4-13	-	3/4 6-7	11/9
3/4 4-14	-	3/4 6-8	-
3/4 4-15	-	3/4 6-9	-
3/4 4-16	-	3/4 6-10	-
3/4 4-17	-	3/4 6-11	-
3/4 4-18	-	3/4 6-12	-
3/4 4-19	16/15	3/4 6-13	11/9
3/4 4-20	16/15	3/4 6-14	69/68
3/4 4-21	16/15	3/4 6-15	73/72
3/4 4-22	-	3/4 6-16	73/72
3/4 4-23	-	3/4 6-17	73/72
3/4 4-24	-	3/4 6-18	73/72
3/4 4-25	18/17	3/4 7-1	-
3/4 4-26	18/17	3/4 7-2	-
3/4 4-27	-	3/4 7-3	-
3/4 4-28	-	3/4 7-4	62/61
3/4 4-29	-	3/4 7-5	62/61
3/4 4-30	54/53	3/4 7-6	-
3/4 4-31	54/53	3/4 7-7	-
3/4 4-32	54/53	3/4 7-8	-
3/4 4-33	54/53	3/4 7-9	-
3/4 4-34	-	3/4 7-9a	72/71
3/4 4-35	55/54	3/4 7-10	-
3/4 4-36	-	3/4 7-11	-
3/4 4-37	55/54	3/4 7-12	-
3/4 4-38	-	3/4 7-13	-
3/4 5-1	72/71	3/4 7-14	35/34
3/4 5-2	-	3/4 7-15	-
3/4 5-3	-	3/4 7-16	-
3/4 5-4	-	3/4 7-17	-
3/4 5-5	-	3/4 7-18	66/65 #
3/4 5-6	72/71	3/4 7-19	66/65 #
3/4 5-6a	65/64 ***	3/4 7-20	66/65 #
3/4 5-7	-	3/4 7-21	66/65 #
3/4 5-8	-	3/4 7-22	66/65 #
3/4 5-9	72/71	3/4 7-23	-
3/4 5-10	72/71	3/4 7-23a	66/65 #
3/4 5-11	53/52	3/4 7-23b	66/65 #
3/4 6-1	73/72	3/4 7-24	55/54
3/4 6-2	-	3/4 7-25	-
3/4 6-3	-	3/4 7-26	55/54
3/4 6-4	-	3/4 7-27	-

APPENDIX A TO LICENSE NOS. DPR-80 AND DPR-82
DIABLO CANYON NUCLEAR POWER PLANT UNITS 1 AND 2 TECHNICAL SPECIFICATIONS (NUREG-1151)

LIST OF EFFECTIVE PAGES

<u>Page No.</u>	<u>Amendment No.</u>	<u>Page No.</u>	<u>Amendment No.</u>
3/4 7-28	55/54	3/4 9-7	55/54
3/4 7-29	-	3/4 9-8	28/27
3/4 7-30	55/54	3/4 9-9	28/27
3/4 7-31	-	3/4 9-10	70/69
3/4 7-32	55/54	3/4 9-11	39/38
3/4 7-33	55/54	3/4 9-11a	39/38
3/4 7-34	-	3/4 9-12	55/54
3/4 7-35	-	3/4 9-13	55/54
3/4 7-36	55/54	3/4 9-14	-
3/4 7-37	-	3/4 9-15	8/6
3/4 7-38	-	3/4 9-16	8/6
3/4 7-39	-	3/4 9-17	8/6
3/4 7-40	55/54	3/4 9-18	8/6
3/4 8-1	74/73	3/4 9-19	8/5
3/4 8-2	44/43	3/4 10-1	72/71
3/4 8-2a	15/14	3/4 10-2	71/70
3/4 8-3	44/43	3/4 10-3	-
3/4 8-4	44/43	3/4 10-4	-
3/4 8-5	15/14	3/4 11-1	67/66
3/4 8-6	15/14	3/4 11-2	67/66
3/4 8-7	15/14	3/4 11-3	67/66
3/4 8-8	15/14	3/4 12-1	67/66
3/4 8-9	-	Title Page	-
3/4 8-10	-	Note	-
3/4 8-11	74/73	B 3/4 0-1	55/54
3/4 8-12	6/4	B 3/4 0-1a	55/54
3/4 8-13	6/4	B 3/4 0-1b	55/54
3/4 8-14	6/4	B 3/4 0-2	57/56 **
3/4 8-15	-	B 3/4 0-2a	55/54 **
3/4 8-16	-	B 3/4 0-3	55/54
3/4 8-17	-	B 3/4 1-1	10/8
3/4 8-18	-	B 3/4 1-2	72/71
3/4 8-19	-	B 3/4 1-3	14/13
3/4 8-20	51/50	B 3/4 2-1	12/10
3/4 8-21	51/50	B 3/4 2-2	12/10
3/4 8-22	-	B 3/4 2-3	12/10
3/4 8-23	55/54	B 3/4 2-4	71/70
3/4 8-24	-	B 3/4 2-5	60/59
3/4 9-1	72/71	B 3/4 2-6	37/36
3/4 9-2	46/45	B 3/4 3-1	69/68
3/4 9-3	-	B 3/4 3-1a	51/50
3/4 9-4	46/45	B 3/4 3-2	-
3/4 9-5	-	B 3/4 3-3	-
3/4 9-6	-	B 3/4 3-4	67/66

APPENDIX A TO LICENSE NOS. DPR-80 AND DPR-82
 DIABLO CANYON NUCLEAR POWER PLANT UNITS 1 AND 2 TECHNICAL SPECIFICATIONS (NUREG-1151)

LIST OF EFFECTIVE PAGES

<u>Page No.</u>	<u>Amendment No.</u>	<u>Page No.</u>	<u>Amendment No.</u>
B 3/4 3-5	67/66	B 3/4 10-1	-
B 3/4 4-1	-	B 3/4 10-2	-
B 3/4 4-2	27/26	B 3/4 11-1	67/66
B 3/4 4-2a	27/26	B 3/4 12-1	67/66
B 3/4 4-3	-	Title Page	-
B 3/4 4-4	-	5-1	-
B 3/4 4-5	18/17	5-2	-
B 3/4 4-6	-	5-3	-
B 3/4 4-7	54/53	5-4	24/23
B 3/4 4-8	54/53	5-5	13/11
B 3/4 4-9	54/53	5-6	8/6
B 3/4 4-10	54/53	5-7	-
B 3/4 4-11	54/53	6-1	59/58
B 3/4 4-12	54/53	6-2	29/28
B 3/4 4-13	54/53	6-3	29/28
B 3/4 4-14	-	6-4	59/58
B 3/4 4-15	-	6-5	59/58
B 3/4 4-16	-	6-6	59/58
B 3/4 5-1	-	6-7	43/42
B 3/4 5-2	65/64 ***	6-7a	41/40
B 3/4 5-2a	72/71	6-8	68/67
B 3/4 5-3	14/13	6-9	68/67
B 3/4 6-1	65/64 ***	6-10	68/67
B 3/4 6-2	65/64 ***	6-11	68/67
B 3/4 6-3	14/13	6-12	68/67
B 3/4 6-4	73/72	6-13	68/67
B 3/4 7-1	-	6-14	41/40
B 3/4 7-2	62/61	6-15	-
B 3/4 7-2a	64/63	6-15a	67/66
B 3/4 7-2b	64/63	6-15b	67/66
B 3/4 7-3	-	6-16	43/42
B 3/4 7-4	66/65 #	6-17	67/66
B 3/4 7-5	66/65 #	6-18	78/77
B 3/4 7-6	-	6-19	71/70
B 3/4 7-7	-	6-20	68/67
B 3/4 7-8	-	6-21	67/66
B 3/4 8-1	44/43	6-22	67/66
B 3/4 8-2	44/43	6-23	67/66
B 3/4 8-3	74/73		
B 3/4 8-3a	74/73		
B 3/4 9-1	46/45		
B 3/4 9-2	46/45		
B 3/4 9-3	70/69		

APPENDIX A TO LICENSE NOS. DPR-80 AND DPR-82
DIABLO CANYON NUCLEAR POWER PLANT UNITS 1 AND 2 TECHNICAL SPECIFICATIONS (NUREG-1151)

LIST OF EFFECTIVE PAGES

- ** Pages B 3/4 0-2 and B 3/4 0-2a were changed by NRC letter from Harry Rood, Senior Project Manager to J. D. Shiffer; Subject, Correction to Technical Specification Bases Issued with Amendments; dated December 21, 1990. "Revised December 21," 1990 should appear in the upper right hand corner of page B 3/4 0-2 and page B 3/4 0-2a should start with "surveillance interval was exceeded."
- *** License Amendments 65 & 64 were reissued by NRC letter from Harry Rood, Senior Project Manager to J. D. Shiffer; Subject, Reissuance of the September 3, 1991, Amendments for Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2; dated September 19, 1991. "Reissued September 19, 1991" should appear in the upper right hand corner of these pages.
- # License Amendments 66 & 65 were reissued by NRC letter from Harry Rood, Senior Project Manager to J. D. Shiffer; Subject, Reissuance of the September 6, 1991, Amendments for Diablo Canyon Nuclear Power Plant, Unit Nos. 1 and 2; dated September 19, 1991. "Reissued September 19, 1991" should appear in the upper right hand corner of these pages.

INDEX

ADMINISTRATIVE CONTROLS

<u>SECTION</u>	<u>PAGE</u>
<u>6.1 RESPONSIBILITY</u>	6-1
<u>6.2 ORGANIZATION</u>	
6.2.1 OFFSITE.....	6-1
6.2.2 PLANT STAFF.....	6-1
TABLE 6.2-1 MINIMUM SHIFT CREW COMPOSITION.....	6-4
6.2.3 ONSITE SAFETY REVIEW GROUP (OSRG)	
Function.....	6-6
Composition.....	6-6
Responsibilities.....	6-6
6.2.4 SHIFT TECHNICAL ADVISOR.....	6-6
<u>6.3 PLANT STAFF QUALIFICATIONS</u>	6-6
<u>6.4 TRAINING</u>	6-7
<u>6.5 REVIEW AND AUDIT</u>	
6.5.1 TECHNICAL REVIEW AND CONTROL	
Activities.....	6-7
6.5.2 PLANT STAFF REVIEW COMMITTEE (PSRC)	
Function.....	6-7
Composition.....	6-7
Alternates.....	6-7
Meeting Frequency.....	6-7
Quorum.....	6-7
Responsibilities.....	6-8
Records.....	6-9

INDEX

ADMINISTRATIVE CONTROLS

<u>SECTION</u>	<u>PAGE</u>
<u>6.5 REVIEW AND AUDIT (Continued)</u>	
6.5.3 NUCLEAR SAFETY OVERSIGHT COMMITTEE (NSOC)	
Function	6-9
Composition	6-10
Alternates	6-10
Consultants	6-10
Meeting Frequency	6-10
Quorum	6-10
Review	6-10
Audits	6-11
Records	6-12
 <u>6.6 REPORTABLE EVENT ACTION</u>	 6-12
 <u>6.7 SAFETY LIMIT VIOLATION</u>	 6-13
 <u>6.8 PROCEDURES AND PROGRAMS</u>	 6-13
 <u>6.9 REPORTING REQUIREMENTS</u>	
6.9.1 ROUTINE REPORTS	6-16
Startup Reports	6-16
Annual Reports	6-16
Annual Radiological Environmental Operating Report	6-17
Annual Radioactive Effluent Release Report	6-18
Monthly Operating Report	6-18
CORE OPERATING LIMITS REPORT	6-18
6.9.2 SPECIAL REPORTS	6-19
<u>6.10 RECORD RETENTION</u>	6-19
 <u>6.11 RADIATION PROTECTION PROGRAM</u>	 6-21
 <u>6.12 HIGH RADIATION AREA</u>	 6-21

ADMINISTRATIVE CONTROLS

ANNUAL REPORTS (Continued)

rem exposure according to work and job functions,* e.g., reactor operations and surveillance, inservice inspection, routine maintenance, special maintenance (describe maintenance), waste processing, and refueling. The dose assignment to various duty functions may be estimates based on pocket dosimeter, TLD, or film badge measurements. Small exposures totalling less than 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole body dose received from external sources shall be assigned to specific major work functions.

The results of specific activity analysis in which the primary coolant exceeded the limits of Specification 3.4.8 will be included in the annual report. The following information shall be included: (1) reactor power history starting 48 hours prior to the first sample in which the limit was exceeded; (2) results of the last isotopic analysis for radioiodine performed prior to exceeding the limit, results of analysis while limit was exceeded and results of one analysis after the radioiodine activity was reduced to less than limit. Each result should include date and time of sampling and the radioiodine concentrations; (3) clean-up system flow history starting 48 hours prior to the first sample in which the limit was exceeded; (4) graph of the I-131 concentration and one other radioiodine isotope concentration in microcuries per gram as a function of time for the duration of specific activity above the steady-state level; and (5) the time duration when the specific activity of the primary coolant exceeded the radioiodine limit.

ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT**

6.9.1.5 The Annual Radiological Environmental Operating Report covering the operation of the unit during the previous calendar year shall be submitted before May 1 of each year. The report shall include summaries, interpretations, and analysis of trends of the results of the Radiological Environmental Monitoring Program for the reporting period. The material provided shall be consistent with the objectives outlined in (1) the RMCP and (2) Sections IV.B.2, IV.B.3, and IV.C of Appendix I to 10 CFR Part 50.

*This tabulation supplements the requirements of 10 CFR 20.407.

**A single submittal may be made for a multiple unit plant.

ADMINISTRATIVE CONTROLS

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT*

6.9.1.6 The Annual Radioactive Effluent Release Report covering the operation of the unit during the previous calendar year shall be submitted before May 1 of each year. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit. The material provided shall be (1) consistent with the objectives outlined in the RMCP and PCP, (2) in conformance with 10 CFR 50.36a and Section IV.B.1 Appendix I to 10 CFR Part 50.

MONTHLY OPERATING REPORT

6.9.1.7 Routine reports of operating statistics and shutdown experience, including documentation of all challenges and failures to the PORVs or safety valves, shall be submitted on a monthly basis to the NRC in accordance with 10 CFR 50.4, no later than the 15th of each month following the calendar month covered by the report.

CORE OPERATING LIMITS REPORT

6.9.1.8.a Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT before each reload cycle or any remaining part of a reload cycle for the following:

1. Shutdown Rod Insertion Limits for Specification 3/4.1.3.5,
2. Control Rod Insertion Limits for Specification 3/4.1.3.6,
3. Axial Flux Difference for Specification 3/4.2.1,
4. Heat Flux Hot Channel Factor, $K(Z)$ and $W(Z) - F_0(z)$ (F_0 ^{RTP} for Specification 3/4.2.2), and
5. PCS Flow Rate and Nuclear Enthalpy Rise Hot Channel Factor - F_{AH} (F_{AH} ^{RTP} and PF_{AH} for Specification 3/4.2.3).

b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC in:

1. WCAP-10216-P-A, Relaxation of Constant Axial Offset Control F_0 Surveillance Technical Specification, June 1983 (Westinghouse Proprietary),
2. WCAP-9272-P-A, Westinghouse Reload Safety Evaluation Methodology, July 1985 (Westinghouse Proprietary),

*A single submittal may be made for a multiple unit plant. The submittal should combine those sections that are common to all units at the plant; however, for units with separate radwaste systems, the submittal shall specify the releases of radioactive material from each unit.