

APR - 9 1993

Docket No. 50-461

Illinois Power Company
ATTN: J. S. Perry
Senior Vice President
Clinton Power Station
Mail Code V-275
P. O. Box 678
Clinton, IL 61727

Dear Mr. Perry:

SUBJECT: EMERGENCY OPERATING PROCEDURES FOLLOWUP INSPECTION,
NRC INSPECTION REPORT NO. 50-461/93005(DRS)

This refers to the inspection conducted by Messrs. R. Langstaff and R. Doornbos of this office and J. DeBor of Science and Engineering Associates on March 15 through March 24, 1993. The inspection included a review of authorized activities for your Clinton Power Station. At the conclusion of the inspection the findings were discussed with those members of your staff identified in the enclosed report.

Areas examined during the inspection are identified in the report. The inspection focused on your emergency operating procedures (EOPs) and your program for maintaining their quality.

No violations of NRC requirements were identified during the course of this inspection. The quality of your EOP program has improved, especially in the area of EOP support procedures.

The plant labeling for your Clinton facility was adequate. Although components were labeled, the labels were difficult to read. Consequently, delays in performing EOP related tasks could result from difficulty in identifying components. We understand that an upgrade to plant labeling is planned. We request that within 30 days of this letter you provide us with a brief description of your plans, your schedule for upgrading the labeling for EOP related components, and a description of any priorities which have been established for upgrading plant labeling.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter, the enclosed inspection report, and your response to this letter will be placed in the NRC Public Document Room.

140061

9304140176 930409
PDR ADOCK 05000461
G PDR

TEO
1/1

APR - 9 1993

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

Original Signed by Mark A. Ring
Mark A. Ring, Chief
Operations Branch

Enclosure: Inspection Report
No. 50-461/93005(DRS)

cc w/enclosure:

- J. Cook, Vice President, Manager
Clinton Power Station
- F. Spangenberg, III, Manager -
Licensing and Safety
OC/LFDCB
Resident Inspector, RIII
- D. V. Pickett, LPM, NRR
- J. McCaffrey, Chief, Public
Utilities Division
- S. Zabel, Esquire, Schiff, Hardin,
& Waite
- K. K. Berry, Licensing Services Manager
General Electric Company
Chairman, DeWitt County Board
Illinois Department of
Nuclear Safety
- Robert Newmann, Office of Public
Counsel, State of Illinois Center
Perry SRI
State Liaison Officer
Chairman, Illinois Commerce
Commission
- J. Arildsen, HHFB, NRR
- J. DeBor (SEA)

bcc: PUBLIC - IE01

RIII ^Y
Rad
Langstaff/cg
04/8/93

RIII ^Y
rad
Doornbos
04/8/93

RIII ^Y
sto
B. Burgess
04/8/93

RIII ^Y
sto
Hague
04/8/93

RIII ^Y
rad
Ring
04/8/93